

TECHNICAL MANUAL

**ARMY FACILITIES
COMPONENTS
SYSTEM-PLANNING
(DESERT)**

TECHNICAL MANUAL
No. 5-301-4

HEADQUARTERS
DEPARTMENT OF THE ARMY
WASHINGTON DC, 27 June 1986

**ARMY FACILITIES COMPONENTS SYSTEM-PLANNING
(DESERT)**

CHAPTER	INTRODUCTION	Paragraph	Page
1.	Purpose	1-1	1-1
	Scope	1-2	1-1
	Related Publications	1-3	1-1
	Training	1-4	1-1
	Comments and Information Sources	1-5	1-1
	Responsibilities	1-6	1-2
2.	EXPLANATION OF THE TERMINOLOGY AND AFCS DATA		
	Army Facilities Components System (AFCS)	2-1	2-1
	Building Blocks	2-2	2-1
	Planning Table.....	2-3	2-1
	Design Criteria.....	2-4	2-1
	Construction Standards.....	2-5	2-1
	Building Structures.....	2-6	2-1
	Construction Effort.....	2-7	2-2
3.	EXPLANATION OF PLANNING TABLES (INSTALLATIONS)		
	Arrangement of Planning Tables	3-1	3-1
	Installation Number.....	3-2	3-1
	Installation Description.....	3-3	3-1
4.	EXPLANATION OF FACILITY PLANNING TABLES		
	Arrangement of Facility Planning Tables.....	4-1	4-1
	Facility Number.....	4-2	4-1
	Facility Description.....	4-3	4-1
	Material Logistic and Cost Data.....	4-4	4-1
	Construction Man-hours	4-5	4-1
5.	PREPACKAGED EXPENDABLE CONTINGENCY SUPPLIES (PECS) AND CONTAINERIZATION		
	Purpose	5-1	5-1
	Description and Use.....	5-2	5-1
6.	SUPPLY PROCEDURES		
	General.....	6-1	6-1
	The Directorate of Material Management	6-2	6-1
	US Army Troop Support Command (TROSCOM)	6-3	6-1
	Requisition and Supply Procedures.....	6-4	6-1
7.	CAMOUFLAGE		
	Treatment of Camouflage in the AFCS	7-1	7-1
	Camouflage Principles, Methods and Materials.....	7-2	7-1
8.	UTILIZATION OF TM 5-301		
	Planning.....	8-1	8-1
	Example Problems.....	8-2	8-1
9.	LISTING OF INSTALLATIONS-DESERT		
	Index of Installation (Desert)	9-1	9-1
	Listing of Installation (Desert).....	9-2	9-3
10.	LISTING OF FACILITIES-DESERT		
	Index of Facilities (Desert)	10-1	10-1
	Listing of Facilities (Desert).....	10-2	10-3

*This manual supersedes TM 5301-4. 1 March 1982

CHAPTER 1 INTRODUCTION

1-1. Purpose

The purpose of this manual is to provide material costs, logistical, and engineering data for use in planning construction support for Army functions in the Theater of Operations (TO). The manual is part of the Army Facilities Components System (AFCS), and it is intended for use by:

a. Contingency, base development, construction, and logistical planners. When data are used in base development planning, the user is advised to refer to FM 31-82, Base Development Planning.

b. Construction units, because it contains the engineering data required for construction of the various structures, facilities, installations, and utilities required by the Army and Air Force to support military missions in the TO.

c. Logistical commands and supply agencies in requisitioning, identifying items, costing, and other related supply functions.

1-2. Scope

This manual contains summary listings of installations (generally referred to as planning tables), facilities and Prepackaged Expendable Contingency Supplies (PECS). The manual is divided into four volumes, one for each of the climatic zones in the AFCS. The summaries include cost, shipping weight, and volume of construction material. In addition, man-hour estimates to construct each facility and installation, minimum real estate requirements for installations, and the utility requirements for facilities and installations are included in this manual.

1-3. Related Publications

The AFCS consists of a series of four Department of the Army Technical Manuals. This manual (series is published in four volumes, one for each climatic zone), plus three accompanying publications indicated as follows:

a. TM 5-302, "Army Facilities Components System-Designs." This multi-volume manual contains installation layouts, facility drawings, construction details and materials lists for the AFCS. The manual is of primary interest to the construction unit performing actual construction of Army components in theaters of operations.

b. TM 5-303, "Army Facilities Components System-Logistic Data and Bills of Materials." This manual is used by planners, builders and suppliers in the identification of items in the bills of materials associated with specific facilities. Each item in a facility is identified by a National Stock Number (NSN), abbreviated description, unit of issue, and quantity. The material cost, shipping weight, volume ap: d estimated construction effort in man-hours are shown in the facility description.

c. TM 5304, "Army Facilities Components System User Guide." This manual provides users with a single source of reference and information concerning the operation of the system, available system products, and example problems demonstrating the use of the system.

1-4. Training

Information contained in the AFCS provides commanders at all levels with sufficient information to plan facilities construction training exercises. Cost and quantity of materials, NSNs, man-hours, and construction drawings are provided in such a manner as to permit unit commanders the flexibility of selecting facilities which, if constructed, would exercise individual military occupational specialties, unit construction planning, organization, and management. Construction times reflected in TM 5-301-1 through TM 5-3014 and TM 5-303 are optimal times to accomplish tasks and will serve as an initial planning guide. TM 5-304 provides tables of engineer unit capabilities. A unit that can accomplish tasks within the man-hours shown the TMs should consider itself proficient in its skills, planning, organization and management. Materials required to construct facilities contained in the AFCS are not normally available as training sets and must be procured under appropriate regulations. If the facility is constructed as an authorized construction project, it is subjected to appropriate regulation governing troop construction.

1-5. Comments and Information Sources

The data for this manual are maintained by the Office of the Chief of Engineers and are available in printouts, magnetic tape or microfiche. Cost data are updated quarterly and can be obtained from Huntsville Division, US Army Corps

of Engineers. All correspondence and requests for technical assistance, drawings and information regarding the AFCS system should be forwarded to either:

US Army Corps of Engineers
Huntsville Division
ATTN: HNDED-FD
PO Box 1600
Huntsville, AL 35807-4301
or
HQDA (DAEN-ZCM)
WASH DC 20310-2600

Users of the AFCS are encouraged to submit comments, corrections and recommendations for improvement or revision directly to HQDA (DAEN-

ZCM). Comments should refer to the specific facility or installation. The reason for each comment or recommendation should be given to ensure proper understanding and evaluation.

1-6. Responsibilities

The Chief of Engineers is responsible for the continuous review and updating of this publication to include coordination with DA staff agencies, oversee commands and other users that are affected by construction for contingency operations. Responsibilities of the Chief of Engineers and other agencies or commands are more specifically stated in AR 41516.

CHAPTER 2

EXPLANATION OF THE TERMINOLOGY AND AFCS DATA

2-1. Army Facilities Components System (AFCS)

The AFCS is a tool used to assist military planners, supply agencies, and construction personnel at all levels that have a role in Army construction in theaters of operations. The AFCS uses a building block concept to permit maximum flexibility. The building blocks are items, subfacilities, facilities and installations.

2-2. Building Blocks

TM 5-304 provides a complete discussion of the building block concept and explains other terminology in the AFCS system. The building blocks are discussed briefly below:

a. *Item*. An item is any construction material or equipment that makes up a larger product. Each item has an associated National Stock Number, description, unit of issue, and quantity. The quantities used include an allowance for material wastage and loss.

b. *Facility and Subfacility*. A facility is a group of items designed to provide a service. Users should therefore carefully read the facility descriptions to ensure that all components necessary to build the desired structure are ordered. A subfacility differs from a facility only in its use in TM 5-303. The purpose of a subfacility is to reduce the repetitive listing of a facility's construction materials. Users should also be aware that components of some facilities (roads, hardstands and bridges) are separated into two subfacility groupings to widen the selections in meeting actual field conditions.

c. *Installation*. An installation is a group of facilities designed to provide a specific service or support to some military function in a TO.

d. *Component*. "Component" is a generic term sometimes used to refer to any facility or installation contained in the AFCS.

2-3. Planning Table

"Planning Table" is a term that is used to refer to the printed installations as explained in Chapter 3.

2-4. Design Criteria

a. Design criteria are shown on the construction drawings in TM 5-302 when considered beneficial in adapting AFCS designs to actual site conditions. Also,

Chapter 2 of TM 5-302 provides additional design and construction considerations.

b. The facilities in the system are designed to operate in one or more of four climatic zones. The four climatic zones are:

(1) *Temperate Zone*. The geographical areas in which mean annual temperatures are between + 30°F and +70°F as identified by isothermal lines.

(2) *Frigid Zone*. The geographical areas in which mean annual temperatures are lower than + 30°F as identified by isothermal lines.

(3) *Tropical Zone*. The geographical areas in which mean annual temperatures are higher than + 70°F as identified by isothermal lines.

(4) *Desert Zone*. The geographical areas which are arid and without vegetation.

2-5. Construction Standards

Standards of construction are identified for the purpose of managing construction resources. The availability of resources, the operational plans and the using unit's mission will dictate the standards of construction to be used in theaters of operation. JCS Publication No. 3 sets forth the standards of construction that are applicable in a theater of operation. The standards are based primarily on the duration of the contingency and previously were defined as follows: initial (INT)-0 zero 6 months, intermediate (ITR)-6 to 24 months, and temporary (TPR)-24 to 60 months. Current JCS Publication No. 3 doctrine refines the construction standards as initial (0-6 months) and temporary (6-24 months). The 24-60 months standards has been deleted. Installations and some facilities listed in the AFCS are identified by a corresponding construction standard. In most cases, facilities contained in the AFCS fall into the intermediate and temporary standards. The nature of materials used in construction of the AFCS facilities and the structural aspects of the designs are such that the life of facilities will normally exceed 2 years when appropriate maintenance is performed.

2-6. Building Structures

The AFCS views building structures as being composed of three basic types: disposable

(woodframe, block, concrete or any other construction material that is formed on the site, and which has little or no salvage value); preengineered relocatable (panelized buildings, tents or any other structure that has an 85 percent recoverability); and mobile (containerized buildings or any other structure that can be moved and erected frequently with little construction effort required, i.e., the MUST Hospital). The AFCS allows for the range of these basic types to permit commanders the option of selecting the facility that best suits available construction effort, mission requirements, and availability of materials. Few mobile facilities other than tents are presently contained in AFCS; however, priority for future designs has been given to the initial mobile-type facilities where feasible.

2-7. Construction Effort

The construction effort in man-hours required for engineer troop units to erect or construct each facility

and installation has been estimated and is shown in this manual. The construction estimates are based on the use of standard construction practices and procedures. The estimates include neither effort of administration, mobilization, and planning, nor effort lost because of weather delays. Estimates of actual working time required for the task was obtained by assuming the use of skilled personnel in the temperate zone. Estimates for other climatic zones were obtained by applying the following adjustment factors:

Tropical	1.45
Desert	1.25
Frigid.....	2.41

Additional information on labor categories, operational conditions and engineer unit capabilities is provided in TM 5-304.

CHAPTER 3

EXPLANATION OF PLANNING TABLES (INSTALLATIONS)

3-1. Arrangement of Planning Tables

"Planning table" is the term used for data published in this manual as AFCS installations. The paragraphs that follow explain the parts of a planning table.

3-2. Installation Number

Installations are shown in ascending order according to the installation number in the upper right-hand corner, which consists of two alpha and four numeric characters. The number is used to identify the complete bill of materials required to construct that installation. This number also identifies the corresponding construction drawing in TM 5-302.

3-3. Installation Description

The installation description appears in the upper left-hand corner, and includes the title, climatic zone, standard and type of construction, purpose, minimum real estate requirements, and utility and aggregate requirements. The following items are contained in the planning tables:

a. Aggregate Requirements. Aggregate cannot be requisitioned from the bills of materials. It is assumed to be available within 5 miles of the construction site.

b. Utility and Road Requirements. Installation requirements include roads, fences, water treatment, sewage treatment, and electrical generation. Facilities providing these requirements are generally not automatically included in the installation. Several installations may be grouped into a complex, with the additional supporting requirements computed for the total complex. The user should carefully review the supporting facilities included in the installation planning table, use the TM 5-302 drawing and TM 5-303 bill of materials for additional information, and augment the listing of the additional required facilities. Also,

appropriate adjustments should be made to the utility sizes and quantities where site plans are changed to accommodate actual field conditions, topography changes, and dispersal requirements.

c. Facility Number. Shows the five numeric and two alphas characters that identify each AFCS facility.

d. Facility Description. Provides a short description of the facilities included in the installation.

e. Size or Unit. Gives dimensions, capacity or unit of measure for each facility in the installation.

f. Basis. Gives the criteria or standard planning basis upon which facilities are included in the installation.

g. Quantity Required. Indicates the actual quantity of a particular facility included in the installation.

h. Material. Displays the total material logistic and cost data associated with the number of facilities in the "Quantity Required" column. The column with the heading "WT-ST" gives the weight of the material to include packaging materials in short tons (2,000 pounds). The column with the heading "VOL = MT" gives the shipping volume to include packaging materials in measurement tons (40 cubic feet). The cost of the material is shown to the nearest dollar in the COST column. The material costs are current as of the listed date. Appropriate inflation factors should be added if data shown is more than 6 months old and a more precise costs is required. CONUS material costs are the only costs shown in AFCS.

i. Constructive Man-hours. Displays the estimated horizontal, vertical, and general construction man-hours for construction by engineer troop units.

j. Installation Totals. The material logistic and cost data and construction effort totals are shown at the end of each table. It should be noted that the costs listed are CONUS material costs only and are current only at the time of publication and thus may be somewhat outdated.

CHAPTER 4

EXPLANATION OF FACILITY PLANNING TABLES

4-1. Arrangement of Facility Planning Tables

The facilities in the AFCS are identified with regard to their application in a theater of operations. The paragraphs that follow explain the parts of the facility planning table. A complete listing of facilities in numerical sequence is contained in Chapter 10.

4-2. Facility Number

The "Facility Number" column shows the five numeric and two alpha characters that identify each facility. The numbering system uses the number for the corresponding construction drawing in TM 5-302. It should be noted, however, that there is not a drawing for every facility.

4-3. Facility Description

The "Description" column contains a full description of each facility. TM 5-303 provides a detailed bill of

materials for each facility, and TM 5-302 provides construction drawings and drawings for utilities (electric, sewage, and water).

4-4. Materials Logistic and Cost Data

The "Construction Material" columns display logistic and cost data associated with each facility. The weight in short tons (2000 lb) includes packing material. The shipping volume is given in measurement tons (40 cu ft). Costs are current as of the date of issue and reflect CONUS material costs only.

4-5. Construction Man-hours

The "Construction Effort in Man-hours" columns give the estimated engineer troop unit effort for horizontal, vertical, and general skills. The total column represents the sum of these items.

CHAPTER 5

PREPACKAGED EXPENDABLE CONTINGENCY SUPPLIES (PECS) AND CONTAINERIZATION

5-1. Purpose

To assist engineer units in the planning and implementation of contingency plans, a series of cargo containers loaded with stylized engineer supplies was developed to meet normal mission requirements for limited periods or for minor repairs for extended periods or for minor repairs for extended periods when supplies are replaced based on demand experience. Also included as facilities are special bomb damage and repair kits. A matrix of bomb damage and repair facilities will be added to TM 5-304.

5-2. Description and Use

Each container is reflected as a separate facility within the AFCS, which allows its requisition as an independent supply kit and permits the requester to obtain as many kits as needed to meet the assigned requirements. The unit commander can also procure a set of kits/facilities which are reflected as installations in the AFCS and are designed to provide a minimum of expendable materials to accomplish the specific engineer tasks. Again, the commander has the option of requesting the number of

installations required. An item consumed from the container can be requisitioned and replaced as separate items since each carries its own NSN. When requisitioning a facility or installation, commanders/requesters should check the size of the shipping/storage container ordered to ensure that proper transportation is available upon delivery of the kits. There are two types of military, containers: the TRICON (8 x 8 x 62/3 feet) and the MILVAN (8 x 8 x 20 feet). The TRICON has a maximum payload of 13,000 pounds, a tare weight of 1,880 pounds, and approximate interior dimensions of 90 x 85 x 73.5 inches. The MILVAN has a maximum payload of 40,000 pounds, a tare weight of 4,700 pounds and approximate interior dimensions of 92 x 87 x 231 inches. The containers are equipped with standard fittings allowing movement by a variety of material handling equipment. In groups of three, the TRICONs form an 8 x 8 x 20 container compatible with the commercial container system. Common commercial containers vary in size up to 8 x 9 x 40 feet with a maximum payload of 60,900 pounds, and a tare weight of 6,300 pounds. The weight of each facility (without container) can be found in TM 5-303.

CHAPTER 6 SUPPLY PROCEDURES

6-1. General

The US Army Materiel Command (AMC), is responsible for developing supply procedures, policies and command guidance necessary to fund, procure, store and ship materiel listed in the Army Facilities Components System. AMC responsibility is set forth in AR 415-16. The focal points within AMC for the Army Facilities Components System and their responsibilities are briefly explained in paragraphs 6-2 and 6-3 below.

6-2. The Directorate of Materiel Management

The Directorate of Materiel Management, Associate Director for Evaluation, Headquarters, US Army Materiel Command (ATTN: AMCM-M-E), Alexandria, VA 22304, is responsible for coordinating AMC activities and interests pertaining to the AFCS. This coordination embraces material development, procurement policies, employment support and other related matters. The Associate Director for Evaluation ensures that AMC can

support the demands for construction materiel at the onset of an emergency and thereafter as required.

6-3. US Army Troop Support Command (TROSCOM)

The Command, TROSCOM, (ATTN: AMSTRSPRA), 4300 Goodfellow Boulevard, St. Louis, MO, 63120 is the central point within the Continental United States (CONUS) for the inclusion of items in the Federal Supply System and the acquisition and supply of items in the AFCS.

6-4. Requisition and Supply Procedures

Requisition and supply procedures, methods, process and interrelationships are contained in chapter 5 of TM 5-304, AFCS User Guide. Every effort should be made to acquire facility construction materials from a source as close to the construction site as possible before requisitioning through the supply system.

CHAPTER 7 CAMOUFLAGE

7-1. Treatment of Camouflage in the AFCS

The AFCS does not include a separate camouflage facility for each structure. Rather, descriptive information and tables are included which will allow the planner to extract the necessary materials for a particular task. However, in accomplishing a camouflage requirement, it should be noted that successful camouflage techniques require imaginative use of not only the issued materials but also such artificial and natural materials as are locally available. These would include such items as cut foliage, search, wire screening and other disrupters. The proper siting

and dispersal of facilities with respect to existing natural or manmade terrain patterns will lessen the need for artificial camouflage. A complete coverage of camouflage techniques and the doctrine and techniques of camouflage practice are contained in FM 5-20, Camouflage, and TM 5-200, Camouflage Materials.

7-2. Camouflage Principles, Methods and Materials

Discussion of camouflage principles, methods, and materials is contained in Appendix D of TM 5-304.

CHAPTER 8

UTILIZATION OF TM 5-301

8-1. Planning

The importance of the planning phase of any undertaking cannot be overemphasized. This is certainly true in providing construction support for the Army in a theater of operations. The construction requirements fluctuate because of national policies, contingency plans, escalation or de-escalation of operations, geographical locations and conditions, and availability of resources.

The facilities and installations in the AFCS have been developed to satisfy many of the Army's construction requirements in accordance with criteria contained in JCS Publication No. 3. The requirements for the AFCS components are provided by major Army commands and elements of the DA staff. Approval of requirements is received from proponent elements of the DA staff per AR 415-16. For example, The Surgeon General established the requirements for and approved the medical components in the AFCS.

The AFCS components are continually updated to ensure adherence to current doctrine and actual field requirements. A range of construction materials is used in developing the components so that planners and users have the flexibility to select those components that best meet their requirements and resources. The resources consist of personnel, transportation, construction materials and equipment.

Planning for construction support of an Army operation should include the following steps as a minimum:

a. Provide contingency or operational plans to determine the scope of construction requirements. Coordinate with technical and administrative staff elements to determine their facility and installation requirements in the theater.

b. Evaluate intelligence data and other information to determine the number and type of existing facilities and installations that are required. This evaluation should include the availability of utilities (water, electric power and sewage treatment) and the availability of construction materials within the theater. The base development process is described in FM 31-82.

c. Determine the standards of construction to be used for the facilities and installations based on the operation duration, military objectives and availability of resources.

d. Select the AFCs facilities and installations necessary to satisfy the construction requirements. This selection should exclude the requirements that can be met with indigenous resources. In his selection, the planner should include allowances for facilities that may be damaged, such as blown bridges and railroad tracks. A matrix of damage and repair facilities (Kits) is being added to the next change to TM 5-304. Those repair kits are included in this manual and TM 5-303.

e. Evaluate manpower resources to determine whether U.S. contractors, troop units, local contractors and self-help programs are to be used in the construction work. Review Prepackaged Expendable Contingency Supplies (PECS) as necessary to determine what expendable construction supplies are required by engineer units in support of minor repair requirements that do not warrant a requisitional facility.

f. Determine the real estate requirements and initiate actions for the acquisition of the real estate.

g. Estimate the construction effort, cost of construction materials, and logistical data for transporting the materials. Add the overseas transportation costs to the material costs shown in this manual if the total cost of materials to be delivered to the theater is required. Also add local labor and material costs, if appropriate.

h. Requisition the construction materials and identify long-lead-time procurement items so that construction tasks will not be unnecessarily delayed.

i. Establish a management-control system such as Critical Path Method (CPM) techniques to keep construction tasks on schedule.

8-2. Example Problems

Several example problems demonstrating the use of AFCS to both engineer and non-engineer users is contained in Chapter 4 of TM 5-304.

CHAPTER 9
LISTING OF INSTALLATIONS

9-1. Index of Installations

<i>Description</i>	<i>Category</i>
Administration	AA
Airfield and Heliports	AG
Camp, PW	PW
Camp, Troop	NT
Hospital.....	GH
Maintenance, Vehicle.....	MT
Marine, Railway Repair	FP
Marine, Terminal POL	PA
Medical Depots	GH
Ordnance, Armament Rebuild Ship, Parks & Collection Point.....	JA
PECS (Containerized Supplies).....	YY
Precast Parts Yard (Concrete, Panelized Wood and Steel)	PY
POL Fuel Drum Cleaning, Filling and Storage.....	PB
POL Pipeline.....	PD
POL Tactical Marine Terminal.....	PF
POL Tank Farm, Bulk Storage	PB
POL Tank Farm, Complex	PC
POL Tank Truck/Car Loading/Unloading	PE
Port, Break-Bulk Cargo	FP
Post Office.....	AP
Railroad, Regulating Station.....	FR
Railroad, Terminal.....	FT
Recreational Center	AR
Storage, Ammunition	DA
Signal Intelligence.....	CC
Storage, Dry Cargo	DC

9-2. Listing of Installations in Category Number Sequence

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 25 AIRCRAFT,1 UH-1H AND 24
 CH-47C OF THE TRANSP.CO.,HELIICOPTER MEDIUM,INSTALLATION DWG.
 SHEET 7 OF 65,INITIAL STD,SUPPORT AREA,
 GRADED AND DRAINED,SURFACING HEAVY DUTY MEMBRANE,PERSONNEL
 FACIL-ORGANIC TOE EQPT,REAL ESTATE REQT FOR INST-104 ACRES,
 READ FROM LOCAL SOURCE---COARSE AGGR,1743 CY,FINE AGGR,1472
 CY,MINERAL FILLER,658 CY,COMBAT BN CONSTR

A60134

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS REQUIRED WT-ST VOL-MT	COST	CONSTR EFFORT IN MANHOURS			
				REQUISITE	WT-ST			HORZ	VERT	GENL	TOT
111120AA	RUNWAY W/25 FT SHOULDER,450 X 60		CH-54 AIRCRAFT	1.0	21	10	45603	324	173	497	
111120AB	RUNWAY LENGTH CORRECTION,100 X 60		TEMP AND ALT	.0							
111120AC	RUNWAY OVERRUN,100 X 110 FT		CH-54 AIRCRAFT	2.0	6	4	4184	143	61	184	
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0				538	345	883	
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	160.0	320	160	167360	7728	3128	10856	
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	1.2	38	34	33014	544	170	714	
111210AB	TAXIWAY W/25 FT SHOULDERS,2000 X 40		CH-54 AIRCRAFT	5.2	426	161	866848	6237	3265	9502	
111320AB	PARKING PAD,4EA 20 X 20 FT		UH-1 AIRCRAFT	.3		1	1967	7	3	10	
111320AC	PARKING PAD,2EA 50 X 25 FT		CH-47 AIRCRAFT	12.0	12	36	78660	497	166	663	
111370AB	AIRCRAFT WASHING APRON,50 X 25 FT		1/INSTALLATION	1.0	1	3	6498	20	7	27	
111371AB	DEFUEL/DECONTN APR,50 X 25 FT		1/INSTALLATION	1.0	1	3	6498	20	7	27	
111380AA	AC LOADING APR,2EA 50 X 25 FT		CH-47 AIRCRAFT	2.0	2	6	13110	55	28	83	
111610AA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	1	3	6527	28	14	42	
112110AA	HOT REFUELING PAD,2EA 50 X 25 FT		3/INSTALLATION	1.5	2	5	9833	41	21	62	
121110AH	SUPPORT ACFT REFUELING 30000 G STOR		5 DAY SUPPLY	2.0	16	40	131052	350	267	736	1353
12110AJ	FUEL STORAGE AUGMENTATION 50000 GAL		5 DAY SUPPLY	1.0	5	5	16865	74	64	167	285
113315AA	AC CONTROL STATION,20 X 20 FT		1/INSTALLATION	1.0	3	2	15	7	1	8	
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0			304	2	2	4	
114111AA	FIRE AND RESCUE STATION,20 X 20 FT		1/INSTALLATION	1.0	3	2	15	7	1	8	
142183AB	AMMUNITION STORAGE,2500DSF		AS REQUIRED	1.0				3	2	5	
85110CK	ROAD PAVEMENT,CLASS C,6IN STBL 1MI		PROVIDE ACCESS	2.2	1472	994	7359	385	111	496	
85110DG	HARDSTAND,APR,TXWY,OR RNWY 1000SQYD		AS REQUIRED	.3	30	20	150	9	3	12	
85130KH	ROAD,CLASS C,GRADED AND DRAINED 1MI		PROVIDE ACCESS	2.2	26	13	15297	4433	1617	6050	
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.3	2	1	1321	74	27	101	
187120AA	DRAINAGE HELIPORT,24 ACRES		1 IN./HR	1.0				53	39	92	
				2387	1503	1410480	21577	333	10054	31964	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 25 AIRCRAFT,1 UH-1H AND 24
 CH-47C OF THE TRANSP CO.,HELICOPTER MEDIUM,INSTALLATION DWG
 SHEETS 8AND9 OF 65,INITIAL STANDARD
 SUPPORT AREA,GRADED AND DRAINED,SURFACING,M8A1,LANDING MAT,
 PERSONNEL FACIL-TROOP CAMP INST NO NT1421,REAL ESTATE REQT
 FOR INST-123 ACRES,REQD FROM LOCAL SOURCE--COARSE AGGR,1596
 CY,FINE AGGR,1338 CY,MINERAL FILLER,598 CY,COMBAT BN CONSTR

AG0234

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT.
111120AC	RUNWAY OVERRUN,100 X 110 FT		CH-54 AIRCRAFT	2.0	6	6	6186	163		41	186
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0			538			345	883
111120AE	CLEAR AREA,1000 SY			167.0	334	167	176682	8066		3265	11331
111120BA	RUNWAY W/25 FT SHOULDER,450 X 60		CH-54 AIRCRAFT	1.0	131	77	73348	342		328	670
111120BC	RUNWAY LENGTH CORRECTION,100 X 60		TEMP AND ALT	.0							
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	1.2	38	34	33014	544		170	714
111210AB	TAXIWAY W/25 FT SHOULDER,2000 X 40		CH-54 AIRCRAFT	.2	16	6	33263	240		126	366
111210BB	TAXIWAY W/25 FT SHOULDER,1000 X 40		CH-54 AIRCRAFT	10.2	2234	1265	1306457	6428		6229	12657
111320BB	PARKING PAD,4EA 20 X 20 FT		UH-1 AIRCRAFT	.3	3	2	2580	6		7	13
111320BC	PARKING PAD,10EA 50 X 25 FT		CH-47 AIRCRAFT	2.4	173	125	117766	408		411	819
111340BD	HANGAR ACCESS,335 X 100 FT		AS REQUIRED	1.0	147	108	104844	262		490	752
111370AB	AIRCRAFT WASHING APRON,50 X 25 FT		1/INSTALLATION	1.0	1	3	6498	20		7	27
111371AB	DEFUEL/DECONTN APR,50 X 25 FT		1/INSTALLATION	1.0	1	3	6498	20		7	27
111380BB	AC LOADING APR,4EA 50 X 25 FT		CH-47 AIRCRAFT	1.0	29	21	19627	58		58	116
111610AA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	1	3	6527	28		14	42
112110BB	HOT REFUELING PAD,2EA 50 X 25 FT		3/INSTALLATION	1.5	21	15	14721	43		43	86
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 6-UNIT		AS REQUIRED	1.0	1	1	1246	9		60	92
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173		374	1213
113315BA	CONTROL TOWER LOW DENSITY TRAFFIC		1/INSTALLATION	1.0	16	21	4632	1		560	112
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0			304			2	4
14110BA	AFOPS BLDG,864SF PNL WD BDG W/ INT		1/INSTALLATION	1.0	27	33	18383	8		1110	879
114111BA	FIRE AND RSQ STA,FAC NO.73010AC		1/INSTALLATION	1.0	192	283	39238	63		930	171
114910AR	AIRCRAFT REVETMENT,IMPROVED,UH-1D/H		UH-1 AIRCRAFT	1.0	15	12	3919	61		102	163
114910AT	AIRCRAFT REVETMENT,IMPROVED,CH-47		CH-47 AIRCRAFT	24.0	504	384	132096			2180	3174
121110BB	ORG MNT HANGAR,105 X 112 FT		CH-47 AIRCRAFT	3.0	237	468	773025	587		1052	1639
141120BA	FLAMMABLE STORAGE,12 X 24 FT		AS REQUIRED	1.0	14	13	3322	1		1	2
41180AG	TANK, POL, 3000 BARREL, W/6 IN PIPE 3000 BBL		5 DAY SUPPLY	1.0	2	32	12538	104		357	242
142183BA	AMMUNITION STORAGE,24 X 36 FT			1.0	25	27	17138	1		1	2
85110CK	ROAD PAVEMENT,CLASS C,6IN STBL,1MI		PROVIDE ACCESS	2.0	1338	904	6690	350		101	451
85110DG	HARDSTAND,APR,TXWY,OR RNWY 1000SQYD		AS REQUIRED	.6	60	41	300	19		7	26
85130KH	ROAD,CLASS C,GRADED AND DRAINED,1MI		PROVIDE ACCESS	2.0	24	12	13906	4030		1470	5500
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.6	4	2	2641	148		53	201
187120BA	DRAINAGE HELIPORT,25 ACRES		1 IN./HR	1.0	32	36	22513	74		64	138
87210AD	CONCERTINA,TRIPLE TAPE TYP D 1000LF		SECUR FENCE	11.0	1287	770	21582	354		1417	1771
				6925	4884	2991344	23068	5634	21625	50327	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQT FOR 25 AIRCRAFT,1 UH-1H AND 24
 CH-47C OF THE TRANSP.CO.,HELICOPTER MEDIUM,INSTALLATION DWG
 SHEETS 10 AND 11 OF 65,TEMPORARY STD,
 SUPPORT AREA,GRADED AND DRAINED,SURFACING BITUMINOUS
 PAVEMENT,PERSONNEL FACIL-TROOP CAMP INST NO NT1621,REAL
 ESTATE REQT FOR INST-123 ACRES,REQD FROM LOCAL SOURCE--
 COARSE AGGR,8828 CY,FINE AGGR,4118 CY,MINERAL FILLER,1269 CY

AG0334

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS REQUIRED WT-ST VOL-MT	COST	CONSTR EFFORT IN MANHOURS			
				WT-ST	VOL-MT			HORZ	VERT	GENL	TOT
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0			538			345	883
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	168.0	336	168	175728	8114		3284	11398
111120BF	RUNWAY OVERRUN,100 X 125 FT		CH-54 AIRCRAFT	2.0	8	6	4882	166		46	212
111120CA	RUNWAY W/25 FT SHOULDERS,450 X 75		CH-54 AIRCRAFT	1.0	260	210	13615	455		189	644
111120CB	RUNWAY LENGTH CORRECTION,100 X 75		TEMP AND ALT	.0							
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	1.2	38	34	33014	544		170	714
111210CB	TAXIWAY W/25 FT SHOULDERS,1000 X 40		CH-54 AIRCRAFT	11.0	3463	2761	181357	7957		3112	11069
111320CB	PARKING PAD,4EA 20 X 20 FT		UH-1 AIRCRAFT	.3	4	3	72	17		3	20
111320CC	PARKING PAD,10EA 50 X 25 FT		CH-47 AIRCRAFT	2.4	228	182	3586	480		116	596
111340CD	HANGAR ACCESS,335 X 100 FT		AS REQUIRED	1.0	250	200	3346	321		99	420
111370CB	AIRCRAFT WASHING APRON,50 X 25 FT		1/INSTALLATION	1.0	10	8	139	26		6	32
111371CB	DEFUEL/DECONTN APR,50 X 25 FT		1/INSTALLATION	1.0	10	8	139	26		6	32
111380CB	AC LOADING APR,4EA 50 X 25 FT		CH-47 AIRCRAFT	1.0	38	30	598	81		20	101
111610CA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	14	11	211	99		29	128
112110CB	HOT REFUELING PAD,2EA 50 X 25 FT		3/INSTALLATION	1.5	30	24	482	85		29	114
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	23	92
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213	1760
113315BA	CONTROL TOWER LOW DENSITY TRAFFIC		1/INSTALLATION	1.0	16	21	4632	1	560	112	673
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0			304		2	2	4
14110BA	AFOPS BLDG 864SF PNL WD BDG W/ INT		1/INSTALLATION	1.0	27	33	18383	8	1110	879	1997
114111BA	FIRE AND RSQ STA, FAC NO. 73010AC		1/INSTALLATION	1.0	192	283	39238	63	930	171	1164
114910AR	AIRCRAFT REVETMENT, IMPROVED, UH-1D/H		UH-1 AIRCRAFT	1.0	15	12	3919		61	102	163
114910AT	AIRCRAFT REVETMENT, IMPROVED, CH-47		CH-47 AIRCRAFT	24.0	504	384	132096		2180	3174	5354
121110CB	ORG MNT HANGAR,105 X 112 FT		CH-47 AIRCRAFT	3.0	363	594	741540	566		731	1297
141120BA	FLAMMABLE STORAGE,12 X 24 FT		AS REQUIRED	1.0	14	13	3322	1		1	2
41180AG	TANK, POL, 3000 BARREL, W/S IN PIPE 3000 BBL		5 DAY SUPPLY	1.0	2	32	12538	104	357	242	703
142183BA	AMMUNITION STORAGE,24 X 36 FT		AS REQUIRED	1.0	25	27	17138	1		1	2
85110BT	ROAD CLASS C, 12 MULTIPLE SURFACE		PROVIDE ACCESS	2.0	798	600	8372	389		69	458
85110DG	HARDSTAND,APR,TXWY,OR RNWY 1000SQYD		AS REQUIRED	.6	60	41	300	19		7	26
85130KH	ROAD,CLASS C, GRADED AND DRAINED 1MI		PROVIDE ACCESS	2.0	24	12	13906	4030		1470	5500
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.6	4	2	2641	148		53	201
137120BA	DRAINAGE HELIPORT,25 ACRES		1 IN./HR	1.0	32	36	22513	74		64	138
87210AA	FENCE,CHAIN LK,W/2 OUTRGRS 1 1000LF		PERIM FENCING	11.0	187	561	132814	1581		5060	6641
87210AF	GATE,CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	5.0	5	10	1395	35		69	104
87210AG	GATE,VEH CHAINL DBL/LEAF 12WI 10 HI		AS REQUIRED	6.0	6	12	2406	48		104	152
87210AJ	FENCE,CORNER POST 10 FT HI CHAINLIN		AS REQUIRED	17.0			1853	196		156	352

6956 6331 1591587 26355 5634 21157 53146

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 27 AIRCRAFT,10 OH-58,9 AH-1G AND 8 UH-1H OF THE AIR CAVALRY TROOP,INSTALLATION DWG.SHEET 120E
 65,INITIAL STANDARD,SUPPORT AREA,GRADED
 AND DRAINED,SURFACING M8A1 LANDING MAT,PERSONNEL FACIL-TROOP
 CAMP INST NO NT1421,REAL ESTATE REQT FOR INST-65 ACRES,REQD
 FROM LOCAL SOURCE---COARSE AGGR,1268 CY,FINE AGGR,1071 CY,
 MINERAL FILLER,316 CY,COMBAT BN CONSTR

AG1234

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT.	GENL
111120AC	RUNWAY OVERRUN,100 X 110 FT		CH-54 AIRCRAFT	2.0	6	6	6184	163		61
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0			538			365
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	42.8	86	63	44769	2067		837
111120BA	RUNWAY W/25 FT SHOULDERS,450 X 60		CH-54 AIRCRAFT	1.0	131	77	73348	342		328
111120BC	RUNWAY LENGTH CORRECTION,100 X 60		TEMP AND ALT	-0						670
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	4.9	157	137	134809	2220		693
111210AB	TAXIWAY W/25 FT SHOULDERS,2000 X 40		CH-54 AIRCRAFT	2	16	6	33263	240		126
111320BA	PARKING PAD,10EA 12 X 12 FT		OH-58 AIRCRAFT	1.0	10	8	8713	18		18
111320BB	PARKING PAD,6EA 20 X 20 FT		AH-1G AIRCRAFT	4.3	39	30	36976	89		94
111340BA	HANGAR ACCESS,105 X 100 FT		AS REQUIRED	1.0	47	35	36467	87		163
111370AA	AIRCRAFT WASHING APRON,40 X 20 FT		1/INSTALLATION	1.0	1	1	3249	17		5
111371AA	DEFUEL/DECONTN APR,40 X 20 FT		1/INSTALLATION	1.0	1	3	6498	17		5
111380BA	AC LOADING APR,6EA 20 X 20 FT		UH-1 AIRCRAFT	1.0	14	11	12898	29		29
111610AA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	1	3	6527	28		42
112110BA	HOT REFUELING PAD,6EA 20 X 20 FT		6/INSTALLATION	1.0	14	11	12898	29		58
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	23
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213
113315BA	CONTROL TOWER LOW DENSITY TRAFFIC		1/INSTALLATION	1.0	16	21	4632	1	560	112
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0			304		2	4
141108B	AFOPS BLDG 2160SF PNL WD BLDG W/ IN		1/INSTALLATION	1.0	170	953	96409	21	2151	610
114111BA	FIRE AND RSG STA, FAC NO.7301QAC		1/INSTALLATION	1.0	192	283	39238	63	930	171
114910AN	AIRCRAFT REVETMENT,IMPROVED,OH-58		OH-58 AIRCRAFT	10.0	110	80	28000	449	817	1266
114910AR	AIRCRAFT REVETMENT,IMPROVED,UH-1D/H		UH-1 AIRCRAFT	8.0	120	96	31352	488	819	1307
114910AV	AIRCRAFT REVETMENT,IMPROVED,AH-1G		AH-1G AIRCRAFT	9.0	108	90	28926	497	880	1377
121110BB	ORG MNT HANGAR,105 X 112 FT		UH-1 AIRCRAFT	1.0	79	156	257675	196	351	547
141120BA	FLAMMABLE STORAGE,12 X 24 FT		AS REQUIRED	1.0	14	13	3322	1		1
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE	1000 BBL	5 DAY SUPPLY	1.0	1	14	8663	92	357	173
42283AC	MAGAZINE,STEEL ARCH 16X36		AS REQUIRED	1.0	14	31	4453	170	179	173
85110CK	ROAD PAVEMENT,CLASS C,6IN STL 1MI		PROVIDE ACCESS	1.6	1070	723	5352	280		81
85110DG	HARDSTAND,APR,TXWY,OR RNWY 1000SQYD		AS REQUIRED	.6	60	41	300	19		26
85130KH	ROAD,CLASS C,GRADED AND DRAINED 1MI		PROVIDE ACCESS	1.0	19	10	11125	3224		1176
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.6	4	2	2641	148		53
187120BB	DRAINAGE HELIPORT,11 ACRES		1 IN./HR	1.0	14	17	9880	23		23
87210AD	CONCERTINA,TRIPLE TAPE TYP D 1000LF		SECUR FENCE	9.2	1076	644	18050	296		1185
				3603	3556	980029	10580	6047	10597	27224

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 27 AIRCRAFT,10 OH-58,9 AH-1G AND
 8 UH-1H OF THE AIR CAVALRY TROOP,INSTALLATION DWG.SHEET 130F
 65,TEMPORARY STD,SUPPORT AREA,GRADED AND
 DRAINED,SURFACING BITUMINOUS,PAVEMENT,PERSONNEL FACIL-TROOP
 CAMP INST NO NT1621,REAL ESTATE REQT FOR INST-65 ACRES,REQD
 FROM LOCAL SOURCE--COARSE AGGR,2320 CY,FINE AGGR,1027 CY,
 MINERAL FILLER,327 CY,COMBAT BN AND SUP CO CONSTR

AG1334

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS REQUIRED WT-ST VOL-MT	CONSTR EFFORT IN MANHOURS				
				WT-ST	VOL-MT		COST	HORZ	VERT	GENL	TOT
111120AR	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0			538			365	883
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	41.5	83	42	43409	2004		811	2815
111120BF	RUNWAY OVERRUN,100 X 125 FT		CH-54 AIRCRAFT	2.0	8	6	4882	166		66	212
111120CA	RUNWAY W/25 FT SHOULDERS,450 X 75		CH-54 AIRCRAFT	1.0	260	210	13615	455		189	644
111120CB	RUNWAY LENGTH CORRECTION,100 X 75		TEMP. AND ALT	.0							
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	5.0	160	140	137560	2266		707	2973
111210CB	TAXIWAY W/25 FT SHOULDERS,1000 X 40		CH-54 AIRCRAFT	.4	125	100	6595	289		113	402
111320CA	PARKING PAD,10EA 12 X 12 FT		OH-58 AIRCRAFT	1.0	11	9	327	140		28	168
111320CB	PARKING PAD,4EA 20 X 20 FT		AH-1G AIRCRAFT	4.3	56	43	1036	242		69	291
111340CA	HANGAR ACCESS,105 X 100 FT		AS REQUIRED	1.0	79	63	1056	118		32	150
111370CA	AIRCRAFT WASHING APRON,40 X 20 FT		1/INSTALLATION	1.0	6	5	86	20		3	23
111371CA	DEFUEL/DECONTN APR,40 X 20 FT		1/INSTALLATION	1.0	6	5	86	20		3	23
111380CA	AC LOADING APR,6EA 20 X 20 FT		UH-1 AIRCRAFT	1.0	18	15	344	84		17	101
111610CA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	14	11	211	99		29	128
112110CA	HOT REFUELING PAD,6EA 20 X 20 FT		6/INSTALLATION	1.0	18	15	344	93		36	129
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	23	92
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213	1760
113315BA	CONTROL TOWER LOW DENSITY TRAFFIC		1/INSTALLATION	1.0	16	21	4632	1	560	112	673
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0		304		2	2	4	
14110BB	AFOPS BLDG 2160SF PNL WD BLDG W/ IN		1/INSTALLATION	1.0	170	953	96409	21	2151	610	2782
114111BA	FIRE AND RSQ STA, FAC NO. 73010AC		1/INSTALLATION	1.0	192	283	39238	63	930	171	1164
114910AN	AIRCRAFT REVETMENT,IMPROVED,OH-58		OH-58 AIRCRAFT	10.0	110	80	28000		449	817	1266
114910AR	AIRCRAFT REVETMENT,IMPROVED,UH-1D/H		UH-1 AIRCRAFT	8.0	120	96	31352		488	819	1307
114910AV	AIRCRAFT REVETMENT,IMPROVED,AH-1G		AH-1G AIRCRAFT	9.0	108	90	28926		497	880	1377
121110CB	ORG MNT HANGAR,105 X 112 FT		UH-1 AIRCRAFT	1.0	121	198	247180	189		244	433
141120BA	FLAMMABLE STORAGE,12 X 24 FT		AS REQUIRED	1.0	14	13	3322	1		1	2
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE	1000 BBL	5 DAY SUPPLY	1.0	1	14	8663	92	357	173	622
42283AC	MAGAZINE,STEEL ARCH	16X36	AS REQUIRED	1.0	14	31	4453	170	179	173	522
85110BT	ROAD CLASS C, 1A MULTIPLE SURFACE		PROVIDE ACCESS	1.6	638	480	6698	311		55	366
85110CN	HARDSTAND,APR,TXWY,OR RNWY	1000SQYD	AS REQUIRED	.8	41	30	398	39		18	57
85130KH	ROAD,CLASS C, GRADED AND DRAINED 1MI		PROVIDE ACCESS	1.6	19	10	11125	3224		1176	4400
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.8	6	2	3522	198		71	269
187120BB	DRAINAGE HELIPORT,11 ACRES		1 IN./HR	1.0	14	17	9880	23		23	46
87210AA	FENCE,CHAIN LK,W/2 OUTRGRS	1 1000LF	PERIM FENCING	10.0	170	510	120740	1438		4600	6038
87210AF	GATE,CHAINLINK SING/LEAF 3 WI	10 HI	AS REQUIRED	5.0	5	10	1395	35		69	104
37210AG	GATE,VEH CHAINL DBL/LEAF 12WI	10 HI	AS REQUIRED	6.0	6	12	2406	48		104	152
87210AJ	FENCE,CORNER POST 10 FT HI CHAINLIN		AS REQUIRED	16.0			1744	184		147	331

2622 3527 875046 12753 6047 13909 32709

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 10 AIRCRAFT,9 CH-54A AND 1 UH-1H
 OF THE TRANSP.CO.HELICOPTER HEAVY,INSTALLATION DWG.SHEET 14
 OF 65,INITIAL STD,SUPPORT AREA,GRADED AND
 DRAINED,SURFACING HEAVY DUTY MEMBRANE,PERSONNEL FACIL-
 ORGANIC TOE EQPT,REAL ESTATE REQT FOR INST-66 ACRES,REQD
 FROM LOCAL SOURCE---COARSE AGGR,1505 CY,FINE AGGR,1272 CY,
 MINERAL FILLER,569 CY,COMBAT BN CONSTR

AG2134

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS		CONSTR EFFORT IN MANHOURS				
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
111120AA	RUNWAY W/25 FT SHOULDERS,450 X 60		CH-54 AIRCRAFT	1.0	.21	10	45603	324		173	497
111120AB	RUNWAY LENGTH CORRECTION,100 X 60		TEMP AND ALT	.0							
111120AC	RUNWAY OVERRUN,100 X 110 FT		CH-54 AIRCRAFT	2.0	.6	4	6184	163		41	186
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0			538			345	883
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	120.0	240	120	125520	5796		2346	8142
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	1.0	32	28	27512	453		141	594
111210AB	TAXIWAY W/25 FT SHOULDERS,2000 X 40		CH-54 AIRCRAFT	2.7	221	84	449056	3239		1695	4936
111320AB	PARKING PAD,4EA 20 X 20 FT		UH-1 AIRCRAFT	.3		1	1967	7		3	70
111320AD	PARKING PAD,50 X 50 FT		CH-54 AIRCRAFT	9.0	9	27	58743	248		124	372
111340AA	HANGAR ACCESS,100 X 100 FT		AS REQUIRED	1.0	6	1	14906	76		54	130
111370AD	AIRCRAFT WASHING APRON,50 X 50 FT		1/INSTALLATION	1.0	1	3	6498	28		14	42
111371AD	DEFUEL/DECONTN APR,100 X 100 FT		1/INSTALLATION	1.0	6	1	14906	76		54	130
111380AB	AC LOADING APR,50 X 50 FT		CH-54 AIRCRAFT	4.0	4	12	26108	110		55	145
111610AA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	1	3	6527	28		14	42
112110AB	HOT REFUELING PAD,50 X 50 FT		2/INSTALLATION	2.0	2	6	13054	55		28	83
12110AH	SUPPORT ACFT REFUELING 30000 G STOR		5 DAY SUPPLY	2.0	16	40	131052	350	267	736	1353
113315AA	AC CONTROL STATION,20 X 20 FT		1/INSTALLATION	1.0	3	2	15	7		1	8
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0			304		2	2	4
114111AA	FIRE AND RESCUE STATION,20 X 20 FT		1/INSTALLATION	1.0	3	2	15	7		1	8
85110CK	ROAD PAVEMENT,CLASS C,6IN STBL 1MI		PROVIDE ACCESS	1.9	1271	859	6356	332		96	428
85110DG	HARDSTAND,APR TXWY,OR RNWY 1000SQYD		AS REQUIRED	.4	40	27	200	12		5	17
85130KH	ROAD,CLASS C,GRADED AND DRAINED 1MI		PROVIDE ACCESS	1.9	23	11	13211	3828		1396	5224
85210AY	HARDSTAND,GRADED AND DRAINED 1000SY		AS REQUIRED	.4	3	1	1761	99		35	134
187120AB	DRAINAGE HELIPORT,10 ACRES		1 IN./HR	1.0				24		16	40
					1908	1242	947498	15780	269	7375	23424

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 10 AIRCRAFT,9 CH-54A AND 1 UH-1H
 OF THE TRANSP.CO,HELICOPTER HEAVY,INSTALLATION DWG,SHEET 15.
 OF 65 INITIAL STANDARD,REAR AREA,GRADED
 AND DRAINED,SURFACING M8A1 LANDING MAT,PERSONNEL FACIL-TROOP
 CAMP INST NO NT1421/REAL ESTATE REQT FOR INST-93 ACRES,REQD
 FROM LOCAL SOURCE---COARSE AGGR,1426 CY,FINE AGGR,1205 CY,
 MINERAL FILLER,539 CY,COMBAT BN CONSTR

A62244

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS COST	CONSTR EFFORT IN MANHOURS			
				REQUIRED WT-ST	VOL-MT		HORZ	VERT	GENL	TOT
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0		538			345	883
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	115.0	230	115	120290	5555	2248	7803
111120BB	RUNWAY W/25 FT SHOULDERS,450 X 75		CH-54 AIRCRAFT	1.0	164	91	91243	399	400	799
111120BD	RUNWAY LENGTH CORRECTION,100 X 75		TEMP AND ALT	.0						
111120BF	RUNWAY OVERRUN,100 X 125 FT		CH-54 AIRCRAFT	2.0	8	6	4882	166	46	212
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	1.0	32	28	27512	453	141	594
111210AB	TAXIWAY W/25 FT SHOULDERS,2000 X 40		CH-54 AIRCRAFT	.2	16	6	33263	260	126	366
111210BB	TAXIWAY W/25 FT SHOULDERS,1000 X 40		CH-54 AIRCRAFT	5.5	1205	682	704462	3466	3359	6825
111320BD	PARKING PAD,40 X 60 FT		UH-1 AIRCRAFT	1.0	8	7	8181	21	22	43
111320BE	PARKING PAD,10EA 100 X 100 FT		CH-54 AIRCRAFT	.9	408	222	224910	594	965	1559
111340BB	HANGAR ACCESS,220 X 100 FT		AS REQUIRED	1.0	98	73	74006	175	327	502
111370AF	AIRCRAFT WASHING APRON,100 X 100 FT		1/INSTALLATION	1.0	6	1	14906	76	54	130
111371AD	DEFUEL/DECONIN APR,100 X 100 FT		1/INSTALLATION	1.0	6	1	14906	76	54	130
111380BC	AC LOADING APR,4EA 100 X 100 FT		CH-54 AIRCRAFT	1.0	181	99	99732	314	469	783
111610AA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	1	3	6527	28	14	42
112110BD	HOT REFUELING PAD,2EA 100 X 100 FT		2/INSTALLATION	1.0	89	68	72151	237	246	483
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	23
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213
113315BA	CONTROL TOWER LOW DENSITY TRAFFIC		1/INSTALLATION	1.0	16	21	4632	1	560	112
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0			304	2	2	4
14110BA	AFOPS BLDG 864SF PNL WD BDG W/ INT		1/INSTALLATION	1.0	27	33	18383	8	1110	879
114111BA	FIRE AND RSQ STA,FAAC NO.73010AC		1/INSTALLATION	1.0	192	283	39238	63	930	171
114910AR	AIRCRAFT REVETMENT,IMPROVED,UH-1D/H		UH-1 AIRCRAFT	1.0	15	12	3919	61	102	163
114910AU	AIRCRAFT REVETMENT,IMPROVED,CH-54		CH-54 AIRCRAFT	9.0	378	297	98577		1553	2070
121110BB	ORG MNT HANGAR,105 X 112 FT		AS REQUIRED	1.0	79	156	257675	196	351	547
141120BA	FLAMMABLE STORAGE,12 X 24 FT			1.0	14	13	3322	1	1	2
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE	1000 BBL	5 DAY SUPPLY	1.0	1	14	8663	92	357	173
85110AT	ROAD CLASS A, 6" STABILIZED SURFACE		PROVIDE ACCESS	1.8	2140	1445	10701	567	157	724
35110DG	HARDSTAND,APR,TXWY,OR RNWY 1000SQYD		AS REQUIRED	.6	60	41	300	19	7	26
85130AY	ROAD,CLASS A,GRADED AND DRAINED 1MI		PROVIDE ACCESS	1.8	29	14	17086	5175	2080	7255
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.6	4	2	2641	148	53	201
187120BC	DRAINAGE HELIPORT,15 ACRES		1 IN./HR	1.0	25	27	17759	47	44	91
87210AD	CONCERTINA,TRIPLE TAPE TYP D	1000LF	SECUR FENCE	9.1	1065	637	17354	293	1172	1465
				6510	4410	2013133	19130	5007	17426	41563

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 10 AIRCRAFT,9 CH-54A AND 1 UH-1H
 OF THE TRANSP CO. HELICOPTER HEAVY, INSTALLATION DWG. SHEET 16
 OF 65, TEMPORARY STD, REAR AREA, GRADED AND
 DRAINED, SURFACING BITUMINOUS PAVEMENT, PERSONNEL FACIL-TROOP
 CAMP INST NO NT1621, REAL ESTATE REQT FOR INST-93 ACRES, REQD
 FROM LOCAL SOURCE--COARSE AGGR, 7909 CY, FINE AGGR, 3638 CY,
 MINERAL FILLER, 1109 CY, COMBAT BN AND SUP CO CONSTR

AG2344

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT
111120AD	APPROACH-DEPARTURE, 1500X250-850 FT		CH-54 AIRCRAFT	4.0		538			345	883
111120AE	CLEAR AREA, 1000 SY		AS REQUIRED	119.0	238	119	124474	5748	2326	8074
111120BF	RUNWAY OVERRUN, 100 X 125 FT		CH-54 AIRCRAFT	2.0	8	6	4882	166	46	212
111120CA	RUNWAY W/25 FT SHOULDERs, 450 X 75		CH-54 AIRCRAFT	1.0	260	210	13615	455	189	644
111120CB	RUNWAY LENGTH CORRECTION, 100 X 75		TEMP AND ALT	0.0						
111141AA	TAXI-HOVERLANE, 450 X 180 FT		CH-54 AIRCRAFT	1.0	32	28	27512	453	141	594
111210CB	TAXIWAY W/25 FT SHOULDERs, 1000 X 40		CH-54 AIRCRAFT	4.2	1315	1054	69245	3038	1188	4226
111320CD	PARKING PAD, 40 X 40 FT		UH-1 AIRCRAFT	1.0	13	10	207	29	6	35
111320CE	PARKING PAD, 10EA 100 X 100 FT		CH-54 AIRCRAFT	.9	672	536	10499	658	232	890
111340CB	HANGAR ACCESS, 220 X 100 FT		AS REQUIRED	1.0	168	134	2252	231	66	297
111370CD	AIRCRAFT WASHING APRON, 100 X 100 FT		1/INSTALLATION	1.0	75	60	1003	118	32	150
111371CD	DEFUEL/DECONTN APR, 100 X 100 FT		1/INSTALLATION	1.0	75	60	1003	118	32	150
111380CC	AC LOADING APR, 4EA 100 X 100 FT		CH-54 AIRCRAFT	1.0	299	239	4453	317	113	430
111610CA	COMPASS SWING BASE, 50 X 50 FT		1/INSTALLATION	1.0	14	11	211	99	29	128
112110CD	HOT REFUELING PAD, 2EA 100 X 100 FT		2/INSTALLATION	1.0	150	120	2351	237	115	352
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	23	92
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213
113315BA	CONTROL TOWER LOW DENSITY TRAFFIC		1/INSTALLATION	1.0	16	21	4632	1	560	112
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0		304		2	2	4
14110BA	AFOPS BLDG 864SF PNL WD BLDG W/ INT		1/INSTALLATION	1.0	27	33	18383	8	1110	879
114111BA	FIRE AND RSQ STA, FAC NO. 73010AC		1/INSTALLATION	1.0	192	283	39238	63	930	171
114910AR	AIRCRAFT REVETMENT, IMPROVED, UH-1D/H		UH-1 AIRCRAFT	1.0	15	12	3919	61	102	163
114910AU	AIRCRAFT REVETMENT, IMPROVED, CH-54		CH-54 AIRCRAFT	1.0	42	33	10953		173	230
121110CB	ORG MNT HANGAR, 105 X 112 FT		CH-54 AIRCRAFT	2.0	242	396	494360	377	488	865
141120BA	FLAMMABLE STORAGE, 12 X 24 FT		AS REQUIRED	1.0	14	13	3322	1	1	2
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE	1000 BBL	5 DAY SUPPLY	1.0	1	14	8663	92	357	173
85110AB	ROAD, CLASS A, 1IN MULT. SURF.	1MI	PROVIDE ACCESS	1.8	1397	1075	16358	604	106	710
85110CN	HARDSTAND, APR, TXWY, OR RNWY	1000SQYD	AS REQUIRED	.6	31	23	299	29	14	43
85130AY	ROAD, CLASS A, GRADED AND DRAINED	1MI	PROVIDE ACCESS	1.8	29	14	17086	5175	2080	7255
85210AY	HARDSTAND GRADED AND DRAINED	1000SY	AS REQUIRED	.6	4	2	2641	148	53	201
187120BC	DRAINAGE HELIPORT, 15 ACRES		1 IN./HR	1.0	25	27	17759	47	44	91
87210AA	FENCE, CHAIN LK, W/2 OUTGRS	1 1000LF	PERIM FENCING	9.0	153	459	108666	1294	4140	5434
87210AF	GATE, CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	2.0	2	4	558	14	28	42
87210AG	GATE, VEH CHAINL DBL/LEAF 12WI 10 HI		AS REQUIRED	2.0	2	4	802	16	35	51
87210AJ	FENCE, CORNER POST, 10 FT HI CHAINLIN		AS REQUIRED	16.0			1744	184	147	331

5524 5013 1026502 20440 3627 14901 38968

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 37 AIRCRAFT,17 UH-1H AND 20 OH-58A OF THE AVIATION CO.,CORPS,INSTALLATION DWG.SHEET 170F
 65,INITIAL STD,SUPPORT AREA,GRADED AND
 DRAINED,SURFACING HEAVY DUTY MEMBRANE,PERSONNEL FACIL-
 ORGANIC TOE EQPT,REAL ESTATE REQT FOR INST-49 ACRES,REQD
 FROM LOCAL SOURCE---COARSE AGGR,1188 CY,FINE AGGR,1004 CY,
 MINERAL FILLER,449 CY,COMBAT BN CONSTR

AG3134

FAC NUMBER	FACILITY DESCRIPTION	SIZE QR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL
111120AA	RUNWAY W/25 FT. SHOULDERS,450 X 60		UH-1 AIRCRAFT	1.0	21	10	45603	324		173
111120AB	RUNWAY LENGTH CORRECTION,100 X 60		TEMP AND ALT	.0						497
111120AC	RUNWAY OVERRUN,100 X 110 FT		UH-1 AIRCRAFT	2.0	6	4	4184	143		41
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		UH-1 AIRCRAFT	4.0				538		186
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	38.0	76	38	39748	1835		883
111141AA	TAXI-HOVERLANE,450 X 180 FT		UH-1 AIRCRAFT	4.5	144	126	123804	2039		743
111320AA	PARKING PAD,9EA 12 X 12 FT		OH-58 AIRCRAFT	2.3	2	7	15339	42		2578
111320AB	PARKING PAD,4EA 20 X 20 FT		UH-1 AIRCRAFT	4.3	6	13	28187	99		637
111370AB	AIRCRAFT WASHING APRON,50 X 25 FT		1/INSTALLATION	1.0	1	3	6498	20		144
111371AB	DEFUEL/DECONTN APR,50 X 25 FT		1/INSTALLATION	1.0	1	3	6498	20		27
111380AA	AC LOADING APR,2EA 50 X 25 FT		UH-1 AIRCRAFT	2.0	2	6	13110	55		83
112110AC	HOT REFUELING PAD,2EA 50 X 50 FT		2/INSTALLATION	1.0	6	9	16704	44		72
12110AH	SUPPORT ACFT REFUELING,30000 G STOR		5 DAY SUPPLY	2.0	16	40	131052	350	267	736
113315AA	AC CONTROL STATION,20 X 20 FT		1/INSTALLATION	1.0	3	2	15	7		1353
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0			304	2		8
114111AA	FIRE AND RESCUE STATION,20 X 20 FT		1/INSTALLATION	1.0	3	2	15	7		4
142183AA	AMMUNITION STORAGE,700SF		AS REQUIRED	1.0						1
85110CK	ROAD PAVEMENT,CLASS C,6IN STBL 1MI		PROVIDE ACCESS	1.5	1004	678	5018	262		1
85110DG	HARDSTAND,APR,TXWY,OR RNWY 1000SQYD		AS REQUIRED	.2	20	14	100	6		338
85130KH	ROAD,CLASS C,GRADED AND DRAINED 1MI		PROVIDE ACCESS	1.5	18	9	10430	3022		2
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.2	1	1	880	49		8
187120AC	DRAINAGE HELIPORT,11 ACRES		1 IN./HR	1.0				12		18
					1328	965	447489	8875	269	4018
										13162

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 37 AIRCRAFT,17 UH-1H AND 20 OH-58A OF THE AVIATION CO.,CORPS,INSTALLATION DWG SHEET 180F
65,INITIAL ALTERNATE STANDARD,SUPPORT AREA,GRADED
AND DRAINED,SURFACING M8A1 LANDING MAT,PERSONNEL FACIL-TROOP.
CAMP INST NO NT1421,REAL ESTATE REQT FOR INST-34 ACRES,REQD
FROM LOCAL SOURCE--COARSE AGGR,1822 CY,FINE AGGR,1539 CY,
MINERAL FILLER,688 CY,COMBAT BN CONSTR

AG3234

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS			CONSTR EFFORT IN MANHOURS			
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT.
111120AC	RUNWAY,OVERRUN,100 X 110 FT		CH-54 AIRCRAFT	2.0	6	4	6184	163		41	184
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0			538			345	883
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	45.9	92	46	48011	2217		897	3114
111120BA	RUNWAY W/25 FT SHOULDERS,450 X 60		CH-54 AIRCRAFT	1.0	131	77	73348	342		328	670
111120BC	RUNWAY LENGTH CORRECTION,100 X 60		TEMP AND ALT	.0							
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	5.0	160	140	137560	2266		707	2973
111210AB	TAXIWAY W/25 FT SHOULDERS,2000 X 40		CH-54 AIRCRAFT	.2	16	6	33263	240		126	366
111320BA	PARKING PAD,10EA 12 X 12 FT		OH-58 AIRCRAFT	2.0	20	16	17426	37		37	74
111320BB	PARKING PAD,4EA 20 X 20 FT		UH-1 AIRCRAFT	4.3	39	30	36976	89		94	183
111340BA	HANGAR ACCESS,105 X 100 FT		AS REQUIRED	1.0	47	35	36467	87		163	250
111370AB	AIRCRAFT WASHING APRON,50 X 25 FT		1/INSTALLATION	1.0	1	3	6498	20		7	27
111371AB	DEFUEL/DECONTN APR,50 X 25 FT		1/INSTALLATION	1.0	1	3	6498	20		7	27
111380BB	AC LOADING APR,4EA 50 X 25 FT		UH-1 AIRCRAFT	1.0	29	21	19627	58		58	116
111610AA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	1	3	6527	28		14	42
112110BC	HQT REFUELING PAD,2EA 50 X 50 FT		2/INSTALLATION	1.0	24	18	18418	58		58	116
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9		60	92
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173		374	1213
613120BA	NAVIGATION AIDS BUILDING,24 X 24 FT		1/INSTALLATION	1.0	20	22	13194	7		346	329
113315BA	CONTROL TOWER LOW DENSITY TRAFFIC		1/INSTALLATION	1.0	16	21	4632	1		560	112
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0			304			2	4
14110BB	AFOPS BLDG 2160SF PNL WD BLDG W/ IN		1/INSTALLATION	1.0	170	953	96409	21		2151	610
114111BA	FIRE AND RSQ STA,FAC NO.73010AC		1/INSTALLATION	1.0	192	283	39238	63		930	171
114910AN	AIRCRAFT REVETMENT,IMPROVED,OH-58		OH-58 AIRCRAFT	20.0	220	160	56000			897	1633
114910AR	AIRCRAFT REVETMENT,IMPROVED,UH-1D/H		UH-1 AIRCRAFT	17.0	255	204	66623			1036	1740
121110BB	ORG MNT HANGAR,105 X 112 FT		UH-1 AIRCRAFT	1.0	79	156	257675	196		351	547
141120BA	FLAMMABLE STORAGE,12 X 24 FT		AS REQUIRED	1.0	14	13	3322	7		1	2
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE	1000 BBL	5 DAY SUPPLY	1.0	1	14	8663	92		357	173
142183BA	AMMUNITION STORAGE,24 X 36 FT		AS REQUIRED	1.0	25	27	17138	1		1	2
85110CK	ROAD PAVEMENT,CLASS C,6IN STBL 1MI		PROVIDE ACCESS	2.3	1539	1040	7694	402		116	518
85110DG	HARDSTAND/APR,TXWY,OR RNWY 1000SQYD		AS REQUIRED	.4	40	27	200	12		5	17
85130KH	ROAD,CLASS C,GRADED AND DRAINED 1MI		PROVIDE ACCESS	2.3	28	14	15992	4634		1690	6324
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.4	3	1	1761	99		35	134
187120BB	DRAINAGE HELIPORT,11 ACRES		1 IN./HR	1.0	14	17	9880	23		23	46
87210AD	CONCERTINA,TRIPLE TAPE TYP D 1000LF		SECUR FENCE	8.7	1018	609	17069	280		1121	1401
				4214	3976	1075705	12157	6713	12231	31101	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

HELIPORT,ARMY,MIN REQTS FOR 37 AIRCRAFT,17 UH-1H AND 20 OH-58A OF THE AVIATION CO.,CORPS,INSTALLATION DWG.SHEET 190F
 65,TEMPORARY STD,SUPPORT AREA,GRADED AND
 DRAINED SURFACING BITUMINOUS PAVEMENT PERSONNEL FACIL-TROOP
 CAMP,INST NO NT1621,REAL ESTATE REQT FOR INST-84 ACRES,REQD
 FROM LOCAL SOURCE--COARSE AGGR,2978 CY,FINE AGGR,1306 CY,
 MINERAL FILLER,418 CY,COMBAT BN AND SUP CO CONSTR

AG3334

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS COST	CONSTR EFFORT IN MANHOURS				
				REQUIRED	WT-ST VOL-MT		HORZ	VERT	GENL	TOT	
111120AD	APPROACH-DEPARTURE,1500X250-850 FT		CH-54 AIRCRAFT	4.0		538			345	883	
111120AE	CLEAR AREA,1000 SY		AS REQUIRED	49.9	100	50	52195	2410	976	3386	
111120BF	RUNWAY OVERRUN,100 X 125 FT		CH-54 AIRCRAFT	2.0	8	6	4882	166	46	212	
111120CA	RUNWAY W/25 FT SHOULDERS,450 X 75		CH-54 AIRCRAFT	1.0	260	210	13615	455	189	644	
111120CB	RUNWAY LENGTH CORRECTION,100 X 75		TEMP AND ALT	.0							
111141AA	TAXI-HOVERLANE,450 X 180 FT		CH-54 AIRCRAFT	4.8	154	134	132058	2175	679	2854	
111210CB	TAXIWAY W/25 FT SHOULDERS,1000 X 40		CH-54 AIRCRAFT	.3	94	75	4946	217	85	302	
111320CA	PARKING PAD,10EA 12 X 12 FT		OH-58 AIRCRAFT	2.0	22	18	654	281	55	336	
111320CB	PARKING PAD,4EA 20 X 20 FT		UH-1 AIRCRAFT	4.3	56	43	1036	242	49	291	
111340CA	HANGAR ACCESS,105 X 100 FT		AS REQUIRED	1.0	79	63	1056	118	32	150	
111370CB	AIRCRAFT WASHING APR,50 X 25 FT		1/INSTALLATION	1.0	10	8	139	26	6	32	
111371CB	DEFUEL/DECONTN APR,50 X 25 FT		1/INSTALLATION	1.0	10	8	139	26	6	32	
111380CB	AC LOADING APR,4EA 50 X 25 FT		4/INSTALLATION	1.0	38	30	598	81	20	101	
111610CA	COMPASS SWING BASE,50 X 50 FT		1/INSTALLATION	1.0	14	11	211	99	29	128	
112110CC	HOT REFUELING PAD,2EA 50 X 50 FT		2/INSTALLATION	1.0	38	32	2297	189	64	253	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	92	
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213	1760
613120BA	NAVIGATION AIDS BUILDING,24 X 24 FT		1/INSTALLATION	1.0	20	22	13194	7	346	329	682
113315BA	CONTROL TOWER LOW DENSITY TRAFFIC		1/INSTALLATION	1.0	16	21	4632	1	560	112	673
113470AA	WIND DIRECTION INDICATOR		1/INSTALLATION	1.0		304		2	2	4	
14110BB	AFOPS BLDG 2160SF PNL WD BLDG W/ IN		1/INSTALLATION	1.0	170	953	96409	21	2151	610	2782
114111BA	FIRE AND RSQ STA/FAC NO.73010AC		1/INSTALLATION	1.0	192	283	39238	63	930	171	1164
114910AN	AIRCRAFT REVETMENT,IMPROVED,OH-58		OH-58 AIRCRAFT	20.0	220	160	56000		897	1633	2530
114910AR	AIRCRAFT REVETMENT,IMPROVED,UH-1D/H		UH-1 AIRCRAFT	17.0	255	204	66623		1036	1740	2776
121110CB	ORG MNT HANGAR,105 X 112 FT		UH-1 AIRCRAFT	1.0	121	198	247180	189		244	433
141120BA	FLAMMABLE STORAGE,12 X 24 FT		AS REQUIRED	1.0	14	13	3322	1		1	2
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE 1000 BBL		5 DAY SUPPLY	1.0	1	14	8663	92	357	173	622
142183BA	AMMUNITION STORAGE,24 X 36 FT		AS REQUIRED	1.0	25	27	17138	1		1	2
85110BT	ROAD CLASS C, 10 MULTIPLE SURFACE		PROVIDE ACCESS	2.3	918	690	9628	447		79	526
85110CN	HARDSTAND,APR,TXWY,OR RNWY 1000SQYD		AS REQUIRED	.4	20	15	199	19		9	28
85130KH	ROAD,CLASS C, GRADED AND DRAINED 1MI		PROVIDE ACCESS	2.3	28	14	15992	4634		1690	6324
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.4	3	1	1761	99		35	134
187120BB	DRAINAGE HELIPORT,11 ACRES		1 IN./HR.	1.0	14	17	9880	23		23	46
87210AA	FENCE,CHAIN LK,W/2 OUTGRRS 1 1000LF		PERIM FENCING	9.0	153	459	108666	1294		4140	5434
87210AF	GATE,CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	6.0	6	12	1674	41		83	124
87210AG	GATE,VEH CHAINL DBL/LEAF 12WI 10 HI		AS REQUIRED	7.0	7	14	2807	56		121	177
87210AJ	FENCE,CORNER POST 10 FT HI CHAINLN		AS REQUIRED	14.0			1526	161		129	290

3079 3818 933770 14354 6713 15142 36209

DDEXER4

RUN DATE 860207

DESERT CLIMATE

AIRCRAFT PARKING AND MAINTENANCE, COLLOCATED WITH AIRFORCE
 AIRFIELD, MIN FACILS FOR 18 AIRCRAFT, 6 OV-10 AND 12 OV-10 OF
 THE MIL. INTEL. CO., INSTALLATION DWG. SHEET 36 OF 65,
 INITIAL STD. SUPPORT AREA, GRADED AND DRAINED.
 SURFACING HEAVY DUTY MEMBRANE, PERSONNEL FACIL-ORGANIC TOE
 FAPT. REAL ESTATE REQT FOR INST-13 ACRES REQD FROM LOCAL
 SOURCE---COARSE AGGR, 634 CY, FINE AGGR, 536 CY, MINERAL FILLER,

12 64134

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT
111120AF	CLEAR AREA, 1000 SY			7.2	14	7	7531	348	141	489
111210AA	TAXIWAY W/25 FT SHOULDERS, 500 X 30		OV-1 AIRCRAFT	.5	15	10	27302	141	78	219
111210AC	TAXIWAY W/25 FT SHOULDERS, 50 X 50		OV-1 AIRCRAFT	2.0	4	6	15186	117	78	195
111310AA	FIXED-WING AC PARK APR W/TAXILANE		OV-1 AIRCRAFT	4.0	56	12	125640	534	276	810
111370AC	AIRCRAFT WASHING APRON, 40 X 50 FT		1/INSTALLATION	1.0	1	3	6498	25	12	37
111371AC	DEFUEL/DECONTN APR, 80 X 50 FT		1/INSTALLATION	1.0	3	5	12996	38	22	60
111382AA	SPECIAL PURPOSE APRON W/TAXILANE		OV-1 AIRCRAFT	1.0	16	4	35660	161	83	244
12110AH	SUPPORT ACFT REFUELING 30000 G STOR		5 DAY SUPPLY	2.0	16	40	131052	350	267	736
162183AB	AMMUNITION STORAGE, 2500SF		AS REQUIRED	.3				1	1	2
85110CK	ROAD PAVEMENT, CLASS C, 6IN STBL 1MI		PROVIDE ACCESS	.8	535	362	2676	140	40	180
85110DG	HARDSTAND/APR, TXWY, OR RNHY, 1000SQYD		AS REQUIRED	.4	40	27	200	12	5	17
85130KH	ROAD, CLASS C, GRADED AND DRAINED 1MI		PROVIDE ACCESS	.8	10	5	5562	1612	588	2200
85210AY	HARDSTAND, GRADED AND DRAINED 1000SY		AS REQUIRED	.6	3	1	1761	99	35	134
187120AD	DRAINAGE FIXED-WING AC, 11 ACRES		1 IN./HR	1.0				7	3	10
				713	482	372064	3585	267	2098	5950

DDEXER4

RUN DATE 860207

DESERT CLIMATE

AIRCRAFT PARKING AND MAINTENANCE, COLLOCATED WITH AIRFORCE
 AIRFIELD, MIN. FACILS FOR 18 AIRCRAFT, 6 OV-10, AND 12 OV-10 OF
 THE MIL. INTEL. CO., INSTALLATION DWG. SHEET 37 OF 65,
 CLIMATE, INITIAL ALTERNATE STANDARD, SUPT AREA, GRADED, DRAINED.
 SURFACING M8A1 LANDING MAT PERSONNEL FACIL-TROOP CAMP INST
 NO NT1421, REAL ESTATE REQT FOR INST-24 ACRES, REQD FROM LOCAL
 SOURCE---COARSE AGGR, 476 CY, FINE AGGR 402 CY, MINERAL FILLER,

A64234

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
111120AE	CLEAR AREA, 1000 SY			9.0	18	9	9414	635		176	611
111210BA	TAXIWAY W/25 FT SHOULDERS, 1000 X 30		OV-1 AIRCRAFT	.4	66	38	48913	227		215	442
111310BA	FIXED-WING AC PARK APR W/TAXILANE		OV-1 AIRCRAFT	4.1	381	209	210396	901		1075	1976
111340BC	HANGAR ACCESS, 248 X 100 FT		AS REQUIRED	1.0	109	80	76893	231		417	648
111370AE	AIRCRAFT WASHING APR, 60 X 50 FT		1/INSTALLATION	1.0	1	3	6498	32		17	69
111371AC	DEFUEL/DECONTN APR/80 X 50 FT		1/INSTALLATION	1.0	3	5	12996	38		22	60
111382BA	SPECIAL PURPOSE APRON W/TAXILANE		OV-1 AIRCRAFT	1.0	110	60	62723	268		271	519
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	23	92
12630AA	LDG. FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213	1760
14110BB	AFOPS BLDG 2160SF PNL WD BLDG W/ IN		1/INSTALLATION	1.0	170	953	96409	21	2151	610	2782
121110BA	ORG MNT HANGAR, 76 X 88 FT		OV-1 AIRCRAFT	3.0	138	240	451926	414		731	1145
141120BA	FLAMMABLE STORAGE, 12 X 24 FT		AS REQUIRED	1.0	14	13	3322	1		1	2
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE 1000 BBL		5 DAY SUPPLY	1.0	1	14	8663	92	357	173	622
142183BA	AMMUNITION STORAGE, 24 X 36 FT		AS REQUIRED	1.0	25	27	17138	1		1	2
85110CK	ROAD PAVEMENT, CLASS C, 6IN STBL 1MI		PROVIDE ACCESS	.6	401	271	2007	105		30	135
85110DG	HARDSTAND, APR, TXWY, OR RNWY 1000SQYD		AS REQUIRED	.4	40	27	200	12		5	17
85130KH	ROAD, CLASS C, GRADED AND DRAINED 1MI		PROVIDE ACCESS	.6	7	4	4172	1209		441	1650
95210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.4	3	1	1761	99		35	134
187120BD	DRAINAGE FIXED-WING AC, 14 ACRES		1 IN./HR	1.0	8	13	4391	10		12	22
87210AD	CONCERTINA, TRIPLE TAPE TYP D 1000LF		SECUR FENCE	4.0	468	280	7848	129		515	644
					1976	2260	1040778	4387	2942	5983	13312

DDEXER4

RUN DATE 860207

DESERT CLIMATE

AIRCRAFT PARKING AND MAINTENANCE, COLLOCATED WITH AIRFORCE
 AIRFIELD, MIN. FACILS FOR 18 AIRCRAFT, 6 OV-10, AND 12 OV-1C OF
 THE MIL. INTEL. CO., INSTALLATION DWG. SHEET 38 OF 65,
 TEMPORARY STD. SUPPORT AREA, GRADED AND DRAINED,
 SURFACING BITUMINOUS PAVEMENT, PERSONNEL FACIL-TROOP CAMP
 INST NO NT1621, REAL ESTATE REQT FOR INST-24 ACRES, REQD FROM
 LOCAL SOURCE---COARSE AGGR, 2263 CY, FINE AGGR, 1027 CY, MINERAL

AG4334

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT
111120AE	CLEAR AREA, 1000 SY		OV-1 AIRCRAFT	9.1	18	9	9519	640	178	618
111210CA	TAXIWAY W/25 FT SHOULDERS, 1000 X 30		OV-1 AIRCRAFT	.4	96	77	6200	271	104	375
111310CA	FIXED-WING AC PARK APR W/TAXILANE		OV-1 AIRCRAFT	4.1	623	496	14699	1051	358	1409
111340CC	HANGAR ACCESS, 248 X 100 FT		AS REQUIRED	1.0	185	148	2479	231	66	297
111370CC	AIRCRAFT WASHING APRON, 60 X 50 FT		1/INSTALLATION	1.0	23	18	302	39	9	48
111371CC	DEFUEL/DECONTN APR, 80 X 50 FT		1/INSTALLATION	1.0	30	24	404	52	14	66
111382CA	SPECIAL PURPOSE APRON W/TAXILANE		OV-1 AIRCRAFT	1.0	181	144	4471	299	110	409
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	23
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213
141108B	AFOPS BLDG 2160SF PNL WD BLDG W/ IN		1/INSTALLATION	1.0	170	953	96409	21	2151	610
121110CA	ORG MNT HANGAR, 76 X 88 FT		OV-1 AIRCRAFT	3.0	213	315	434034	397	497	894
141120BA	FLAMMABLE STORAGE, 12 X 24 FT		AS REQUIRED	1.0	14	13	3322	1	1	2
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE	1000 BBL	5 DAY SUPPLY	1.0	1	16	8663	92	357	173
142183BA	AMMUNITION STORAGE, 24 X 36 FT		AS REQUIRED	1.0	25	27	17138	1	1	2
85110BT	ROAD CLASS C, 10 MULTIPLE SURFACE		PROVIDE ACCESS	.6	239	180	2512	117	21	138
85110CN	HARDSTAND/APR, TXWY, OR RNWY 1000SQYD		AS REQUIRED	.4	20	15	199	19	9	28
85130KH	ROAD, CLASS C, GRADED AND DRAINED 1MI		PROVIDE ACCESS	.6	7	4	4172	1209	441	1650
85210AY	HARDSTAND GRADED AND DRAINED 1000SY		AS REQUIRED	.4	3	1	1761	99	35	134
187120BD	FIXED-WING AC, 14 ACRES		1 IN./HR	1.0	8	13	4391	10	12	22
87210AA	FENCE, CHAIN LK, W/2 OUTRGRS	1 1000LF	PERIM FENCING	4.0	68	204	48296	575	1840	2415
87210AF	GATE, CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	3.0	3	6	837	21	41	62
87210AG	GATE, VEH CHAINL DBL/LEAF 12WI 10 HI		AS REQUIRED	4.0	4	8	1604	32	69	101
87210AJ	FENCE, CORNER POST 10 FT HI CHAINLIN		AS REQUIRED	15.0			1635	173	138	311
					1964	2682	678155	5332	2942	5963
										14237

DDEXER4

RUN DATE 860207

DESERT CLIMATE

RUNWAY,ARMY,MIN.FACILITIES FOR C-130 AIRCRAFT INSTALLATION DWG
 SHEET 39 OF 65,INITIAL ALTERNATE STD.,SUPPORT
 AREA,GRADED AND DRAINED,SURFACING M8A1 LANDING MAT,REQD
 FROM LOCAL SOURCES---COARSE AGGR,1030 CY,FINE AGGR,870 CY,
 MINERAL FILLER,389 CY,COMBAT BN CONSTR

AG5034

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
111110BA	RUNWAY W/40 FT. SHOULDERS,1000 X 96.		C-130 AIRCRAFT	3.5	1561	872	918162	3651		3574	7225
111110BB	RUNWAY LENGTH CORRECTION,100 X 96		TEMP AND ALT	.0							
111110BC	RUNWAY OVERRUN,300 X 96 FT		C-130 AIRCRAFT	2.0	16	12	11158	331		97	428
111110BD	RUNWAY TURNAROUND,2EA 200 X 52 FT		C-130 AIRCRAFT	1.0	91	49	49689	237		246	483
111110BE	ON-OFF TAXIWAY,100 X 36 FT		C-130 AIRCRAFT	6.0	114	66	78888	393		338	731
111110BF	APPROACH ZONE,32000X596-2500 FT		C-130 AIRCRAFT	2.0							
111110BG	LANDING AREA GRADED-DRAINED,1000SY		AS REQUIRED	39.0	78	39	67580	2556		762	3318
111110BH	CLEAR ZONE,5000X249-596 FT		C-130 AIRCRAFT	2.0	72	58	50212	504		281	785
11135QBA	WARM-UP APRON,100 X 96 FT		C-130 AIRCRAFT	2.8	123	67	70459	335		486	821
85110CK	ROAD PAVEMENT,CLASS C,6IN STRL 1MI		AS REQUIRED	2.2	1472	994	7359	385		111	496
85130KH	ROAD,CLASS C,GRADED AND DRAINED 1MI		AS REQUIRED	2.2	26	13	15297	4433		1617	6050
187120BE	DRAINAGE FIXED-WING AC,9 ACRES		1 IN./HR	1.0	10	16	7773	25		23	48
87210AD	CONCERTINA,TRIPLE TAPE TYP.D 1000LF		SECUB. FENCE	11.9	1392	833	23348	383		1533	1916
					4955	3019	1279925	13417		9068	22485

DDEXER4

RUN DATE 860207

DESERT CLIMATE

RUNWAY,ARMY,MIN.FACILITIES FOR C-130 AIRCRAFT INSTALLATION DWG
 SHEET 40 OF 65 TEMPORARY STD REAR AREA
 GRADED AND DRAINED,SURFACING BITUMINOUS PAVEMENT,REQD FROM
 LOCAL SOURCES--COARSE AGGR.18766 CY,FINE AGGR.9383 CY,
 MINERAL FILLER,2540 CY,COMBAT BN AND SUP CO CONSTR

AG5044

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
111110BG	LANDING AREA,GRADED-DRAINED,1000SY			47.0	94	47	57360	3081		919	4000
111110CA	RUNWAY W/50 FT SHOULDERS,1000 X 150		C-130 AIRCRAFT	6.0	9348	7722	295476	12420		6231	18651
111110CB	RUNWAY LENGTH CORRECTION,100 X 150		TEMP AND ALT	.0							
111110CC	RUNWAY OVERRUN,500 X 150 FT		C-130 AIRCRAFT	2.0	42	34	28594	766		285	1051
111110CD	RUNWAY TURNAROUND,2EA,200 X 25 FT		C-130 AIRCRAFT	1.0	103	85	1567	205		64	269
111110CE	ON-OFF TAXIWAY,100 X 36 FT		C-130 AIRCRAFT	6.0	234	192	13206	800		297	1097
111110CF	APPROACH ZONE,32000X670-3500 FT		C-130 AIRCRAFT	2.0				184			184
111110CH	CLEAR ZONE,500X320-670 FT		C-130 AIRCRAFT	2.0	82	66	57536	593		331	924
111350CA	WARM-UP APRON,100 X 100 FT		C-130 AIRCRAFT	2.8	291	241	7356	551		167	718
85110AB	ROAD,CLASS A,1IN MULT. SURF.	1MI	AS REQUIRED	3.0	2328	1791	27264	1007		176	1183
85130AY	ROAD,CLASS A,GRADED AND DRAINED	1MI	AS REQUIRED	3.0	48	24	28476	8625		3467	12092
187120CA	DRAINAGE FIXED-WING AC,22 ACRES		1 IN./HR	1.0	27	35	15015	39		37	76
87210AA	FENCE,CHAIN LK,W/2 OUTRGRS 1,1000LF		PERIM FENCING	17.0	289	867	205258	2444		7820	10264
87210AF	GATE,CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	2.0	2	4	558	14		28	42
87210AG	GATE,VEH CHAINL DBL/LEAF 12WI 10 HI		AS REQUIRED	2.0	2	4	802	16		35	51
87210AJ	FENCE,CORNER POST 10 FT HI CHAINLIN		AS REQUIRED	12.0			1308	138		110	248
				12890	11112	739756	30883		19967	50850	

DDEXER4

DESERT CLIMATE

SIGNAL INTELEGENCE INSTALLATION, TEMPORARY STANDARD OF CONSTRUCTION, DESERT CLIMATE. 400 MAN TROOP CAMP FACILITIES ARE INCLUDED. WOOD FRAME FACILITIES FOR SUPPORT AND PRE-ENG METAL FOR OPERATIONS. REQUIRES 39.65 ACRES/1597 CUBIC YARDS OF COARSE AGGR., 25000GPD WATER AND 7000GPD SEWAGE.

CC1014

RUN DATE 860207

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS		CONSTR EFFORT IN MANHOURS				
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
213120AR	SIGINT INST. OPERATIONS BLDG	8000SF	AS REQUIRED	1.0	47084	554107	23824757	547	7590	1359	9496
213120AT	SIGINT ELE/SUPPLY BLDG 80X100FT TROP	8000SF	AS REQUIRED	1.0	47086	554109	23822550	547	7590	1359	9496
213120AU	SIGINT OPS/COMM BLDG 80X100FT TROP	8000SF	AS REQUIRED	1.0	47120	554147	23858123	547	7590	1359	9496
213120AV	SIGINT ELE/MAINT BLDG 80X100FT TROP	8000SF	AS REQUIRED	1.0	59187	554127	80605203	547	7590	1359	9496
21410GG	2400 SQ.FT. BUILDING GG WOOD		1PER INST	1.0	712	636	54627	423	3368	1102	4893
44110BA	STOREHOUSE WD FR BLDG 20X50X8	20X50X8FT	AS REQUIRED	1.0	22	27	4897	37	530	156	723
55010BC	DISP.TROOP,20X60 W/O WARD.WD W/INT		1 PER INST	1.0	34	48	12751				
161050BN	HQTRS & UNIT SUP BLDG 20X 40X8	20X40X8FT	AS REQUIRED	1.0	19	25	4628	32	496	92	620
172211AW	BRKS 50MAN 20X100 WOOD BLDG	20X100X8FT	72 SF PER MAN	8.0	360	440	74808	414	6909	1711	9034
72210GB	INT.KIT+DNG 5-11HD MAN 60X120FT D/T		1PER INSTAL	1.0	38	88	194536		3447	601	4048
173015ED	GUARD HOUSE WD FRAME BLDG W/INTER	20X60X8FT	AS REQUIRED	1.0	28	36	7290	32	531	129	692
174050AR	GUARD HOUSE WD FRAME BLDG W/INTER	20X60X8FT	1 PER INST	1.0	28	36	7290	32	531	129	692
181110CV	GEN PLANT 1.5 MW IN BLDGS TEMPERATE		AS REQUIRED	1.0	160	335	340318	104	6526	1426	8056
81242BE	ELECT DIST FOR SIGINT INST.	8000SF	AS REQUIRED	1.0	29174	332893	45114371	230	690	690	1610
33111BM	ELECT DIST FOR SIGINT INST.	8000SF	AS REQUIRED	1.0	29174	332893	45114371	230	690	690	1610
83140CC	CONVENT SEW LAG 2 ACRES W/O LINER		AS REQUIRED	2.0	114	236	54866	938	9009	607	10554
84120AB	WATER SUPPLY WELL 200GPM821MGAL STOR 500 BBL STR	AS REQUIRED		1.0	21	47	24204	557	148	253	958
84120AC	WATER TANK TOWER 4200 GAL W/ACCESOR 200 GAL	AS REQUIRED		1.0	9	22	7950		121	5	126
84140CC	WATER TANK TOWER 4200 GAL W/ACCESOR 200 GAL	AS REQUIRED		2.0	18	44	15900		242	9	251
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	AS REQUIRED	1.0	7	5	145	18	124	133	275
85110AL	ROAD PAVEMENT,CLASS A,CLD MIX BITUM		AS REQUIRED	.6	566	451	7608	226		83	309
85110BH	ROAD PAVEMENT,CLASS B,CLD MIX BITUM		AS REQUIRED	.1	82	65	1094	34		12	46
85110CJ	ROAD PAVEMENT,CLASS C,STAB SURFACE		AS REQUIRED	.6	265	179	1326	85		28	113
85110DB	HARDSTAND,CLD MIX BITUM,STAB BASE		AS REQUIRED	3.0	156	129	2337	121		41	162
85130AH	ROAD,CLASS A,GRADED AND DRAINED		AS REQUIRED	.6	2	4	1322	1419		591	2010
85130EM	ROAD,CLASS B,GRADED AND DRAINED 1MI		AS REQUIRED	.1	2	1	196	214		88	302
85130JT	ROAD,CLASS C,GRADED AND DRAINED 1MI		AS REQUIRED	.6	2	2	808	929		367	1296
187190AA	SITE PREPARATION/ONE ACRE		AS REQUIRED	39.7				4018		1461	5479
87210AB	FENCE,BARBED WIRE W/2 CTGR 1000LF		AS REQUIRED	2.0	12	16	3346	805	1380	1380	3565
87210AM	GATE,VEH SGL/LEAF 12 FT WI 10 FT HI		AS REQUIRED	4.0	8	8	4092	32	46	55	133
87210AP	SECURITY FENCE TYPE X 1000 FEET	1000 FEET	AS REQUIRED	8.0	64	72	13248	423	2337	2355	5115
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
87230AA	SENTRY BOX 4X4		AS REQUIRED	2.0			244	219	920	460	1599

2615562885232 43179870 13778 68681 20200 102659

DDEXER4

RUN DATE 860207

DESERT CLIMATE

SIGNAL INTELEGENCE STATION, TEMPORARY STANDARD OF CONSTRUCTI
ON DESERT CLIMATE. 50 MAN TROOP CAMP FACILITIES ARE INCL
USED. WOOD FRAME FACILITIES FOR SUPPORT AND PRE ENGINEERED
METAL FOR OPERATIONS. REQUIRES 9.69 ACRES, 157 CUBIC YARDS OF
COARSE AGGR, 2500GPD OF WATER, 700GPD SEWAGE.

CC1024

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
313120CC	SIGINT OPS/CQMM RQX100FT FRIGID	8000SF	AS REQUIRED	1.0	47088	554123	23856419	547	7590	1359	9496
313120CD	SIGINT ELE/MAINT BLDG 80X100FT FRIG	8000SF	AS REQUIRED	1.0	59187	554127	80605203	547	7590	1359	9496
172111AW	BRKS 50MAN 20X100 WOOD BLDG	20X100X3FT	72SQFT PERMAN	2.0	.90	110	18702	104	1727	428	2259
81242BF	ELECT. DIST. FOR SIGINT STATION	8000SF	AS REQUIRED	1.0	46648	231959	73694001	115	345	345	805
83111BK	ELECT. DIST. FOR SIGINT STATION	8000SF	AS REQUIRED	1.0	46648	231959	73694001	115	345	345	805
85110BM	ROAD PAVEMENT, CLASS B, STAB SURFACE	AS REQUIRED		.1	69	46	344	22		7	29
85130EM	ROAD, CLASS B, GRADED AND DRAINED 1MI	AS REQUIRED		.1		1	196	214		88	302
187190AA	SITE PREPARATION, ONE ACRE	AS REQUIRED		9.7				982		357	1339
87210AB	FENCE, BARBED WIRE W/2 DTGR, 1000LF	AS REQUIRED		2.0	12	16	3346	805	1380	1380	3565
87210AM	GATE, VEH SGL/LEAF 12 FT WI 10 FT HI	AS REQUIRED		4.0	8	8	4092	32	46	55	133
87210AP	SECURITY FENCE, TYPE X 1000 FEET	1000 FEET	AS REQUIRED	3.0	24	27	4968	159	876	883	1918
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				1997781572380	51881936			3660	20175	6716	30551

DDEXER4

RUN DATE 860207

DESERT CLIMATE

AMMO STORAGE, 12000 TON CAP., DESERT CLIMATE, INITIAL STD.
 DWG. DA1064 PROVIDES EARTH BARRICADED STORAGE ON PAVED HARD-
 STANDS, HELIPORT, INTERNAL ROADS, LIGHTED SECURITY FENCE, 20FTX
 100FT OPER. BLDG., 20FTX20FT SUB-OPEP. BLDGS., GUARD TOWERS,
 SENTRY BOXES AND PIT LATRINES. REQUIRES 1584.0 ACRES FOR IN-
 STALL, PLUS 1142.0 ACRES CONTROL AREA. ITEMS PROCURED LOCALLY
 -282538CY FILL, 28002CY COARSE AGG., 10183CY FINE AGG., 2637CY

DA1064

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED			MATERIALS WT-ST VOL-MT	COST	CONSTR EFFORT IN MANHOURS		
				WT	ST	VOL			HORZ	VERT	GENL
11130AA	HELIPORT/C47 SLINGOUT AREA		AS REQD.	1.0	11	7	6894	1195	558	1753	
14930AA	EARTH BARRICADE, AMMO STORAGE, 100LF		AS REQD.	166.5			58454	4380	4717	9097	
44110BE	STOREHOUSE WD FR BLDG 20X20X8	20X20X8FT	90SF/MAN	3.0	30	33	5829	79	904	183	1166
161050BP	HQTRS & UNIT SUP BLDG 20X100X8	20X100X8FT	90SF/MAN	1.0	44	60	11736	75	1459	311	1845
72321BB	LATRINE/PIT TYPE, 2 SEATS, 4X5X8, WOOD 5X4X8FT		AS REQD.	7.0	7	7	658		322	66	386
72321BD	LAT PIT TYPE 160MAN 8 SEATS 10X20 10X20X8	10X20X8FT	160EM OR BOFF	1.0	8	9	1559	2	230	37	269
81240GC	ELECTRICAL DISTRIBUTION SYSTEM, ONE 1 MILE 1/2		AS REQD.	8.8	158	167	72934	1366	11636	6780	19582
81260AE	TRANSFORMER ASSY 5KVA SGL PHASE CSP		AS REQD.	33.0	33	33	27654		1822		1822
81260AG	SP XFMR ASSY 15KVA 1PH 4160-120/240		AS REQD.	1.0	1	1	731		60		60
81260BB	SP XFMR ASSY 225 KVA 4160-208Y/120		AS REQD.	1.0	3	3	3491		120		120
85110AC	ROAD PAVEMENT, CLASS A, HOT MIX BITUM		AS REQD.	8.5	8033	6401	107253	3304		1173	4477
85110BU	ROAD PAVEMENT, CLASS C, HOT MIX BITUM		AS REQD.	2.7	1409	1110	17688	618		224	842
85110CP	HARDSTAND, HOT MIX BITUM, STAB BASE		AS REQD.	23.9	1243	1028	18546	989		330	1319
85110DF	HARDSTAND, STAB SURF, 1000SQ YD, 4 IN		AS REQD.	5.7	239	160	1197	157		52	209
85111AD	RDWY PVMT HVY WH BSC 1MI 3IN ASPH		AS REQD.	1.5	1508	1206	20222	680		254	934
85111AP	RDWY PVMT HVY WH 2FT INCR 3IN ASPH		AS REQD.	18.0	2394	1980	35874	1180		476	1656
85111EB	RDWY HVY WH BSC 4FT SHLDRS 12IN THK		AS REQD.	1.5	5	5	2316	745		216	961
85111EM	RDWY HVY WH 2FT INCR 12IN THK		AS REQD.	18.0			1980	1056		228	1284
85111KB	HDSTD HVY WH 1000SY 4FT SHLDR 12IN		AS REQD.	65.0	90	90	33075	2950		569	3519
85130AK	ROAD, CLASS A, GRADED AND DRAINED		AS REQD.	8.5	34	34	16881	10704		3734	14438
85130JV	ROAD, CLASS C, GRADED AND DRAINED 1MI		AS REQD.	2.7	5	5	3278	2484		817	3301
85210AK	HARDSTAND, 1000 SQ YDS, NO ROCK		AS REQD.	29.6	89	30	49314	2451		885	3336
87210AT	VEH-MAN GATE FOR SECURITY FENCE 1		AS REQD.	8.0	16	16	2656	74	1104	442	1620
87210AU	SECURITY FENCE, TYPE X CONVERTED TO 1000 FEET		AS REQD.	38.1	38	38	57074		9464		9464
87230AA	SENTRY BOX 4X4		AS REQD.	3.0			366	328	1380	690	2398
					15398	12423	557660	34817	28301	22740	85858

DDEXER4

RUN DATE 860207

DESERT CLIMATE

AMMO STORAGE, 35000 TON CAP., DESERT CLIMATE, INITIAL STD.
 DWS DA1074 PROVIDES EARTH BARRICADED STORAGE ON PAVED HARD-
 STANDS, HELIPORT, INTERNAL ROADS, LIGHTED SECURITY FENCE, 20FT X
 100FT OPER. BLDGS., 20FT X 20FT SUB-OPER. BLDGS., GUARD TOWERS,
 SENTRY BOXES AND PIT LATRINES. REQUIRES 1732.0 ACRES FOR IN-
 STALL, PLUS 1614.0 ACRES CONTROL AREA. ITEMS PROCURED LOCALLY
 .541167CY FILL, .42196CY COARSE AGG., .17895CY FINE AGG., .5094CY

DA1074

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL			
11130AA	HELIPORT, C67 SLINGOUT AREA		AS REQD.	1.0	11	7	6894	1195		558	1253		
14930AA	EARTH BARRICADE, AMMO STORAGE, 100LF		AS REQD.	279.0			111321	8342		8984	17326		
66110BE	STOREHOUSE WD FR BLDG 20X20X8	20X20X8FT	90SF/MAN	3.0	30	33	5829	79	904	183	1166		
161050BP	HQTRS & UNIT SUP BLDG 20X100X8	20X100X8FT	90SF/MAN	2.0	88	120	23472	150	2919	621	3690		
72321BB	LATRINE, PIT TYPE, 2 SEATS, 4X5X8, WOOD	5X6X8FT	AS REQD.	12.0	12	12	1128			552	110	662	
72321BD	LAT PIT TYPE 160MAN 8 SEATS 10X20	10X20X8	160EM OR 80FF	1.0	8	9	1559	2	230	37	269		
81260GC	ELECTRICAL DISTRIBUTION SYSTEM, ONE 1 MILE \ 2		AS REQD.	9.3	162	122	72078	1444	12085	7166	20695		
81260AE	TRANSFORMER ASSY 5KVA SGL PHASE CSP		AS REQD.	35.0	35	35	29330					1932	
81260AH	SP XEMR ASSY 25KVA 1PH 4160-120/240		AS REQD.	1.0	1	1	668					63	
81260BA	SP XEMR ASSY 150 KVA 4160-208Y/120		AS REQD.	1.0	2	2	2674					112	
81260BB	SP XEMR ASSY 225 KVA 4160-208Y/120		AS REQD.	1.0	3	3	3491					120	
85110AC	ROAD PAVEMENT, CLASS A, HOT MIX BITUM		AS REQD.	8.0	7560	6024	100944	3110				1104	4214
85110BU	ROAD PAVEMENT, CLASS C, HOT MIX BITUM		AS REQD.	3.4	1725	1392	22273	278				282	1060
85110CP	HARDSTAND, HOT MIX BITUM, STAB BASE		AS REQD.	37.1	1929	1595	28790	1536				512	2048
85110DF	HARDSTAND, STAB SURF, 1000SQ YD, 4 IN		AS REQD.	5.7	239	160	1197	157				52	209
85111AD	RDWY PVMT HVY WH BSC 1MI 3IN ASPH		AS REQD.	3.0	3015	2412	40443	1359				507	1866
85111AP	RDWY PVMT HVY WH 2FT INCR 3IN ASPH		AS REQD.	18.0	2394	1980	35874	1180				476	1656
85111EB	RDWY HVY WH BSC 4FT SHLDRS 12IN THK		AS REQD.	3.0	9	9	4632	1490				431	1921
85111EM	RDWY HVY WH 2FT INCR 12IN THK		AS REQD.	18.0			1980	1056				228	1284
85111KB	HDSTD HVY WH 1000SY 4FT SHLDR 12IN		AS REQD.	110.3	221	221	81071	7230				1395	8625
85130AK	ROAD, CLASS A, GRADED AND DRAINED		AS REQD.	8.0	32	32	15888	10074				3514	13588
85130JV	ROAD, CLASS C, GRADED AND DRAINED 1MI		AS REQD.	3.4	7	7	4128	3128				1028	4156
85210AK	HARDSTAND, 1000 SQ YDS, NO ROCK		AS REQD.	42.8	128	43	71305	3544				1280	4824
87210AT	VEH-MAN GATE FOR SECURITY FENCE 1		AS REQD.	8.0	16	16	2656	74	1104	442	1620		
87210AU	SECURITY FENCE, TYPE X CONVERTED TO 1000 FEET		AS REQD.	40.8	41	41	61118		10135			10135	
87230AA	SENTRY BOX 4X4		AS REQD.	3.0			366	328	1380	690	2398		
				17723	14336	736109	46256	31536	29600	107392			

DDEXER4

RUN DATE 860207

DESERT CLIMATE

AMMO STORAGE,70000 TON CAP.,DESERT CLIMATE,INITIAL STD.
 DWG.DA1084 PROVIDES EARTH BARRICADED STORAGE ON PAVED HARD-
 STANDS,HELIPORT,INTERNAL RDS.,LIGHTED SECURITY FENCE,50000SF
 OPER,BLDG.,20FTX20FT SUB-OPE, BLDGS.,GUARD TOWERS,SENTRY
 BOXES AND PIT LATRINES.REQUIRES 2117.0 ACRES FOR INSTALL.
 PLUS .1761.0 ACRES CONTROL AREA ITEMS PROCURED LOCALLY.
 990998 CY FILL,50088CY COARSE AGG.,23328CY FINE AGG.,7023CY

DA1084

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS		CONSTR COST	EFFORT HORZ	IN MANHOURS VERT	GENL	TOT
					WT-ST	VOL-MT					
11130AA	HELIPORT,667 SLINGOUT AREA		AS REQD.	1.0	11	7	6894	1195	558	1753	
14930AA	EARTH BARRICADE,AMMO STORAGE,100LF		AS REQD.	514.1			205126	15372			
44110BE	STOREHOUSE WD FR BLDG 20X20X8	20X20X8FT	90SF/MAN	3.0	30	33	5829	79	906	183	1166
161050BW	ADMIN SUP BLDG,WD FR,30FTX70FTX8FT		90SF/MAN	1.0	47	56	8948	58	1064	219	1341
161050BY	ADMIN SUP. BLDG,WD FR,30FTX50FTX8FT		90SF/MAN	2.0	70	78	13098	81	1860	322	2263
72321BB	LATRINE,PIT TYPE,2 SEATS,4X5X8,WOOD 5X4X8FT		AS REQD.	14.0	14	14	1316		644	129	773
72321BD	LAT.PIT TYPE 160MAN 8 SEATS,10X20 10X20X8	10X20X8	160EM OR 800F	1.0	8	9	1559	2	230	37	269
81240GC	ELECTRICAL DISTRIBUTION SYSTEM, ONE 1 MILE V 2		AS REQD.	9.4	169	179	77907	1459	12215	7243	20917
81260AE	TRANSFORMER ASSY 5KVA SGL PHASE CSP		AS REQD.	37.0	37	37	31006			2042	2042
81260AH	SP XFMR ASSY 25KVA 1PH 4160-120/240		AS REQD.	1.0	1	1	668			63	63
81260BA	SP XFMR ASSY 150 KVA 4160-208Y/120		AS REQD.	1.0	2	2	2674			112	112
81260BB	SP XFMR ASSY 225 KVA 4160-208Y/120		AS REQD.	1.0	3	3	3491			120	120
85110AC	ROAD PAVEMENT,CLASS A,HOT MIX BITUM		AS REQD.	8.4	7938	6325	105991	3265		1159	4424
85110BU	ROAD PAVEMENT,CLASS C,HOT MIX BITUM		AS REQD.	3.9	2036	1603	25549	893		323	1216
85110CP	HARDSTAND,HOT MIX BITUM,STAB BASE		AS REQD.	40.6	2111	1746	31506	1681		560	2241
85110DF	HARDSTAND,STAB SURF,1000SQ YD, 4 IN		AS REQD.	5.7	239	160	1197	157		52	209
85111AD	RDWY PVMT HVY WH BSC 1MI 3IN ASPH		AS REQD.	5.2	5226	4181	70101	2356		879	3235
85111AP	RDWY PVMT HVY WH 2FT INCR 3IN ASPH		AS REQD.	18.0	2394	1980	35874	1180		476	1656
85111EB	RDWY HVY WH BSC 4FT SHLDRS 12IN THK		AS REQD.	5.2	16	16	8029	2583		748	3331
85111EM	RDWY HVY WH 2FT INCR 12IN THK		AS REQD.	18.0			1980	1056		228	1284
85111KB	HDSTD HVY WH 1000SY 4FT SHLDR 12IN		AS REQD.	156.7	313	313	115175	10272		1982	12254
85130AK	ROAD,CLASS A,GRADED AND DRAINED		AS REQD.	8.4	34	34	16682	10578		3690	14268
85130JV	ROAD,CLASS C,GRADED AND DRAINED 1MI		AS REQD.	3.9	8	8	4735	3588		1180	4768
85210AK	HARDSTAND,1000 SQ YDS,NO ROCK		AS REQD.	46.3	139	46	77136	3834		1384	5218
87210AT	VEH-MAN GATE FOR SECURITY FENCE 1		AS REQD.	8.0	16	16	2656	74	1104	442	1620
87210AU	SECURITY FENCE, TYPE X CONVERTED TO 1000 FEET		AS REQD.	41.5	42	42	62167		10309		10309
87230AA	SENTRY BOX 4X4		AS REQD.	3.0			366	328	1380	690	2398
				20904	16887	917660	60091	32027	39038	131156	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

AMMO STORAGE, 3500 TON CAP., DESERT CLIMATE, INITIAL STD.
 DA1094 PROVIDES UNBARRICADED STORAGE ON GRAVEL HARDSTAND,
 HELIPORT AND INTERNAL GRAVEL ROADS. REQUIRES 1093 ACRES FOR
 INSTALLATION PLUS 1531 ACRES CONTROL AREA. ITEMS PROCURED
 LOCALLY, 960CY COARSE AGG., 807CY FINE AGG., 365CY MINERAL
 FILLER.

DA1094

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONST EFFORT IN MANHOURS			
				REQUIRED	WT-MT	VOL-MT	COST	HORZ	VERT	GENL		TOT
11130AA HELIPORT/C67 SLINGOUT AREA			1/INST.	1.0	11	7	4894	1193		558	1783	
85110DF HARDSTAND, STAB SURF, 100089 YD, 4 IN			AS REQD.	19.2	804	538	4032	530		177	707	
85210AK HARDSTAND, 1000 10. YD, NO ROCK			AS REQD.	19.2	18	12	31987	1590		574	2164	
							675	564	42913	3315	1309	4626

DDEXER4

RUN DATE 860207

DESERT CLIMATE

STORAGE, DRY CARGO, 50000 SF OPEN, ALL CLIMATES, STD 2,
 NEW CONST, TENTAGE, PROVIDES 50000 SF STORAGE SPACE ON
 EARTH, GRADED AND DRAINED. ADMINISTRATION IN TENT ERECTED
 BY USING SERVICE/PIT TYPE LATRINES. MINIMUM REAL ESTATE
 REQUIREMENT FOR INSTALLATION 7.4 ACRES, REQUIRED FROM LOCAL
 SOURCE - FINE AGGREGATE .6 CY, COARSE AGGREGATE .7 CY.

DC1169

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
72321BD	LAT PIT TYPE 160MAN 8 SEATS 10X20	10X20X8	160 EM	1.0	8	9	1559	2	230	37	269
72520AA	TENTAGE/MED GEN PURP, 32FTX16FT	10-16X32	ADMIN	.1		1	1170			5	5
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	EFF RAD 500FT	1.0	7	5	165	18	124	133	275
					15	15	2874	20	354	175	569

DDEXER4

RUN DATE 860207

DESERT CLIMATE

STORAGE, DRY CARGO, 50000 SF OPEN, ALL CLIMATES, STD 6,
 NEW CONSTR. TENTAGE, PROVIDES 50000 SF STORAGE SPACE. ON
 6 INCHES STABALIZED STONE W/ASPHALT BINDER. ADMIN. IN TENT
 ERECTED BY USING SERVICE PIT TYPE LATRINES. MIN. REAL ESTATE
 REQUIREMENT FOR INSTALLATION=7.4 ACRES, REQUIRED FROM LOCAL
 SOURCE = FINE AGGREGATE 1000 CY, COARSE AGGREGATE 1283 CY.

DC1179

FAC NUMBER	FACILITY DESCRIPTION	SIZE DR. UNIT	BASIS	QUANTITY		MATERIALS	CONSTR EFFORT IN MANHOURS				
				REQUIRED	MT-AT VOL-MT		COST	MHRZ	VERT	GENL	TOT
72321BD LAT PIT TYPE 140MAN 8 SEATS 10X20	10X20X8	140 SF		1.0		8	1880	2	230	37	249
72320AA TENTAGE, MED GEN PURP, 32FTX16FT	10-16X32	ADMIN		.1		1	1170			3	3
86330AC SUMP FIRE PROTECTION 10000 GAL	10000 GAL	EFF RAD 900FT		1.0		7	145	18	124	133	273
						15	2874	20	354	175	549

DDEXER4

RUN DATE 860207

DESERT CLIMATE

STORAGE, DRY CARGO, 100000 SF OPEN, ALL CLIMATES, STD 2,
 NEW CONST, TENTAGE, PROVIDES 100000 SF STORAGE SPACE ON
 EARTH, GRADED AND DRAINED. ADMINISTRATION IN TENT ERECTED
 BY USING SERVICE PIT TYPE LATRINES. MINIMUM REAL ESTATE
 REQUIREMENT FOR INSTALLATION 11.8 ACRES, REQUIRED FROM LOCAL
 SOURCE - FINE AGGREGATE 6 CY, COARSE AGGREGATE 7 CY.

DC1189

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
72321BD	LAT PIT, TYPE 160MAN, 8 SEATS, 10X20	10X20X8	160 EM	1.0	8	9	1559	2	230	37	269
72520AA	TENTAGE, MED GEN PURP, 32FTX16FT	10-16X32	ADMIN	.1		1	1170			5	5
86330AC	SUMP, FIRE PROTECTION, 10000 GAL	10000 GAL	EFF RAD, 500FT	1.0	7	5	145	18	124	133	275
					15	15	2874	20	354	175	569

DDEXER4

RUN DATE 860207

DESERT CLIMATE

DC1199

STORAGE, DRY CARGO, 100000 SF OPEN, ALL CLIMATES, STD 6,
 NEW CONSTR TENTAGE. PROVIDES 100000 SF STORAGE SPACE ON 6 IN.
 STAB. STONE W/ASPHALT BINDER. ADMINISTRATION IN TENT ERECTED
 BY USING SERVICE/PIT TYPE LATRINES. MINIMUM REAL ESTATE.
 REQUIREMENT FOR INSTALLATION 11.8 ACRES, REQUIRED FROM LOCAL
 SOURCE - FINE AGGREGATE, 1919 CY, COARSE AGGREGATE, 2377 CY.

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST VOL-MI	COST	HORZ	VERT	GENL		TOT
72321BD	LAT PIT TYPE 160MAN 8 SEATS 10X20	10X20X8	1.6Q EM	1.0	.8	9	1559	2	230	37	269
72520AA	TENTAGE, MED GEN PURP, 32FTX16FT	10-16X32	ADMIN	.1	.1	1	1170			5	5
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	EFF RAD 500FT	1.0	.2	5	165	18	124	133	275
					15	15	2874	20	354	175	549

DDEXER4

RUN DATE 860207

DESERT CLIMATE

STORAGE, DRY CARGO, 200000 SF OPEN, ALL CLIMATES, STD 2,
 NEW CONST, TENTAGE. PROVIDES 200000 SF STORAGE SPACE ON
 EARTH, GRADED AND DRAINED. ADMINISTRATION IN TENT ERECTED
 BY USING SERVICE/PIT TYPE LATRINES. MINIMUM REAL ESTATE
 REQUIREMENT FOR INSTALLATION 24.2 ACRES, REQUIRED FROM LOCAL
 SOURCE - FINE AGGREGATE, 11 CY, COARSE AGGREGATE, 12 CY.

DC1209

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS REQUIRED WT-ST VOL-MT	CONSTR EFFORT IN MANHOURS				
				REQ'D.	WT-ST VOL-MT		COST	HORZ	VERT	GENL	TOT
72321BD	LAT. PIT TYPE 160MAN 8 SEATS 10X20	10X20X8	160 EM	2.0	16	18	3118	5	460	74	539
72520AA	TENTAGE, MED GEN PURP, 32FTX16FT	10-16X32	ADMIN	.1		1	1170			5	5
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	EFF RAD 500FT	2.0	14	10	290	37	248	267	552
							30	29	6578	62	708
										366	1096

DDEXER4

RUN DATE 860207

DESERT CLIMATE

DC1219

STORAGE, DRY CARGO, 200000 SF OPEN, ALL CLIMATES, STD 4,
 MED CONST. TENTAGE. PROVIDES 200000 SF STORAGE SPACE ON 6 IN.
 STAB. STONE W/ASPHALT BINDER. ADMINISTRATION IN TENT ERECTED
 BY USING SERVICE PIT TYPE LATRINES. MINIMUM REAL ESTATE
 REQUIREMENT FOR INSTALLATION 24.2 ACRES, REQUIRED FROM LOCAL
 SOURCE - FINE AGGREGATE, 3800 CY, COARSE AGGREGATE, 6690 CY.

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS		CONSTR EFFORT IN MANHOURS				
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
72321BD	LAT PIT TYPE 160MAN 8 SEATS 10X20	10X20X8	160 EM	2.0	16	18	3118	5	660	74	539
72520AA	TENTAGE, MED GEN PURP, 32FTX16FT	10-16X32	ADMIN	.1		1	1170			5	5
86330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	EFF RAD 500FT	2.0	16	10	290	37	268	267	552
					30	29	4578	62	708	346	1096

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE RAILWAY REPAIR, TEMPORARY CONSTRUCTION STANDARD, WOOD
 FRAME BLDGS. PROVIDES 500-TON AND
 1800-TON MARINE RAILWAYS WITH REPAIR AND MAINTENANCE SHOPS.
 REQUIRES 2 ACRES. AGGREGATE REQUIRED 352-CY FINE, 517-CY
 COARSE. UTILITIES REQUIRED BUT NOT PROVIDED 62.0 KW ELEC
 CONNECTED LOAD.

FP1005

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
121330AE	SHOP MARINE REP. 60X180X20, WD, FR		MAINT&PRODUCTN	1.0	393	573	358729	208	9373	820	10401
44110BE	STOREHOUSE WD FR BLDG 20X20X8	20X20X8FT	FOR WINCHES	1.0	10	11	1943	26	301	61	388
144110BF	STOREHOUSE WD FR BLDG. 20X30X8	20X30X8FT	FOR WINCHES	1.0	14	16	2671	28	330	83	661
161050BP	HQTRS & UNIT SUP BLDG 20X100X8	20X100X8FT	80 SF/MAN	1.0	64	60	11736	75	1459	311	1845
81240AG	ELEC DISTR W/FDLTG MARINE RWAY RPR		BLD & DOCK	1.0	5	7	4589	58	920	403	1381
187190AA	SITE PREPARATION, ONE ACRE		REQUIRED AREA	2.0				202		74	276
					466	667	379668	597	12383	1752	14732

DDEXER4

RUN DATE 860207

UWEAR4
DESERT CLIMATE

GENERAL CARGO PORT-CONTAINER, BREAKBULK, RO-RO, LIGHTERAGE & PORTS SERVICE VESSEL PIERS LST RAMP ON SHORE SUPPORTING FACILITIES, PIERS & CAUSEWAY FOR 20FT TIDE RANGE-GROUND SLOPE 15-PERCENT, BERTHING, RAMP & ONSHORE SUPPORTING FACILITIES FOR CAPACITY UP TO 14,880 TONS PER DAY, REQUIRES 300 ACRES, 1000 MAN TROOP CAMP (NT3611/NT1531) " 10 BAY MAINT. INSI. (MT1081/MT2008), ALL UTILITIES INCLUDED WITH INSTALLATION.

FP1105

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-SI	VOL-MT	COST	HORZ	VERT	GENL	TOT
11130AB HELIPD/CH54/PAD/APPR/DEP. 1-1/2IN HM		CH 54		1.0	152	120	3797	18		41	59
111210CB TAXIWAY W/25 FT SHOULDERS, 1000 X 40				.1	31	25	1649	72		28	100
12110AL SPRT ACFT REFLNG 30000 G. W/MANIFOLD 2				4.0	28	64	221056	736	664	1619	2999
12630AA LDG FACIL FOR TWO FUEL TRUCKS	2-STATION			1.0	12	12	13862	173	374	1213	1760
14970AF RAMP FOR LANDING CRAFT							207		58	288	553
15150EL CONTAINER PIER/TRESTLE, & CAUSEWAY				1.0	13100	18399	23001817	7710	29711	12090	49511
15150EN BREAKBULK-RO/RO PIER/TRESTLE & CWY.				1.0	16744	24253	34619662	8618	36398	15719	60535
15150EP LIGHTERAGE PIER/TRESTLE & CAUSEWAY				1.0	6649	6888	5644858	2423	7151	3223	12797
15150ER SERVICE PIER/TRESTLE & CAUSEWAY				1.0	6605	6468	5688110	2745	6079	2044	10868
15150ET PORT-SERVICE PIERS/TRESTLE & CWY.				1.0	10467	21662	17927489	2530	6916	2126	11572
121330AD SHOP MARINE REP 40X100X12/STL FR				1.0	42	212	42634	308	3830	1904	6042
21410BY VEH WASH RACK				5.0	105	75	7990	23	339	472	834
41180AE TANK POL 1000 BARREL 1/4 IN PIPE	1000 BBL			2.0	2	26	18516	184	236	299	1219
44110AL STOREHOUSE STL FR BLDG 20X50X8	20X50X8FT	AS REQUIRED		1.0	10	56	11736	31	370	190	591
44110AP WHSE CLOSED STL FR 60X220X12	80X220X12FT	AS REQUIRED		1.0	231	350	151045	342	3338	2144	5824
161050BH ADMINISTRATION/HEADQUARTERS BLDG, ST	5000SF			2.0	36	94	61686	301	4018	1622	5941
161050CB ADMIN.SUPPORT BLDG, 30X50FT, ST FRAME		90 SF/QCCUP.		2.0	24	46	31480	81	1610	299	1990
72321BD LAT PIT TYPE 160MAN 8 SEATS 10X20	10X20X8			5.0	40	45	.7795	12	1150	184	1346
373010AC FS 6144SF WD FR BLDG OP-A W/ INTER				1.0	192	283	39238	141	5545	882	6568
81110AG GEN PLANT 300 KW 208Y/120 V OUTDOOR	20X 20X8			1.0	24	40	47996		1181	28	1209
181110DF GEN PLANT 10.5 MW IN VANS TEMPERATE		1000 REEFERS		1.0	539	1205	1971219	307	7998	2990	11295
81240GE LIGHTING-CONTAINERS-GEN/CARGO PORT				1.0	713	949	2829933	1617	41400	2300	45317
81240GF AREA ILLUMINATION-GEN/CARGO PORT				1.0	27	30	93469	64	1352		1416
81240GG AERIAL DISTRIBUTION-GEN/CARGO PORT				1.0	29	23	60429	18	1840		1858
81240GH FIRE PUMP STATION-GEN/CARGO PORT				1.0	10	19	53428	28	938		966
81240GJ PIERS-FEEDERS&EQPT-GEN/CARGO PORT				1.0	27	57	103840	75	1665		1740
82209AA STEAM SYSTEM-GEN CARGO PORT ONSHORE				1.0	19	125	47913	676	2329	1352	4357
82209AB STEAM SYSTEM-BRKBLK/RO-RO PIER				1.0	19	133	64284	856	1978	1334	4168
82209AC STEAM SYSTEM CONTAINER PIER				1.0	23	95	50430	559	1312	874	2745
83210AA SANITARY SYST-GEN CARGO PORT-SHORE				1.0	3	21	21840		869	435	1304
84120AD WATER TANK TOWER 10500 GAL W/ACCESS 10,500 GAL		1000 MAN		1.0	8	18	7415		276		276
84210GA PORTABLE WATER SYST-GEN CARGO SHORE				1.0	12	245	1548649		3802	3802	7604
84330AF FIRE WATER SYSTEM-GEN.CARGO ONSHORE				1.0	206	222	570022	2001	3843	2001	7845
84330AG FIRE WATER SYSTEM-LIGHTERAGE PIER				1.0	7	22	11820	138	227	186	551
84330AH FIRE WATER SYST.-BRKBLK/RO-RO PIER				1.0	53	185	242806	559	1601	1093	3253
84330AJ FIRE WATER SYSTEM-SERVICE PIERS				1.0	12	35	22625	184	458	423	1065

DDEXER4

RUN DATE 860207

DESERT CLIMATE

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED		MATERIALS		CONSTR EFFORT IN MANHOURS			
				WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
84330AK	FIRE WATER SYSTEM-CONTAINER PIER			1.0	38	320	144298	462	1369	995	2826
84520AA	SEAWATER SYST-GEN CARGO PORT-SHORE			1.0	1	4	3484		313	313	626
84520AB	SEAWATER SYS.-BRKBLK/RO-RO PIER			1.0	1	6	6786	48	269	216	533
85110CN	HARDSTAND/APR/TXWY/OR RNWY 1000SQYD			95.4	4865	3625	47509	4608		2194	6802
85110ER	ROAD PAVEMENT/CLASS B/CLD MIX BITUM			25.2	15952	14742	407484	17156		13708	30864
85111AD	RDWY PVMT HVY WH BSC 1MI 3IN ASPH		AS REQUIRED	3.1	3116	2492	41791	1605		524	1929
85111AP	RDWY PVMT HVY WH 2FT INCR 3IN ASPH		AS REQUIRED	36.0	4788	3960	71748	2360		952	3312
85111ED	RDWY HVY WH BSC 4FT SHLDRS 24IN THK		AS REQUIRED	1.0	4	3	1765	799		278	1077
85111EE	RDWY HVY WH BSC 4FT SHLDRS 30IN THK		AS REQUIRED	2.1	8	6	3938	1963		720	2683
85111EP	RDWY HVY WH 2FT INCR 24IN THK		AS REQUIRED	12.0			1320	925		276	1201
85111FB	HDSTD PVMT HVY WH 1000SY 3IN ASPH		AS REQUIRED	11.8	850	708	13924	719		285	1004
85111FD	HDSTD PVMT HVY WH 1000SY 3IN ASPH		AS REQUIRED	406.9	35400	29297	541991	31352		11230	42582
85111KA	HDSTD HVY WH 1000SY 4FT SHLDR 6IN		AS REQUIRED	11.8	24	12	8520	516		95	611
85111KD	HDSTD HVY WH 1000SY 4FT SHLDR 24IN		AS REQUIRED	128.6	257	257	97736	14937		3254	18191
85111KE	HDSTD HVY WH 1000SY 4FT SHLDR 30IN		AS REQUIRED	278.3	557	557	215126	38605		8321	46726
85210AG	HARDSTAND,1000 SQ YDS,NO ROCK			95.4	286	95	158936	6912		2194	9106
87210AF	GATE/CHAINLINK SING/LEAF 3 WI 10 HI			2.0	2	4	558	14		28	42
87210AP	SECURITY FENCE TYPE X 1000 FEET	1000 FEET		9.1	73	82	15070	481	2658	2679	5818
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET		8.5	60	68	11934	469	2170	2190	4829
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1		8.0	16	16	2656	74	1104	442	1620
87230AA	SENTRY BOX 6X4			2.0			264	219	920	460	1599

122499 138756 97039356 157361 190139 114559 462059

DDEXER4

RUN DATE 860207

DDEXER4
DESERT CLIMATE

AMMUNITION PORT-CONTAINER, BREAKBULK & LIGHTERAGE PIERS, LST RAMP, BARRICADED CONTAINER MARSHALLING YARD, OTHER ONSHORE SUPPORTING FACILITIES, PIERS & CAUSEWAY FOR 20FT TIDE RANGE-GROUND SLOPE 15-PERCENT. BERTHING RAMP & ONSHORE SUPPORTING FACILITIES FOR CAPACITY UP TO 9,880 TONS PER DAY. REQUIRES 5000 ACRES. UTILITIES INCLUDED WITH INSTALLATION.

FP1115

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MI	COST	HORZ	VERT	GENL	
11130AB	HELIPD, CH56, PAD/APPR/DEP, 1-1/2IN HM	CH 56		1.0	152	120	3797	18		61 59	
111210CB	TAXIWAY W/25 FT SHOULDERS, 1000 X 40			.4	125	100	6595	289		113 402	
14970AF	RAMP FOR LANDING CRAFT			1.0				207	58	288 553	
15150EL	CONTAINER PIER, TRESTLE, & CAUSEWAY			1.0	13100	18399	23001817	7710	29711	12090 49511	
15150EM	BREAKBULK PIER, TRESTLE, & CAUSEWAY			1.0	12990	16848	20522368	6088	25056	10986 42130	
15150EP	LIGHTERAGE PIER, TRESTLE & CAUSEWAY			1.0	6649	6888	5644858	2423	7151	3223 12797	
21850AB	BATT CHG FAC STL FR BLD W/INT 20X20			1.0	4	9	6858	25	450	150 625	
161050BC	ADMIN BLDG STL FR-INTERIOR 20X30X8 20X30X8FT			1.0	5	11	9128	18	343	101 462	
172321BA	ADMIN BLDG STL FR-INTERIOR 20X30X8 20X30X8FT			2.0	10	22	18256	37	685	202 924	
73010AA	FS 6144SF WD FR BLDG OP-A W/ INTER			1.0	192	272	38303	141	5545	882 6568	
181110CV	GEN PLANT 1.5 MW IN BLDGS TEMPERATE		AS REQUIRED	1.0	160	335	360318	104	6526	1426 8056	
81240GF	AREA ILLUMINATION-GEN, CARGO PORT			1.0	27	30	93469	64	1352		1416
81240GF	POWER EQPT & ROAD LIGHTG-AMMO PORT			1.0	1794	2106	2393611	6606	52918		59524
81240GL	LIGHTING-CONTAINER AREA-AMMO PORT			1.0	89	95	333681	745	4692		5437
81240GM	FIRE PUMP STATION-AMMUNITION PORT			1.0	6	6	36943	9	414		423
81240GP	FENCE LIGHTING-AMMUNITION PORT			1.0	58	65	293348	575	4186		4761
83120AF	SEPTIC TANK 500 GL, W/ DRAIN FIELD			2.0	2	2	2522	58		690 748	
84330AG	FIRE WATER SYSTEM-LIGHTERAGE PIER			1.0	7	22	11820	138	227	186 551	
84330AH	FIRE WATER SYST.-BRKBLK/RO-RO PIER			1.0	53	185	242806	559	1601	1093 3253	
84330AK	FIRE WATER SYSTEM-CONTAINER PIER			1.0	38	320	144298	462	1369	995 2826	
84330AL	FIRE WATER SYSTEM-AMMO PORT ONSHORE			1.0	519	661	3930813	2529	4830	2529 9888	
85110CK	ROAD PAVEMENT-CLASS C/6IN STBL 1MI			5.5	3680	2486	18398	961		278 1239	
85111AD	RDWY PVMT HVY WH BSC 1MI 3IN ASPH			8.5	8543	6834	114589	3851		1437 5288	
85111AP	RDWY PVMT HVY WH 2FT INCR 3IN ASPH			51.0	6783	5610	101643	3343		1349 4692	
85111EE	RDWY HVY WH BSC 4FT SHLDRS 30IN THK		AS REQUIRED	8.5	34	26	15938	7947		2913 10860	
85111ER	RDWY HVY WH 2FT INCR 30IN THK			51.0			5610	4751		1349 6100	
85111FD	HDSTD PVMT HVY WH 1000SY 3IN ASPH		AS REQUIRED	160.1	13929	11527	213253	12336		4419 16755	
85111KD	HDSTD HVY WH 1000SY 4FT SHLDR 24IN		AS REQUIRED	23.3	47	47	17708	2706		589 3295	
85130JR	ROAD, CLASS C, GRADED AND DRAINED 1MI			5.5	11	11	6677	4212		1322 5534	
85240GN	ROAD, CLASS C, GRADED AND DRAINED 1MI		AS REQUIRED	1.0	2	2	1214	766		240 1006	
87210AP	SECURITY FENCE TYPE X 1000 FEET	1000 FEET	AS REQUIRED	29.0	232	261	48024	1534	8471	8538 18563	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110 404	
87230AA	SENTRY BOX 4X4			1.0			122	109	460	230 799	

69245 73304 57619649 71281 156379 57769 285429

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MEDICAL DEPOT, INITIAL STANDARD, ALL CLIMATES, PROVIDES APPROX 69600 SF OF STORAGE AREA. 25 PERCENT IN TENTS WITH EARTH FLOORS AND 15 PERCENT IN OPEN HARDSTAND. ADMINISTRATION, MEDICAL MAINTENANCE, OPTICAL FABRICATING, ACID-FLAMMABLE STORAGE IN TENTS

6H4019

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
86330AB	SUMP FIRE PROTECTION 2000 GAL	2000 GAL	AS REQUIRED	7.0	14	14	336	32	177	193	402
85110DH	HARDSTAND, STAB SURF, 1000 SQ YD, 8 IN		AS REQUIRED	1.0	84	57	420	46		9	55
85210AV	HARDSTAND, 1000 SQ YDS, HEAVY ROCK		AS REQUIRED	47.6	333	190	210392	18174		6569	24743
187190AA	SITE PREPARATION, ONE ACRE		AS REQUIRED	21.1				2135		776	2911
87210AD	CONCERTINA, TRIPLE TAPE TYP D, 1000LF		AS REQUIRED	4.4	515	308	8633	142		567	709
87210AH	GATE, PER BAR SGL/LEAF 3FT X 7 FT HI		AS REQUIRED	2.0	2	2	716	16	23	9	48
87210AI	GATE, PER BAR SGL/LEAF 3FT X 7 FT HI		AS REQUIRED	5.0	5	5	1790	40	58	23	121
					953	576	222287	20585	258	8146	28989

DDEXER4

RUN DATE 860207

~~UNCLASSIFIED~~
DESERT CLIMATE

MEDICAL DEPOT, INITIAL STANDARD, ALL CLIMATES, PROVIDES APPROX 88800 SF OF STORAGE AREA 90 PERCENT IN TENTS WITH EARTH FLOORS AND 10 PERCENT IN OPEN HARDSTAND. ADMINISTRATION, MEDICAL MAINTENANCE, OPTICAL FABRICATING, ACID-FLAMMABLE STORAGE IN TENTS
~~MEDSON FOR COMMUNICATION ZONE AND COMBAT ZONE~~

6H4029

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
86330AB	SPRING PROTECTION, 2000 GAL	2000 GAL	AS REQUIRED	7.0	14	14	336	32	177	193	402
85110DH	HARDSTAND, STAB SURF, 1000 SQ YD, 8 IN		AS REQUIRED	1.0	84	57	420	46		9	55
85210AV	HARDSTAND, 1000 SQ YDS, HEAVY ROCK		AS REQUIRED	57.6	403	230	256592	21992		7949	29941
187190AA	SITE PREPARATION, ONE ACRE		AS REQUIRED	25.0				2530		920	3450
87210AD	CONCERTINA, TRIPLE TAPE, TYP D, 1000 LF		AS REQUIRED	4.7	550	329	9221	151		605	756
87210AH	GATE, PER BAR SGL/LEAF 3FT X 7 FT HI		AS REQUIRED	2.0	2	2	716	16	23	9	48
87210AX	GATE, PER BAR SGL/LEAF 3FT X .7 FT HI		AS REQUIRED	5.0	5	5	1790	40	58	23	121
					1058	637	267075	24807	258	9708	34773

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MEDICAL DEPOT, DESERT CLIMATE, TEMPORARY STANDARD, PROVIDES APPROX 69600 SF OF STORAGE AREA, 85 PERCENT IN BUILDINGS WITH CONCRETE FLOORS AND 15 PERCENT IN OPEN HARDSTAND. ADMINISTRATION BLDG AND MEDICAL MAINTENANCE, OPTICAL FABRICATING, MOTOR MAINTENANCE, ACID-FLAMMABLE STORAGE AND MEDSAM FOR COMMUNICATION ZONE AND COMBAT ZONE

GH4034

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST VOL-MI	COST	HORZ	VERT	GENL	TOT
21410GT	3600 SQ.FT. BUILDING GT WOOD		1PER INST	1.0	1015	881	75577	426	3393	1106
21885CC	GEN PURP MAINT SHOP 36X60 PAN WD:DT	1800SF	AS REQUIRED	1.0	164	942	94319	94	837	94
44110BC	WHSE CLOSED WD FR BLDG 48X96X14	48X96X14FT	AS REQUIRED	1.0	116	120	14467	81	1743	645
44220AC	WAREHOUSE WOOD FRM CONST 80FTX240FT	19200SF	34.5SF/ST	2.0	958	1058	206494	1162	6360	623
44220AL	WAREHOUSE WOOD FRM CONST 80FTX240FT	19200SF	34.5SF/ST	1.0	483	534	103025	628	3735	212
44222AC	SHED STORAGE WOOD FRAME 20FTX100FT	2000SF	AS REQUIRED	1.0	55	69	15375	86	590	86
44240AB	ACID FLAMMABLE STORAGE BLDG 20X90	1800SF	AS REQUIRED	1.0	48	57	10362	120	706	120
61025BC	ADMINISTRATION BLDG WOOD FRM 40X110	4400SF	90SF/MAN	1.0	75	134	31510	174	984	174
72321AA	PORATA-KAMP LATRINE		1/40 MEN	5.0	5	5	1240	17	92	86
81241AA	ELECTRICAL DISTRIBUTION SYSTEM		AS REQUIRED	1.0	39	239	68886	263	1313	263
83120AB	SEPTIC TANK 1000 GPD/CONCRETE		AS REQUIRED	5.0	55	45	12700	17	782	104
83120DA	SEWAGE		AS REQUIRED	1.0			176	12	18	23
84210KA	WATER SYSTEM		AS REQUIRED	1.0	1	3	3799	71	338	71
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	AS REQUIRED	2.0	14	10	290	37	248	267
85110AG	ROAD PAVEMENT, CLASS A, HOT MIX BITUM		AS REQUIRED	.1	132	110	2043	65		28
85110CM	HARDSTAND, SINGLE BITUM/STAB BASE		AS REQUIRED	1.0	45	35	543	38		45
85110DH	HARDSTAND/STAB SURF/1000SQ YD, 8 IN		AS REQUIRED	19.8	1663	1129	8316	911	182	1093
85120FA	RD BRDG SGL LANE TMBR 30 FT HIGH		AS REQUIRED	.1	3	3	798	4	10	12
85210AV	HARDSTAND/1000 SQ YDS/HEAVY ROCK		AS REQUIRED	31.4	220	126	138788	11989	4333	16322
187190AA	SITE PREPARATION, ONE ACRE		AS REQUIRED	14.1						1946
87210AA	FENCE, CHAIN LK.W/2 OUTRGRS 1 1000LF		AS REQUIRED	3.1	53	158	37429	446		1426
87210AF	GATE, CHAINLINK SING/LEAF 3 WI 10 MI		AS REQUIRED	2.0	2	4	558	14		42
87210AJ	FENCE, CORNER POST 10 FT HI CHAINLIN		AS REQUIRED	4.0			436	46		83
87210AL	GATE, VEH CHAINLINK 10 FT HI 32 F WI		AS REQUIRED	2.0	2	4	802	16		51
87230AA	SENTRY BOX 4X4		AS REQUIRED	2.0			244	219	920	460
					5148	5666	828177	18363	22067	10741
										51171

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MEDICAL DEPOT, DESERT CLIMATE, TEMPORARY STANDARD, PROVIDES APPROX 88000 SF OF STORAGE AREA, 20 PERCENT IN BUILDINGS WITH CONCRETE FLOORS AND 10 PERCENT IN OPEN HARDSTAND. ADMINISTRATION BLDG AND MEDICAL MAINTENANCE, OPTICAL FABRICATING, MOTOR MAINTENANCE, ACID-FLAMMABLE STORAGE AND UNIT PICK-UP BUILDINGS PROVIDED WOOD FRAME CONSTRUCTION. MEDSOM FOR COMBAT ZONE

GH4044

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
21410GT	3600 SQ.FT. BUILDING GT WOOD.		1PER INST	1.0	1015	881	75577	426	3393	1106	4925
21885CC	GEN PURP MAINT SHOP 36X60 PAN WD;DT	1800SF	AS REQUIRED	1.0	164	942	94319	94	837	94	1025
44110BC	WHSE CLOSED WD FR BLDG 48X96X14	48X96X14FT	AS REQUIRED	1.0	116	120	144667	81	1743	645	2469
44220AC	WAREHOUSE WOOD FRM CONST 80FTX240FT	19200SF	34.5SF/ST	3.0	1437	1587	309741	1742	9539	635	11916
44220AL	WAREHOUSE WOOD FRM CONST 80FTX240FT	19200SF	34.5SF/ST	1.0	483	534	103025	628	3735	212	4575
44222AC	SHED STORAGE WOOD FRAME 20FTX100FT	2000SF	AS REQUIRED	1.0	55	69	15375	86	590	86	762
44240AB	ACID FLAMMABLE STORAGE BLDG 20X90	1800SF	AS REQUIRED	1.0	48	57	10362	120	704	120	946
61025BC	ADMINISTRATION BLDG WOOD FRM 40X110	4400SF	90SF/MAN	1.0	75	134	31510	174	984	174	1332
72321AA	PORTA-KAMP LATRINE	1/40 MEN		5.0	5	5	1240	17	92	86	195
81241AA	ELECTRICAL DISTRIBUTION SYSTEM	AS REQUIRED		1.0	39	239	68886	263	1313	263	1839
83120AB	SEPTIC TANK 1000 GPD CONCRETE	AS REQUIRED		5.0	55	45	12700	17	782	104	903
83120DA	SEWAGE	AS REQUIRED		1.0			176	12	18	23	53
84210KA	WATER SYSTEM	AS REQUIRED		1.0	1	3	3799	71	338	71	480
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	AS REQUIRED	2.0	14	10	290	37	248	267	552
85110AG	ROAD PAVEMENT, CLASS A, HOT MIX BITUM	1000SY/UNIT		1.0	132	110	2043	65		28	93
85110CH	HARDSTAND, SINGLE BITUM, STAB BASE	AS REQUIRED		1.0	45	35	543	38		7	45
85110DH	HARDSTAND, STAB SURF, 1000SQ YDS, 8 IN	AS REQUIRED		18.0	1512	1026	7560	828		166	994
85130FA	ROAD, CLASS B, GRADED AND DRAINED 1MI	AS REQUIRED		1.0	1	1	865	240		95	335
85210AV	HARDSTAND, 1000 SQ YDS, HEAVY ROCK	AS REQUIRED		41.0	287	164	181220	15654		5658	21312
187190AA	SITE PREPARATION, ONE ACRE	AS REQUIRED		16.3				1650		600	2250
87210AA	FENCE, CHAIN LK, W/2 OUTGRRS 1 1000LF	AS REQUIRED		3.7	63	182	44674	532		1702	2234
87210AF	GATE, CHAINLINK SING/LEAF 3 WI 10 HI	AS REQUIRED		2.0	2	4	558	14		28	42
87210AJ	FENCE, CORNER POST 10 FT HI CHAINLIN	AS REQUIRED		4.0			436	46		37	83
87210AL	GATE, VEH CHAINLINK 10 FT HI 32 F WI	AS REQUIRED		2.0	2	4	802	16		35	51
87230AA	SENTRY BOX 4X4	AS REQUIRED		2.0			244	219	920	460	1599

5551 6159 980412 23070 25236 12702 61008

DDEXER4

RUN DATE 860207

DESERT CLIMATE

VEHICLE MAINTENANCE INSTALLATION FOR ALL LEVELS OF SUPPORT
 THROUGH GENERAL SUPPORT ACTIVITIES, CONSISTS OF TEN BAYS AND
 SHOP AREA FOR OFF VEHICLE REPAIR. TEMPORARY STANDARD IN THE
 TROPIC/DESERT CLIMATES/WOOD BUILDINGS.

MT2008

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED			MATERIALS			CONSTR EFFORT IN MANHOURS		
				WT-ST	VOL-MT	CQST	HORZ	VERT	GENL	TOT		
21410BW	TRACKED VEH TURNING PAD		AS REQUIRED	17.3	346	260	22698		617	935	1552	
21410BY	VEH WASH RACK		3PER INST	3.0	63	45	4794	14	204	283	501	
21410GT	3600 SQ.FT. BUILDING GT WOOD		1PER INST	1.0	1015	881	75577	426	3393	1106	4925	
21410HN	VEHICLE MAINT FAC.WD.FR.6BAY T/D		1PER INST	1.0	1305	1117	91628	458	3933	1233	5624	
21411AA	LUB.RACK/VECHICLE,12X56 RAMP+PLATFO		2PER INST	2.0	14	10	1730		828	138	966	
72321BD	LAT PIT TYPE 160MAN 8 SEATS 10X20	10X20X8	1PER INST	1.0	8	9	1559	2	230	37	269	
81240HA	ELECTRICAL SYSTEM 125 MAN TR CP		AS REQUIRED	1.0	19	21	15370	13	1972	122	2107	
86120FA	ELECTRICAL SYSTEM 125 MAN TR CP		AS REQUIRED	1.0	19	21	15370	13	1972	122	2107	
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	AS REQUIRED	1.0	7	5	145	18	124	133	275	
84330AE	FIREFHT EQPT POL W/10MGAL WTR&PUMP		AS REQUIRED	1.0	1	5	16777		39		39	
85110DF	HARDSTAND/STAB SURF/1000SQ YD, 4 IN		AS REQUIRED	18.0	756	504	3780	497		166	663	
187190AA	SITE PREPARATION,ONE ACRE		AS REQUIRED	4.2				425		155	580	
87210AA	FENCE,CHAIN LK.W/2 OUTGRRS 1 1000LF		AS REQUIRED	1.0	17	51	12074	146		460	604	
87210AF	GATE,CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	1.0	1	2	279	7		14	21	
87210AL	GATE,VEH CHAINLINK 10 FT HI 32 F WI		AS REQUIRED	1.0	1	2	401	8		17	25	
					3572	2933	262182	2025	13312	4921	20258	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

VEHICLE MAINTENANCE INSTALLATION FOR ALL LEVELS OF SUPPORT
 THROUGH GENERAL SUPPORT ACTIVITIES. CONSISTS OF TEN BAYS AND
 SHOP AREA FOR OFF VEHICLE REPAIR. TEMPORARY STANDARD IN THE
 TROPIC/DESERT CLIMATES, METAL BUILDINGS.

MT2018

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HDRZ	VERT	GENL	TOT
21410BW	TRACKED VEH TURNING PAD		AS REQUIRED	17.3	346	260	22698		617	935	1552
21410BY	VEH WASH RACK		3PER INST	3.0	63	43	4794	14	204	283	501
21410GU	3600 SQ.FT. BUILDING GU METAL		1PER INST	1.0	51	46	46815	271	2432	1049	3752
21410HP	VEHICLE MAINT. FAC. ST. FR./6BAY/T/D		1PER INST	1.0	69	61	58873	350	2760	1132	4242
21411AA	LUB.RACK,VECHICLE,12X56 RAMP+PLATFO		2PER INST	2.0	14	10	1730		828	138	966
72321BA	LUB.RACK,VECHICLE,12X56 RAMP+PLATFO		1PER INST	1.0	7	5	865		414	69	483
81240HA	ELECTRICAL SYSTEM 125 MAN TR CP		AS REQUIRED	1.0	19	21	15370	13	1972	122	2107
84120FA	ELECTRICAL SYSTEM 125 MAN TR CP		AS REQUIRED	1.0	19	21	15370	13	1972	122	2107
84330AC	UMP FIRE PROTECTION 10000 GAL	10000 GAL	AS REQUIRED	1.0	7	5	145	18	124	133	275
84330AE	FIREFHT EQPT POL W/10MGAL WTR&PUMP		AS REQUIRED	1.0	1	5	16777		39		39
85110DF	HARDSTAND/STAR SURF,1000SQ YD, 4 IN		AS REQUIRED	18.0	756	504	3780	497		166	663
187190AA	SITE PREPARATION,ONE ACRE		AS REQUIRED		4.2			425		155	580
87210AA	FENCE,CHAIN LK,W/2 OUTGRRS,1 1000LF		AS REQUIRED	1.8	31	92	21733	259		828	1087
87210AF	GATE,CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	1.0	1	2	279	7		14	21
87210AL	GATE,VEH CHAINLINK 10 FT HI 32 F.WI		AS REQUIRED	1.0	1	2	401	8		17	25
				1385	1079	209630	1875	11362	5163	18400	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

VEHICLE MAINTENANCE INSTALLATION FOR ALL LEVELS OF SUPPORT
 THROUGH GENERAL SUPPORT ACTIVITIES. CONSISTS OF TWENTY BAYS
 AND SHOP AREA FOR OFF VEHICLE REPAIR. TEMPORARY STANDARD IN
 THE TROPIC/DESERT CLIMATES. WOOD BUILDINGS.

MT2028

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED			MATERIALS		CONSTR EFFORT IN MANHOURS		
				WT-ST	VOL-MT	COST	HORZ	VERT	GENL		TOT
21410BW	TRACKED VEH TURNING PAD		AS REQUIRED	31.4	628	671	61197		1119	1697	2816
21410BY	VEH WASH RACK		6PER INST	6.0	126	90	9588	28	407	566	1001
21410GT	3600 SQ.FT. BUILDING GT WOOD		2PER INST	2.0	2030	1762	151154	851	6785	2213	9849
21410HN	VEHICLE MAINT FAC. WD. FR. 6BAY T/D		2PER INST	2.0	2610	2234	183256	915	7866	2466	11247
21411AA	LUB.RACK,VECHICLE,12X56 RAMP+PLATFO		4PER INST	4.0	28	20	3460		1656	276	1932
72321BD	LAT PIT TYPE 160MAN 8 SEATS 10X20	10X20X8	1PER INST	1.0	8	9	1559	2	230	37	269
81240HB	ELECTRICAL DISTRIBUTION SYS 250 MAN		AS REQUIRED	1.0	28	42	27991	2	26	2	30
84120FA	ELECTRICAL DISTRIBUTION SYS 250 MAN		AS REQUIRED	1.0	28	42	27991	2	26	2	30
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	AS REQUIRED	1.0	7	5	145	18	124	133	275
84330AE	FIREFHT EQPT POL W/10MGAL WTR&PUMP		AS REQUIRED	1.0	1	5	16777		39		39
85110DF	HARDSTAND,STAB SURF,1000SQ YD, 4 IN		AS REQUIRED	36.0	1512	1008	7560	994		331	1325
187190AA	SITE PREPARATION,ONE ACRE		AS REQUIRED	8.3				840		305	1145
87210AA	FENCE,CHAIN LK.W/2 OUTGRGS 1 1000LF		AS REQUIRED	2.5	43	128	30185	359		1150	1509
87210AF	GATE,CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	1.0	1	2	279	7		14	21
87210AL	GATE,VEH CHAINLINK 10 FT HI 32 F WI		AS REQUIRED	1.0	1	2	401	8		17	25
					7051	5820	501543	4026	18278	9209	31513

DDEXER4

RUN DATE 860207

DESERT CLIMATE

VEHICLE MAINTENANCE INSTALLATION FOR ALL LEVELS OF SUPPORT
 THROUGH GENERAL SUPPORT ACTIVITIES. CONSISTS OF TWENTY BAYS
 AND SHOP AREA FOR OFF VEHICLE REPAIR. TEMPORARY STANDARD IN
 THE TROPIC/DESERT CLIMATES. METAL BUILDINGS.

MT2038

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS		
				REQUIRED	WT-ST	VOL-MI	COST	HORZ	VERT	GENL	TOI	
21410BW	TRACKED VEH TURNING PAD		AS REQUIRED	31.4	628	471	41197	1119	1697	1697	2814	
21410BY	VEH WASH RACK		6PER INST	6.0	126	90	9588	28	407	566	1001	
21410BU	3600 SQ.FT. BUILDING GU METAL		2PER INST	2.0	102	92	93630	543	4865	2098	7506	
21410HP	VEHICLE MAINT. FAC. ST. FR. 6BAY, T/D		2PER INST	2.0	138	122	117746	699	5520	2263	8482	
21411AA	LUB.RACK, VEHICLE, 12X56 RAMP+PLATFO		4PER INST	4.0	28	20	3460	1656	276	1932		
72321BA	LUB.RACK, VEHICLE, 12X56 RAMP+PLATFO		1PER INST	1.0	7	5	865	414	69	69	483	
81240HA	ELECTRICAL SYSTEM 125 MAN TR CP		AS REQUIRED	1.0	19	21	15370	13	1972	122	2107	
84120FA	ELECTRICAL SYSTEM 125 MAN TR CP		AS REQUIRED	1.0	19	21	15370	13	1972	122	2107	
84330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	AS REQUIRED	1.0	7	5	145	18	124	133	275	
84330AE	FIREFHQ EQPT POL W/10MGAL WTR&PUMP		AS REQUIRED	1.0	1	5	16777	39	39		39	
85110DE	HARDSTAND/STAB SURF, 1000SQ YD, 4 IN		AS REQUIRED	36.0	1512	1008	7560	994		331	1325	
187190AA	SITE PREPARATION, ONE ACRE		AS REQUIRED	8.3					840	305	1145	
87210AA	FENCE, CHAIN LK. W/2 OUTGRRS 1 1000LF		AS REQUIRED	2.5	43	128	30185	359		1150	1509	
87210AF	GATE, CHAINLINK SING/LEAF 3 WI 10 HI		AS REQUIRED	1.0	1	2	279	7		14	21	
87210AL	GATE, VEH CHAINLINK 10 FT HI 32 F WI		AS REQUIRED	1.0	1	2	401	8		17	25	
				2632	1992	352573	3522	18088	9163	30773		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 200000 BBL CAPAC W/50M WLDD TNKS, 10M&3M BLTD. TANKS FOR EXISTG DOCK FOR TNKR DISCHARGE, TEMP, TROP& DST CLIM. T-2 TNKR OR SUPER TANKER DISCHARGING W/ 24HR TURN AROUND TIME. MARINE TERMINAL W/ESTG DOCK MOORING BERTH, 12IN INLAND PPELN, BOOSTER PMP STA & OPER BLDG., TANK FARM FOR BULK STAGE OF 4 PRODUCTS FOR RECEIVING 800000 BBL/S/ MO. MAX REQUIRES 60 ACRES. FINE AGGR. 20CY. COARSE AGGR. 22

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED		MATERIALS		CONSTR EFFORT IN MANHOURS			
				WT-ST.	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/TNK. FARM NO PMP	12-INCH	AS REQUIRED	1.0	26	23	97212	35	276	92	603
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	1.0	14	21	50497	23	614	115	552
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	4.0	28	56	65016	23	184	69	276
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	1.0	18	21	78664	52	397	81	530
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	1.0	9	32	4440	17	224	81	322
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	4.0	180	708	95916	184	4370	1932	6486
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	4.0	16	16	44460	66	1058	736	1840
12530AG	BOOSTER STATION PCL 7000 BPH	7000 BPH	AS REQUIRED	4.0	108	224	216436	184	1288	368	1840
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	2.0	2	2	2736	12	81	46	139
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR	4-UNIT	AS REQUIRED	4.0	4	4	4984	37	239	92	368
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	1.0	32	49	221603	759	184	963	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	3.0	15	30	15606	86	345	155	586
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	3.0	6	96	36132	311	1070	759	2140
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	4.0	12	164	113536	667	3910	2001	6578
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	3.0	12	579	182766	1035	15318	6900	23253
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	2.0	14	30	23462	74	1051	391	1516
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404

529 2104 1269004 3117 32649 15292 51058

DDEXER4

RUN DATE 860207

DESERT CLIMATE

PA1025

MARINE TERMINAL, POL, 4000000 BBL CAPAC. USED FOR PHASE1. WLDD & MLTD. TNKR FOR EXBIG DOCK FOR TNKR DISCHARGE, TEMP, TROP & DST
 CLIM.T-2 TNKR OR SUPER TANKER DISCHARGING W/13
 HR TURN AROUND TIME. MARINE TERMINAL W/EXSTG DOCK, MOORING
 BERTH, 12IN INLAND PPLN, BOOSTER PMP STA & OPER BLDG., TANK
 FARM FOR BULK SIZE OF 4 PRODUCTS. FOR RECEIVING 1500000 BBLS/
 MO. MAX REQUIRES 121 ACRES. FINE AGGR. 40CY. COARSE AGGR. 44

FAC NUMBER,	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
1251QAD	12IN SWITCH MNFLD F/JNK FARM NO PMP	12-INCH	AS REQUIRED	3.0	78	69	291636	104	828	276	1208
1251OAG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1104
1251OAK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	8.0	56	112	130032	66	368	138	552
1251OAR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	2.0	36	42	157328	104	794	161	1059
1251OAM	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	2.0	18	64	8880	35	449	161	645
1251OBC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	8.0	360	1416	191832	368	8740	3864	12972
1251OBL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	8.0	32	32	88920	92	2116	1472	3680
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	8.0	216	448	432872	368	2576	736	3680
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	2-UNIT	AS REQUIRED	4.0	4	4	5472	23	161	92	276
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT	4-UNIT	AS REQUIRED	4.0	4	4	4984	37	239	92	368
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	1.0	32	49	221603	759	184	943	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219
41180AH	TANK, POL, 3000 BARREL, W/5 IN PIPE	3000 BBL	AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	8.0	24	328	227072	1334	7820	4002	13156
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	6.0	24	1158	365532	2070	30636	13800	46506
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	4.0	28	60	46924	147	2102	782	3031
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	8.0	56	64	11232	442	2042	2061	4545
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810
				1040	4172	2411113	6277	64759	30469	101505	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 400000 BBL CAPAC. USED FOR PHASE-2. WLDD & BLTD TNKS FOR EXISTS DOCK TANKER DISCHARGE, TEMP, TROP & DST CLIM. T-2 TNKR OR SUPER TANKER DISCHARGING W/13HR TURN AROUND TIME. MARINE TERMINAL W/EXESTS DOCK MOORING BERTH, 12IN INLAND PPELN, BOOSTER PMP STA & OPER BLDG., TANK FARM FOR BULK SIZG OF 4 PRODUCTS FOR RECEIVING 1500000 BBLS/MO. MAX REQUIRES 121 ACRES. FINE AGGR. 40CY. COARSE AGG

PA1035

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS REQUIRED WT-ST VOL-MT	COST	CONSTR EFFORT IN MANHOURS			
				WT	ST			HORZ	VERT	GENL	TOT
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP.	12-INCH	AS REQUIRED	3.0	78	69	291636	104	828	276	1208
12510AG	FLOOD PMP 1355BPH	12 IN MANIFOLD	1355 BPH	2.0	28	42	100994	46	828	230	1104
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	8.0	56	112	130032	46	368	138	552
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	2.0	36	42	157328	104	794	161	1059
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	2.0	18	64	8880	35	449	161	665
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	16.0	720	2832	383664	736	17480	7728	25944
12510BL	PPLN POL 1M FT OF 12. IN API GROVE	1000 FT	AS REQUIRED	8.0	32	32	88920	92	2116	1472	3680
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	16.0	432	896	865744	736	5152	1472	7360
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	4.0	4	4	5472	23	161	92	276
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	16.0	16	16	19936	147	957	368	1472
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	2.0	64	98	443206		1518	368	1886
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	8.0	24	328	227072	1334	7820	4002	13156
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	6.0	24	1158	365532	2070	30636	13800	46506
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	4.0	28	60	46924	147	2102	782	3031
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	8.0	56	64	11232	442	2042	2061	4545
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810
				1660	6097	3272372	7123	77552	35529	120204	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 200000 BBL CAPAC W/10 THOUS. & 3 THOUS.
 BOLTED STL FOR EXISTG DOCK FOR TANKER DISCHARGE, TEMP, TROP&
 DST CLIM, T-2 TANKER OR SUPER TANKER DISCHARGING W/24HR
TURN AROUND TIME, MARINE TERMINAL W/EXSTS DOCK MOORING BERTH,
 12IN INLAND PPELN, BOOSTER PMP STA & OPER BLDG., TANK FARM
 FOR BULK STGE OF 4 PRODUCTS FOR RECEIVING 80000 BBLS/MO. MAX
 REQUIRES 60 ACRES. FINE AGGR. 20CY. COARSE AGGR. 22CY. FIRFT

PA1043

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/INK FARM NO PMP	12-INCH	AS REQUIRED	1.0	26	23	97212	35	276	92	403	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1104	
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	4.0	28	56	63016	23	184	69	276	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	1.0	18	21	78664	52	397	81	530	
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	1.0	9	32	4440	17	224	81	322	
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	4.0	180	708	95916	184	4370	1932	6486	
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	.2	3	3	700	2	46	32	80	
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	6.0	24	24	66690	69	1587	1104	2760	
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	4.0	108	224	216436	184	1288	368	1840	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	2.0	2	2	2736	12	81	46	139	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR	4-UNIT	AS REQUIRED	4.0	4	4	4984	37	239	92	368	
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800SPH	AS REQUIRED	1.0	32	49	221603	759	184	943		
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	3.0	15	30	15606	86	365	155	586	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	614	1426	1012	2852	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	19.0	57	779	539296	3168	18573	9505	31246	
161050BF	HQTRS. & UNIT SUPPLY&GQ STL FR	20X40X8FT	AS REQUIRED	2.0	14	30	23462	74	1051	391	1516	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	5.0	35	40	7020	276	1277	1288	2841	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404	

596 2212 1598873 4789 33595 16922 55306

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 400000 BBL CAPAC W/10 THOUSAND. & 3 THOU
 BOLTED STEEL FOR EXISTING DOCK FOR TANKER DISCHARGE, TEMPER-
 ATE, TROPICAL AND DESERT CLIMATE. T-2 TANKER OR SUPER TANKER
 DISCHARGING, MARINE TERMINAL W/EXISTING DOCK MOORING BERTH
 12IN INLAND PPELN, BOOSTER PMP STA & OPER BLDG., TANK FARM
 FOR BULK STGE OF 4 PRODUCTS FOR RECEIVING 1500000 BBLs/MO.
 MAX REQUIRES 121 ACRES. FINE AGGR. 40CY. COARSE AGGR. 44CY.

PA1055

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS			CONSTR EFFORT			IN MANHOURS	
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL		
12510AD	12IN SWITCH MNFLD. F/TNK FARM NO PMP	12-INCH	AS REQUIRED	3.0	78	69	291636	104	828	276	1208	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	4.0	56	84	201988	92	1656	460	2208	
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	8.0	56	112	130032	46	368	138	552	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	2.0	36	42	157328	104	794	161	1059	
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	2.0	18	64	8880	35	449	161	645	
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	2.0	90	354	47958	92	2185	966	3243	
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	8.0	104	128	28000	92	1840	1288	3220	
12510BL	PPLN POL 1M FT OF 12 IN API GROOVE	1000 FT	AS REQUIRED	.4	2	2	4446	5	106	74	185	
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	16.0	432	896	865764	736	5152	1472	7360	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	4.0	4	4	5472	23	161	92	276	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR	4-UNIT	AS REQUIRED	8.0	8	8	9968	74	478	184	736	
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	2.0	64	98	443206		1518	368	1886	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	186	736	299	1219	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	8.0	16	256	96352	828	2852	2024	5704	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	38.0	114	1558	1078592	6337	37145	19010	62492	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	4.0	28	60	46924	147	2102	782	3031	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	10.0	70	80	14040	552	2553	2576	5681	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810	
				1208	3903	3484102	9707	62349	30932	102988		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 1000000 BBL CAPAC. USED FOR PHASE 1. WLDG & BLTD TNKS FOR EXISTG DOCK FOR TANKER DISCHARGE. TEMP, TROP & DST CLIM. T-2 TANKER OR SUPER TANKER DISCHARGING W/13 HR TURN AROUND TIME. MARINE TERMINAL W/EXSTG DOCK MOORING BERTH 12IN INLAND PPELN, BOOSTER PMP STA & OPER. BLDG., TANK FARM FOR BULK STGE OF 4 PRODUCTS FOR RECEIVING 3000000 BBLS/MO. MAX REQUIRES 307 ACRES. FINE AGGR. BOCY. COARSE AGGR. 88 CY.

PA1065

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS	
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL		TOT
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP	12-INCH	AS REQUIRED	5.0	130	115	686060	173	1380	460	2013
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	112	168	403976	184	3312	920	4416
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	16.0	112	224	260064	92	736	276	1104
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	4.0	72	84	314656	207	1587	322	2116
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	4.0	36	128	17760	69	897	322	1288
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	16.0	720	2832	383664	736	17480	7728	25944
12510BL	PPLN POL 1M FT OF 12 IN API GROOVE	1000 FT	AS REQUIRED	24.0	96	96	266760	276	6368	4416	11040
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	16.0	432	896	865744	736	5152	1472	7360
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	8.0	8	8	10944	46	322	184	552
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	16.0	16	16	19936	147	957	368	1472
12665AU	PIPE POL 12IN F/SUPER TNKR AT RQCK	12IN 2800BPH	AS REQUIRED	1.0	32	69	221603	759	184	963	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	20.0	60	820	567680	3335	19550	10005	32890
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	16.0	64	3088	974752	5520	81696	36800	124016
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	8.0	56	120	93848	294	4204	1564	6062
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	15.0	105	120	21060	828	3830	3864	8522
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620

2123 8946 5013092 13477 152350 70616 236443

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 1000000 BBL CAPAC USED FOR PHASE2. WLDD & BLTD TNKS FOR EXISTG DOCK FOR TANKER DISCHARGE, TEMP, TROP & DST CLIM. T-2 TANKER OR SUPER TANKER DISCHARGING W/13 HR TURN AROUND TIME. MARINE TERMINAL W/EXSTS DOCK MOORING BERTH 12IN INLAND PPELN, BOOSTER PMP STA & OPER BLDG., TANK FARM FOR BULK, STGE OF 6 PRODUCTS FOR RECEIVING 3000000 BBLs/MO. MAX REQUIRES 307 ACRES. FINE AGGR. BOCY. COARSE AGGR. 88 CY.

PA1075

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH	AS REQUIRED		5.0	130	115	486060	173	1380	460	2013	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	112	168	403976	184	3312	920	4416	
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	16.0	112	224	260064	92	736	276	1104	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	4.0	72	84	314656	207	1587	322	2116	
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	4.0	36	128	17760	69	897	322	1288	
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	32.0	1440	5664	767328	1472	34960	15456	51888	
12510BL	PPLN POL 1M FT OF 12 IN API GROOVE	1000 FT	AS REQUIRED	24.0	96	96	266760	276	6368	4416	11040	
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	32.0	864	1792	1731488	1472	10304	2944	14720	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	2-UNIT	AS REQUIRED	8.0	8	8	10944	46	322	184	552	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT	4-UNIT	AS REQUIRED	32.0	32	32	39872	294	1914	736	2944	
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	2.0	64	98	443206		1518	368	1886	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	416	173	691	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	20.0	60	820	567680	3335	19550	10005	32890	
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	16.0	64	3088	974752	5520	81696	36800	124016	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	8.0	56	120	93848	294	4204	1564	6062	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	15.0	105	120	21060	828	3830	3864	8522	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620	
				3323	12739	6504046	15096	176698	80368	272162		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 1000000 BBL CAPAC WITH 10M BOLTED STEEL
 TNKS FOR EXISTS DOCK FOR TANKER DISCHARGE, TEMP, TROP& DST
 DST CLIM. T-2 TANKER OR SUPER TANKER DISCHARGING W/13 HR
 TURN AROUND TIME. MARINE TERMINAL W/EXSTG DOCK MOORING BERTH
 12IN INLAND PPELN, BOOSTER PMP STA & OPER.BLDG., TANK FARM FOR
 BULK STGE OF 4 PRODUCTS FOR RECEIVING 3000000 BBLs/MO-MAX.
 REQUIRES 307 ACRES. FINE AGGR. 70CY. COARSE AGGR. 77CY. FIRE

PA1085

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MI	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP. 12-INCH		AS REQUIRED	5.0	130	115	486060	173	1380	460	2013	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	112	168	403976	184	3312	920	4416	
12510AK	TANK PMP. POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	2.0	16	28	32508	12	92	35	139	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	4.0	72	84	314656	207	1587	322	2116	
12510AW	PPLN. POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	8.0	72	256	35520	138	1794	644	2576	
12510BC	PPLN. POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	24.0	1080	4248	575496	1104	26220	11592	38916	
12510BK	PPLN. POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	1.2	16	19	6200	16	276	193	485	
12510BL	PPLN. POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	28.0	112	112	311220	322	7406	5152	12880	
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	32.0	864	1792	1731688	1472	10304	2944	16720	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	8.0	8	8	10944	46	322	184	552	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	32.0	32	32	39872	294	1914	736	2944	
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	2.0	64	98	443206		1518	368	1886	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	16.0	32	512	192704	1656	5704	4048	11408	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	96.0	288	3936	2724864	16008	93840	48024	157872	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	7.0	49	105	82117	258	3679	1369	5306	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	20.0	140	160	28080	1104	5106	5152	11362	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620	
				3157	11855	7521503	23826	168594	83874	276294		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERM POL 200000 BBL CAPAC W/50M WLDD TANKS, 10M & 3M
 BLTD STL TANKS W/JETTY FOR TANKER FOR TANKER DISCHARGE. TEMP
 TROP & DST CLIM. T-2 TANKER DISCHARGING W/24 HR TURN AROUND.
 TIME. MARINE TERM W/JETTY MOORING BERTH, 12IN INLD PPLN,
 BOOSTER PMP STA & OPER BLDG. TANK FARM FOR BLK STGE OF
 4 PROD FOR RECEIVG 800000 BBL/MO MAX. REQUIRES 60 ACRES
 FINE AGGR. 20CY, COARSE AGGR. 22CY. FIREFTG EQUIP. HAND EXTG

PA1095

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS		CONSTR EFFORT			IN MANHOURS	
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AD	12IN SWITCH MNFLD. F/TNK EARM NO PMP 12-INCH		AS REQUIRED	1.0	26	23	97212	35	276	92	403
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	1.0	14	21	50497	23	414	115	552
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	4.0	28	56	65016	23	184	69	276
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	1.0	18	21	78664	52	397	81	530
12510AW	PPLN PQL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	1.0	9	32	4440	17	224	81	322
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	4.0	180	708	95916	184	4370	1932	6486
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	4.0	16	16	44460	66	1058	736	1860
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	4.0	108	224	216436	184	1288	368	1840
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	4.0	4	4	4984	37	239	92	368
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	1.0	32	49	221603		759	184	943
16440AA	JETTY POL 14FT X 1M FT WALK&PIPEWAY	1000&40X70FT	AS REQUIRED	1.0	695	718	278329	4945	8050	219	13214
16440AB	HOSE DERRICK PARTS FOR POL WHARFS.		AS REQUIRED	1.0	2	1	2709		104	104	208
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	5.0	25	50	26010	144	575	259	978
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	3.0	6	96	36132	311	1070	759	2140
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	4.0	12	164	113536	667	3910	2001	6578
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	3.0	12	579	182766	1035	15318	6900	23253
161050BF	HQTRS & UNIT SUPPLY&GO STL FR.	20X40X8FT	AS REQUIRED	2.0	14	30	23462	74	1051	391	1516
84290AA	TANKER WATERING SERVICE FACILITIES,	1000 BBL	AS REQUIRED	1.0	8	28	18849		920	150	1070
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
					1244	2871	1579295	8120	41953	15869	65942

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERM, POL, 4000000 BBL CAPAC W/50M WLDD TANKS, 10M & 3M
 BLTD STL TANKS W/JETTY FOR TANKER FOR TANKER DISCHARGE. TEMP
 TROP & DST CLIM. T-2 TANKER DISCHARGING W/13 HR TURN AROUND
 TIME. MARINE TERM W/JETTY MOORING BERTH, 12IN INLD PPLN,
 BOOSTER PMP STA & OPER BLDG. TANK FARM FOR BLK STGE OF 4
 PROD FOR RECEIVG 1500000 BALS/MO. MAX. REQUIRES 121 ACRES
 FINE AGGR. 40CY, COARSE AGGR. 44CY. FIREFTG EQUIP. HAND EXTG

PA1105

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP	12-INCH	AS REQUIRED	3.0	78	62	291634	104	628	276	1208	
12510AG	FLOOD PMP 1355BPH 12 IN MNFLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1104	
12510AK	TANK PMP POL 2800 BPH W/12IN MNFLD	2800 BPH	AS REQUIRED	6.0	16	112	130032	46	368	138	552	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFLD	2800 BPH	AS REQUIRED	2.0	36	42	157328	104	794	161	1059	
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	8.0	72	256	35520	138	1794	644	2576	
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	12.0	540	2124	287748	552	13110	5796	19458	
12510BL	PPLN POL 1M FT OF 12 IN API GROOVE	1000 FT	AS REQUIRED	2.0	8	8	22230	23	529	368	920	
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	8.0	216	448	432872	368	2576	736	3680	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	4.0	4	4	5472	21	161	92	27.6	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR	4-UNIT	AS REQUIRED	12.0	12	12	14952	110	718	276	1104	
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	1.0	32	49	221603		759	184	943	
16440AA	JETTY POL 14FT X 1M FT WALK&PIPEWAY	1000&40X70FT	AS REQUIRED	1.0	695	718	278329	4945	8050	219	13214	
16440AB	HOSE DERRICK PARTS FOR POL WHARFS.		AS REQUIRED	1.0	2	1	2709		104	104	208	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	106	414	173	691	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	8.0	24	328	227072	1334	7820	4002	13156	
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	6.0	24	1158	365532	2070	30636	13800	46506	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	4.0	28	60	46924	147	2102	782	3031	
84290AA	TANKER WATERING SERVICE FACILITIES,	1000 BBL	AS REQUIRED	1.0	8	28	18849		920	150	1070	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	8.0	56	64	11232	442	2042	2061	4545	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810	
				1963	5803	2776834	11513	78440	32437	122390		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERM, POL, 4000000 BBL CAPAC W/50M WLDD TANKS, 10M & 3M
BLTD STL TANKS, W/JETTY FOR TANKER FOR TANKER DISCHARGE. TEMP.
 TROP & DST CLIM. T-2 TANKER DISCHARGING W/13 HR TURN AROUND
 TIME, MARINE TERM W/JETTY MOORING BERTH, 12IN INLD PPLN,
 BOOSTER PMP STA & OPER BLDG. TANK FARM FOR BLK STGE OF 4
 PROD FOR RECEIVG. 1500000 BBL/MSQ MAX. REQUIRES. 121 ACRES
 FINE AGGR. 40CY, COARSE AGGR. 44CY. FIREFTG EQUIP. HAND EXTG

PA1115

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS			CONSTR EFFORT			IN MANHOURS	
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	3.0	78	69	291636	104	828	276	1208	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1104	
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD 2800 BPH		AS REQUIRED	8.0	56	112	130032	46	368	138	552	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD 2800 BPH		AS REQUIRED	2.0	36	42	157328	104	794	161	1059	
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	8.0	72	256	35520	138	1794	644	2576	
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	20.0	900	3540	479580	920	21850	9660	32430	
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	2.0	8	8	22230	23	529	368	920	
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	16.0	432	896	865744	736	5152	1472	7360	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	4.0	4	4	5472	23	161	92	276	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	20.0	20	20	24920	184	1196	460	1840	
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	2.0	64	98	443206	1518	368	1886		
16440AA	JETTY POL 14FT X 1M FT WALK&PIPEWAY	1000&40X70FT	AS REQUIRED	1.0	695	718	278329	4945	8050	219	13214	
16440AB	HOSE DERRICK PARTS FOR POL WHARFS.		AS REQUIRED	1.0	2	1	2709	104	104	104	208	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	8.0	24	328	227072	1334	7820	4002	13156	
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	6.0	24	1158	365532	2070	30636	13800	46506	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	4.0	28	60	46924	147	2102	782	3031	
84290AA	TANKER WATERING SERVICE FACILITIES,	1000 BBL	AS REQUIRED	1.0	8	28	18849	920	150	1070		
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	8.0	56	64	11232	442	2042	2061	4545	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810	
					2579	7724	3633109	12323	90993	37605	140721	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERM, POL, 1000000 BBL CAPAC W/50M WLDD TANKS, 10M & 3M
BLTD STL TANKS W/JETTY FOR TANKER FOR TANKER DISCHARGE. TEMP.
TROP & DST CLIM. T-2 TANKER DISCHARGING W/13 HR TURN AROUND
TIME. MARINE TERM W/JETTY MOORING BERTH, 12IN INLD. PPLN.
BOOSTER PMP STA & OPER BLDG. TANK FARM FOR BLK STGE OF 4 PROD
FOR RECEIVNG 3000000 BBL/S/MO. MAX. REQUIRES 307 ACRES
FINE AGGR. 80CY, COARSE AGGR. 88CY. FIREFTG EQUIP. HAND EXTG

PA1125

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	5.0	130	115	486060	173	1380	460	2013
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	112	168	403976	184	3312	920	4616
12510AK	TANK PMP PQL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	16.0	112	224	260064	92	736	276	1104
12510AR	TRANS PMP PQL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	4.0	72	84	314656	207	1587	322	2116
12510AW	PPLN PQL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	4.0	36	128	17760	69	897	322	1288
12510BC	PPLN PQL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	16.0	720	2832	383664	736	17480	7728	25944
12510BL	PPLN PQL 1M FT OF 12 IN API GROOVE	1000 FT	AS REQUIRED	24.0	96	96	266760	276	6368	6416	11040
12530AG	BOOSTER STATION PQL 7000 BPH	7000 BPH	AS REQUIRED	16.0	432	896	865744	736	5152	1472	7360
12530AK	PUMP STATION FUEL SUPPLY, PQL, FOR 2-UNIT		AS REQUIRED	8.0	8	8	10944	46	322	184	552
12530AL	PUMP STATION FUEL SUPPLY, PQL, FOR 4-UNIT		AS REQUIRED	16.0	16	16	19936	147	957	368	1472
12665AU	PIPE PQL 12IN F/SUPER JNKR AT DOCK	12IN 2900BPH	AS REQUIRED	1.0	32	49	221603		759	184	943
16440AA	JETTY PQL 14FT X 1M FT WALK&PIPEWAY	1000X40X70FT	AS REQUIRED	1.0	695	718	278329	4945	8050	219	13214
16440AB	HOSE DERRICK PARTS FOR PQL WHARFS.		AS REQUIRED	1.0	2	1	2709		104	104	208
41180AB	TANK, PQL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956
41180AC	TANK, PQL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691
41180AE	TANK PQL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438
41180AL	TANK PQL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	20.0	60	820	567680	3335	19550	10005	32890
41180AN	TANK PQL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	1.6	6	309	97475	552	8170	3680	12402
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	8.0	56	120	93848	294	4204	1564	6062
84290AA	TANKER WATERING SERVICE FACILITIES,	1000 BBL	AS REQUIRED	1.0	8	28	18849		920	150	1070
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	15.0	105	120	21060	828	3830	3864	8522
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620
				2770	6914	4435709	13454	87898	37969	139321	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERM, POL, 1000000 BBL CAPAC W/50M WLDD TANKS, 10M & 3M
 BLTD STL TANKS W/JETTY FOR TANKER FOR TANKER DISCHARGE, TEMP,
 TROP & DST CLIM. T-2 TANKER DISCHARGING W/13 HR TURN AROUND
 AROUND TIME. MARINE TERM W/JETTY MOORING BERTH, 12IN INLD
 PPLN, BOOSTER PMP STA & OPER BLDG. TANK FARM FOR BLK STGE OF
 4 PROD FOR RECEIVG 3000000 BBL/MO. MAX. REQUIRES 307 ACRES
 FINE AGGR. 80CY, COARSE AGGR. 88CY. FIREFTG EQUIP. HAND EXTG

PA1135

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	5.0	130	115	686060	173	1380	660	2013
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	112	168	403976	184	3312	920	4416
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	16.0	112	224	260064	92	736	276	1104
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	4.0	72	84	314656	207	1587	322	2116
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	4.0	36	128	17760	69	897	322	1288
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	32.0	1440	5664	767328	1472	34960	15456	51888
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	24.0	96	96	266760	276	6368	4416	11040
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	32.0	864	1792	1731488	1472	10304	2944	14720
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	8.0	8	8	10944	46	322	184	552
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	32.0	32	32	39872	294	1914	736	2944
12665AU	PIPE POL 12IN F/SUPER TNKR AT DOCK	12IN 2800BPH	AS REQUIRED	2.0	64	98	443206		1518	368	1886
16440AA	JETTY POL 14FT X 1M FT WALK&PIPEWAY	1000&40X70FT	AS REQUIRED	1.0	695	718	278329	4945	8050	219	13214
16440AB	HOSE DERRICK PARTS FOR POL WHARFS.		AS REQUIRED	1.0	2	1	2709		104	104	208
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	20.0	60	820	567680	3335	19550	10005	32890
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	16.0	64	3088	974752	5520	81696	36800	124016
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	8.0	56	120	93848	294	4204	1564	6062
84290AA	TANKER WATERING SERVICE FACILITIES,	1000 BBL	AS REQUIRED	1.0	8	28	18849		920	150	1070
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	15.0	105	120	21060	828	3830	3864	8522
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620
				4028	13486	6803933	20041	185772	80841	286654	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 200000 BARREL CAPAC W/50M WLDD TNKS, 10M
AND 3M BLTD TANKS W/12 SUBM PPLN. TEMP, TROP. & DST CLIMATE.
T-2 TANKER DISCHARGING W/24HR TURN AROUND TIME. MARINE TERM
W/5-LEG MOORING BERTH, 12IN SUBMARINE PPLN, 12IN INLAND PPLN.
BOOSTER PMP STA & OPER BLDG. TANK FARM COMPLEX FOR STGE OF
4 PROD. FOR RECEIVG 800000 BBLS/MO MAX. REQUIRES 60 ACRES.
FINE AGGR. 20CY. COARSE AGGR. 22CY. FIREFTG EQUIP. HAND EXT.

PA1145

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS	
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL		TOT
12510AD	12IN SWITCH MNFD. FA/TNK FARM NO PMP	12-INCH	AS REQUIRED	1.0	26	23	97212	35	276	92	403
12510AG	FLOOD PMP 1355BPH	12 IN MANIFOLD	1355 BPH	AS REQUIRED	1.0	14	21	50497	23	614	115
12510AK	TANK PMP POL 2800 BPH	W/12IN MANIFO	2800 BPH	AS REQUIRED	4.0	28	56	65016	23	186	69
12510AR	TRANS PMP POL 2800 BPH	W/12 IN MNFD	2800 BPH	AS REQUIRED	1.0	18	21	78664	52	397	81
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	1.0	9	32	4460	17	224	81	322
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	4.0	180	708	95916	184	4370	1932	6486
12510BL	PPLN POL 1M FT OF 12 IN API GROOVE	1000 FT	AS REQUIRED	4.0	16	16	44660	46	1058	736	1840
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	4.0	108	226	216636	184	1288	368	1840
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	4.0	4	4	4984	37	239	92	368
12590AT	PPLN SUBMAR 12IN POL 60FT DEP 1 MI	5300FT-12IN	AS REQUIRED	1.0	272	322	96144	2070	2563	943	5578
16390AD	TNKR MOORING POL SLEGS-60 FT DEPTH	SLEG 60FT DP	AS REQUIRED	1.0	98	254	169468	690	771	460	1921
41180AD	TANK, POL, 250 BARREL W/4 IN PIPE	250 BBL	AS REQUIRED	3.0	15	30	15606	86	345	155	586
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL W/8 IN PIPE	3000 BBL	AS REQUIRED	3.0	6	96	36132	311	1070	759	2140
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	4.0	12	164	113536	667	3910	2001	6578
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	3.0	12	579	182766	1035	15318	6900	23253
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	2.0	14	30	23462	74	1051	391	1516
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
				868	2629	1312681	5868	35088	16456	57412	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 400000 BARREL CAPAC W/50M WLDD TNKS, 10M
AND 3M BLTD TANKS W/12 SUBM PPLN, TEMP, TROP & DST CLIMATE.
T-2 OR SUPER TNK DISCHG W/13HR TURN AROUND TIME. MARINE TERM
W/7-LEG MOORING BERTH, 12IN SUBMARINE PPLN, 12IN INLAND
PPLN, BOOSTER PMP STA & OPER BLDG. TANK FARM COMPLEX FOR STGE
OF 4 PROD. FOR RECEIVG 1500000 BBLs/MO. MAX. REQUIRES 121 ACRE
FINE AGGR. 40CY. COARSE AGGR. 44CY. FIREFTG EQUIP. HAND EXT.

PA1155

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/INK FARM NO PMP 12-INCH		AS REQUIRED	3.0	78	69	291636	104	828	276	1208	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1104	
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	8.0	56	112	130032	46	368	138	552	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	2.0	36	42	157328	104	794	161	1059	
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	2.0	18	64	8880	35	449	161	645	
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	4.0	180	708	95916	184	4370	1932	6486	
12510BL	PPLN PQL 1M FT OF 12 IN API GROOVE	1000 FT	AS REQUIRED	8.0	32	32	88920	92	2116	1472	3680	
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	8.0	216	448	432872	368	2576	736	3680	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	4.0	6	4	5472	23	161	92	276	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	8.0	8	8	9968	74	478	184	736	
12590AT	PPLN SUBMAR 12IN POL 60FT DEP 1 MI	5300FT-12IN	AS REQUIRED	1.0	275	322	96144	2070	2565	943	5578	
16390AG	TNKR MOORING POL 7LEGS-60 FT DEPTH	7LEG 60FT DP	AS REQUIRED	1.0	136	351	235507	966	1035	644	2665	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	8.0	24	328	227072	1334	7820	4002	13156	
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	6.0	24	1158	365532	2070	30636	13800	46506	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	4.0	28	60	46924	147	2102	782	3031	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	8.0	56	64	11232	442	2042	2061	4545	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810	
				1243	6092	2430229	9166	63469	30032	102667		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 40000 BARREL CAPAC W/50M WLDD TNKS, 10M AND 3M BLTD TANKS W/12 SUBM PPLN. TEMP, TROP & DST CLIMATE. T-2 OR SUPER TNK DISCHG W/13HR TURN AROUND TIME. MARINE TERM W/7-LEG MOORING BERTH. 12IN SUBMARINE PPLN, 12IN INLAND PPLN, BOOSTER PMP STA & OPER BLDG. TANK FARM COMPLEX FOR STGE OF 4 PROD. FOR RECEIVING 15000000 BBLs/MO. MAX. REQUIRES 121 ACRES. FINE AGGR. 40CY. COARSE AGGR. 44CY. FIREFTG EQUIP.

PA1165

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS		
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT		
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP	12-INCH	AS REQUIRED	3.0	78	69	291636	104	828	276	1208	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1104	
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	8.0	56	112	130032	46	368	138	552	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	2.0	36	42	157328	104	794	161	1059	
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	2.0	18	64	8880	35	449	161	645	
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	12.0	540	2124	287748	552	13110	5796	19458	
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	8.0	32	32	88920	92	2116	1472	3680	
12530AG	BOOSTER STATION PCL 7000 BPH	7000 BPH	AS REQUIRED	12.0	324	672	649308	552	3864	1106	5520	
12530AH	LOADING PMP FOR 2TNK/TRK/SCAR INSTL	700X1400 BPH	AS REQUIRED	3.0	24	75	55329	35	293	86	414	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	4.0	4	4	5472	23	161	92	276	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	12.0	12	12	14952	110	718	276	1104	
12590AT	PPLN SUBMAR 12IN POL 60FT DEP 1 MI	5300FT-12IN	AS REQUIRED	2.0	550	644	192288	4140	5129	1886	11155	
16390AG	TNKR MOORING POL 7LEGS-60 FT DEPTH	7LEG-60FT DP	AS REQUIRED	1.0	136	351	235507	966	1035	644	2645	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219	
41180AH	TANK, POL, 3000 BARREL, W/3 IN PIPE	3000 BBL	AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	8.0	24	328	227072	1334	7820	4002	13156	
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	6.0	24	1158	365532	2070	30636	13800	46506	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	4.0	28	60	46924	147	2102	782	3031	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	8.0	96	64	11232	442	2042	2061	4545	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810	

2014 6133 2994954 11859 76594 35385 123838

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 1000000 BARREL CAPAC W/50M WLDD TNKS,
 10M & 3M BLTD TANKS W/12 SUBM PPLN, TEMP, TROP & DST CLIMATE.
 T-2 OR SUPER TANKER DISCHARGING W/13 HR TURN AROUND TIME.
 MARINE TERM, W/7-LEG MOORING BERTH, 12IN SUBMARINE PPLN, 12IN
 INLAND PPLN, BOOSTER PMP STA & OPER BLDG, TANK FARM COMPLEX
 FOR STGE OF 4 PROD. FOR RECEIVG 3000000 BBLs/MO. MAX. REQUIRE
 307 ACRES. FINE AGGR. 80CY. COARSE AGGR. 88CY. FIREFTG EQUIP

PA1175

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS			CONSTR EFFORT IN MANHOURS			
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	5.0	130	115	486060	173	1380	660	2013
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	112	168	403976	184	3312	920	4416
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	16.0	112	224	260064	92	736	276	1104
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	4.0	72	84	314656	207	1587	322	2116
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	4.0	36	128	17760	69	897	322	1288
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	16.0	720	2832	383664	736	17480	7728	25944
12510BL	PPLN POL 1M. FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	24.0	96	96	266760	276	6368	4416	11040
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	16.0	432	896	865744	736	5152	1472	7360
12530AH	LOADING PMP FOR 2TNK/TRK/SCAR INSTL	7000X1400 BPH	AS REQUIRED	5.0	60	125	92215	58	689	144	691
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	12.0	12	12	14952	110	718	276	1104
12590AT	PPLN SUBMAR 12IN POL 60FT DEP 1 MI	5300FT-12IN	AS REQUIRED	1.0	275	322	96144	2070	2565	943	5578
16390AG	TNKR MOORING POL 7LEGS-60 FT DEPTH	7LEG 60FT DP	AS REQUIRED	1.0	136	351	235507	966	1035	644	2645
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	2.0	2	14	12884	104	414	173	691
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	20.0	60	820	567680	3335	19550	10005	32890
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	16.0	64	3088	974752	5520	81696	36800	124016
161050BF	HQTRS & UNIT SUPPLY&60 STL FR	20X40X8FT	AS REQUIRED	8.0	56	120	93848	294	4204	1564	6062
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	15.0	103	120	21060	828	3830	3864	8522
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620
				2530	9683	5199434	16488	155119	71887	243494	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

MARINE TERMINAL, POL, 1000000 BARREL CAPAC W/50M WLDD TNKS, 10M
AND 3M BLTD TNKR W/12 SUBM PPLN. TEMP, TROP & DST CLIMATE.
T-2 OR SUPER TNKR DISCH W/13HR TURN AROUND TIME. MARINE TERM
W/7-LEG MOORING BERTH, 12IN SUBMARINE PPLN, 12IN INLAND PPLN.
BOOSTER PMP STA & OPER BLDG. TANK FARM COMPLEX FOR STGE OF
4 PROD. FOR RECEIVING 3000000 BBL/S/HO MAX. REQUIRES . ACRE
8. FINE AGGR. 80CY. COARSE AGGR. 88CY. FIREFTG EQUIP. HAND

PA1185

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS COST	CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST VOL-MT		HORZ	VERT	GENL TOT
12510AD 12IN SWITCH MNFLD F/TNK FARM NO PMP. 12-INCH	AS REQUIRED	.1.0	130	115	486060	173	1380	460	2013
12510AG FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH AS REQUIRED	8.0	112	168	403976	184	3312	920	4416
12510AK TANK PMP POL 2800 BPH W/12IN MANIFD 2800 BPH.	AS REQUIRED	16.0	112	224	260064	92	736	276	1104
12510AR TRANS PMP POL 2800 BPH W/12 IN MNFD 2800 BPH	AS REQUIRED	4.0	72	84	314636	207	1587	322	2116
12510AW PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN AS REQUIRED	4.0	36	128	17760	69	897	322	1288
12510BC PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH AS REQUIRED	32.0	1440	5664	767328	1472	34960	15436	51888
12510BL PPLN POL 1M FT OF 12 IN API GROVE	1000 FT AS REQUIRED	24.0	96	96	266760	276	6368	4616	11040
12530AG BOOSTER STATION POL 7000 BPH	7000 BPH AS REQUIRED	32.0	864	1792	1731488	1472	10304	2944	14720
12530AK PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	AS REQUIRED	8.0	8	8	10946	46	322	184	552
12530AL PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT	AS REQUIRED	12.0	12	12	14952	110	718	276	1104
12590AT PPLN SUBMAR 12IN POL 60FT DEP 1 MI	5300FT-12IN AS REQUIRED	2.0	530	664	192288	4140	5129	1886	11155
16390AG TNKR MOORING POL 7LEGS-60 FT DEPTH	7LEG 60FT DP AS REQUIRED	1.0	136	351	235507	966	1035	644	2645
41180AB TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL AS REQUIRED	10.0	50	100	52020	288	1150	518	1956
41180AC TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL AS REQUIRED	2.0	2	14	12884	104	414	173	691
41180AE TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL AS REQUIRED	4.0	4	52	37032	368	1472	598	2438
41180AL TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL AS REQUIRED	20.0	60	820	567680	3335	19550	10005	32890
41180AN TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL AS REQUIRED	16.0	64	3088	974752	5520	81696	36800	124016
161050BF HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT AS REQUIRED	8.0	56	120	93848	294	4204	1564	6062
87210AR SECURITY FENCE TYPE Y 1000 FEET	1000 FEET AS REQUIRED	15.0	105	120	21060	828	3830	3864	8522
87210AT VEH-MAN GATE FOR SECURITY FENCE	1 AS REQUIRED	8.0	16	16	2656	74	1104	442	1620

3925 13616 6463715 20018 180148 82070 282236

DDEXER4

RUN DATE 860207

DESERT CLIMATE

150000 BBL TNK FARM BULK STGE WITH 8IN PIPE & ACCESSORIES
 TEMPERATE, TROPIC, FRIGID & DESERT. USES 2-50M BBL AND 4-10M
 83-3M BLTD STEEL TANKS W/ 8IN PIPE, FITTINGS, PMP'S MANIFOLDS,
OPERATIONS BLDG. WATER STGE TANK & SECURITY FENCING.
 REQUIRES 26 ACRES. 10CY FINE AGGR. 11CY. COARSE AGGR. HAND
 EXT. ONLY INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1019

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED			MATERIALS WT-ST VOL-MT	COST	CONSTR EFFORT IN MANHOURS		
				WT	ST	VOL			HORZ	VERT	GENL
12510AC	BIN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH		AS REQUIRED	1.0	16	16	19680	12	207	69	288
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	22	40	41254	46	644	184	874
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD 1400 BPH		AS REQUIRED	4.0	16	36	31748	23	161	46	230
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD 1400 BPH		AS REQUIRED	1.0	12	16	16109	40	282	58	380
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE 1000FT-4IN		AS REQUIRED	1.0	6	15	9258	12	127	69	208
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE 1000 FT		AS REQUIRED	3.0	39	48	10500	35	690	483	1208
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	3.0	6	96	36132	311	1070	759	2140
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	4.0	12	160	80460	644	3910	1978	6532
41180AM	TANK POL 50000 BARREL W/8 IN PIPE	50000 BBL	AS REQUIRED	2.0	8	386	105694	690	10189	4600	15479
161050BF	HQTRS & UNIT SUPPLY&60 STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	3.4	24	27	4774	188	868	876	1932
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				180	884	385200	2189	19514	9676	31379	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

200000 BBL TNK FARM BULK STGE WITH BIN PIPE & ACCESSORIES
 TEMPERATE,TROPIC,FRIGID & DESERT. USES 3-50M BBL & 4-10M 83-
 3M BLTD STEEL TANKS W/BIN PIPE,FITTINGS,PMPMS,MANIFOLDS,
 OPERATIONS BLDG. WATER STGE TANK & SECURITY FENCING. REQUIRE
 11 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EXT. ONLY
 INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1029

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED		MATERIALS WT-ST VOL-MT	COST	CONSTR EFFORT		IN MANHOURS	
				HT	ST			HORZ	VERT	GENL	TOT
12510AC	BIN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH		AS REQUIRED	1.0	16	16	19680	12	207	69	288
12510AF	FLOOD PMP 1355BPH BIN MANIFOLD	1355 BPH	AS REQUIRED	2.0	22	40	41254	46	644	184	874
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFLD	1400 BPH	AS REQUIRED	1.0	12	16	16109	40	282	58	380
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	1.0	6	15	9258	12	127	69	208
12510BK	PPLN POL 1M FT OF 8 IN APT GROOVE	1000 FT	AS REQUIRED	4.0	52	64	14000	46	920	644	1610
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	1.0	6	96	36132	311	1070	759	2140
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	4.0	12	160	80460	644	3910	1978	6532
61180AM	TANK POL 50000 BARREL W/8 IN PIPE	50000 BBL	AS REQUIRED	3.0	12	579	158541	1035	15286	6900	23219
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X5FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	3.6	25	29	5056	199	910	927	2045
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				182	1059	410079	2533	24729	12142	39404	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

200000 BBL TNK FARM BULK STGE WITH 12IN PIPE & ACCESSORIES
 TEMPERATE, TROPIC, FRIGID & DESERT. USES 3-50M BBL & 4-10M &
 3-3M BBL STEEL TANKS W/12IN PIPE, FITTINGS, PMP'S, MANIFOLDS,
 OPERATIONS BLDG, WATER STORAGE TANK & SECURITY FENCING.
 REQUIRES 11 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND
 EXL. ONLY INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1039

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS				
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL		
12510AD	12IN SWITCH MNFLD. F/JNK FARM NO PMP	12-INCH	AS REQUIRED	1.0	26	23	97212	35	276	92	403	
12510AG	FLOOD PMP 1355BPH	12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1104
12510AK	TANK PMP POL 2800 BPH	W/12IN MANIFD	2800 BPH	AS REQUIRED	4.0	28	56	65016	23	184	69	276
12510AR	TRANS PMP POL 2800 BPH	W/12 IN MNFD	2800 BPH	AS REQUIRED	1.0	18	21	78664	52	397	81	530
12510AW	PPLN POL 1000 FT DE	12 INCH GROOVE	1000FT-12IN	AS REQUIRED	1.0	9	32	6440	17	224	81	322
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	4.0	16	16	64460	46	1058	736	1840	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	2.0	2	2	2236	12	81	46	139	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	3.0	6	96	36132	311	1070	759	2140	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	4.0	12	164	113536	667	3910	2001	6578	
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	3.0	12	579	182766	1035	15318	6900	23253	
161050BF	MTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	3.6	25	29	5054	199	919	927	2045	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404	
				199	1102	757865	2619	25550	12430	40599		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

250000 BBL TANK FARM BULK STGE WITH 8IN PIPE & ACCESSORIES
 TEMPERATE, TROPIC, FRIGID & DESERT. USES 4-50M BBL & 5-10000
 BBL BLTD STEEL TANKS W / 8IN PIPE, FITTINGS, PMPS MANIFOLDS
 OPERATIONS BLDG, WATER STGE TANK & SECURITY FENCING. REQUIRES
 28 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EXT. ONLY
 INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1049

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MI	COST	HORZ	VERT	GENL	TOT
12510AC	8IN-SWITCH MNFD F/TANK FARM W/O PMP	8-INCH	AS REQUIRED	1.0	16	16	19680	12	207	69	288
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	22	40	41254	46	664	184	874
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	6.0	16	36	31748	23	161	46	230
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	1.0	12	16	16109	40	282	58	380
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	1.0	6	15	9258	12	127	69	208
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	6.0	78	96	21000	69	1380	966	2415
12530AK	PUMP STATION FUEL SUPPLY POL FOR 2-UNIT	AS REQUIRED	2.0	2	2	2736	12	81	46	139	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	5.0	15	200	100575	805	4888	2473	8166
41180AM	TANK POL 50000 BARREL W/8 IN PIPE	50000 BBL	AS REQUIRED	4.0	16	772	211388	1380	20378	9200	30958
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				228	1267	486219	2796	30454	14649	47899	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

250000 BBL TNK FARM BULK STGE WITH 12IN PIPE & ACCESSORIES
 TEMPERATE,TROPIC,FRIGID & DESERT. USES 4-50M BBL & 5-10000
 BBL BLTD STEEL TANKS W/ IN PIPE, FITTINGS, PMP'S MANIFOLDS,
 OPERATIONS BLDG, WATER STGE TANK & SECURITY FENCING.REQUIRE
 28 ACRES, 10CY FINE AGGR. 11CY COARSE AGGR. HAND EXT. ONLY
INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1059

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST VOL-MI	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH	AS REQUIRED	1.0	26	23	97212	35	276	92	403	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	66	828	230	1104
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	4.0	28	56	65016	23	184	69	276
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	1.0	18	21	78664	52	397	81	530
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	1.0	9	32	4440	17	224	81	322
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	6.0	24	24	66690	69	1587	1104	2760
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	5.0	15	205	141920	834	4888	2501	8223
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	4.0	16	772	243688	1380	20424	9200	31004
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				211	1251	833831	2865	31195	14942	49002	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

50000 BBL TNK FARM BULK STGE WITH 6IN PIPE & ACCESSORIES
TEMPERATE, TROPIC, FRIGID & DESERT. USES 4-10M BBL & 4-3M BBL
BOLTED STEEL TANKS W/ 6IN PIPE, FITTINGS, PMPS MANIFOLDS,
OPERATIONS BLDG, WATER STGE TANK & SECURITY FENCING.
REQUIRES 14 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EX
T. ONLY INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1069

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST.	VOL-MT	COST	MHRZ	VERT	GENL	TOT
12510AB	6IN-MANIFOLD F/TNK FARM W/Q PMP 6-INCH		AS REQUIRED	1.0	.9	.9	15941	12	121	58	243
12510AE	FLOOD PMP 785 BPH 6IN MANIFOLD	785 BPH	AS REQUIRED	2.0	20	38	43920	23	495	127	645
12510AH	TANK PMP POL 700 BPH W/6 IN MANIFD 700 BPH		AS REQUIRED	2.0	.8	16	15484	12	81	23	116
12510AN	TRANS PMP POL 700 BPH W/6 IN MNFD 700 BPH		AS REQUIRED	1.0	11	15	18715	35	265	58	358
12510AU	PPLN POL 1000 FT OF 6 INCH GROOVE 1000FT-4IN		AS REQUIRED	1.0	6	11	5196	12	86	52	150
12510BJ	PPLN POL 1M FT OF 6 IN API GROOVE 1000 FT		AS REQUIRED	1.6	18	21	11621	9	212	129	350
12530AK	PUMP STATION FUEL SUPPLY, POL FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE 250 BBL		AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE 1000 BBL		AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AG	TANK, POL, 3000 BARREL, W/6 IN PIPE 3000 BBL		AS REQUIRED	4.0	8	128	50152	414	1426	966	2806
41180AJ	TANK POL 10000 BARREL W/6 IN PIPE 10000 BBL		AS REQUIRED	4.0	8	160	82984	666	3910	1932	6486
161050BF	HQTRS & UNIT SUPPLY&GO STL FR 20X40X8FT		AS REQUIRED	1.0	7	15	11731	37	526	196	739
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	3.6	24	27	6776	188	868	876	1932
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404

131 469 277978 1537 8882 4775 15194

DDEXER4

RUN DATE 860207

DESERT CLIMATE

50000 BBL TNK FARM BULK STGE WITH 8IN PIPE & ACCESSORIES
 TEMPERATE/TROPIC/FRIGID & DESERT. USES 4-10M BBL & 4-3M
 BBL BOLTED STEEL TANKS W/ 8IN PIPE, FITTINGS, PMP'S MANIFOLDS,
 OPERATIONS BLDG. WATER STGE TANK & SECURITY FENCING.
 REQUIRES 14 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EX
 T. ONLY INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1079

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS			CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AC	8IN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH		AS REQUIRED	1.0	16	16	19680	12	207	69	288	
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	22	40	41254	46	644	184	874	
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	2.0	8	18	15874	12	81	23	116	
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	1.0	12	16	16109	40	282	58	380	
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	1.0	6	15	9258	12	127	69	208	
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	1.6	21	26	5600	18	368	258	644	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852	
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	4.0	12	160	80460	644	3910	1978	6532	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	3.4	24	27	4774	188	868	876	1932	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404	
				148	490	270776	1574	9279	5081	15934		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

100000 BBL TNK FARM BULK STGE WITH 6IN PIPE & ACCESSORIES
 TEMPERATE, TROPIC, FRIGID & DESERT. USES 9-10M BBL & 4-3M BBL
 BOLTED STEEL TANKS W/6 IN PIPE, FITTINGS, PMP'S MANIFOLDS,
 OPERATIONS BLDG. WATER STGE, TANK & SECURITY FENCING. REQUIRES
 23 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EXT. ONLY
INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1089

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS	
				REQUIRED	WT-ST	VOL-MI	COST	HORZ	VERT	GENL	TOT
12510AB	6IN-SWITCH MNFLD. F/TNK FARM W/O PMP	6-INCH	AS REQUIRED	1.0	.9	.9	15541	12	173	58	243
12510AE	FLOOD PMP 785 BPH 6IN MANIFOLD	785 BPH	AS REQUIRED	2.0	20	38	43920	23	495	127	645
12510AH	TANK PMP POL 700 BPH W/6 IN MANIFD	700 BPH	AS REQUIRED	5.0	20	40	38710	29	201	58	288
12510AN	TRANS PMP POL 700 BPH W/6 IN MNFD	700 BPH	AS REQUIRED	1.0	11	15	18715	35	265	58	358
12510AU	PPLN POL 1000 FT OF 6 INCH GROOVE	1000FT-4IN	AS REQUIRED	2.0	12	22	10392	23	173	104	300
12510BJ	PPLN POL 1M FT OF 6 IN API GROOVE	1000 FT	AS REQUIRED	3.0	33	39	21789	17	397	242	656
12530AK	PUMP STATION FUEL SUPPLY, POL FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	66	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK, POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AG	TANK, POL, 3000 BARREL, W/6 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	50152	414	1426	966	2806
41180AJ	TANK, POL 10000 BARREL W/6 IN PIPE	10000 BBL	AS REQUIRED	9.0	18	360	186714	1649	8798	4347	14594
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.2	29	36	5897	232	1072	1082	2386
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				179	729	421421	2422	14366	7596	24384	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

100000 BBL TANK FARM BULK STGE WITH 8IN PIPE & ACCESSORIES
 TEMPERATE/TROPIC/FRIGID & DESERT. USES 9-10M & 4-3M
 BBL BOLTED STEEL TANKS W/8 IN PIPE, FITTINGS, PMP'S MANIFOLDS,
 OPERATIONS BLDG., WATER STGE TANK & SECURITY FENCING.
 REQUIRES 23 ACRES. 10CY FINE AGGR. 10CY COARSE AGGR. HAND EX
 T. ONLY INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1099

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED		WT-ST	VOL-MT	COST	HORZ	VERT	GENL
12510AC	8IN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH		AS REQUIRED	1.0	16	16	19680	12	207	69	288
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	22	40	41254	46	644	184	874
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD 1400 BPH	1400 BPH	AS REQUIRED	5.0	20	45	39685	29	201	58	288
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD 1400 BPH		AS REQUIRED	1.0	12	16	16109	40	282	58	380
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE 1000FT-4IN		AS REQUIRED	2.0	12	30	18516	23	253	138	414
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE 1000 FT		AS REQUIRED	3.0	39	48	10500	35	690	483	1208
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	66	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE 250 BBL		AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE 1000 BBL		AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE 3000 BBL		AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852
41180AK	TANK POL 10000 BARREL W/8 IN PIPE 10000 BBL		AS REQUIRED	9.0	27	360	181035	1449	8798	4451	14698
161050BF	HQTRS & UNIT SUPPLY&GO STL FR 20X40X8FT		AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.2	29	34	5897	232	1072	1082	2386
87210AT	VEN-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				204	761	410443	2468	14939	8089	25496	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

150000 BBL TNK FARM BULK STGE WITH 8IN PIPE & ACCESSORIES
 TEMPERATE, TROPIC, FRIGID & DESERT. USES 16-10M & 4-3M
 8BL BOLTED STEEL TANKS W/8IN PIPE, FITTINGS, PMPMS MANIFOLDS
 OPERATIONS, BLDG-WATER STGE TANK & SECURITY FENCING.
 REQUIRES 31 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EX
 T. ONLY INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1109

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AC	BIN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH		AS REQUIRED	1.0	16	16	19680	12	207	69	288
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	22	40	41254	46	644	184	874
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	4.0	16	36	31748	23	161	46	230
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	1.0	12	16	16109	40	282	58	380
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-6IN	AS REQUIRED	3.0	18	45	27774	35	380	207	622
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	4.0	52	64	14000	46	920	644	1610
12530AK	PUMP STATION FUEL SUPPLY, POL FOR 2-UNIT		AS REQUIRED	2.0	2	2	2734	12	81	66	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	14.0	62	560	281610	2256	13685	6923	22862
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.5	32	36	6318	268	1149	1159	2556
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				237	985	516260	3306	20220	10856	34382	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

200000 BBL TNK FARM BULK STGE WITH 8IN PIPE & ACCESSORIES
 TEMPERATE, TROPIC, FRIGID & DESERT. USES 19-10M & 4-3M BBL
 BOLTED STEEL TANKS W/8 IN PIPE, FITTINGS, PMP'S MANIFOLDS,
 OPERATIONS BLDG., WATER STGE TANK & SECURITY FENCING. REQUIRES
 31 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EXT. ONLY
 INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1119

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AC	8IN-SWITCH MNFLD F/TNK FARM W/D PMP 8-INCH		AS REQUIRED	1.0	16	16	19680	12	207	69	288
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	22	40	41254	46	644	184	874
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	4.0	16	36	31768	23	161	46	230
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	1.0	12	16	16109	40	282	58	380
12510AV	PPLN PQL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	1.0	6	15	9258	12	127	69	208
12510BK	PPLN PQL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	6.0	78	96	21000	69	1380	966	2615
12530AK	PUMP STATION FUEL SUPPLY, PQL, FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	66	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK, POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852
41180AQ	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	19.0	57	760	382185	3059	18573	9396	31028
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	5.0	35	40	7020	276	1277	1288	2861
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				269	1191	606021	4139	25443	13642	43224	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

200000 BBL TNK FARM BULK STGE WITH 12IN PIPE & ACCESSORIES
 TEMPERATE, TROPIC, FRIGID & DESERT. USES 19-1DM & 4-3M BBL.
 BOLTED STEEL TANKS W/12IN PIPE, FITTINGS, PMP'S MANIFOLDS,
 OPERATIONS BLDG. WATER STGE TANK & SECURITY FENCING.
 REQUIRES 31 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EX
 T. ONLY INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1129

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIR'D	MATERIALS			CONSTR EFFORT IN MANHOURS			
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	1.0	26	23	97212	35	276	92	403
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1104
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	4.0	28	56	65016	23	184	69	276
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	1.0	18	21	78664	52	397	81	530
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	.2	3	3	700	2	46	32	80
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	6.0	24	24	66690	69	1587	1104	2760
12530AK	PUMP STATION FUEL SUPPLY, POL FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	19.0	57	779	539296	3168	18573	9505	31246
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	5.0	35	40	7020	276	1277	1288	2841
87210AT	VEN-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				246	1160	1033359	4273	25960	13967	44200	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

250000 BBL TNK FARM BULK STGE WITH 8IN PIPE & ACCESSORIES
 TEMPERATE, TROPIC, FRIGID & DESERT. USES 24-10M & 4-3M
 BEL BOLTED STEEL TANKS W/ 8IN PIPE, FITTINGS, PMPS
 MANIFOLDS, OPERATIONS BLDG, WATER STGE TANK & SECURITY
 FENCING. REQUIRES ACRES. 10CY FINE AGGR. 11CY COARSE AGGR.
 HAND EXL. ONLY INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1139

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS COST	CONSTR EFFORT IN MANHOURS			
				REQUIRED WT-ST	VOL-MT		HORZ	VERT	GENL	TOT
12510AC	8IN-SWITCH MNFLD F/TNK FARM W/Q PMP 8-INCH		AS REQUIRED	1.0	16	19680	12	207	69	288
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	22	41254	46	644	184	874
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	5.0	20	39685	29	201	58	288
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	1.0	12	16109	40	282	58	380
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	2.0	12	18516	23	253	138	416
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	7.0	91	24500	81	1610	1127	2818
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	2.0	2	2736	12	81	46	139
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	48176	414	1426	1012	2852
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	24.0	72	482760	3864	23460	11868	39192
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	5.0	35	7020	276	1277	1288	2861
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	664	18	276	110	404
				307	1431	727291	4973	30726	16356	52055

DDEXER4

RUN DATE 860207

DESERT CLIMATE

250000 BBL TNK FARM BULK STGE WITH 12 IN PIPE & ACCESSORIES
 TEMPERATE,TROPIC,FRIGID & DESERT. USES 24-10M & 4-3M BBL
 BOLTED STEEL TANKS W/12IN PIPE,FITTINGS/PNPS MANIFOLDS,
 OPERATIONS BLDG.WATER STGE TANK & SECURITY FENCING. REQUIRES
 30 ACRES. 10CY FINE AGGR. 11CY COARSE AGGR. HAND EXT. ONLY
 INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PB1149

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	1.0	26	23	97212	35	276	92	603	
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	2.0	28	42	100994	46	828	230	1106	
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	5.0	35	70	81270	29	230	86	365	
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	1.0	18	21	78664	52	397	81	530	
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	2.0	18	64	8880	35	449	161	645	
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	7.0	28	28	77805	81	1852	1288	3221	
12530AK	PUMP STATION FUEL SUPPLY, POL FOR 2-UNIT		AS REQUIRED	2.0	2	2	2736	12	81	46	139	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852	
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	24.0	72	984	681216	4002	23460	12006	39468	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	5.0	35	60	7020	276	1277	1288	2861	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404	
				287	1464	1210828	5158	31561	16798	53517		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM,MODULAR INSTALLATION 6INCH LINE
50000 BBL

PB1159

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12502AA	PMP,CENTR,1050GPM,850FTHD W/8IN. MAN		AS REQUIRED	12.0	108	312	328176	883	2098	662	3663
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518
12504AA	METER,TURBINE,6IN,1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2551	74	175	55	304
12506AA	PPL BBL CLEANER ASSY,6IN		AS REQUIRED	1.0	4	4	6995	21	123	52	196
12510BN	PPLN POL 1 MILE- 6 IN API GROVE	1 MILE	AS REQUIRED	2.0	118	126	89200	92	1196	667	1955
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	365
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	4.0	12	160	80460	644	3910	1978	6532
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				345	981	911514	2951	12355	6349	21655	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM, MODULAR INSTALLATION 8INCH LINE
100000 BBL

PB1169

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12502AA	PMP, CENTR, 1050GPM, 85QFTHD, W/8IN MAN		AS REQUIRED	17.0	153	662	666916	1251	2972	938	5161
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518
12504AA	METER, TURBINE, 6IN, 1050GPM, W/10IN PI		AS REQUIRED	1.0	8	14	2551	74	175	55	304
12506AB	PPL BBL CLEANER ASSY, 8IN		AS REQUIRED	1.0	5	4	6737	21	123	52	196
12510BP	PPLN POL, 1 MILE- 8 IN API GROVE, 1 MILE		AS REQUIRED	2.0	142	1.62	38414	184	1702	805	2691
12550AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE, 250 BBL		AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE, 500 BBL		AS REQUIRED	1.0	1	7	6442	52	207	86	345
41180AE	TANK, POL, 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852
41180AK	TANK, POL, 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	9.0	27	360	181035	1649	8798	4451	14698
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE, TYPE Y, 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				630	1347	1097785	4216	18623	9236	32075	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM/MODULAR INSTALLATION 8INCH LINE
150000 BBL

PB1179

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12502AA	PMP/CENTR,1050GPM,850FTHD W/8IN MAN		AS REQUIRED	13.0	117	338	355524	957	2272	718	3947
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518
12504AA	METER/TURBINE,6IN,1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2551	74	175	55	304
12506AB	PPL BBL CLEANER ASSY.8IN		AS REQUIRED	1.0	5	4	6737	21	123	52	196
12510BP	PPLN POL 1 MILE- 8 IN API GROVE 1 MILE		AS REQUIRED	2.0	142	162	38414	184	1702	805	2691
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69
41180AB	TANK, POL, 250 BARREL W/4 IN PIPE 250 BBL		AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AE	TANK POL 1000 BARREL W/4 IN PIPE 1000 BBL		AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE 3000 BBL		AS REQUIRED	3.0	6	96	36132	311	1070	759	2140
41180AK	TANK POL 10000 BARREL W/8 IN PIPE 10000 BBL		AS REQUIRED	4.0	12	160	80460	644	3910	1978	6532
41180AM	TANK POL 50000 BARREL W/8 IN PIPE 50000 BBL		AS REQUIRED	2.0	8	386	105694	690	10189	4600	15479
161050BF	HQTRS & UNIT SUPPLY&GO STL FR 20X40X8FT		AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET 1000 FEET		AS REQUIRED	1.0	7	8	1404	55	255	258	568
87210AT	VEH-MAN GATE FOR SECURITY FENCE 1		AS REQUIRED	2.0	4	4	664	18	276	110	404
				363	1366	970814	3486	21895	10032	35413	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM, MODULAR INSTALLATION 10INCH LINE
200000 BBL

PB1189

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS			CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12502AA	PMP, CENTR, 1050GPM, 850FTHD W/8IN MAN		AS REQUIRED	14.0	126	364	382872	1030	2447	773	4250	
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518	
12504AA	METER,TURBINE,6IN,1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2551	74	175	55	304	
12506AC	PIPELN BBL CLEANER TRAP 10IN IN-OUT		AS REQUIRED	1.0	7	13	8851	21	123	52	196	
12510CD	PIPELN,1MILE,10IN GRVD STL API PIPE		AS REQUIRED	2.0	196	350	60464	230	2082	978	3290	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE 250 BBL		AS REQUIRED	1.0	5	10	5202	29	115	52	196	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE 500 BBL		AS REQUIRED	1.0	1	7	6442	52	207	86	345	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE 1000 BBL		AS REQUIRED	1.0	1	13	9258	92	368	150	610	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE 3000 BBL		AS REQUIRED	3.0	6	96	36132	311	1070	759	2140	
41180AK	TANK POL 10000 BARREL W/8 IN PIPE 10000 BBL		AS REQUIRED	4.0	12	160	80460	644	3910	1978	6532	
41180AM	TANK POL 50000 BARREL W/8 IN PIPE 50000 BBL		AS REQUIRED	3.0	12	579	158541	1035	15284	6900	23219	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR 20X40X8FT		AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404	
				454	1813	1085827	4168	28518	13418	46104		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM, MODULAR INSTALLATION 10INCH LINE
250000 BBL

PB1199

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED			MATERIALS		CONSTR EFFORT			IN MANHOURS	
				WT-ST	VOL-MT	COST	HORZ	VERT	GENL			TOT	
12502AA	PMP/CENTR/1050GPM/850FTHD W/8IN MAN		AS REQUIRED	18.0	162	468	492264	1325	3146	994	5465		
12504AA	METER/TURBINE/6IN/1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2551	74	175	55	304		
12506AC	PIPELN BBL CLEANER TRAP 10IN IN-OUT		AS REQUIRED	1.0	7	13	8851	21	123	52	196		
12510CD	PIPELN,1MILE,10IN GRVD STL API PIPE		AS REQUIRED	2.0	196	350	60464	230	2082	978	3290		
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69		
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196		
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345		
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610		
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852		
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	5.0	15	200	100575	805	4888	2473	8166		
41180AM	TANK POL 50000 BARREL W/8 IN PIPE	50000 BBL	AS REQUIRED	4.0	16	772	211388	1380	20378	9200	30958		
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759		
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272		
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404		
				459	2027	964550	4704	34771	16411	55886			

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM, MODULAR INSTALLATION 6INCH LINE
21000 BBL

PB1209

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12502AA	PMP, CENTR, 1050GPM, 850FTHD W/8IN MAN		AS REQUIRED	11.0	99	286	300828	810	1923	607	3340
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2551	74	175	55	304
12506AA	PPL BBL CLEANER ASSY, 6IN		AS REQUIRED	1.0	4	4	6995	21	123	52	196
12510BN	PPLN POL 1 MILE- 6 IN API GROVE	1 MILE	AS REQUIRED	2.0	118	126	89200	92	1196	667	1955
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	7.0	14	224	84308	725	2496	1771	4992
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				330	891	839838	2545	9340	5075	16960	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM, MODULAR INSTALLATION 8INCH LINE
43000 BBL

PB1219

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS			CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12502AA	PMP, CENTR, 1050GPM, 850FTHD W/8IN MAN		AS REQUIRED	12.0	108	312	328176	883	2098	662	3663	
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518	
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2551	74	175	55	304	
12506AB	PPL BBL CLEANER ASSY, 8IN		AS REQUIRED	1.0	5	4	6737	21	123	52	196	
12510BP	PPLN POL 1 MILE- 8 IN API GROVE	1 MILE	AS REQUIRED	2.0	142	162	38414	184	1702	805	2691	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69	
41180AB	TANK, POL, 250 BARREL, W/6 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	5.0	10	160	60220	518	1783	1265	3566	
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	3.0	9	120	60365	483	2933	1484	6900	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	6.0	28	32	5616	221	1021	1030	2272	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404	
				369	1009	852399	2986	12241	6246	21473		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM/MODULAR INSTALLATION 8INCH LINE
45000 BBL

PB1229

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT.	GENL	TOT	
12502AA	PMP,CENTR,1050GPM,850ETHD W/BIN MAN		AS REQUIRED	12.0	108	312	328176	883	2098	662	3643
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518
12504AA	METER,TURBINE,6IN,1050GPM W/10IN PI		AS REQUIRED	1.0	8	16	2551	74	175	55	304
12506AB	PPL BBL CLEANER ASSY,8IN		AS REQUIRED	1.0	5	4	6737	21	123	52	196
12510BP	PPLN POL 1 MILE- 8 IN API GROVE	1 MILE	AS REQUIRED	2.0	142	162	38414	184	1702	805	2691
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69
61180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	5.0	10	160	60220	518	1783	1265	3566
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	5.0	15	200	100575	805	4888	2473	8166
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AK	FENCE, CORNER POST 10 FT HI BARR. WIR		AS REQUIRED	4.0	4	4	508	61	64	64	169
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
				351	1061	887521	3128	13239	6269	22636	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM MODULAR INSTALLATION 10INCH LINE,
85000 BBL.

PB1239

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12502AA	PMP & CENTR, 1050GPM, 850FTHD, W/8IN MAN		AS REQUIRED	16.0	164	616	437588	1178	2797	883	4858
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518
12504AA	METER/TURBINE, 6IN, 1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2551	74	175	55	304
12506AC	PIPELN BBL CLEANER TRAP 10IN IN-OUT		AS REQUIRED	1.0	7	13	8851	21	123	52	196
12510CD	PIPELN/1MILE, 10IN, GRV'D STL, API PIPE		AS REQUIRED	2.0	196	350	60664	230	2082	978	3290
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345
41180AE	TANK POL, 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	5.0	10	160	60220	518	1783	1265	3566
41180AK	TANK POL, 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	7.0	21	280	140805	1127	6843	3462	11632
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y, 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
					472	1481	1075341	4054	17460	8712	30226

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SYSTEM TANK FARM MODULAR INSTALLATION 10INCH LINE,
110000 BBL.

PB1249

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12302AA	PUMP, CENTR, 1050GPM, 850FTHD W/8IN. MAN		AS REQUIRED	12.0	153	462	664916	1251	2972	938	5161	
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	5.0	40	155	315675	368	874	276	1518	
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2551	76	175	55	304	
12506AC	PIPELN BBL CLEANER TRAP 10IN IN-OUT		AS REQUIRED	1.0	7	13	8851	21	123	52	196	
12510CD	PIPELN, 1MILE, 10IN GRVD STL API PIPE		AS REQUIRED	2.0	196	350	60466	230	2082	978	5290	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	1.0	1	1	1368	6	40	23	69	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345	
41180AE	TANK, POL 1000 BARREL, W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	4.0	8	128	48176	414	1426	1012	2852	
41180AK	TANK, POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	10.0	30	400	201150	1610	9775	4945	16330	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404	
				489	1584	1142064	4423	19980	9903	34306		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

400000 BBL CAPACITY TANK FARM COMPLEX BULK STG OF 4 PROD.
 TEMPERATE,TROPIC,DESERT & FRIGID CLIM. W/6IN-INLAND PPLN,
 BOOSTER PMP STA.& OPER BLDG. CONSISTS OF 2-200000 BBL TANK
 FARMS MADE UP OF 6 50BBL W/LDD,8-1QM & 6-3M BARREL BLTD STL
 TANKS,WATER SUPPLY TANK & SECURITY FENCING. REQUIRES 110ACRE
 300CY FINE AGGR., 33CY COARSE AGGR. HAND EXT. ONLY INCLUDED
 W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1019

FAC NUMBER	FAACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AB	6IN-SWITCH MNFLD F/TNK FARM W/O PMP 6-INCH		AS REQUIRED	1.0	9	15541	12	173	58	243	
12510AC	8IN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH		AS REQUIRED	2.0	32	39360	23	414	138	575	
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD 1355 BPH		AS REQUIRED	4.0	44	80	82508	92	1288	368	1748
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD 1400 BPH		AS REQUIRED	8.0	32	72	63496	46	322	92	460
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD 1400 BPH		AS REQUIRED	2.0	24	32	32218	81	266	115	760
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE 1000FT-4IN		AS REQUIRED	2.0	12	30	18516	23	253	138	414
12510BA	PPLN PQL 1 MILE QF 6 INCH GRQOVE 1MILE-6INCH		AS REQUIRED	4.0	120	200	128832	138	1472	1012	2622
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE 1000 FT		AS REQUIRED	8.0	104	128	28000	92	1840	1288	3220
12530AE	BOOSTER STATION POL 1400 BPH	1400 BPH	AS REQUIRED	4.0	52	112	108604	184	437	161	782
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	8.0	8	8	10944	46	322	184	552
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE 250 BBL		AS REQUIRED	4.0	20	40	20808	115	460	207	782
41180AE	TANK POL 1000 BARREL W/4 IN PIPE 1000 BBL		AS REQUIRED	2.0	2	26	18516	184	736	299	1219
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE 3000 BBL		AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278
41180AK	TANK POL 10000 BARREL W/8 IN PIPE 10000 BBL		AS REQUIRED	8.0	24	320	160920	1288	7820	3956	13064
41180AM	TANK POL 50000 BARREL W/8 IN PIPE 50000 BBL		AS REQUIRED	6.0	24	1158	317082	2070	30567	13800	46437
161050BF	HQTRS & UNIT SUPPLY&GO STL FR 20X40X8FT		AS REQUIRED	3.0	21	45	35193	110	1577	587	2274
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	7.1	50	57	9968	392	1813	1829	4034
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810
					598	2549	1164098	5554	52749	25971	84274

DDEXER4

RUN DATE 860207

DESERT CLIMATE

600000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
TEMPERATE, TROPIC, DESERT & FRIGID. W/8IN-INLAND PPLN, BOOSTER
 PMP STAT. & OPER BLDG. CONSISTS OF 2-200000 BBL TANK FARMS
 MADE UP OF 6 50M WELDED, 8-10M & 6 3M BARREL BLD STL TANKS,
 WATER SUPPLY TANK & SECURITY FENCING. REQUIRES 110 ACRES
 SOCY FINE AGGR. 33CY COARSE AGGR. HAND EXT. INCLUDED W/INSTA
 LLATION AS FIREFIGHTING EQUIP.

PC1029

FAC NUMBER,	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WI-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AC	8IN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH		AS REQUIRED	3.0	48	48	59040	35	621	207	863
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	4.0	44	80	82508	92	1288	368	1748
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	8.0	32	72	63496	46	322	92	460
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	2.0	24	32	32218	81	564	115	760
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	2.0	12	30	18516	23	253	138	414
12510BB	PPLN POL 1 MILE OF 8 INCH GROOVE	1 MILE-8INCH	AS REQUIRED	8.0	288	696	302376	368	4140	2944	7452
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	8.0	104	128	28000	92	1840	1288	3220
12530AF	BOOSTER STATION POL 2800 BPH	2800 BPH	AS REQUIRED	8.0	112	232	216560	368	874	322	1564
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	12.0	12	12	16416	69	483	276	828
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782
41180AE	TANK POL 1000 BARREL W/6 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	8.0	24	320	160920	1288	7820	3956	13064
41180AM	TANK POL 50000 BARREL W/8 IN PIPE	50000 BBL	AS REQUIRED	6.0	24	1158	317082	2070	30567	13800	46637
161050BF	HOTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	3.0	21	45	35193	110	1577	587	2274
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	7.1	50	57	9968	392	1813	1829	4034
				829	3168	1453881	5954	55497	27946	89397	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

400000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
 TEMPERATE, TROPIC, DESERT & FRIGID. W/12IN-INLAND PPLN,
 BOOSTER PMP STA. & OPER BLDG. CONSISTS OF 2-2000000 BBL TANK
 FARMS MADE UP OF 6-20M WELDED, B-10M & 6-3M BARREL STL
 TANKS, WATER SUPPLY TANK & SECURITY FENCING REQUIRES 110ACRES
 30CY FINE, AGGR. 33CY COARSE AGGR. HAND EXT. ONLY INCLUDED
 W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1039

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	3.0	78	69	291636	104	828	276	1208
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	4.0	56	84	201988	92	1656	460	2208
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	8.0	56	112	130032	46	368	138	552
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	2.0	36	42	157328	104	794	161	1059
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	2.0	18	64	8880	35	469	161	665
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	8.0	360	1416	191832	368	8740	3864	12972
12510BL	PPLN POL 1M FT OF 12 IN API GROVE	1000 FT	AS REQUIRED	8.0	32	32	88920	92	2116	1672	3680
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	8.0	216	448	432872	368	2576	736	3680
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	4.0	6	6	5472	23	161	92	276
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	8.0	8	8	9968	74	478	184	736
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	4.0	20	40	20808	115	460	207	782
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	6.0	12	192	72264	621	2139	1518	4278
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	8.0	24	328	227072	1334	7820	4002	13156
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	6.0	24	1158	365532	2070	30636	13800	46506
161050BF	4QTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	3.0	21	45	35193	110	1577	587	2274
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	8.0	56	64	11232	442	2042	2061	4545
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810
				1031	4140	2270873	6219	64128	30239	100586	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

600000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
 TEMPERATE, TROPIC, DESERT & FRIGID. W/8IN-INLAND PPLN, BOOSTER
 PMP STA. & OPER BLDG. CONSISTS OF 3-200000 BBL TANK FARMS
 MADE UP OF 9-50M WELDED 12-10M & 9-3M BARREL BLTD STL
 TANKS, WATER SUPPLY TANK & SECURITY FENCING. REQUIRES 188
 ACRES. 50CY FINE AGGR. 55CY COARSE AGGR. HAND EXT. ONLY INCL
 UDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1049

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AC	8IN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH	AS REQUIRED		4.0	64	64	78720	46	828	276	1150	
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	6.0	66	120	123762	138	1932	552	2622	
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	12.0	48	108	95244	69	483	138	690	
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	3.0	36	48	48327	121	845	173	1139	
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	3.0	18	45	27774	35	380	207	622	
12510BB	PPLN POL 1 MILE OF 8 INCH GROOVE	1 MILE-BINCH	AS REQUIRED	18.0	648	1566	680346	828	9315	6624	16767	
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	12.0	156	192	42000	138	2760	1932	4830	
12530AF	BOOSTER STATION POL 2800 BPH	2800 BPH	AS REQUIRED	12.0	168	348	324840	552	1311	483	2346	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	6.0	6	6	8208	35	242	138	415	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	6.0	6	6	7476	55	359	138	552	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	6.0	30	60	31212	173	690	311	1174	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	3.0	3	39	27774	276	1104	449	1829	
41180AH	TANK, POL, 3000 BARREL, W/B IN PIPE	3000 BBL	AS REQUIRED	9.0	18	288	108396	932	3209	2277	6418	
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	12.0	36	480	241380	1932	11730	5934	19596	
41180AM	TANK POL 50000 BARREL W/8 IN PIPE	50000 BBL	AS REQUIRED	9.0	36	1737	475623	3105	45851	20700	69656	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	5.0	35	75	58655	184	2628	978	3790	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	10.7	75	86	15023	591	2732	2756	6079	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	6.0	12	12	1992	55	828	331	1214	
					1461	5280	2396752	9265	87227	44397	140889	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

600000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
 TEMPERATE/TROPIC/DESERT & FRIGID. W/12IN-INLAND PPLN,
 BOOSTER PMP STA. & OPER BLDG. CONSISTS OF 3-200000 BBL TANK
 FARMS MADE UP OF 9-50M WELDED, 12-10M & 9-3M BARREL BLTD STL
 TANKS, WATER SUPPLY TANK & SECURITY FENCING. REQUIRES 188
 ACRES. SOCY.FINE AGGR. 55CY COARSE AGGR. HAND EXT. ONLY INCL
 UDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1039

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP	12-INCH	AS REQUIRED	4.0	104	92	388848	138	1104	368	1610
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	6.0	84	126	302982	138	2484	690	3312
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	12.0	84	168	195048	69	552	207	828
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	3.0	54	63	235992	155	1190	242	1587
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	3.0	27	96	13320	52	673	242	967
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	18.0	810	3186	431622	828	19665	8694	29187
12510BL	PPLN POL 1M FT QF 12 IN API GROVE	1000 FT	AS REQUIRED	12.0	48	48	133380	138	3174	2208	5520
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	12.0	324	672	649308	552	3864	1104	5520
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	6.0	6	6	8208	35	242	138	415
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR	4-UNIT	AS REQUIRED	12.0	12	12	14952	110	718	276	1104
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	6.0	30	60	31212	173	690	311	1174
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	3.0	3	39	27774	276	1104	449	1829
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	9.0	18	288	108396	932	3209	2277	6418
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	12.0	36	492	340608	2001	11730	6003	19734
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	9.0	36	1737	548298	3105	45954	20700	69759
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	2DX40X8FT	AS REQUIRED	5.0	35	75	58655	184	2628	978	3790
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	10.7	75	86	15023	591	2732	2756	6079
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	6.0	12	12	1992	55	828	331	1214

1798 7258 3505618 9532 102541 47974 160047

DDEXER4

RUN DATE 860207

DESERT CLIMATE

800000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
 TEMPERATE, TROPIC, DESERT & FRIGID. W/8 IN-INALND PPLN,
 BOOSTER PMP STA. & OPER BLDG. CONSISTS OF 4-200000 BBL TANK
 FARMS MADE UP OF 12-50M WELDED 16-10M & 12-3M BARREL SLTD
 TANKS, WATER SUPPLY TANK & SECURITY FENCING. REQUIRES 267
 ACRES. 70CY FINE AGGR. 77CY AGGR. HAND EXT. ONLY INCLUDED
 W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1069

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS WT-ST VOL-MT	COST	CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST			HORZ	VERT	GENL	TOT	
12510AC	8IN-SWITCH MNFLD E/TNK FARM W/Q PMP 8-INCH		AS REQUIRED	5.0	80	80	98400	58	1035	365	1438	
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	88	160	165016	184	2576	736	3496	
12510AL	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	16.0	66	166	126992	92	644	184	920	
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	4.0	48	64	64436	161	1127	230	1518	
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	4.0	24	60	37032	46	506	276	828	
12510BB	PPLN POL 1 MILE OF 8 INCH GROOVE	1 MILE-8INCH	AS REQUIRED	24.0	864	2088	907128	1104	12420	8832	22356	
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	1.6.0	208	256	56000	184	3680	2576	6660	
12530AF	BOOSTER STATION POL 2800 BPH	2800 BPH	AS REQUIRED	24.0	336	696	649680	1104	2622	966	4692	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	8.0	8	8	10944	46	322	184	552	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	12.0	12	12	14952	110	718	276	1104	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	12.0	24	384	146528	1242	4278	3036	8556	
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	16.0	48	640	321840	2576	15640	7912	26128	
41180AM	TANK, POL, 50000 BARREL W/8 IN PIPE	50000 BBL	AS REQUIRED	12.0	48	2316	634164	4140	61134	27600	92874	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	7.0	49	105	82117	258	3679	1369	5306	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	14.2	99	114	19937	784	3625	3658	8067	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620	
				2070	7295	3424874	12819	117732	59738	190289		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

800000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
 TEMPERATE, TROPIC, DESERT & FRIGID. W/12IN-INLAND PPLN/
 BOOSTER PMP STA. & OPER BLDG. CONSISTS OF 4-200000 BBL TANK
 FARMS MADE UP OF 12-50M HELDED, 16-10M & 12-3M BARREL BLTD
 STL TANKS, WATER SUPPLY TANK & SECURITY FENCING. REQUIRES
 267 ACRES. 70CY FINE AGGR. 77CY COARSE AGGR. HAND EXT. ONLY
 INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1079

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	5.0	130	115	486060	173	1380	460	2013
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	112	168	403976	184	3312	920	4416
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	16.0	112	224	260064	92	736	276	1104
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	4.0	72	84	314656	207	1587	322	2116
12510AW	PPLN POL 1000 FT OF 12. INCH GROOVE	1000FT-12IN	AS REQUIRED	4.0	36	128	17760	69	897	322	1288
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	24.0	1080	4248	575496	1104	26220	11592	38916
12510BL	PPLN POL 1M FT OF 12. IN API GROVE	1000 FT	AS REQUIRED	16.0	64	64	177840	184	4232	2946	7360
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	24.0	648	1344	1298616	1104	7728	2208	11040
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	8.0	8	8	10944	46	322	184	552
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	24.0	24	24	29904	221	1435	552	2208
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438
41180AH	TANK, POL, 3000 BARREL, W/3 IN PIPE	3000 BBL	AS REQUIRED	12.0	24	384	144528	1242	4278	3036	8556
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	16.0	48	656	454144	2668	15640	8004	26312
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	12.0	48	2316	731064	4140	61272	27600	93012
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	7.0	49	105	82117	258	3679	1369	5306
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	14.2	99	114	19937	784	3625	3658	8067
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620

2624 10150 5098814 13206 140069 65005 218280

DDEXER4

RUN DATE 860207

DESERT CLIMATE

1000000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
 TEMPERATE, TROPIC, DESERT & FRIGID. W/8 IN-INLAND PPLN,
 BOOSTER PMP STA. & OPER BLDG. CONSISTS OF 4-250000 BBL TANK
FARMS MADE UP OF 16-50M WELDED, AND TWENTY 10 THOUSAND BBL
STL TANKS, WATER SUPPLY TANK & SECURITY FENCING. REQUIRES 263
ACRES. 70CY FINE AGGR. 77CY COARSE AGGR. HAND EXT. ONLY INCL
UDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1089

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AC	BIN-SWITCH MNFLD F/JNK FARM W/Q PMP 8-INCH		AS REQUIRED	5.0	.80	.80	98400	58	1035	345	1438	
12510AF	FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	.88	.160	165016	184	2576	736	3496	
12510AJ	TANK PMP POL 1400 BPH W/8 IN MANIFD	1400 BPH	AS REQUIRED	16.0	.64	.164	126992	92	646	184	920	
12510AP	TRANS PMP POL 1400 BPH W/8 IN MNFD	1400 BPH	AS REQUIRED	4.0	.48	.64	64436	161	1127	230	1518	
12510AV	PPLN POL 1000 FT OF 8 INCH GROOVE	1000FT-4IN	AS REQUIRED	4.0	.24	.60	37032	46	506	276	828	
12510BB	PPLN POL 1 MILE OF 8 INCH GROOVE	1 MILE-8INCH	AS REQUIRED	24.0	.864	.2088	907128	1104	12420	8832	22356	
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1.000 FT	AS REQUIRED	24.0	.312	.384	86000	276	5520	3864	9660	
12530AF	BOOSTER STATION POL 2800 BPH	2800 BPH	AS REQUIRED	24.0	.336	.696	649680	1104	2622	966	4692	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	8.0	.8	.8	10944	46	322	184	552	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR	4-UNIT	AS REQUIRED	12.0	.12	.12	14952	110	718	276	1104	
41180AB	TANK POL 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	.50	.100	52020	288	1150	518	1956	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	.4	.52	37032	368	1472	598	2438	
41180AK	TANK POL 10000 BARREL W/8 IN PIPE	10000 BBL	AS REQUIRED	20.0	.60	.800	402300	3220	19550	9890	32660	
41180AM	TANK POL 50000 BARREL W/8 IN PIPE	50000 BBL	AS REQUIRED	16.0	.64	.3088	845552	5520	81512	36800	123832	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	7.0	.49	.105	82117	258	3679	1369	5306	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	15.0	.105	.120	21060	828	3830	3864	8522	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	.16	.16	2656	74	1104	442	1620	
				2184	7977	3601317	13737	139787	69374	222898		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

1000000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
 TEMPERATE, TROPIC, DESERT & FRIGID. W/12IN-INLAND PPLN,
 BOOSTER PMP STA. & OPER BLDG. CONSISTS OF 4-250000 BBL TANK
 FARMS MADE UP OF 12-50M WELDED AND TWENTY 10 THOUSAND BLTD
 STL TANKS, WATER SUPPLY TANK & SECURITY FENCING. REQUIRES 263
 ACRES. 70CY FINE AGGR., 77CY COARSE AGGR. HAND EXT. ONLY INCL
 UDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1099

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS			CONSTR EFFORT IN MANHOURS			
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AD	12IN SWITCH MNFLD F/TNK FARM NO PMP 12-INCH		AS REQUIRED	5.0	130	115	486060	173	1380	460	2013
12510AG	FLOOD PMP 1355BPH 12 IN MANIFOLD	1355 BPH	AS REQUIRED	8.0	112	168	403976	184	3312	920	4416
12510AK	TANK PMP POL 2800 BPH W/12IN MANIFD	2800 BPH	AS REQUIRED	16.0	112	224	260064	92	736	276	1104
12510AR	TRANS PMP POL 2800 BPH W/12 IN MNFD	2800 BPH	AS REQUIRED	4.0	72	84	314656	207	1587	322	2116
12510AW	PPLN POL 1000 FT OF 12 INCH GROOVE	1000FT-12IN	AS REQUIRED	4.0	36	128	17760	69	897	322	1288
12510BC	PPLN POL 1 MILE OF 12 INCH GROOVE	1MILE-12INCH	AS REQUIRED	24.0	1080	4248	575496	1104	26220	11592	38916
12510BL	PPLN POL 1M FT OF 12 IN API GROOVE	1000 FT	AS REQUIRED	24.0	96	96	266760	276	6348	4416	11040
12530AG	BOOSTER STATION POL 7000 BPH	7000 BPH	AS REQUIRED	24.0	648	1344	1298616	1104	7728	2208	11040
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	8.0	8	8	10944	46	322	184	552
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	24.0	24	24	29904	221	1435	552	2208
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	10.0	50	100	52020	288	1150	518	1956
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	4.0	4	52	37032	368	1472	598	2438
41180AL	TANK POL 10000 BARREL W/12 IN PIPE	10000 BBL	AS REQUIRED	20.0	60	820	567680	3335	19550	10005	32890
41180AN	TANK POL 50000 BARREL W/12 IN PIPE	50000 BBL	AS REQUIRED	16.0	64	3088	974752	5520	81696	36800	124016
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	7.0	49	105	82117	258	3679	1369	5306
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	15.0	105	120	21060	828	3830	3864	8522
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	8.0	16	16	2656	74	1104	442	1620
					2666	10740	5401553	14147	162446	74848	251441

DDEXER4

RUN DATE 860207

DESERT CLIMATE

4000 BBL CAPACITY TANK FARM COMPLEX BULK STGE OF 4 PROD.
 TEMPERATE, TROPIC, DESERT & FRIGID. W/4 IN-INLAND PPLN/BOOSTER
 PMP STA. & OPER BLDG. CONSISTS XF 2-200000 BBL TANK FARMS MADE
 UP OF 3A-10 THOUSAND AND EIGHT 3 THOUSAND BL D S.1 TANKS,
 WATER SUPPLY TANK & SECURITY FENCING. REQUIRES 110 ACRES
 20CY FINE AGGR. 22CY COARSE AGGR. HAND EXT. ONLY INCLUDED
 W/INSTALLATION AS FIREFIGHTING EQUIP.

PC1109

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12510AB 6IN-SWITCH MNFLD F/TNK FARM W/O PMP 6-INCH	AS REQUIRED	1.0	9	15561	12	123	58	263				
12510AC 8IN-SWITCH MNFLD F/TNK FARM W/O PMP 8-INCH	AS REQUIRED	2.0	32	39360	23	414	138	575				
12510AF FLOOD PMP 1355BPH 8IN MANIFOLD	1355 BPH	AS REQUIRED	4.0	44	80	82508	92	1288	368	1768		
12510AJ TANK PMP POL 1400 BPH W/8 IN MANIFD 1400 BPH	AS REQUIRED	8.0	32	72	63496	46	322	92	460			
12510AP TRANS PMP POL 1400 BPH W/8 IN MNFD 1400 BPH	AS REQUIRED	2.0	24	32	32218	81	566	115	760			
12510AV PPLN POL 1000 FT OF 8 INCH GROOVE 1000FT-4IN	AS REQUIRED	2.0	12	30	18516	23	253	138	414			
12510BA PPLN POL 1 MILE OF 6 INCH GROOVE 1MILE-6INCH	AS REQUIRED	4.0	120	200	128832	138	1472	1012	2622			
12510BK PPLN POL 1M FT OF 8 IN API GROOVE 1000 FT	AS REQUIRED	12.0	156	192	42000	138	2760	1932	4830			
12530AE BOOSTER STATION POL 1400 BPH	1400 BPH	AS REQUIRED	4.0	52	112	108604	184	437	161	782		
12530AK PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	AS REQUIRED	8.0	8	8	10944	46	322	184	552			
41180AB TANK, POL, 250 BARREL, W/4 IN PIPE 250 BBL	AS REQUIRED	4.0	20	60	20808	115	480	207	782			
41180AE TANK POL 1000 BARREL W/4 IN PIPE 1000 BBL	AS REQUIRED	2.0	2	26	18516	184	736	299	1219			
41180AH TANK, POL, 3000 BARREL, W/8 IN PIPE 3000 BBL	AS REQUIRED	8.0	16	256	96352	828	2852	2024	5704			
41180AK TANK POL 10000 BARREL W/8 IN PIPE 10000 BBL	AS REQUIRED	38.0	114	1520	764370	6118	37145	18791	62054			
161050BF HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	3.0	21	45	35193	110	1577	587	2274		
87210AR SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	10.0	70	80	14040	552	2553	2576	5681		
87210AT VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	4.0	8	8	1328	37	552	221	810		
				740	2742	1492626	8727	53880	28903	91510		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE, 41M 8MILES, WITH 355 BPH PUMP.
 STATION FOR TEMP,TROP,DST & FRIGID CLIMATE. TRANSFER OF POL
 PRODUCTS AT RATE OF 7000 BBL/DAY. REQUIRES 97 ACRES. 2 CY F
 INE AGGR. 2 CY COARSE AGGR. ONLY HAND EXT. INCLUDED WITH INS
 TALLATION AS FIREFIGHTING EQUIP.

PD1019

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	
12510BD	PPLN POL 5 MILE OF 4 INCH GROOVE	5 MILES-4 IN	AS REQUIRED	1.0	61	110	61704	58	1265	828	2151
12510BM	PPLN POL 1 MILE- 4 IN API GROVE	1 MILE	AS REQUIRED	3.0	102	69	96474	104	1469	966	2519
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	1.0	1	1	1368	6	40	23	69
12530AM	PUMP STATION POL FOR 4 IN PIPELINE	385 BPH	AS REQUIRED	1.0	5	86	80584	40	115	40	195
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	.3	2	2	421	17	77	77	171
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
					178	280	246085	263	3199	2041	5503

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE, 61M 17MILES, WITH 785 BPH PUMP.
 STATION FOR TEMP, TROP, DST & FRIGID CLIMATE. TRANSFER OF POL
 PRODUCTS AT RATE OF 15000 BBL/DAY. REQUIRES 206 ACRES. 2 CY
 FINE AGGR. 2 CY COARSE AGGR. ONLY HAND EXT. INCLUDED WITH IN
 STALLATION AS FIREFIGHTING EQUIP.

PD1029

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT		IN MANHOURS	
				REQUIRED	WT-ST	VOL-MI	COST	HORZ	VERT	GENL	TOT
12510BE	PPLN POL 5 MILE OF 6 INCH GROOVE	5 MILES-6 IN	AS REQUIRED	3.0	441	717	476826	173	5003	3795	8971
12510BN	PPLN POL 1 MILE- 6 IN API GROVE	1 MILE	AS REQUIRED	2.0	118	126	89200	92	1196	667	1955
12530AL	PUMP STATION FUEL SUPPLY, POL, FQR 4-UNIT		AS REQUIRED	1.0	1	1	1266	9	60	23	92
12530AN	PUMP STATION POL FOR 6 IN PIPELINE	789 BPH	AS REQUIRED	1.0	9	171	155992	40	247	104	391
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE.	500 BBL	AS REQUIRED	1.0	1	7	6642	52	207	86	345
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	.4	3	3	562	22	102	103	227
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
					575	1027	730600	397	6953	4833	12183

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE 81M 17MILES, WITH 1355 BPH PUMP.
 STATION FOR TEMP, TROP, DST & FRIGID CLIMATE. TRANSFER OF POL
 PRODUCTS AT RATE OF 27000 BBL/DAY. REQUIRES 206 ACRES. 2 CY
 FINE AGGR, 2 CY COARSE AGGR, ONLY HAND EXH. INCLUDED WITH IN
 STALLATION AS FIREFIGHTING EQUIP.

PD1039

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS COST	CONSTR EFFORT IN MANHOURS				
				REQUIRED	WT-ST VOL-MT		HORZ	VERT	GENL	TOT	
12510BF	PPLN POL 5 MILE OF 8 INCH GROOVE	5 MILES=8 TM	AS REQUIRED	3.0	546	1296	595626	173	5368	3657	9178
12510BP	PPLN POL 1 MILE- 8 IN API GROVE	1 MILE	AS REQUIRED	2.0	142	162	38414	184	1702	805	2691
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	23	92
12530AP	PUMP STATION POL FOR 8 IN PIPELINE	1355 BPH	AS REQUIRED	1.0	32	63	62452	46	276	127	449
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345
87210AR	SECURITY FENCE TYPE Y 1300 FEET	1000 FEET	AS REQUIRED	.4	3	3	562	22	102	103	227
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
				727	1534	705074	495	7833	4856	13184	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SHORE BOOSTER STATION, 6INCH LINE, 1800 BPH PUMP.

PD1049

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS				
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
12671AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL, 5-10000GAL	AS REQUIRED	1.0	7	22	49987	12	63	17	92		
12502AA	PMP, CENTR, 1050GPM, 850FTHD W/8IN MAN	AS REQUIRED	2.0	18	52	54696	147	350	110	607		
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES	AS REQUIRED	1.0	8	31	63135	74	175	55	304		
12504AA	METER/TURBINE, 6IN, 1050GPM W/10IN PI	AS REQUIRED	1.0	8	14	2551	74	175	55	304		
12505AA	FILTER COALESCER, W/10IN PIPE	AS REQUIRED	1.0	9	32	75000	74	175	55	304		
12506AA	PPL BBL CLEANER ASSY, 6IN	AS REQUIRED	1.0	4	4	6995	21	123	52	196		
12510BJ	PPLN POL 1M FT OF 6 IN API GROOVE 1000 FT	AS REQUIRED	2.0	22	26	16526	12	265	161	638		
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE 1000 FT	AS REQUIRED	3.0	39	48	10500	35	690	483	1208		
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 6-UNIT	AS REQUIRED	1.0	1	1	1246	9	60	23	92		
61180AB	TANK, POL, 250 BARREL, W/4 IN PIPE 250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196		
161050BF	HOTRS & UNIT SUPPLY&GO STL FR 20X40X8FT	AS REQUIRED	1.0	7	15	11731	32	526	196	759		
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202	
				158	289	301517	754	3876	2344	6974		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SHORE BOOSTER STATION, 8INCH LINE, 3600 BPA PUMP.

PD1059

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12471AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL 5-10000GAL		AS REQUIRED	1.0	7	22	49987	12	63	17	92
12502AA	PMP, CENTR, 1050GPM, 850FTHD W/8IN MAN		AS REQUIRED	3.0	27	78	82044	221	524	166	911
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	2.0	16	62	126270	147	350	110	607
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI		AS REQUIRED	1.0	8	14	2351	74	175	55	304
12505AA	FILTER COALESCER, W/10IN PIPE		AS REQUIRED	1.0	9	32	75000	74	175	55	304
12506AB	PPL BBL CLEANER ASSY, 8IN		AS REQUIRED	1.0	5	4	6737	21	123	52	196
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE 1000 FT		AS REQUIRED	2.0	26	32	7000	23	460	322	805
12510CC	PIPELN, 1000FT, 10IN GRVD STL API PI		AS REQUIRED	3.0	54	93	17256	35	742	518	1295
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	1	1246	9	60	23	92
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE 500 BBL		AS REQUIRED	1.0	1	7	6442	52	207	86	345
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	YEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
					191	394	392212	935	4564	2685	8184

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SHORE BOOSTER STATION, 8INCH LINE, 5400 BPH PUMP.

PD1069

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT		
12471AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL 5-10000GAL		AS REQUIRED	1.0	.7	.22	49987	12	.63	17	.92		
12502AA	PMP/CENTR, 1050GPM, 850FTHD W/8IN MAN		AS REQUIRED	4.0	36	104	109392	294	699	221	1214		
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES		AS REQUIRED	2.0	16	.62	126270	167	350	110	607		
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI		AS REQUIRED	1.0	8	.14	2551	74	175	55	304		
12505AA	FILTER COALESCER W/10IN PIPE		AS REQUIRED	1.0	9	.32	75000	74	175	55	304		
12506AB	PPL BBL CLEANER ASSY. 8IN		AS REQUIRED	1.0	5	.4	6737	21	123	52	196		
12510BK	PPLN POL 1M ET OF 8 IN API GROOVE 1000 FT		AS REQUIRED	2.0	26	.32	7000	23	460	322	805		
12510CC	PIPELN, 1000FT, 10IN GRVD STL API PI		AS REQUIRED	3.0	54	.93	17256	35	742	518	1295		
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT		AS REQUIRED	1.0	1	.1	1246	.9	60	23	.92		
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE 500 BBL		AS REQUIRED	1.0	1	.7	6442	52	207	86	345		
16105QBF	MOTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	.7	.15	11731	37	526	196	759		
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	.32	5616	221	1021	1030	2272		
87210AT	VEH-MAN GATE FOR SECURITY FENCE	.1	AS REQUIRED	1.0	.2	.2	332	.9	138	55	202		
					200	420	419560	1008	4739	2740	8487		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SHORE BOOSTER STATION, 10INCH LINE 7200 BPH PUMP.

PD1079

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED			MATERIALS			CONSTR EFFORT			IN MANHOURS	
				WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT				
12471AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL 5-10000GAL	AS REQUIRED	1.0	7	22	69987	12	63	17	92				
12502AA	PMP, CENTR, 1050GPM, 850FTHD W/8IN MAN	AS REQUIRED	7.0	63	182	191436	515	1224	386	2125				
12503AA	SWITCHING MAN, 8/10IN W/3-WAY VALVES	AS REQUIRED	4.0	32	124	252340	294	699	221	1214				
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI	AS REQUIRED	1.0	8	14	2551	74	175	55	304				
12505AA	FILTER COALESCER, W/10IN PIPE	AS REQUIRED	1.0	9	32	75000	74	175	55	304				
12506AC	PIPELN BBL CLEANER TRAP 10IN IN-OUT	AS REQUIRED	1.0	7	13	8851	21	123	52	196				
12510BL	PPLN POL 1M FT OF 12 IN API GROVE 1000 FT	AS REQUIRED	3.0	12	12	33345	35	794	552	1381				
12510CC	PIPELN, 1000FT, 10IN GRVD STL API PI	AS REQUIRED	2.0	36	62	11504	23	495	345	863				
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT	AS REQUIRED	1.0	1	1	1246	9	60	23	92				
61180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610			
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759			
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272			
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202			
				213	524	653397	1416	5861	3137	10414				

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL SHORE BOOSTER STATION, 10INCH LINE 9000 BPH PUMP.

PD1089

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT		
12671AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL 5-10000GAL	AS REQUIRED	1.0	7	22	69987	12	63	17	92			
12502AA	PMP/CENTR, 1050GPM/850FTHD W/8IN MAN	AS REQUIRED	8.0	72	208	218784	589	1398	442	2429			
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES	AS REQUIRED	4.0	32	126	252560	294	699	221	1214			
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI	AS REQUIRED	1.0	8	14	2551	74	175	55	304			
12505AA	FILTER COALESCER, W/10IN PIPE	AS REQUIRED	1.0	9	32	75000	74	175	55	304			
12506AC	PIPELN BBL CLEANER TRAP 10IN IN-OUT	AS REQUIRED	1.0	7	13	8851	21	123	52	196			
12510BL	PPLN POL 1M FT OF 12 IN API GROVE 1000 FT	AS REQUIRED	3.0	12	12	33345	35	794	552	1381			
12510CC	PIPELN, 1000FT, 10IN GRVD STL API PI	AS REQUIRED	2.0	36	62	11504	23	495	345	863			
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 6-UNIT	AS REQUIRED	1.0	1	1	1246	9	60	23	92			
41180AE	TANK POL 1000 BARREL W/4 IN PIPE 1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610			
161050BF	HATRS & UNIT SUPPLY&GO STL FR 20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759			
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272		
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202		
				222	550	680745	1490	6035	3193	10718			

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE PUMPING STATION, 6INCH LINE 1800 BPH PUMP.

PD1149

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST VOL-MT	COST	HORZ	VERT	GENL	TOT	
12471AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL S-10000GAL	AS REQUIRED	1.0	7	22	49987	12	63	17	92	
12502AA	PMP,CENTR,1050GPM,850FTHD W/8IN MAN	AS REQUIRED	2.0	18	52	54696	147	350	110	607	
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES	AS REQUIRED	1.0	8	31	63135	74	175	55	304	
12504AA	METER,TURBINE,6IN,1050GPM W/10IN PI	AS REQUIRED	1.0	8	14	2551	74	175	55	304	
12506AA	PPL BBL CLEANER ASSY,6IN	AS REQUIRED	1.0	4	4	6995	21	123	52	196	
12510BJ	PPLN POL 1M FT OF 6 IN API GROOVE 1000 FT	AS REQUIRED	1.0	11	13	7263	6	132	81	219	
12530AK	PUMP STATION FUEL SUPPLY, POL FOR 2-UNIT	AS REQUIRED	1.0	1	1	1368	6	60	23	69	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE 250 BBL	AS REQUIRED	1.0	5	10	5202	29	115	52	196	
16105QBF	HQTRS & UNIT SUPPLY&GO STL FR 20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
				99	196	208876	636	2858	1726	5220	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE PUMPING STATION, 8INCH LINE 3600 BPH PUMP.

PD1159

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST.	VOL-MT	COST	HORZ	VERT	GENL	TOT
12671AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL, 5-10000GAL	AS REQUIRED		1.0	7	22	49987	12	63	17	92
12502AA	PNP, CENTR, 1050GPM, 850FTHD W/8IN MAN	AS REQUIRED		3.0	27	78	82044	221	524	166	911
12503AA	SWITCHING MAN, 8/10IN W/3-WAY VALVES	AS REQUIRED		2.0	16	62	126270	147	350	110	607
12504AA	METER/TURBINE, 6IN, 1050GPM W/10IN PI	AS REQUIRED		1.0	8	14	2551	74	175	55	304
12506AB	PPL BBL CLEANER ASSY, 8IN	AS REQUIRED		1.0	5	4	6737	21	123	52	196
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE 1000 FT	AS REQUIRED		1.0	13	16	3500	12	230	161	403
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	AS REQUIRED		1.0	1	1	1368	6	40	23	69
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345
16105QB	FRTRS & UNIT SUPPLY&GO STL FR	2QX4QX8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
					115	253	296578	812	3397	1951	6160

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE PUMPING STATION, 8INCH LINE 5400 BPH PUMP.

PD1169

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS			CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL		TOT
12471AA	JANKS, COLLAPSIBLE W/EQUIPMENT, POL 5-10000GAL	AS REQUIRED		1.0	7	22	49987	12	63	17	92	
12502AA	PMP, CENTR, 1050GPM, 850FTHD W/8IN MAN	AS REQUIRED		4.0	36	104	109392	294	699	221	1214	
12503AA	SWITCHING MAN, 8/10IN W/3-WAY VALVES	AS REQUIRED		2.0	16	62	126270	147	350	110	607	
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI	AS REQUIRED		1.0	8	14	2551	74	175	55	304	
12506AB	PPL BBL CLEANER ASSY, BIN	AS REQUIRED		1.0	5	4	6737	21	123	52	196	
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE 1000 FT	AS REQUIRED		1.0	13	16	3500	12	230	161	403	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	AS REQUIRED		1.0	1	1	1368	6	40	23	69	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE 500 BBL	AS REQUIRED		1.0	1	7	6442	52	207	86	345	
161050BF	HQJRS & UNIT SUPPLY&GO STL FR	20X4QX8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202	
				124	279	323926	885	3572	2006	6463		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE PUMPING STATION, 10INCH LINE 7200 BPH PUMP.

PD1179

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12471AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL 5-10000GAL	AS REQUIRED		1.0	7	22	69987	12	63	17	92
12502AA	PMP/CENTR, 1050GPM, 850FTHD W/8IN MAN	AS REQUIRED		7.0	63	182	191436	515	1224	386	2125
12503AA	SWITCHING MAN 8/10IN W/3-WAY VALVES	AS REQUIRED		4.0	32	126	252540	294	699	221	1214
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI	AS REQUIRED		1.0	8	14	2551	74	175	55	304
12506AC	PIPELN BBL CLEANER TRAP 10IN IN-OUT	AS REQUIRED		1.0	7	13	8851	21	123	52	196
12510CC	PIPELN, 1000FT, 10IN GRVD STL API PI	AS REQUIRED		1.0	18	31	5752	12	247	173	432
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	AS REQUIRED		1.0	1	1	1368	6	60	23	69
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	AS REQUIRED	1.0	1	7	6442	52	207	86	345
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202
					174	643	536606	1253	4463	2294	8010

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE PUMPING STATION, 10INCH LINE 9000 BPH PUMP.

PD1189

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS			CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL		TOT
12471AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL 5-10000GAL	AS REQUIRED		1.0	7	22	49987	12	63	17	92	
12502AA	PMP, CENTR, 1050GPM, 850FTHD W/8IN MAN	AS REQUIRED		8.0	72	208	218784	589	1398	442	2429	
12503AA	SWITCHING MAN, 8/10IN W/3-WAY VALVES	AS REQUIRED		4.0	32	124	252540	294	699	221	1214	
12504AA	METER, TURBINE, 6IN, 1050GPM W/10IN PI	AS REQUIRED		1.0	8	14	2551	74	175	55	304	
12506AC	PIPELN BBL CLEANER TRAP, 10IN IN-OUT	AS REQUIRED		1.0	7	13	8851	21	123	52	196	
12510CC	PIPELN, 1000FT, 10IN GRVD STL API PI	AS REQUIRED		1.0	18	31	5752	12	247	173	432	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	AS REQUIRED		1.0	1	1	1368	6	40	23	69	
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE 500 BBL	AS REQUIRED		1.0	1	7	6442	52	207	86	345	
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	4.0	28	32	5616	221	1021	1030	2272	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	1.0	2	2	332	9	138	55	202	
					183	469	563954	1327	4637	2350	8314	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE PUMP STATION, ONE 6 INCH DIESEL DRIVEN PUMP, 19 MILES OF 6 INCH PIPE AND TUBING, 785 BPH CAPABILITY.

PD1259

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510BA	PPLN POL 1 MILE OF 6 INCH GROOVE	1MILE-6INCH	AS REQUIRED	2.0	60	100	64416	69	736	506	1311
12510BE	PPLN POL 5 MILE OF 6 INCH GROOVE	5 MILES-6 IN	AS REQUIRED	3.0	441	717	476826	173	5003	3795	8971
12510BN	PPLN POL 1 MILE- 6 IN API GROVE	1 MILE	AS REQUIRED	2.0	118	126	89200	92	1196	667	1955
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT	2 UNIT	1.0	1	1	1368	6	40	23	69	
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR 4-UNIT	4 UNIT	1.0	1	1	1266	9	60	23	92	
12530AR	PUMP STA POL 6IN LINE 1 PUMP 600GPM	600 GPM	785 BPH	1.0	9	48	41366	209	1012	368	1589
61180AA	TANK, POL, 100 BARREL, W/4 IN PIPE	100 BBL	100 BBL	2.0	6	32	11256	58	173	69	300
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	500 BBL	1.0	1	7	6442	52	207	86	345
161050BF	HOTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	20FTX40FT	1.0	7	15	11731	37	526	196	759
72321BC	LAT PIT TYPE FEMALE 2 SEATS	10X10	10X10X8FT	2 SEAT FEMALE	1.0	5	6	1028	129	18	147
81260AB	ELEC DISTR POL PUMP STA 6 IN LINE	2	AS REQUIRED	1.0	3	6	14092	81	276	175	532
84330AD	FIREFIGHT SYS EQP FOAM,POL 3000GAL		AS REQUIRED	1.0	1	5	17434		37		37
85110CJ	ROAD PAVEMENT,CLASS C,STAB SURFACE		ONE LANE	.4	177	119	884	57		18	75
85130KB	ROAD,CLASS C,GRADED AND DRAINED 1MI		ONE LANE	.4	1	2	538	1185		748	1933
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	TYPE Y	2.0	14	16	2808	110	511	515	1136
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	MAN/VEH	6.0	12	12	1992	55	828	331	1214
				857	1213	742627	2193	10734	7538	20465	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL PIPELINE PUMP STATION.TWO 6 INCH DIESEL DRIVEN PUMPS,19
MILES OF 6 INCH PIPE AND TUBING,1570 BPA CAPABILITY.

PD1269

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED			MATERIALS		CONSTR EFFORT IN MANHOURS		
				WT-ST	VOL-MT	COST	HORZ	VERT	GENL		TOT
12510BA	PPLN POL 1 MILE OF 6 INCH GROOVE	1MILE-6INCH	AS REQUIRED	2.0	60	100	64416	69	736	506	1311
12510BE	PPLN POL 5 MILE OF 6 INCH GROOVE	5 MILES-6 IN	AS REQUIRED	3.0	441	717	476826	173	5003	3795	8971
12510BN	PPLN POL 1 MILE- 6 IN API GROVE	1 MILE	AS REQUIRED	2.0	118	126	89200	92	1196	667	1955
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	2 UNIT	1.0	1	1	1368	6	40	23	69
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR	4-UNIT	4.UNIT	1.0	1	1	1266	9	60	23	92
12530AT	PUMP STA POL 6IN TWO PUMPS 1200 GPM	1200 GPM	785 BPH	1.0	14	92	76277	235	1198	442	1875
61180AA	JANKE POL, 100 BARREL, W/4 IN PIPE	100 BBL	100 BBL	2.0	6	32	11256	58	173	69	300
61180AC	TANK, POL, 500 BARREL, W/4 IN PIPE	500 BBL	500 BBL	1.0	1	7	6442	52	207	86	345
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40XBFT	20FTX40FT	1.0	7	15	11731	37	526	196	739
72321BC	LAT PIT TYPE FEMALE 2 SEATS 10X10	10X10X8FT	2 SEAT FEMALE	1.0	5	6	1028	129	18	147	
81260AB	ELEC DISTR POL PUMP STA 6 IN LINE	2	AS REQUIRED	1.0	3	6	14092	81	276	175	532
84330AD	FIREFIGHT SYS EQP FOAM,POL 3000GAL		AS REQUIRED	1.0	1	5	17434	37			37
85110CJ	ROAD PAVEMENT,CLASS C,STAB SURFACE		ONE LANE	.4	177	119	884	57		18	75
85130KB	ROAD,CLASS C,GRADED AND DRAINED TMI		ONE LANE	.4	1	2	538	1185		748	1933
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	TYPE Y	2.0	14	16	2808	110	511	515	1136
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	MAN/VEH	6.0	12	12	1992	55	828	331	1214
				862	1257	777538	2219	10920	7612	20751	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL TANK TRUCK LOADING STATION. 2 STATIONS, 4 UNITS.
 TEMP, TROP, DST & FRIGID CLIM. LOAD 5000 GALLON TRUCKS AT RATE
 OF TWENTY TRUCKS/DAY/PRODUCT. TANKS, PPLNS, MANIFOLDS, PUMPS,
 OPERATIONS BLDG TO HANDLE 4 PRODUCTS OR LESS. REQUIRES 60 AC
 RES. 185 CY FINE AGGR. 290 CY COARSE AGGR. ONLY HAND EXT. IN
 CLUDGED W/INSTALLATION AS FIREFIGHTING EQUIP.

PE1019

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED	MATERIALS			CONSTR EFFORT IN MANHOURS			
					WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12510AE	FLOOD PMP 785 BPH 6IN MANIFOLD	785 BPH	AS REQUIRED	1.0	10	19	21960	12	247	63	322
12510AL	DIST MNFLD F/DRUM & CAN LOADG INSTL	785BPH, 6-IN	AS REQUIRED	1.0	1	1	1792	6	52	12	70
12510AT	PPLN POL 1000 FT OF 4 INCH GROOVE	1000FT-4IN	AS REQUIRED	1.0	3	5	2498	12	85	41	138
12510BA	PPLN POL 1 MILE OF 6 INCH GROOVE	1MILE-6INCH	AS REQUIRED	8.0	240	400	257664	276	2944	2024	5244
12510BJ	PPLN POL 1M FT OF 6 IN API GROOVE	1000 FT	AS REQUIRED	2.0	22	26	16526	12	265	161	638
12530AH	LOADING PMP FOR 2TNK/TRK/5CAR INSTL	700X1400 BPH	AS REQUIRED	4.0	32	100	73772	46	391	115	552
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR	2-UNIT	AS REQUIRED	3.0	3	3	6104	17	121	69	207
12630AA	LDG FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED	1.0	12	12	13862	173	374	1213	1760
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	3.0	15	30	15606	86	365	155	586
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610
41180AG	TANK, POL, 3000 BARREL, W/6 IN PIPE	3000 BBL	AS REQUIRED	8.0	16	256	100304	828	2852	1932	5612
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	2.7	19	22	3791	169	689	696	1534
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404

385 906 531532 1764 9535 6937 18236

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL TANK CAR LOADING STATION/S STATIONS.
 TEMP,TROP,DST & FRIGID CLIM. LOAD FIFTEEN 10 THOUSAND GALLON
 RAILWAY TANK CARS PER DAY. PROVIDES TANKS,PPLNS,MANIFOLDS,
 PUMPS,OPERATIONS BLDG TO HANDLE 4 PRODUCTS OR LESS. REQUIRES
 41 ACRES. 185CY FINE AGGR. 290CY COARSE AGGR. ONLY HAND EXT
 INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PE1029

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS
12510AE	FLOOD PMP 785 BPH 6IN MANIFOLD	785 BPH	AS REQUIRED
12510AL	DIST MNFLD F/DRUM & CAN LOADG INSTL	785BPH,6-IN	AS REQUIRED
12510AT	PPLN POL 1000 FT OF 4 INCH GROOVE	1000FT-6IN	AS REQUIRED
12510BA	PPLN POL 1 MILE OF 6 INCH GROOVE	1MILE-6INCH	AS REQUIRED
12510BJ	PPLN POL 1M FT OF 6 IN API GROOVE	1000 FT	AS REQUIRED
12530AH	LOADING PMP FOR 2TNK/TRK/SCAR INSTL	700X1400 BPH	AS REQUIRED
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED
12640AA	TANK CAR LOADING, POL, FOR LOADING 5-TANK CARS		AS REQUIRED
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED
41180AG	TANK, POL, 3000 BARREL, W/6 IN PIPE	3000 BBL	AS REQUIRED
161050BF	HQTRS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED

QUANTITY REQUIRED	MATERIALS			CONSTR EFFORT			IN MANHOURS	
	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT	
1.0	10	19	21960	12	267	63	322	
1.0	1	1	1792	6	52	12	70	
1.0	3	5	2698	12	85	41	138	
8.0	240	400	257664	276	2944	2024	5244	
2.0	22	26	16526	12	265	161	438	
4.0	32	100	73772	46	391	115	552	
3.0	3	3	6104	17	121	69	207	
1.0	35	61	53557	598	1840	4025	6463	
3.0	15	30	15606	86	345	155	586	
1.0	1	13	9258	92	368	150	610	
8.0	16	256	100304	828	2852	1932	5612	
1.0	7	15	11731	37	526	196	759	
2.7	19	22	3791	149	689	696	1534	
2.0	4	4	664	18	276	110	404	
	408	955	571227	2189	11001	9749	22939	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL TANK CAR LOADING STATION 10 STATIONS.
TEMP,TROP,DT, & ERGID CLIM. LOAD THIRTY 10 THOUSAND GALLON
RAILWAY TANK CARS PER DAY. PROVIDES TANKS,PPLNS,MANIFOLDS,
PUMPS,OPERATIONS BLDG TO HANDLE 4 PRODUCTS OR LESS. REQUIRES
42 ACRES. 185CY FINE AGGR. 290CY COARSE AGGR. ONLY HAND EXT
- INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PE1039

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT			IN MANHOURS	
				REQUIRED	WT-ST	VOL-MT	COST	HQRZ	VERT	GENL	TOT	
12510AF	FLOOD PMP. 1355 BPH. 8IN. MANIFOLD	1355 BPH	AS REQUIRED	1.0	11	20	20627	23	322	92	437	
12510AM	DIST MNFLD F/10STA-TNK CAR LDG INST	10STATION	AS REQUIRED	1.0	2	2	2464	6	52	12	70	
12510AI	PPLN POL. 1000 FT OF 4 INCH GROOVE	1000FT-4IN	AS REQUIRED	1.0	3	5	2498	12	85	41	138	
12510BB	PPLN POL 1 MILE OF 8 INCH GROOVE	1 MILE-8INCH	AS REQUIRED	8.0	288	696	302376	368	4140	2944	7452	
12510BJ	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	2.0	22	26	14526	12	265	161	438	
12510BK	PPLN POL 1M FT OF 8 IN API GROOVE	1000 FT	AS REQUIRED	.5	7	8	1750	6	115	81	202	
12530AJ	LOADING PMP. FOR 1QTNK/CAR INSTL.	2000-2500BPH	AS REQUIRED	4.0	56	164	111960	69	506	207	782	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR 2-UNIT		AS REQUIRED	3.0	3	3	4104	17	121	69	207	
12640AB	TANK CAR LOADING, POL, FOR LOADING 10-TANK CARS		AS REQUIRED	1.0	74	75	71174	782	2392	5244	8418	
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE	250 BBL	AS REQUIRED	3.0	15	30	15606	86	345	155	586	
41180AE	TANK POL 1000 BARREL W/4 IN PIPE	1000 BBL	AS REQUIRED	1.0	1	13	9258	92	368	150	610	
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE	3000 BBL	AS REQUIRED	8.0	16	256	96352	828	2852	2024	5704	
161050BE	HQT.RS & UNIT SUPPLY&GO STL FR	20X40X8FT	AS REQUIRED	1.0	7	15	11731	37	526	196	759	
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	2.7	19	22	3791	149	689	696	1534	
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404	
				528	1339	668881	2505	13054	12182	27741		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL TANK CAR UNLOADING STATION, 5 STATIONS.
 TEMP, TROP, DST & FRIGID CLIM. UNLOADS UP TO FIFTY 10000 GALLON RAILWAY TANK CARS /10HR DAY. PROVIDES TANKS, PPLNS, MANIFOLD S, PUMPS, OPERATIONS BLDG TO HANDLE 4 PRODUCTS OR LESS. REQUIRES 27 ACRES. 2CY FINE AGGR. 3CY COARSE AGGR. ONLY HAND EXT. INCLUDED W/INSTALLATION AS FIREFIGHTING EQUIP.

PE1049

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12665AA	FUEL TRANSFER, POL, TANK CAR UNLOAD 5 STA-2 PROD AS REQUIRED			1.0	45	67	79691	63	426	161	650
87210AR	SECURITY FENCE TYPE Y 1000 FEET	1000 FEET	AS REQUIRED	1.0	7	8	1404	35	255	258	568
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	AS REQUIRED	2.0	4	4	664	18	276	110	404
						56	81759	136	957	529	1622

DDEXER4

RUN DATE 860207

DESERT CLIMATE

POL TANK CAR LOADING STATION. 2 STATIONS, 4-UNIT.
 TEMP., TROP., DS, & FRIGID. CLIM. PROVIDES TANK TRUCK LOADING FOR
 2 STATION AT TANK FARM. THE EXISTING FUEL STORAGE TANKS OF
TANK FARM ARE CONNECTED TO THE LOADING STAND. LOADS 5000 GAL
 . TRUCKS AT RATE OF 20 TRUCKS/DAY/PRODUCT. LINES FOR 4 PROD.
REAL EST. REQUIREMENT 4 ACRES. 6CY. FINE AGGR. 12CY. COARSE
 AGGR. ONLY HAND EXT. INCLUDED W/INSTALLATION AS FIREFIGHTING

PE1059

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS
12510BJ	PPLN POL 1M FT OF 6 IN API GROOVE	1000 FT	AS REQUIRED
12530AH	LOADING PMP FOR 2TNK/TRK/5CAR INSTL	700X1400 BPH	AS REQUIRED
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR	4-UNIT	AS REQUIRED
12630AA	LGD FACIL FOR TWO FUEL TRUCKS	2-STATION	AS REQUIRED

QUANTITY REQUIRED	MATERIALS		CONSTR EFFORT			IN MANHOURS	
	WT-ST	VOL-MI	COST	HORZ	VERT	GENL	TOT
2.0	22	26	16526	12	265	161	438
4.0	32	100	73772	46	391	115	552
2.0	2	2	2492	18	120	46	186
1.0	12	12	13862	173	374	1213	1760
	68	140	104652	249	1150	1535	2934

DDEXER4

RUN DATE 860207

DESERT CLIMATE

TEMPERATE CLIMATE., TACTICAL, POL, 50M BSL STOR COEC W/6IN SUBM
 PPLN & 6 BUOYANT HOSELINE FOR TKR DISCHARGE, TEM, TROP & DST
 CLIM. DISCHARGE AND TRANSFER CAPACITY OF 600 GPM AND STOR.
 OF 3 PROD OR LESS/MOGAS, JP-4 & DIESEL FUEL).
 REQUIRES 160 ACRES.

PF1015

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY REQUIRED		MATERIALS		CONSTR EFFORT IN MANHOURS		
				WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
12665AN MARINE TERM 50M BSL STOR CAP	50000 BBL	AS REQUIRED	1.0	6	250	575092	2645	4255	1724	8626
85190AA ROAD BEACH 2 LN PORT MAT SURF 1 MI		ACCESS ROAD	.4	197	120	49913	414	879	879	1293
87190AB CLEARING AND GRUBBING ONE ACRE		SITE PREP.	160.0				6256		6624	12880
87210AY TRIPLE STANDARD CONCERTINA FENCE		SECURITY FENCE	20.0	20	60	76840	2438	12190	12190	14628
				223	430	701845	8901	7107	21487	37495

DDEXER4

RUN DATE 860207

DESERT CLIMATE

FABRICATION PLANT, PANELIZED WOOD BUILDING SUB-FACILITY ASSEMBLY AND STORAGE AREA 12.9 ACRES REQUIRED FOR REAL ESTATE.
REQUIRED FROM LOCAL SOURCE, FINE AGGREGATE 2026 CY, COARSE AGGREGATE 2616 CY. POWER REQUIREMENT MUST BE DETERMINED AND APPROPRIATE AFCS FACILITY SELECTED.

PY2894

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
22892AA	SAW HORSE FOR PAN.WD.BLDG.FAB.WORK.		2 PER INST	2.0			58			5	5
22892AB	FABRICATION JIG WOOD FLOOR PANELS		2 PER INST	2.0	2	2	326		37		37
22892AC	FABRICATION JIG 6-8FT WALL PANELS		4 PER INST	4.0		4	576		64		64
22892AD	FABRICATION JIG 12FT WALL PANELS		2 PER INST	2.0	2	2	320		37		37
22892AE	FABRICATION JIG 24FT TRUSSES		2 PER INST	2.0	2	4	748		83		83
22892AF	FABRICATION JIG 30FT TRUSSES		2 PER INST	2.0	4	6	1082		92		92
22892AG	FABRICATION JIG 36FT TRUSSES		2 PER INST	2.0	4	6	998		87		87
22892AH	FABRICATION JIG ROOF PANELS		2 PER INST	2.0	2	2	396		46		46
22892AJ	FABRICATION JIG BOX BEAMS		2 PER INST	2.0	2	2	652		28		28
72321BD	LAT PIT TYPE 160MAN 8 SEATS 10X20	10X20X8	1 PER INST	1.0	8	9	1559	2	230	37	269
86330AC	SUMP FIRE PROTECTION 10000 GAL	10000 GAL	EFF RAD 500FT	1.0	7	5	145	18	124	133	275
187190AA	SITE PREPARATION, ONE ACRE		BUILDINGS	2.5				253		92	345
87210AP	SECURITY FENCE TYPE X 1000 FEET	1000 FEET	PERIMETER	2.0	16	18	3312	106	584	589	1279
87210AT	VEH-MAN GATE FOR SECURITY FENCE	1	2 PER INST	2.0	4	4	664	18	276	110	404
87230AA	SENTRY BOX 4X4		2 PER INST	2.0			244	219	920	460	1599
93112AA	BLDG/PANELIZED WD 12X24X8FT C/F D/T		6 PER INST	6.0	66	36	9846	97	1201	711	2009
93112LA	BLDG/PANELIZED WD 144X140X12FT D/T		1 PER INST	1.0	739	2828	256776	436	6972	3856	11264
				858	2928	277702	1149	10781	5993	17923	

DDEXER4

RUN DATE 860207

DESERT CLIMATE

PRE-PACKAGED CULVERT SECTIONS IN ASSORTED SIZES AND SANDBAGS
FOR ROAD CONSTRUCTION AND REPAIR.

YY1009

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
99999AA	PRE-PKG'D DRAINAGE-FLD FORTS CULVERT		AS REQUIRED	1.0	5	13	6566				
99999AB	PRE-PACKAGED DRAINAGE SUPPLIES CULV		AS REQUIRED	1.0	5	12	4391				
99999AC	PRE-PACKAGED DRAINAGE SUPPLIES CULV		AS REQUIRED	1.0	4	14	3663				
99999AD	PRE-PACKAGED DRAINAGE SUPPLIES CULV		AS REQUIRED	1.0	4	16	3175				
99999AE	PRE-PACKAGED SANDBAGS MULTI-PURPOSE		AS REQUIRED	1.0	5	18	5963				
					23	73	21738				

DDEXER4

RUN DATE 860207

DESERT CLIMATE

CONTAINERIZED SUPPLIES FOR CONSTRUCTION OF FIELD FORTIFICATIONS.

YY1019

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MI	COST	HORZ	VERT	GENL	TOT
99999AA PRE-PKG'D DRAINAGE-FLD FORTS. CULVERT			AS REQUIRED	1.0	5	13	6366				
99999AE PRE-PACKAGED SANDBAGS MULTI-PURPOSE			AS REQUIRED	1.0	5	18	5963				
99999AF FIELD FORTS- BARBED-TAPE CONCERTINA			AS REQUIRED	1.0	2	16	12390				
99999AG FLD FORTS-BARBED WIRE-POSTS-STL SEC			AS REQUIRED	1.0	8	15	5266				
99999AH LUMBER 2 X 12 FLD FORTS & GEN CONST			AS REQUIRED	1.0	16	49	6324				
99999AJ STRUCTURAL TIMBER 3IN X 10IN			AS REQUIRED	1.0	16	49	7824				
					52	160	42313				

DDEXER4

RUN DATE 860207

DESERT CLIMATE

PRE-PACKAGED CONSTRUCTION SUPPLIES (LUMBER, HARDWARE,
ELECTRICAL AND PLUMBING FIXTURES, ETC) FOR GENERAL
CONSTRUCTION AND RENOVATION.

YY1029

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS		CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
99999AH	LUMBER 2 X 12 FLD. FORTS & GEN CONST		AS REQUIRED	1.0	16	49	6324				
99999AJ	STRUCTURAL TIMBER 3IN X 10IN		AS REQUIRED	1.0	16	49	7824				
99999AK	PLYWOOD-LUMBER & CORR SHEET METAL		AS REQUIRED	1.0	21	59	12639				
99999AL	ASSORTED SIZES OF STRUCTURAL LUMBER		AS REQUIRED	1.0	16	49	5349				
99999AM	ASSORTED CONST SUPPLIES & HARDWARE		AS REQUIRED	1.0	11	20	12614				
99999AN	ASSORTED ELEC SUPPLIES & FIXTURES		AS REQUIRED	1.0	9	38	52212				
99999AP	ASSORTED PLUMBING SUPPLIES/FIXTURES		AS REQUIRED	1.0	2	12	3755				
					91	276	100517				

DDEXER4

RUN DATE 860207

DESERT CLIMATE

PRE-PACKAGED MULTI-PURPOSE RIGGING KIT W/ASSORTED SIZES OF
FIBER ROPE, WIRE ROPE, CHAIN AND RELATED ACCESSORIES.

YY1039

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS			CONSTR EFFORT IN MANHOURS			
				REQUIRED	WT-ST	VOL-MT	QST	HORZ	VERT	GENL	TOT		
99999AR	PRE-PACK MULTI-PURPOSE RIGGING KIT	AS REQUIRED		1.0	7	14	13090						
					7	14	13090						

DDEXER4

RUN DATE 860207

DESERT CLIMATE

PRE-PACKAGED MARKING & CAMOUFLAGE KIT W/MARKING & CAMOUFLAGE PAINT AND CAMOUFLAGE NETS-WOOLAND RADAR SCATTERING. YY7049
19

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY			MATERIALS		CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST	VOL-MT	COST	HORZ	VERT	GENL	TOT
99999AT	MARKING PAINT & CAMOU PAINT & NETS	AS REQUIRED		1.0	5	19	21159				
					5	19	21159				

DDEXER4

RUN DATE 860207

DESERT CLIMATE

~~PRE-PACKAGED MARKING & CAMOUFLAGE KIT W/MARKING & CAMOUFLAGE PAINT AND CAMOUFLAGE NETS-DESERT RADAR SCATTERING.~~

YY1059

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS REQUIRED HI-ST VOL-MI	CONSTR EFFORT IN MANHOURS		
				REQUIRED	HI-ST VOL-MI		COST	HRS	VERT
99999AV	MARKING PAINT & CAMO PAINT & NETS	AS REQUIRED		1.0	4	15	8160		
				4		15	8160		

DDEXER4

RUN DATE 860207

DESERT CLIMATE

PRE-PACKAGED HAND TOOL KIT FOR USE BY INDIGENOUS LABOR.

YY1069

FAC NUMBER	FACILITY DESCRIPTION	SIZE OR UNIT	BASIS	QUANTITY		MATERIALS COST	CONSTR EFFORT IN MANHOURS		
				REQUIRED	WT-ST		VOL-MT	HORZ	VERT
99999AU	PRE-PACK INDIGENOUS LABOR TOOL KIT		AS REQUIRED	1.0		373			373

END REPORT DDEXER4

CHAPTER 10
LISTING OF FACILITIES-TEMPERATE

10-1. Index of Facilities (Temperate)

<i>Description</i>	<i>Category No.</i>
Access Apron, Hangar.....	11340
Administration	61025
Air Conditioning.....	82610
Aircraft Defueling/Decontamination Apron.....	11371
Aircraft Loading Apron	11380
Air Washing Apron	11370
Airfield Surfacing.....	11150
Ammunitions Storage.....	42183
Approach Trestle (Ports)	86090
Approach Zone (Airfields).....	11110
Athletic Court	75013
Barbed Concertina Obstacle.....	87210
Barracks.....	72111
Bath House	72332
Boiler Plants.....	82150
Booster Station, POL	12530
Bridges, Railroad, (Superstructure and Substructure).....	86030
Bridges, Road (Superstructure and Substructure).....	85120
Buildings, Panelized.....	93112
Buildings, Pre-engineered Metal.....	93101
Buildings, Wood	93111
Camouflage	14991
Carpentry Shop	22990
Carrier & Repeater Station	13190
Casualty Receiving (See Hospitals).....	51010
Cell Blocks.....	73015
Cesspools	83190
Chapels.....	74018
Chlorination.....	83110
Classroom, Training, Outdoor	17120
Clear Zone (Airfields)	11110
Clearing and Grading	87190
Communications	21430
Compass Swing Base, Heliport	11610
Confinement	73015
Control Tower, Aircraft	13315
Craft Shop.....	74022
Day Room	74069
Demolition	93310
Dental (See Hospitals)	53020
Dispensary (See Hospitals)	55010
Drainage Structures	85210
Dry Cargo Storage (See Supply)	44110
Education.....	74025
Electrical Kits	81231
Electric Power Generation and Distribution	81110
Engine House, Railroad.....	21860
Equipment for Combat Tasks	99999
Erdlator Building.....	84110

<i>Description</i>	<i>Category No.</i>
Exchanges	74040
Fabrication Jigs, Panelized Buildings	22892
Fencing	87210
Field Fortification	14910
Film Exchange	74040
Finance	61027
Firefighting System	84340
Firehouse	14111
Floodlighting	81230
Fueling System, Rear Area (Aircraft)	12110
Generating Plant	81110
General Purpose Buildings	93101
Guardhouse	73015
Guard Tower	87220
Hangars, Aircraft	21110
Hardstands	85110
Headquarters	61050
Heliports	11120
Hospitals	51010
Housing (Also Listed Under Buildings)	72111
Hydrant Refueling System, Air Transportable	12110
Ice Plants	89050
Jetty, POL	16440
Kitchens	72210
Laboratory, POL	31090
Lagoon, Sewage	83120
Landing Ramp	14970
Latrines	72321
Laundries	73030
Library	74041
Lubrication Racks	21411
Magazine	42283
Maintenance	21110
Marine Railway	21320
Marine Terminal, Tactical	12665
Medical (See Hospitals)	51010
Mess Halls (See Kitchens)	72210
Minefields	14990
Motion Picture Laboratory	22890
Operations Building, Airfield	14110
Panelized Wood Building	93112
Parking Pad, Helicopter	11320
PECS (Containerized Kits)	99999
Petroleum, Oil and Lubricants (POL)	12474
Pharmacy (See Hospitals)	51010
Piers	15150
Pipelines	12510
Platform, Unloading	86090
Ports	15250
Portable Buildings	72111
Postal	74059
Pre-engineered Metal Buildings	93101
Pump Station, POL	12530
Quarters	72410

<i>Description</i>	<i>Category No.</i>
Railroads.....	21840
Railway, Marine	21320
Recreational.....	74069
Refueling Pad	12110
Refrigeration	43190
Relay Station, Communication	13190
Repair Shops (See Maintenance and Shops)	21330
Revetment	14910
Roads, Paved or Graded.....	85130
Runway (C-130 Aircraft).....	11110
Sanitary (See-Latrines and Sewage Treatment)	72321
Security (See Cell Blocks and Fencing).....	73015
Septic Tanks	83120
Service Club	74068
Sewage Treatment.....	83110
Shelter	14931
Signal (See Communications)	13120
Site Preparations (See Clearing and Grading)	87190
Shop, Automotive	21410
Shop Buildings (See Buildings)	21330
Shop, Carpentry	22990
Shop, Craft.....	74022
Shop, Maintenance, Wood and Steel	22990
Shop, Marine Repair	24330
Shop, Motor Repair	21410
Shop, Ordnance, Artillery & Fire Control.....	21430
Shop, Railroad Machine	21840
Shop, Railroad Car Repair	21840
Shop, Signal Maintenance.....	21720
Shop, Vehicle Maintenance.....	21410
Snack Bar	74062
Special Purpose Apron.....	11382
Special Services Building.....	74069
Standard Details.....	99980
Storage (See Supply).....	42183
Storehouse.....	44110
Submarine Pipeline (See Petroleum, Oil and Lubricants)	12590
Substations	81320
Sump, Fire Protection	84330
Supply.....	44110
Surgery (See Hospitals)	51010
Tank Car & Truck Loading & Unloading (See POL)	12640
Tanks, POL.....	12640
Tanker Mooring.....	12471
Taxiway, On-Off (C-130 Aircraft).....	16390
Telephone (See Communications)	11110
Tentage.....	13180
Tent Frames	72520
Theaters.....	74067
Transformers.....	81260
Training Facilities.....	17220
Utility Building	51010
Ventilation	82610
Walkway	51010

<i>Description</i>	<i>Category No.</i>
Wards (See Hospitals)	51010
Warehouse Buildings (See Buildings).....	44110
Warm-up Apron	11350
Wash Rack, Vehicle.....	21410
Water Distribution	84210
Water Supply & Treatment.....	84210
Water Tank	83120
Wharf (See Ports)	15250
X-Ray (See Hospitals)	53020

10-2. Listing of Facilities (Temperate)

10-4

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
11130AA	HELIPORT/C47 SLINGOUT AREA FOR AMMO STORAGE INSTALLATIONS. INCLUDES PARKING PAD AND APPROACH-DEPARTURE ZONE REQUIREMENTS	11	7	6,894	1,195		558	1,753
11130AB	HELIPAD, XCH54] & PARKING PAD, 100X100FT W/APPROACH/DEPARTURE ZONES 1500FT. PAVE 1-1/2-IN HOT-MIX. SEE DWG FP1105-1115-SH1	152	120	3,797	18		41	59
11150AA	AIRFIELD SURFACING, M8A1 NON-PIERCED STEEL MAT, 1000 SQ YDS	34	21	8,584	2		67	69
11150AB	AIRFIELD RUNWAY SURFACING, T17 NEOPRENE-COATED NYLON MEMBRANE 1000 SQ YD	3	6	6,275	6		29	35
11150AC	AIRFIELD SURFACING, FIBERGLASS REINFORCED PLASTIC MATTING, 1000 SQ YD	8	4	63,024	6		25	31
11150AD	AIRFIELD SURFACING, XM18 ALUMINUM MAT, 125,000 SQ FT	5	7	493,923	25		225	250
11150AE	AIRFIELD SURFACING, XM19 ALUMINUM MAT, 125,000SQ FT	3	250	727,650	37		375	412
11150AF	RAPID RUNWAY REPAIR USING AM-2 MATTING (3 CRATERS)	319	226	38,477	104	14	166	284
11150AG	BOMB DAMAGE REPAIR TO USAF RUNWAYS, TAXIWAYS, AND APRONS (THREE CRATERS), 1260 SQ YDS	424	282	57,965	87	14	106	207
11150AH	BOMB DAMAGE REPAIR OF USAF RUNWAYS, TAXIWAYS, AND APRONS USING REGULATED SET CEMENT 1434 SQ YDS	462	304	9,500	77	28	69	174
12110AE	FORWARD AREA REFUELING EQUIPMENT SYSTEM (FARE) W/TANKAGE 1000 GAL STORAGE CAPACITY	1	3	12,037		28	18	46
12110AF	FORWARD AREA REFUELING EQUIPMENT SYSTEM (FARE) W/TANKAGE 5000 GAL STORAGE CAPACITY		3	13,533		28	28	50
12110AG	FORWARD AREA REFUELING EQUIPMENT SYSTEM (FARE) W/TANKAGE 10000 GAL STORAGE CAPACITY	1	4	14,473		30	41	71
12110AH	SUPPORT AREA REFUELING SYSTEM 30000 GAL STORAGE CAPACITY FOR ROTARY AND FIXED WING AIRCRAFT	8	20	65,526	175	133	368	670

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	IN HRS	GENL TOT
12110AJ	CONSIST OF 1-50,000 GAL COLLAPSIBLE STORAGE TANK CONNECTING HOSE AND FITTING, CONCERTINA FENCING AND THE NECESSARY SITE WORK. THE STORAGE CAPACITY OF THE SYSTEM CAN BE INCREASED IN INCREMENTS OF 50,000 GAL BY ADDING THE REQUIRED NUMBER OF THIS FACILITY TO THE SYSTEM	5	5	16,865	74	64	167	285
12110AK	REAR AREA FUELING SYSTEM, 300,000 GAL STORAGE CAPACITY, FOR ROTARY AND FIXED WING AIRCRAFT	15	45	156,850	248	189	442	879
12110AL	SUPPORT AREA REFUELING SYSTEM, 30,000 GAL STORAGE CAPACITY, FOR ROTARY AND FIXED WING AIRCRAFT W/FLIGHT LINE MANIFOLD 12 POINTS	7	16	55,264	184	161	405	750
12110AM	REAR AREA FUELING SYSTEM, 300,000 GAL STORAGE CAPACITY, FOR ROTARY AND FIXED WING AIRCRAFT W/FLIGHT LINE MANIFOLD, 24 POINTS	19	54	194,480	106	541	299	944
12110AN	SUPPORT AREA REFUELING SYSTEM W/STANDARD MILITARY APPURTENANCES, 30,000 GAL STORAGE CAPACITY, FOR ROTARY AND FIXED WING AIRCRAFT, W/FLIGHT LINE MANIFOLD, 12 POINTS	6	11	17,085	69			69
12471AA	TANKS, COLLAPSIBLE W/EQUIPMENT, POL, 50000 GAL TOTAL CAPACITY FIVE 10000 GAL TANKS W/ONE CENTRIFUGAL PUMP & FITTINGS	7	22	49,987	12	63	17	92
12471AB	TANKS, COLLAPSIBLE W/EQUIPMENT, POL, 100000 GAL TOTAL CAPACITY TEN 10000 GAL TANKS W/ONE CENTRIFUGAL PUMP & FITTINGS	10	32	77,552	29	81	29	139
12471AC	TANKS, COLLAPSIBLE W/EQUIPMENT, POL, 40000 GALLON TOTAL CAPACITY - FOUR 10,000 GAL TANKS W/CENTRIFUGAL PUMP, POL MANIFOLD, TWO PORTABLE TRUCK FILL STANDS AND FITTINGS	5	13	22,547	6	58	29	93
12490AA	SEPARATOR FILTER. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.	1	7	3,257	6	23	8	37

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL	TOT
12502AA	PUMP, CENTRIFUGAL, 1050 GPM, 850FT HD, W/8IN MANIFOLD 1-TWO STAGE PUMP W/FLEXIBLE HOSE, PIPE TRANSITION PIECES, W/VALVES, SKID MOUNTED	9	26	27,348	74	175	55	304
12503AA	SWITCHING MANIFOLD, POL FOR PUMP STATION&TANK FARM, 10IN BOTTOM PIPE, 8IN TOP PIPE W/3-WAY BALL VALVES FOR PUMP OR P/L CONNECTION, W/FLEXIBLE HOSE AND PIPE TRANSITION PIECES, SKID MOUNTED	8	31	63,135	74	175	55	304
12504AA	METER, TURBINE, 1050 GPM, 10IN PIPE, W/FLEXIBLE HOSE AND PIPE TRANSITION PIECES, SKID MOUNTED	8	14	2,551	74	175	55	304
12505AA	FILTER COALESCER, 1050 GPM, 300PSI W/10IN PIPE, MANIFOLDING & VALVE, W/FLEXIBLE HOSE&PIPE TRANSITION PIECES, SKID MTD	9	32	75,000	74	175	55	304
12506AA	PIPELINE BARREL CLEANER TRAP W/3 6IN GATE & 2 4IN GATE VALVES W/6IN SPOOL PIECES.	4	4	6,995	21	123	52	196
12506AB	PIPELINE BARREL CLEANER TRAP W/3 8IN GATE & 2 4IN GATE VALVES W/8IN SPOOL PIECES.	5	4	6,737	21	123	52	196
12506AC	PIPELINE BARREL CLEANER TRAP W/3 10IN GATE&2 4IN GATE VALVE S W/10IN SPOQL PIECES	7	13	8,851	21	123	52	196
12510AA	SWITCHING MANIFOLD, POL, FOR TANK FARM, 4 IN PIPE & FITTINGS, W/O PUMP	4	4	11,268	12	186	46	242
12510AB	SWITCHING MANIFOLD, POL, FOR TANK FARM, 6 IN PIPE & FITTINGS, W/O PUMP	9	9	15,541	12	173	58	243
12510AC	SWITCHING MANIFOLD, POL, FOR TANK FARM, 8 IN PIPE & FITTINGS, W/O PUMP	16	16	19,680	12	207	69	288
12510AD	SWITCHING MANIFOLD, POL, FOR TANK FARM, 12 IN PIPE & FITTINGS, W/O PUMP	26	23	97,212	35	276	92	403
12510AE	FLOOD PUMP, POL, 785 BPH, W/6 IN MANIFOLD, 2-SINGLE STAGE PUMPS	10	19	21,960	12	247	63	322

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST. EFFORT IN MAN-HOURS			
					HOR	VERY	GENL	TOT
12510AF	FLOOD PUMP, POL, 1355 BPH, W/8-INCH MANIFOLD, 2-SINGLE STAGE PUMPS.	11	20	20,627	23	322	92	437
12510AG	FLOOD PUMP, POL, 1355 BPH, W/12-INCH MANIFOLD, 2 SINGLE	14	21	50,497	23	414	115	592
12510AH	TANK PUMP, POL, 700 BPH, W/6 IN MANIFOLD, 1-SINGLE STAGE PUMP	4	8	7,742	6	40	12	58
12510AJ	TANK PUMP, POL, 1400 BPH, W/8 IN MANIFOLD, 1-SINGLE STAGE PUMP	6	9	7,937	6	40	12	58
12510AK	TANK PUMP, POL, 2800 BPH, W/12 IN MANIFOLD, 1-TWO STAGE PUMP	7	14	16,254	6	46	17	69
12510AL	DISTRIBUTION MANIFOLD, POL, 785 BPH, 6 IN PIPE, FOR DRUM & CAN LOADING INSTALLATION	1	1	1,792	6	52	12	70
12510AM	DISTRIBUTION MANIFOLD, POL, 8-INCH PIPE FOR 10 STATION TANK CAR LOADING INSTALLATION.	2	2	2,664	6	52	12	70
12510AN	TRANSFER PUMP, POL, 700 BPH, W/6 IN MANIFOLD, 1-SINGLE STAGE PUMP	11	15	18,715	35	265	58	358
12510AP	TRANSFER PUMP, POL, 1600 BPH, W/8 IN MANIFOLD, 1-SINGLE STAGE PUMP	12	16	16,109	40	282	58	380
12510AR	TRANSFER PUMP, POL, 2800 BPH, W/12 IN MANIFOLD, 1-TWO STAGE PUMP	18	21	78,664	52	397	81	530
12510AT	PIPELINE, POL, 1000 FT OF 6 IN GROOVED LT WT TUBING, W/COUPLINGS, W/O VALVES	3	5	2,698	12	85	41	138
12510AU	PIPELINE, POL, 1000FT OF 6 IN GROOVED LT WT TUBING, W/COUPLINGS, W/O VALVES	6	11	5,196	12	86	52	150
12510AV	PIPELINE, POL, 1000 FT OF 8 IN GROOVED LT WT TUBING, W/COUPLINGS, W/O VALVES	6	15	9,258	12	127	69	208

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL TOT
12510AW	PIPELINE, POL, 1000 FT OF 12 IN GROOVED LT WT TUBING, W/COUPLINGS, W/O VALVES	9	32	4,440	17	226	81 322
12510AY	PIPELINE, POL, 1 MILE OF 6 IN GROOVED LT WT TUBING, W/COUPLINGS, W/2 GATE & 1 CHECK VALVE	13	23	11,886	23	230	184 437
12510BA	PIPELINE, POL, 1 MILE OF 6 IN GROOVED LT WT TUBING, W/COUPLINGS, W/2 GATE & 1 CHECK VALVE	30	50	32,208	35	368	253 656
12510BB	PIPELINE, POL, 1 MILE OF 8 IN GROOVED LT WT TUBING, W/COUPLINGS, W/2 GATE & 1 CHECK VALVE	36	87	37,797	46	518	368 932
12510BC	PIPELINE, POL, 1 MILE OF 12 IN GROOVED LT WT TUBING, W/COUPLINGS, W/2 GATE & 2 CHECK VALVE	45	177	23,979	46	1,093	483 1,622
12510BD	PIPELINE, POL, 5 MILES OF 6 IN GROOVED LT WT TUBING, W/COUPLINGS 500 FT API BEVELED PIPE, 5 GATE & 1 CHECK VALVE	61	110	61,704	58	1,265	828 2,151
12510BE	PIPELINE, POL, 5 MILES OF 6 IN GROOVED LT WT TUBING, W/COUPLINGS 500 FT API BEVELED PIPE, 5 GATE & 1 CHECK VALVE	167	239	158,942	58	1,668	1,265 2,991
12510BF	PIPELINE, POL, 5 MILES OF 8 IN GROOVED LT WT TUBING, W/COUPLINGS 500 FT API BEVELED PIPE, 5 GATE & 1 CHECK VALVE	182	432	198,542	58	1,783	1,219 3,060
12510BG	PIPELINE, POL, 5-MILES OF 12-INCH GROOVED LT WT TUBING W/COUPLINGS, 500 FT API BEV PIPE, 5 GATE & 1-CHECK VALVE.	225	893	205,741	69	2,530	1,645 4,244
12510BH	PIPELINE, POL, 1000 FT OF 4 IN GROOVED API PIPE, W/COUPLINGS, W/O VALVES	7	5	5,986	6	104	63 173
12510BJ	PIPELINE, POL, 1000 FT OF 6-INCH GROOVED API PIPE, W/COUPLINGS, W/O VALVES.	11	13	7,263	6	132	81 219
12510BK	PIPELINE, POL, 1000 FT OF 8 IN GROOVED API PIPE, W/COUPLINGS, W/O VALVES	13	16	3,500	12	230	161 403
12510BL	PIPELINE, POL, 1000 FT OF 12 IN GROOVED API PIPE, W/COUPLINGS, W/O VALVES	6	6	11,715	12	285	184 461

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
12510BM	PIPELINE, POL, 1 MILE OF 4 IN GROOVED API PIPE, W/COUPLINGS, W/2 GATE & 1 CHECK VALVE	36	23	32,158	35	483	322	840
12510BN	PIPELINE, POL, 1-MILE OF 6-INCH GROOVED API PIPE, W/COUPLINGS, W/2 GATE VALVES & 1 CHECK VALVE.	59	63	64,600	46	598	334	978
12510BP	PIPELINE, POL, 1 MILE OF 8 IN GROOVED API PIPE, W/COUPLINGS, W/2 GATE & 1 CHECK VALVE	71	81	19,207	92	857	403	1,366
12510BR	PIPELINE, POL, 1 MILE OF 12 IN GROOVED API PIPE, W/COUPLINGS, W/2 GATE & 1 CHECK VALVE	15	15	62,125	138	1,231	575	1,944
12510BT	PIPELINE, POL, 1000 FT OF 4-INCH API PIPE, BEVELED ENDS FOR WELDING W/150 LBS OF WELDING ROD.	5	4	16,748	23	219	81	323
12510BU	PIPELINE, POL, 1000 FT OF 6-INCH API PIPE, BEVELED ENDS FOR WELDING W/150 LBS OF WELDING ROD.	11	10	10,144	29	328	92	449
12510BV	PIPELINE, POL, 1000 FT OF 8-INCH API PIPE, BEVELED ENDS FOR WELDING W/150 LBS OF WELDING ROD.	16	16	23,774	60	365	98	483
12510BW	PIPELINE, POL, 1000 FT OF 12-INCH API PIPE, BEVELED ENDS FOR WELDING W/200 LBS OF WELDING ROD.	23	30	188,573	92	391	127	610
12510BY	PIPELINE, 1000FT 10IN GROOVED STEEL TUBING, W/COUPLINGS, W/0 VALVES	10	35	9,739	15	178	75	268
12510CA	PIPELINE, 1MILE, 10IN GROOVED STEEL TUBING, W/COUPLINGS, W/2 GATE&1 CHK VALVE	51	193	52,569	46	230	426	702
12510CB	PIPELINE, 5MILES, 10IN GROOVED STEEL TUBING W/COUPLINGS, 500FT API BEVELED PIPE, 5 GATE&1 CHK	264	997	268,669	63	2,183	1,7432	3,680
12510CC	PIPELINE, 1000FT, 10IN GROOVED STEEL API PIPE, W/COUPLINGS, W/2 GATE&1 CHK	18	31	5,752	12	247	173	432
12510CD	PIPELINE, 1MILE, 10IN GROOVED STEEL API PIPE, W/COUPLINGS W/0 VALVES	98	175	30,232	115	1,7041	489	1,845

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HRS	EFFORT VERT	IN GENL	TOT
12510CE	PIPELINE,1000 FEET OF 10 INCH API PIPE WITH BEVELED ENDS FOR WELDING WITH 200 LBS OF WELDING RODS.	20	19	11,883	66	368	113	367
12510CF	PIPELINE,1000FT,10IN GROOVED ALUMINUM SCH 40,W/COUPLING W/O VALVES	10	23	21,160	12	267	173	632
12510CG	PIPELINE,1 MILE OF 10 INCH ALLUMINUM PIPE.GROOVED PIPE AND CLAMPS WITH VALVES.	49	124	119,241	115	1,041	689	1,645
12510CH	PIPELINE,5MILES,10IN GROOVED ALUMINUM SCH 40,W/COUPLINGS W/5 GATE&1 CHK VALVE	241	615	593,182	58	1,265	1,610	2,933
12510CJ	PIPELINE,5MILES,10IN ZAPLOC ALUM SCH 40 W/JOINING PRESS, GROOVER,MANDRELS,POWER UNIT,ADHESIVE,W/5GATE&1 CHK VALVE	199	526	521,116	63	2,415	1,610	4,088
12510CK	PIPELINE,POL,5 MILES,10IN ZAPLOC STEEL TUBING W/JOINING PRESS,GROOVER,MANDRELS,POWER UNIT,ADHESIVE,W/5 GATE&1 CHK VALVE	549	526	251,836	69	2,530	1,645	4,244
12510CL	PIPELINE,POL,5 MILES,10IN ZAPLOC STEEL SCH 20 PIPE W/JOININ G PRESS,GROOVER,MANDRELS,POWER UNIT,ADHESIVE,W/5 GATE&1 CHK VALVE	38	37	21,905	75	2,665	1,725	4,445
12510CT	PIPELINE,10IN STEEL WELDED RIVER BED CROSSING W/ALTERNATE BY-PASS PIPELINE FOR 750FT CROSSING	120	109	74,633	1,599	1,852	1,380	4,831
12510CU	PIPELINE,10IN STEEL WELDED,RIVER BED CROSSING W/ALTERNATE BY-PASS PIPELINE FOR 1000FT CROSSING	156	143	96,409	2,062	2,391	1,610	6,063
12510CV	PIPELINE,10IN STEEL WELDED RIVER BED CROSSING W/ALTERNATE BY-PASS PIPELINE FOR 1250FT CROSSING	192	176	118,188	2,432	2,844	1,840	7,116
12510CW	PIPELINE,10IN STEEL WELDED RIVER BED CROSSING W/ALTERNATE BY-PASS PIPELINE FOR 1500FT CROSSING	232	210	142,727	2,634	3,145	2,070	7,849
12520AA	BOMB DAMAGE REPAIR OF POL PIPELINE,8 IN,200 FT	2	4	1,601	23	55	55	133

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST \$	CONST HRS	EFFORT IN MAN-HOURS	IN MAN-HOURS	
		SHT	TONS			HOR	VERT	BRL	TOT
12520AB	BOMB DAMAGE REPAIR OF POL PIPELINE, 6 IN, 200 FT	1	2	1,213	21	63	33	99	
12520AC	BOMB DAMAGE REPAIR OF POL PIPELINE, 4 IN, 200 FT	1	1	581	20	63	33	98	
12530AA	SUPPLEMENTARY FITTINGS AND VALVES FOR REVERSING PUMPING FROM COLLAPSIBLE STORAGE TANK FARM (100,000, 50,000 OR 40,000 GAL)	1	1	3,003	184	29	29	213	
12530AB	REVERSING MANIFOLD FOR BOOSTER PUMP STATION, POL, FOR LOADING, SHORE TO SHIP, 6 INCH PIPELINE	4	5	3,903	167	29	29	196	
12530AC	REVERSING MANIFOLD FOR BOOSTER PUMP STATION, POL, FOR LOADING, SHORE TO SHIP, 8-INCH PIPELINE MANIFOLD, TWO PORTABLE TRUCK FILL STANDS AND FITTINGS	13	28	48,614	12	219	33	266	
12530AD	REVERSING MANIFOLD FOR BOOSTER PUMP STATION, POL, FOR LOADING, SHORE TO SHIP, 12-INCH PIPELINE.	5	4	8,824	23	334	46	403	
12530AE	BOOSTER STATION, POL, 1400 BPH, W/2-TWO STAGE PUMPS, MANIFOLD FOR STAGES IN SERIES, PUMPS IN SERIES	13	28	27,751	46	109	40	195	
12530AF	BOOSTER STATION, POL, 2800 BPH, W/2-TWO STAGE PUMPS, MANIFOLD FOR STAGES IN PARALLEL, PUMPS IN SERIES	14	29	27,070	46	109	40	195	
12530AG	BOOSTER STATION, POL, 7000 BPH, W/4-TWO STAGE PUMPS, MANIFOLD FOR STAGES IN PARALLEL, PUMPS IN PARALLEL	27	36	54,109	66	322	92	460	
12530AH	LOADING PUMP & MANIFOLD, POL, 700 TO 1400 BPH, 6 IN PIPE, FOR 2 TANK TRUCK, 5 TANK CAR OR DRUM & CAN LOADING INSTALLATIONS, W/1 SINGLE STAGE PUMP	8	25	18,443	12	98	29	139	
12530AJ	LOADING PUMP & MANIFOLD, POL, 2000 TO 2500 BPH, 8IN PIPE INCOMING, 6IN PIPE OUTGOING, FOR 10 TANK CAR INSTALLATION, W/1 TWO STAGE PUMP	14	41	27,990	17	127	52	196	
12530AK	PUMP STATION FUEL SUPPLY, POL, FOR ALL 2 PUMP FACILITIES, W/O TANK OR PUMP	1	1	1,368	6	40	23	69	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	TONS	WT SHT	VOL MEAS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
12530AL	PUMP STATION FUEL SUPPLY, POL, FOR ALL 4 PUMP FACILITIES, W/O TANK OR PUMP	1		1	1,246	9	60	23	92
12530AM	PUMP STATION, POL, FOR 4-INCH PIPELINE, 2 PUMPS W/MANIFOLDING VALVES AND SANDTRAP.	5		86	80,584	40	115	40	195
12530AN	PUMP STATION, POL, FOR 6 IN PIPELINE, 4-PUMPS W/MANIFOLDING, VALVES, SANDTRAP, & PIPECLEANER STATIONS	9		171	155,992	40	247	104	391
12530AP	PUMP STATION, POL, FOR 8 IN PIPELINE, 4-PUMPS W/MANIFOLDING, VALVES, SANDTRAP, & PIPECLEANER STATIONS	32		63	62,652	46	276	127	669
12530AR	PUMP STATION, POL, FOR 6 INCH COUPLED PIPELINE, ONE DIESEL ENGINE DRIVEN PUMP RATED AT 857 BHP AT 1630 FEET TOTAL HEAD W/MANIFOLDING, VALVES, STRAINERS, AND PIPE CLEANER STATIONS	9		48	41,366	209	1,012	368	1,589
12530AT	PUMP STATION, POL, FOR 6 INCH COUPLED PIPELINE, TWO DIESEL ENGINE DRIVEN PUMPS EACH RATED AT 857 BHP AT 1630 FEET HEAD W/MANIFOLDING, VALVES, STRAINERS, AND PIPE CLEANER STATIONS	14		92	76,277	235	1,198	442	1,875
12530AU	METAL CLADDING&INTERIOR LINER FOR 40X60X12FT STEEL FRAME BLDG HOUSING TWO DED PUMPS RATED AT 785BPH W/HEATING	15		49	11,932	66	474	184	644
12530AV	4IN COLLAPSIBLE ASSULT HOSELINE SYSTEM,2.5 MILES W/GED PORT ABLE PUMP,320BPH AT 250FT HD,COMPLETE W/EVAC. AND DISP.FLOW CONTROL PACKAGE& RPR KITS,ANCILLRY FTGS&VALVES	5		26	42,918	14	48		62
12585AA	POL OPERATIONS-LABORATORY FACILITY 1536 SQ FT WOOD FRAME BUILDING 48 FT X 32 FT ONE STORY CONCRETE FLOOR 13 FT 9 IN HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	115		143	25,278	112	1,418	278	1,808
12585AB	INTERIOR FOR POL OPERATIONS-LABORATORY FACILITY 1536 SQ FT WOOD FRAME BUILDING TEMPERATE AND DESERT CLIMATE	12		28	14,592		168	198	366
12585AG	POL OPERATIONS-LABORATORY FACILITY 1600 SQ FT PRE-ENGINEERED METAL BUILDING 40 FT X 40 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	76		252	30,611	175	1,327	776	2,278

DHDXER1

RUN DATE 860128

DESERT CLIMATE

<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>
12585AH	INTERIOR FOR POL OPERATIONS-LABORATORY FACILITY 1600 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE AND DESERT CLIMATE
12585AP	POL OPERATIONS-LABORATORY FACILITY 1440 SQ FT PANELIZED WOOD BUILDING 36 FT X 40 FT ONE STORY CONCRETE FLOOR 12 FT HIGH WOOD PANEL CLADDING AND WOOD PANEL ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE
12590AA	TACTICAL FIBERGLASS SUBMARINE PIPELINE, 8" DIA, 80' DEPTH, 1MI.
12590AB	TACTICAL FIBERGLASS SUBMARINE PIPELINE, 8" D., 120' DEPTH, 1MI.
12590AC	PIPELINE, SUBMARINE, POL, 25 FEET DEPTH, 6-INCH, 1000 FT MAXIMUM (ADJUST TO SITE REQUIREMENTS) LENGTH, API PIPE, CONC. WEIGHTS, 75 FOOT HEAVY HOSE, AND BUOY FOR UNLOADING SMALL VESSELS (11,500 BBLS) AND BARGES (4160 BBLS) IN SHALLOW DEPTH WATER.
12590AD	PIPELINE, SUBMARINE, POL, 60-FT DEPTH, 6-INCH 2750 FT (ADJUST TO SITE REQUIREMENTS) LENGTH, API PIPE, CONC WGTs, 150 FT HVY HOSE AND 2 BUOYS.
12590AE	PIPELINE, SUBMARINE, POL, 90-FT DEPTH, 6-INCH 2750 FT (ADJUST TO SITE REQUIREMENTS) LENGTH, API PIPE, CONC WGTs, 225 FT HVY HOSE AND 2 BUOYS.
12590AF	PIPELINE, SUBMARINE, POL, 120 FT DEPTH, 6-INCH (ADJUST TO SITE REQUIREMENTS) LENGTH, API PIPE, CONC WGTs, 300 FT HVY HOSE AND TWO BOUYS. 2750FT. OF PIPE PROVIDED.
12590AG	PIPELINE, SUBMARINE, POL, 60 FT DEPTH, 8-INCH, 2750 FT (ADJUST TO SITE CONDITIONS) LGTH, API PIPE, HEAVY WALL, CONC WGTs, 150 FT HVY HOSE AND 2 BUOYS.
12590AH	PIPELINE, SUBMARINE, POL, 90-FT DEPTH, 8-INCH 2750 FT (ADJUST TO SITE CONDITIONS) LGTH, API PIPE, HEAVY WALL, CONC WGTs, 225 FT HVY HOSE AND 2 BUOYS.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS
HOR	VERT	GENL	TOT
12	26	14,282	152 83 235
201	714	65,028	78 520 201 799
131	425	261,774	1,011 2,254 1,150 4,415
127	402	241,787	1,011 2,263 1,150 4,424
27	35	32,473	1,012 1,093 138 2,243
36	38	49,611	1,353 2,300 207 4,060
58	61	53,869	1,353 2,300 207 4,060
59	63	58,096	1,353 2,300 207 4,060
55	62	29,480	1,587 2,369 207 4,163
57	67	33,863	1,587 2,369 207 4,163

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
12590AJ	PIPELINE, SUBMARINE, POL, 120-FT DEPTH, 8-INCH, 2750 FT (ADJUST TO SITE CONDITIONS) LGTH, API PIPE, HEAVY WALL, CONC WGT\$, 300 FT HVY HOSE AND 2 BUOYS.	59	72	38,416	1,387	2,369	207	4,763
12590AK	PIPELINE, SUBMARINE, POL, 60-FT DEPTH, 12-INCH, 2750 FT (ADJUST TO SITE CONDITIONS) LGTH, API PIPE, CONC WGT\$, 150 FT HVY HOSE AND 2 BUOYS.	123	142	548,634	2,070	2,507	230	4,807
12590AL	PIPELINE, SUBMARINE, POL, 90-FT DEPTH, 12-INCH, 2750 FT (ADJUST TO SITE CONDITIONS) LGTH, API PIPE, CONC WGT\$, 225 FT HVY HOSE AND 2 BUOYS.	126	148	553,092	2,070	2,507	230	4,807
12590AM	PIPELINE, SUBMARINE, POL, 120 FT DEPTH, 12-INCH, 2750 FT (ADJUST TO SITE CONDITIONS) LGTH, API PIPE CONC WGT\$ 300 F T HVY HOSE AND 2 BUOYS.	128	153	557,530	2,070	2,507	230	4,807
12590AN	PIPELINE, SUBMARINE, POL, 60-FT DEPTH, 8-IN, 5300 FT. LENGTH, API PIPE, HEAVY WALL, 200 FT HVY HOSE AND 2 BUOYS.	98	91	104,114	1,955	2,185	920	5,060
12590AP	PIPELINE, SUBMARINE, POL, 90-FT DEPTH, 8-IN, 5300 FT. LGTH, API PIPE, HEAVY WALL, 275 FT. HVY HOSE AND 2 BUOYS.	100	96	109,162	2,185	2,530	1,035	5,750
12590AR	PIPELINE, SUBMARINE, POL, 120-FT. DEPTH, 8-IN, 5300 FT. LGTH, API PIPE, HEAVY WALL, 350 FT. HVY HOSE AND 2 BUOYS.	102	101	113,389	2,643	2,990	1,035	6,670
12590AT	PIPELINE, SUBMARINE, POL, 60-FT DEPTH, 12-IN, 5300 FT LGTH , CONCRETE COATED API PIPE, 200 FT HVY HOSE AND 2 BUOYS.	275	322	96,144	2,070	2,565	943	5,578
12590AU	PIPELINE, SUBMARINE, POL, 90-FT DEPTH, 12-IN, 5300 FT LGTH , CONCRETE COATED API PIPE, 275 FT HVY HOSE AND 2 BUOYS.	278	327	101,106	2,300	2,990	978	6,268
12590AV	PIPELINE, SUBMARINE, POL, 120-FT DEPTH, 12-IN, 5300 FT LGT H CONCRETE COATED API PIPE, 350 FT HVY HOSE AND 2 BUOYS.	280	333	105,244	2,818	3,335	1,035	7,188
12590AW	PIPELINE, SUBMARINE, POL, 60-FT DEPTH, 16-IN. 5300 FT LGTH , CONCRETE COATED API PIPE, 200 FT HVY HOSE AND 2 BUOYS.	433	469	99,236	2,875	3,335	1,380	7,390

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL	MAN-HOURS TOT
12590AY	PIPELINE, SUBMARINE, POL, 90-FT DEPTH, 16-IN, 5300 FT LGTH , CONCRETE COATED API PIPE, 275 FT HVY HOSE AND 2 BUOYS.	436	474	104,198	3,163	3,623	1,495	8,281
12590BA	PIPELINE, SUBMARINE, POL, 120-FT DEPTH, 16-IN, 5300 FT LGTH, CONCRETE COATED API PIPE, 350 FT HVY HOSE AND 2 BUOY S	439	480	108,581	3,565	4,025	1,610	9,200
12590BB	PIPELINE, SUBMARINE, POL, 60-FT DEPTH, 20-IN, 5300 FT LGTH , CONCRETE COATED API PIPE, 200 FT HVY HOSE AND 2 BUOYS.	369	663	97,020	3,335	3,824	1,840	8,999
12590BC	PIPELINE, SUBMARINE, POL, 90-FT DEPTH, 20-IN, 5300 FT LGTH , CONCRETE COATED API PIPE, 275 FT HVY HOSE AND 2 BUOYS.	552	649	101,982	3,565	4,169	1,955	9,689
12590BD	PIPELINE, SUBMARINE, POL, 120-FT DEPTH, 20-IN, 5300 FT LGTH, CONCRETE COATED API PIPE, 350 FT HVY HOSE AND 2 BUOY S	355	654	106,121	3,939	4,600	2,070	10,609
12590CA	PIPELINE SUBMARINE POL 60FT.DEPHT 10IN.5300FT.LENGTH,API PIPE,HEAVY WALL,200FT HVY-HOSE AND 2 BOUYS.	106	111	139,375	1,955	2,185	920	5,060
12590CB	PIPELINE SUBMARINE POL 90FT DEPTH 10IN.5300FT LENGTH,API PIPE HEAVY WALL 275FT HVY-HOSE AND 2 BOUYS.	108	117	143,482	2,185	2,530	1,035	5,750
12590CC	PIPELINE SUBMARINE POL 120FT DEPTH 10IN 5300FT.LENGTH API PIPE,HEAVY WALL 350FT HVY-HOSE AND 2 BOUYS.	110	123	149,145	2,645	2,990	1,035	6,670
12591AA	POL PRESSURE REDUCING STATION FOR 4IN,6IN,OR 8 INCH MAIN TRUNKLINE, 25 TO 800 POUNDS PRESSURE REDUCING RANGE, CONSISTING OF GATE VALVES, PLUG VALVES AND REDUCING BY-PASS LINE VALVES, GROOVED WITH ADAPTERS, COUPLINGS, GASKETS AND NIPPLES	3	5	5,804	40	6	46	
12592AA	PIPELINE 8IN WELDED RIVER BED CROSSING W/ALTERNATE BY-PASS PIPELINE FOR 750FT CROSSING	111	88	35,644	1,279	1,481	1,104	3,884
12592AB	PIPELINE 8IN WELDED RIVER BED CROSSING W/ALTERNATE BY-PASS PIPELINE FOR 1000FT CROSSING	144	114	45,388	1,649	1,912	1,288	4,849
12592AC	PIPELINE 8IN WELDED RIVER BED CROSSING W/ALTERNATE BY-PASS PIPELINE FOR 1250FT CROSSING	177	141	55,119	1,966	2,275	1,472	5,695

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	HOR	VERT	GENL	TOT
12592AD	Pipeline 8in welded river bed crossing w/alternate by-pass pipeline for 1500ft crossing	211	168	64,818	2,107	2,516	1,656	6,279	
12592AE	POL Pipeline suspension f/8" or smaller line, 100ft. span.	2	3	1,822	13	22	32	67	
12592AF	POL Pipeline suspension f/8" or smaller line, 200ft. span.	6	4	3,408	13	36	41	90	
12592AG	POL Pipeline suspension f/8" or smaller line, 400ft. span.	8	7	7,328	14	56	62	132	
12630AA	Tank truck loading POL for loading 2-tank trucks simultaneously at 357 BPH each w/4-inch riser pipe & swing arm connected to 6in header pipe	12	12	13,862	173	374	1,213	1,760	
12640AA	Tank car loading, POL, for loading 5-tank cars simultaneously, at 357 BPH each, w/4-inch header pipe.	35	61	53,557	598	1,840	4,025	6,463	
12640AB	Tank car loading, POL, for loading 10 tank cars simultaneously, at 357 BPH each, w/4in riser pipe & swing arm, connected to 6in header pipe	74	75	71,174	782	2,392	5,244	8,418	
12645AA	Fuel transfer, POL, tank car unloading, 2 products, 5 stations, pipe, pumps, filter-separator, valves and accessories.	45	67	79,691	63	426	161	650	
12655AA	Barge (4160 BBLS) or small vessel (11,500BBLS) mooring in shallow depth water (25ft), POL, anchors, chains, 8 4 mooring and marking buoys.	32	69	73,797	276	345	207	828	
12665AA	mono mooring, 4 legs, 60 foot depth				886	1,530	748	3,164	
12665AB	mono mooring, 4 legs, 80 foot depth				920	1,576	771	3,267	
12665AC	mono mooring, 4 legs, 100 foot depth				1,001	1,725	828	3,354	
12665AD	mono mooring, 4 legs, 120 foot depth				1,047	1,817	874	3,738	
12665AE	mono mooring, 6 legs, 60 foot depth				989	1,760	817	3,566	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL TOT
12665AF	MONO MOORING, 6 LEGS, 80 FOOT DEPTH				1,024	1,829	863 3,716
12665AG	MONO MOORING, 6 LEGS, 100 FOOT DEPTH				1,116	2,024	963 4,083
12665AH	MONO MOORING, 6 LEGS, 120 FOOT DEPTH				1,162	2,116	978 4,256
12665AJ	MONO MOORING, 8 LEGS, 60 FOOT DEPTH				1,081	2,001	897 3,979
12665AK	MONO MOORING, 8 LEGS, 80 FOOT DEPTH				1,127	2,082	943 4,152
12665AL	MONO MOORING, 8 LEGS, 100 FOOT DEPTH				1,219	2,300	1,012 4,531
12665AM	MONO MOORING, 8 LEGS, 120 FOOT DEPTH				1,277	2,392	1,058 4,727
12665AN	MARINE TERMINAL, TACTICAL, 50000 BARREL STORAGE CAPACITY 60 0 GPM RECEIVE AND TRANSFER CAPACITY	6	250	575,092	2,645	4,255	1,794 8,696
12665AP	PIPE, POL, 4-INCH, FOR T-1 TANKER DISCHARGE AT DOCK, 250 BPH, 1000 FT API PIPE, VALVES, TANKER HOSE, AND T-50 GPM PUMP.	6	6	28,286		403	115 518
12665AR	PIPE, POL, 6-INCH, FOR T-1 TANKER DISCHARGE AT DOCK, 680 BPH, 1000 FT API PIPE, VALVES, TANKER HOSE, AND T-50 GPM PUMP.	14	13	22,472		506	115 621
12665AT	PIPE, POL, 8-INCH, FOR T-2 TANKER DISCHARGE AT DOCK, 980 BPH, 1000 FT API PIPE, VALVES, TANKER HOSE, AND T-50 GPM PUMP.	20	24	37,367		598	138 736
12665AU	PIPE, POL, 12-INCH FOR T-2 OR SUPERTANKER-DISCHARGE AT DOCK, 980-2800 BPH, 1000 FT API PIPE, VALVES, TANKER HOSE AND 1-50 GPM PUMP.	32	49	221,603		759	184 943
12665AV	PIPE, POL, 16-INCH, FOR SUPERTANKER DISCHARGE AT DOCK, 2800 BPH, 1000 FT API PIPE, VALVES, TANKER HOSE AND 1-50 GPM PUMP.	18	28	36,985		1,208	288 1,496

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					HOR	VERT	GENL	TOT
12665AW	PIPE POL 10IN FOR T-2 TANKER DISCHARGE AT DOCK 980 BPH 1000 FEET. API PIPE, VALVES, TANKER HOSE AND 1-50 GPM PUMP.	23	28	21,545	598	138	736	
12665BA	PIPE POL 10IN FOR T-2 TANKER DISCHARGE AT DOCK 980 BPH 1000 FT. API PIPE, VALVES, TANKER HOSE AND 1-50 GPM PUMP.	2	1	4,038	598	138	736	
12690AC	DRUM FILLING, BLDG, POL, 40X100, STEEL FRAME BLDG W/METAL CLADDING, INTERIOR & VENTILATION FOR DESERT ZONE	100	82	34,881	212	4,091	725	5,028
13120A6	SIGINT INSTALLATION OPS/COMMAND BLDG W/INTERIOR 80X100 DESERT CLIMATE W/TWO EXTERIOR DOUBLE DOORS AND NO WINDOWS	47,090	554,118	23,822,249	547	7,590	1,313	9,450
13120AH	SIGINT INSTALLATION OPS/COMPUTER BLDG W/INTERIOR 80X100 DESERT CLIMATE W/TWO EXTERIOR DOUBLE DOORS AND NO WINDOWS	47,092	554,115	23,831,869	547	7,590	1,313	9,450
13120AJ	SIGINT INSTALLATION OPERATIONS BLDG W/INTERIOR 80X100 DESERT CLIMATE W/ THREE EXTERIOR DOUBLE DOORS AND NO WINDOWS	47,084	554,107	23,824,757	547	7,590	1,359	9,496
13120AK	SIGINT INSTALLATION SUPPLY/ELEC MAINT BLDG W/INTERIOR 80X100 DESERT CLIMATE W/FIVE EXTERIOR DOUBLE DOORS AND NO WINDOWS	47,086	554,109	23,822,550	547	7,590	1,359	9,496
13120AL	SIGINT STATION OPS/COMMUNICATIONS BLDG W/INTERIOR 80X100 DESERT CLIMATE W/THREE EXTERIOR DOUBLE DOORS AND NO WINDOWS	47,120	554,147	23,858,123	547	7,590	1,359	9,496
13120AM	SIGINT STATION OPS/ELEC MAINT BLDG W/INTERIOR 80X100 DESERT CLIMATE W/ THREE EXTERIOR DOUBLE DOORS AND NO WINDOWS	59,187	554,127	80,605,203	547	7,590	1,359	9,496

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HRS	EFFORT VERT	IN MAN-HOURS GENL	TOT
13120CE	INTERIOR FOR SIGINT INSTALLATION OPS/COMMAND BLDG.80X100FT BUILDING	47,016	553,988	23,750,837	2,070	644	2,716	
13120CF	INTERIOR FOR SIGINT INSTALLATION OPS COMPUTER BUILDING 80X100FT.	47,018	553,985	23,760,457	2,070	644	2,716	
13120CG	INTERIOR FOR SIGINT INSTALLATION OPERATIONS BUILDING 80X100FEET	47,010	553,977	23,753,363	2,070	690	2,760	
13120CH	INTERIOR FOR SIGINT INSTALLATION SUPPLY ELECTRONIC MAINT. BUILDING 80X100FEET	47,012	553,979	23,751,138	2,070	690	2,760	
13120CJ	INTERIOR FOR SIGINT STATION OPS/COMMUNICATION FACILITY 80X 100FT BLDG	47,014	553,993	23,785,007	2,070	690	2,760	
13120CK	INTERIOR FOR SIGINT STATION IPS/ELECTRONIC MAINTENANCE BUILDING 80X100 FEET.	59,081	553,973	80,532,087	2,070	690	2,760	
13610AA	BOMB DAMAGE REPAIR TO AIRFIELD RUNWAY LIGHTING.8000 LIN FT OF RUNWAY-TAXIWAY LIGHTING.IF NECESSARY,THE SYSTEM WILL REQUIRE TWO 30KW AC GENERATORS (NSN 6115-00-118-1240)	22	71	83,200	97	69	166	
14110AA	AIRFIELD OPERATIONS FACILITY 600 SQ FT WOOD FRAME BUILDING 20 FT X 30 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD CLADDING WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	16	22	4,833	25	610	133	768
14110AB	INTERIOR FOR AIRFIELD OPERATIONS FACILITY 600 SQ FT WOOD FRAME BUILDING TEMPERATE / FRIGID AND DESERT CLIMATE	2	6	2,422	436	83	519	
14110AC	AIRFIELD OPERATIONS FACILITY 600 SQ FT PRE-ENGINEERED METAL BUILDING 20 FT X 30 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE / FRIGID AND DESERT CLIMATE	6	16	8,816	37	896	298	1,231
14110AD	INTERIOR FOR AIRFIELD OPERATIONS FACILITY 600 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE / FRIGID AND DESERT CLIMATE	3	8	2,950	654	92	566	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
14110AE	AIRFIELD OPERATIONS FACILITY 2100 SQ FT WOOD FRAME BUILDING 30 FT X 70 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD CLADDING WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	53	68	13,356	76	2,805	499	3,380
14110AF	INTERIOR FOR AIRFIELD OPERATIONS FACILITY 2100 SQ FT WOOD FRAME BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	8	18	6,650		1,216	236	1,432
14110AG	AIRFIELD OPERATIONS FACILITY 2100 SQ FT PRE-ENGINEERED METAL BUILDING 30 FT X 70 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE , FRIGID AND DESERT CLIMATE	24	50	31,656	144	2,768	1,025	3,937
14110AH	INTERIOR FOR AIRFIELD OPERATIONS FACILITY 2100 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	10	22	8,024		1,267	260	1,527
14110BA	AIRFIELD OPERATIONS FACILITY 864 SQ FT PANEL WOOD BUILDING 24 FT X 36 FT ONE STORY WOOD FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE AND FRIGID CLIMATE. DESIGN DETAILS ARE ON INST. DWG AG0131-5044, SHT 8 OF 65	27	33	18,383	8	1,110	879	1,997
14110BB	AIRFIELD OPERATIONS FACILITY 2160 SQ FT PANEL WOOD BUILDING 36 FT X 60 FT ONE STORY WOOD FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE AND FRIGID CLIMATE DESIGN DETAILS ARE ON INST. DWG AG0131-5044,SHT.37 OF 65	170	953	96,409	21	2,151	610	2,782
14110CC	OPERATIONS BUILDING AIRFIELD, LIGHTWEIGHT STEEL PANEL WITH INTERIOR, 20 BY 30 BY 8, DESERT/TROPIC CLIM	4	8	3,051	7	507	139	653
14110CD	OPERATIONS BUILDING AIRFIELD, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 70 BY 8, DESERT/TROPIC CLIM	18	26	8,200	37	1,308	667	2,212
14910DA	REVESTMENT KIT,PREFABRICATED MODULAR TYPE,CORRUGATED PANELS PIN ASSEMBLED STACKED SECTIONS SIZE A-12FT HIGH BY 5FT WIDE BY 252FT LONG MIL-R-28653.	23	58	4,299	9	55	21	85

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	SHT TONS	WT TONS	VOL MEAS TONS	COST \$	CONST HRS	EFFORT IN MAN-HOURS	IN MAN-HOURS	
						WOR	VERT	GENL	TOT
14910DB	REVESTMENT KIT, PREFABRICATED MODULAR TYPE, CORRUGATED PANELS, PIN ASSEMBLED STACKED SECTIONS SIZE 8-16FT HIGH BY 7FT WIDE BY 252FT LONG MIL-R-28653	39	98	6,854	14	69	28	777	
14910EA	STANDOFF, DIMENSIONED TIMBER CONSTRUCTION, 100 FT LONG BY 5 FT 6 IN. HIGH	7	7	966	87		35	122	
14910EB	STANDOFF, DIMENSIONED TIMBER CONSTRUCTION, 100 FT LONG BY 9 FT HIGH	8	9	1,413	117		35	152	
14910EC	STANDOFF, DIMENSIONED TIMBER CONSTRUCTION, 100 FT LONG BY 11 FT HIGH	9	10	1,698	160		35	175	
14910ED	STANDOFF, LOG CONSTRUCTION, 100 FT LONG BY 5 FT 6 IN. HIGH	15	45	999	40		45	85	
14910EE	STANDOFF, LOG CONSTRUCTION, 100 FT LONG BY 9 FT HIGH	21	63	1,181	62		45	107	
14910EF	STANDOFF, LOG CONSTRUCTION, 100 FT LONG BY 11 FT HIGH	24	73	1,323	69		43	112	
14910EG	STANDOFF, STEEL SHEET PILE CONSTRUCTION, 100 FT LONG BY 5 FT 6 IN. HIGH	11	18	4,888	41		15	56	
14910EH	STANDOFF, STEEL SHEET PILE CONSTRUCTION, 100 FT LONG BY 9 FT HIGH	16	26	6,892	63		15	58	
14910EJ	STANDOFF, STEEL SHEET PILE CONSTRUCTION, 100 FT LONG BY 11 FT HIGH	19	30	8,125	44		15	59	
14910FA	REVESTMENT, SANDBAG, 100 FT LONG BY 5 FT 6 IN. HIGH, 34.7 CY FILL REQUIRED	3	5	2,742	125		1,304	1,429	
14910FB	REVESTMENT, SANDBAG, 100 FT LONG BY 9 FT HIGH, 68.2 CY FILL REQUIRED	5	10	5,395	245		2,559	2,804	
14910FC	REVESTMENT, SANDBAG, 100 FT LONG BY 11 FT HIGH, 91.8 CY FILL REQUIRED	7	14	7,258	329		3,667	3,776	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
14910FD	REVESTMENT, SANDBAG AND EARTH, 100 FT LONG BY 5 FT 6 IN. HIGH, 53.3 CY FILL REQUIRED	1	3	1,376	74		632	726
14910FE	REVESTMENT, SANDBAG AND EARTH, 100 FT LONG BY 9 FT HIGH, 125.7 CY FILL REQUIRED	3	5	2,697	148		1,280	1,428
14910FF	REVESTMENT, SANDBAG AND EARTH, 100 FT LONG BY 11 FT HIGH, 186.4 CY FILL REQUIRED	3	7	3,630	279		1,751	1,970
14910GA	REVESTMENT, GRAVITY, EARTH CONSTRUCTION, 100 FT LONG BY 5 FT 6 IN. HIGH, 533.8 CY FILL REQUIRED	2	5	5,993	77		20	97
14910GB	REVESTMENT, GRAVITY, EARTH CONSTRUCTION, 100 FT LONG BY 9 FT HIGH, 1020.6 CY FILL REQUIRED	2	7	9,457	120		33	153
14910GC	REVESTMENT, GRAVITY, EARTH CONSTRUCTION, 100 FT LONG BY 11 FT HIGH, 1350.3 CY FILL REQUIRED	2	7	9,497	147		38	185
14910GD	REVESTMENT, GRAVITY, LOG CONSTRUCTION, 100 FT LONG BY 5 FT 6 IN. HIGH, 463.3 CY FILL REQUIRED	22	56	6,610	124		133	257
14910GE	REVESTMENT, GRAVITY, LOG CONSTRUCTION, 100 FT LONG BY 9 FT HIGH, 831.6 CY FILL REQUIRED	31	79	9,669	185		202	387
14910GF	REVESTMENT, GRAVITY, LOG CONSTRUCTION, 100 FT LONG BY 11 FT HIGH, 1068.1 CY FILL REQUIRED	37	92	9,726	227		245	472
14910GG	REVESTMENT, GRAVITY, TIMBER CONSTRUCTION, 100 FT LONG BY 5 FT 6 IN. HIGH, 463.3 CY FILL REQUIRED	6	8	6,405	99		36	135
14910GH	REVESTMENT, GRAVITY, TIMBER CONSTRUCTION, 100 FT LONG BY 9 FT HIGH, 831.6 CY FILL REQUIRED	8	11	9,609	143		55	200
14910GJ	REVESTMENT, GRAVITY, TIMBER CONSTRUCTION, 100 FT LONG BY 11 FT HIGH, 1068.1 CY FILL REQUIRED	10	13	9,615	181		66	247
14910GK	REVESTMENT, GRAVITY, M8A1 LANDING MAT CONSTRUCTION, 100 FT LONG BY 5 FT 6 IN. HIGH, 463.3 CY FILL REQUIRED	9	8	7,303	92		36	168

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL	MAN-HOURS TOT
149106L	REVESTMENT, GRAVITY, M8A1 LANDING MAT CONSTRUCTION, 100 FT LONG BY 9 FT HIGH, 831.6 CY FILL REQUIRED	10	10	10,181	131		87	238
149106M	REVESTMENT, GRAVITY, M8A1 LANDING MAT CONSTRUCTION, 100 FT LONG BY 11 FT HIGH, 1068.1 CY FILL REQUIRED	12	11	10,531	162		104	266
149106N	REVESTMENT, GRAVITY, STEEL SHEET PILE CONSTRUCTION, 100 FT LONG BY 5 FT 6 IN. HIGH, 463.3 CY FILL REQUIRED	14	22	10,689	125		36	161
149106P	REVESTMENT, GRAVITY, STEEL SHEET PILE CONSTRUCTION, 100 FT LONG BY 9 FT HIGH, 831.6 CY FILL REQUIRED	19	30	13,124	181		48	229
149106R	REVESTMENT, GRAVITY, STEEL SHEET PILE CONSTRUCTION, 100 FT LONG BY 11 FT HIGH, 1068.1 CY FILL REQUIRED	21	33	16,079	206		54	260
149106A	REVESTMENT, BULKHEAD, LOG CONSTRUCTION, 100 FT LONG BY 1 FT WIDE BY 5 FT 6 IN. HIGH, 25.5 CY FILL REQUIRED	20	57	6,303	179		59	238
149106B	REVESTMENT, BULKHEAD, LOG CONSTRUCTION, 100 FT LONG BY 1 FT WIDE BY 9 FT HIGH, 41.7 CY FILL REQUIRED	34	91	7,283	263		166	389
149106C	REVESTMENT, BULKHEAD, LOG CONSTRUCTION, 100 FT LONG BY 1 FT WIDE BY 11 FT HIGH, 51.0 CY FILL REQUIRED	40	110	8,768	288		163	451
149106G	REVESTMENT, BULKHEAD, M8A1 LANDING MAT-TIMBER POST CONSTRUCTION, 100 FT LONG BY 1 FT WIDE BY 5 FT 6 IN. HIGH, 25.5 CY FILL REQUIRED	17	12	5,951	107		102	209
149106K	REVESTMENT, BULKHEAD, M8A1 LANDING MAT-STEEL PIPE CONSTRUCTION, 100 FT LONG BY 1 FT WIDE BY 5 FT 6 IN. HIGH, 25.5 CY FILL REQUIRED	17	10	7,027	107		102	209
149106L	REVESTMENT, BULKHEAD, M8A1 LANDING MAT-STEEL PIPE CONSTRUCTION, 100 FT LONG BY 1 FT WIDE BY 9 FT HIGH, 41.7 CY FILL REQUIRED	18	10	7,657	121		148	269
149106M	REVESTMENT, BULKHEAD, M8A1 LANDING MAT-STEEL PIPE CONSTRUCTION, 100 FT LONG BY 1 FT WIDE BY 11 FT HIGH, 51.0 CY FILL REQUIRED	18	11	7,964	166		168	312

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
14910JA	REVESTMENT, FREE STANDING, SOIL CEMENT CONSTRUCTION, 100 FT LONG BY 6 FT HIGH, 88.2 CY FILL REQUIRED	18	15	1,639	232		102	334
14910JB	REVESTMENT, FREE STANDING, SOIL CEMENT CONSTRUCTION, 100 FT LONG BY 9 FT HIGH, 151.2 CY FILL REQUIRED	30	24	2,611	669		176	625
14910JC	REVESTMENT, FREE STANDING, SOIL CEMENT CONSTRUCTION, 100 FT LONG BY 12 FT HIGH, 218.4 CY FILL REQUIRED	44	35	3,602	667		254	921
14910JE	REVESTMENT, FREE STANDING, CORRUGATED STEEL CONSTRUCTION, 100 FT LONG BY 1 FT WIDE BY 6 FT HIGH, 26.8 CY FILL REQUIRED	3	4	1,647	187		55	242
14910KA	REVESTMENT, PREFABRICATED, MODULAR TYPE, CORRUGATED PANELS, PIN ASSEMBLED, STACKED SECTIONS, 252 FT LONG BY 12 FT HIGH, 720 CY FILL REQUIRED	23	58	4,299	115		69	184
14910KB	REVESTMENT, PREFABRICATED, MODULAR TYPE, CORRUGATED PANELS, PIN ASSEMBLED, STACKED SECTIONS, 252 FT LONG BY 16 FT HIGH, 1320 CY FILL REQUIRED	39	98	6,854	184		92	276
14910KC	REVESTMENT, PREFABRICATED, MOBILE TYPE, M8A1 LANDING MAT CONSTRUCTION, 100 FT LONG BY 4 FT 9 IN. HIGH	11	27	7,110	22		37	59
14910KD	REVESTMENT, PREFABRICATED, MOBILE TYPE, M8A1 LANDING MAT CONSTRUCTION, 100 FT LONG BY 10 FT HIGH	17	31	8,586	32		53	85
14910KE	REVESTMENT, PREFABRICATED, MOBILE TYPE, M8A1 LANDING MAT CONSTRUCTION, 100 FT LONG BY 11 FT 8 IN. HIGH	18	32	8,919	38		63	101
14910KF	REVESTMENT, PREFABRICATED, PANELS WITH FOOTERS, CONCRETE CONSTRUCTION, 100 FT LONG BY 6 FT 10 IN. HIGH	14	16	2,884	14		22	36
14910KG	REVESTMENT, PREFABRICATED, PANELS WITH FOOTERS, CONCRETE CONSTRUCTION, 100 FT LONG BY 9 FT HIGH	39	37	4,969	14		22	36
14910KH	REVESTMENT, PREFABRICATED, PANELS WITH FOOTERS, CONCRETE CONSTRUCTION, 100 FT LONG BY 11 FT HIGH	44	42	5,610	14		22	36

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SNT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
14910KJ	REVESTMENT, PREFABRICATED, SELF-SUPPORTING, CONCRETE CONSTRUCTION, 100 FT LONG BY 5 FT HIGH	21	21	4,765	8		16	24
14910KK	REVESTMENT, PREFABRICATED, SELF-SUPPORTING, CONCRETE CONSTRUCTION, 100 FT LONG BY 9 FT HIGH	34	33	8,204	8		16	24
14910KL	REVESTMENT, PREFABRICATED, SELF-SUPPORTING, CONCRETE CONSTRUCTION, 100 FT LONG BY 12 FT HIGH	52	49	10,900	8		16	24
14920AA	BOMB DAMAGE REPAIR OF AIRCRAFT ARRESTING BARRIER - BAK-12	11	27	80,237	25	110	69	204
14930AA	EARTH BARRICADE FOR AMMO STORAGE INSTALLATIONS, 67FT WIDE X 16FT HIGH, 100LF. 1/1.5 SIDE SLOPES. REQUIRES 1840.0CY EARTH FILL.			399	30		32	62
14930AB	EARTH BARRICADE FOR AMMO STORAGE INSTALLATIONS, 91FT WIDE X 22FT HIGH, 100LF SEE DWG FP1105-1115, SH 2			542	220		64	284
14931BA	FIGHTING POSITION, FABRIC-FRAME STRUCTURE WITH SANDBAG OR EARTH COVER	12	19	20,470	1		5	6
14931BB	FIGHTING BUNKER, PRECAST CONCRETE SLAB	6	4	823	3		7	10
14931BC	PERSONNEL SHELTER, FABRIC-FRAME STRUCTURE WITH EARTH COVER	17	31	35,302	1		5	6
14931BD	VERTICAL ENTRY SHAFT FOR PERSONNEL SHELTER, FABRIC-FRAME AND SHEET METAL STRUCTURE	7	12	14,164	1		7	8
14931BE	EQUIPMENT SHELTER, FABRIC-FRAME STRUCTURE WITH EARTH COVER	24	43	49,651	1		7	8
14931BF	COMMAND POST SHELTER, FABRIC-FRAME STRUCTURE WITH EARTH COVR	34	63	72,041	2		7	9
14970AA	LANDING RAMP, LANDING SHIP TANK, 25FT X 100FT	10	7	2,872	69		92	161
14970AB	LANDING RAMP FOR LST, LANDING CRAFT, AND AMPHIBIOUS VEHICLES, 15 FT X 100 FT, 12 IN CONCRETE	44	30	931	150	196	360	

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			
					<u>HOR</u>	<u>VERT</u>	<u>GENL</u>	<u>TOT</u>
14970AC	LANDING RAMP FOR LST, LANDING CRAFT, AND AMPHIBIOUS VEHICLES, 25 FT X 100 FT, 12 IN CONCRETE	31	21	1,347	293	322	375	
14970AE	LANDING RAMP, DUKW W/CRUSHED ROCK 15FTX100FTX1FT (NO DWG)				109	29	150	288
14970AF	LANDING RAMP (LCU/LCM/LST) 30FTX100FTX18IN (SEE FM101-10-1)				207	58	288	553
14970AG	RAMP FOR AMPHIBIOUS VEH, 60FTX100FTX18IN (SEE FM 101-10-1)				426	104	541	1,071
14970AH	BEACH STABILIZATION, HARDSTAND, 1000SY, 6IN ROCK	140	95	700	253	63	322	638
14991AE	CAMOUFLAGE, DESERT RADAR SCATTERING SYSTEM AND SCREEN SUPPORT SYSTEM. (CONSULT TM 5-301 TO DETERMINE QUANTITY OF THESE FACILITIES REQUIRED FOR COMPLETE COVERAGE.)			903			1	1
14991AF	CAMOUFLAGE, DESERT RADAR TRANSPARENT SYSTEM AND SCREEN SUPPORT SYSTEM. (CONSULT TM 5-301 TO DETERMINE QUANTITY OF THESE FACILITIES REQUIRED FOR COMPLETE COVERAGE.)			871			1	1
15150AD	BOMB DAMAGE REPAIR TO A COMMERCIAL CARGO PIER	3	152	139,108	414	1,477	1,932	3,823
15150BA	GUARD RAIL FOR DELONG BARGE 1FT-4IN HIGHX100LF,STEEL SHEET 4	2		1,033	6	23	12	41
15150BB	GUARD RAIL FOR DELONG BARGE 1FT-11.5IN HIGHX100LF,STEEL SHEET 4	4		1,760	6	23	12	41
15150BC	SEACUSHION, 6FTX7.4FT, DELONG PIER, W/PADEYES & FITTINGS SHEET 6	1	7	5,814	2	5		7
15150BD	ROPE SLING FOR CONCRETE BALLAST UNITS/FLOATING FENDERS SHEET 9				64		2	2
15150BE	CORNER GUARD, 71-INX1.5INX10.0FT STEEL PIPE, DELONG B PIER SHEET 4	8	10	5,822	28	55		83
15150BF	DELONG A BARGE, MOORED TO RO/RO FACILITY SHEET 6	3	250	2,305,914	5	2	9	16

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL HOURS	TOT
151508G	SPUD PILE & CONNECTING BRACKET,AMMI PIER SHEET 5	3	5	10.691	16	69			85
151508H	MOORING POST,24-IN PIPE,DE LONG PIER SHEET 7	3	1	3.067	5	28			33
151508J	BITTS,ONE PAIR,AMMI PIER SHEET 7			164	2	23			25
151508K	BITTS,ONE PAIR,DELONG PIER SHEET 7			370	1	5			6
151508L	MOORING BITT,FLOATING FENDER SHEET 7			236	2	48			50
151508M	WIRE ROPE WRAP-AROUND TIE FOR PAIR OF CAISSENS-DELONG B PIER SHEET 6			923	9	48	14	71	
151508N	STEEL CLOSURE PLATES,20 FT LONG,DELONG/AMMI BARGES SHEET 6	1		496	1	1	1	1	3
151508P	TIMBER CLOSURE PLUG,8 FT LONG,DELONG/AMMI BARGES SHEET 6			86	7	46	18	71	
151508R	SEACUSHION,6FTX12FT,DELONG PIER,W/PADEYES & FITTINGS SHEET 6	2	20	13,772	2	5			7
151508T	SEACUSHION,10FTX16FT,DELONG PIER,W/PADEYES & FITTINGS SHEET 6	6	66	39,212	2	5			7
151508U	TIMBER BACKING FOR 4-FT SEACUSHION, FLOATING FENDERS SHEET 9	1	2	306	6	9			15
151508V	TIMBER BACKING FOR L-FT SEACUSHION, FLOATING FENDERS SHEET 1	1	2	388	15	89	39	143	
151508W	TIMBER & STL BACKING FOR 10-FT SEACUSHION, FLOATING FENDERS SHEET 9	6	7	2,005	24	98	39	161	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT	IN MAN-HOURS	
		SHT TONS	MEAS TONS		HOR	VERT	GENL	TOT
15150BY	TIMBER FENDER FOR SIDESHELL, DELONG BARGE, 19FTX10FTX12IN SHEET 6	3	5	822	17	51	23	91
15150CA	END GUARD, TIMBER & STEEL, FLOATING FENDERS SHEET 8	13	10	5,530	21	28	14	63
15150CB	INTERMEDIATE GUARD, TIMBER & STEEL, FLOATING FENDERS SHEET 8	10	7	5,011	10	14	7	31
15150CC	RAMP, RO/RO PIER, MACBRIDGE, TYPE, H/27FT-6IN RISE SHEET 2	700	1,850	2,000,000	5	2	9	16
15150CD	TRUNK, CAUSEWAY, SHEET PILE BULKHEADS, 10-FT SURF, 100 LF. SHEET 13	3,841	2,567	97,559	662	938	221	1,821
15150CE	FLOATING FENDER ASSEMBLY, 128 FT LONG X 8FT WIDE X 12FT HIGH W/CONCRETE BALLAST, MOORING ROPES & MOORING COLLARS SHEET 10	108	18	65,145	110	138	55	303
15150CF	CONNECTING RAMP FOR DELONG A BARGES, 22FT-2IN WIDE X 40FTLONG SHEET 11	22	8	17,509	9	12	37	58
15150CG	TIMBER DECK FOR DELONG:B:BARGE, 12IN THICK SHEET 4	142	208	37,803	66	273	258	595
15150CH	TIMBER DECK FOR DELONG:A:BARGE, 12IN THICK SHEET 4	384	562	102,432	345	690	1,035	2,070
15150CJ	TIMBER DECK FOR DELONG:B:BARGE, 4 IN THICK SHEET 4	45	66	9,604	66	258	129	451
15150CK	TIMBER DECK FOR AMMI BARGE, 12IN THICK SHEET 5	22	32	5,791	25	76	51	152
15150CL	TIMBER DECK FOR AMMI BARGE, 4 IN THICK SHEET 5	11	16	2,873	25	76	51	152

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT	
15150CH	JACKED-UP DELONG IB: BARGE SHEET 4	479	828	1,342,761	125	580	166	871
15150CN	JACKED-UP AMMI BARGE - 60FT X 30FT X 5FT, SHEET 5	37	262	91,064	46	166	53	265
15150CP	RAMP,RO/RO PIER,MACBRIDGE TYPE,W/22FT-6IN RISE SHEET 4	600	1,930	1,630,000	5	2	9	16
15150CR	PLATFORM,STEEL,4 FIRE PUMPS,15FTX22FT,ON SIDE OF AMMI BARGE SHEET 12	6	5	6,463	21	124	41	186
15150CT	PLATFORM,STL,4 FIRE & 2 DESALINATION PUMPS,15FTX22FT,ON AMMI SHEET 12	7	6	7,858	21	124	41	186
15150CU	HEAD,CAUSEWAY,STONE,SLOPE H/V<2.0,UNIT WT OF STONE 145PCF SHEET 13							
15150CV	HEAD,CAUSEWAY,STONE,SLOPES[H/V>2.0,UNIT WT OF STONE > 155PCF SHEET 13				163	92	276	531
15150CW	HEAD,CAUSEWAY,STONE,SLOPES[H/V>2.0,UNIT WT OF STONE > 165PCF SHEET 13				138	76	228	442
15150CY	HEAD,CAUSEWAY,SHEET PILE CELLS SHEET 13	1,262	829	83,551	129	154	83	366
15150DA	TRUNK,CAUSEWAY,STONE(145PCF),10-FT SURF,SLOPE H/V>1.5,100LF SHEET 13	2	2	639	268	166	276	690
15150DB	TRUNK,CAUSEWAY,STONE(155PCF),10-FT SURF,SLOPE H/V>1.5,100LF SHEET 13	2	2	639	268	166	276	690
15150DC	TRUNK,CAUSEWAY,STONE(165PCF),10-FT SURF,SLOPE H/V>1.5,100LF SHEET 13	2	2	639	268	166	276	690
15150DD	TRUNK,CAUSEWAY,STONE(145PCF),5-FT SURF,SLOPE H/V>1.5,100LF SHEET 13	2	2	639	299	77	243	619

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
				HOR	VERT	GENL	TOT	
15150DE	TRUNK, CAUSEWAY, STONE(155pcf), 5-FT SURF, SLOPE H/V>1.5, 100LF SHEET 13	2	2	639	299	77	243	619
15150DF	TRUNK, CAUSEWAY, STONE(165pcf), 5-FT SURF, SLOPE H/V>1.5, 100LF SHEET 13	2	2	639	184	77	244	505
15150DG	TRUNK, CAUSEWAY, STONE(145-165pcf), SLOPE H/V>1.5, ON DRY LAND HEIGHT>15FT, 100LF, SHEET 13	2	2	639	81	40	81	202
15150DH	TRUNK, CAUSEWAY, COMPACTED LANDFILL, SLOPES H/V>1.5, HEIGHT>15FT ON DRY LAND, 100 LF, SHEET 13	2	2	639	60	20	40	100
15150DJ	TRUNK, CAUSEWAY, STONE(145-165pcf) SLOPES H/V>1.5, HEIGHT>10FT ON DRY LAND, 100LF, SHEET 13	2	2	639	81	40	81	202
15150DK	TRUNK, CAUSEWAY, COMPACTED LANDFILL, SLOPES H/V>1.5, HEIGHT>10FT ON DRY LAND, 100LF, SHEET 13	2	2	639	60	20	40	100
15150DL	TRUNK, CAUSEWAY, STONE(145-165pcf), SLOPES H/V>1.5, HEIGHT>5 FT ON DRY LAND, 100LF, SHEET 13	2	2	639	35	17	35	87
15150DM	TRUNK, CAUSEWAY, COMPACTED LANDFILL, SLOPES H/V>1.5, HEIGHT>5 FT ON DRY LAND, 100LF, SHEET 13	2	2	639	17	9	17	43
15150DN	FOUNDATION FOR MACBRIDGE TYPE RO/RO RAMP ON DELONG A BARGE SHEET 4			780		2	2	4
15150DP	STEEL COVER, DE LONG BARGE CAISSON WELL, 130X135X7IN. SHEET 4	18	2	14,022				
15150DR	1X15 NL PONTOON FENDER W/SEACUSHIONS, FOR AMMI PIER NAVFAC DWG SK9105 & 15150BA-EK, SHT 5			250	28	28		56
15150DT	HANGER, 1 OR 2 PIPES, STEEL, AMMI/DELONG:B:B BARGE DWG 1105-15, SHEET 8			18	2	5	5	12
15150DU	BRACKET, SUPPORT FOR 3 PIPES, STEEL, AMMI BARGE DWG 1105-15, SHEET 8			68	3	3	3	6

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT	VOL	MEAS	COST	CONST EFFORT IN MAN-HOURS			
		TONS	TONS			HHR	VERT	SENL	TOT
15150DV	BRACKET,SUPPORT FOR 2 PIPES,STEEL,DELONG:B:BARGE DWG 1105-15,SHEET 8				51		2	2	4
15150DW	BRACKET,ANCHOR FOR 3 PIPES,STEEL,AMMI BARGE DWG 1105-15,SHEET 8				80		5	5	10
15150DY	BRACKET,ANCHOR FOR 2 PIPES,STEEL,DELONG:B:BARGE DWG 1105-15,SHEET 8				59		3	3	6
15150EA	DELONG CONTAINER PIER-900FT LONG X 120 FT WIDE-12 DELONG B:S SHEET 1	9,599	14,756	21,055,308	6,500	26,514	10,819	43,833	
15150EB	DELONG BREAKBULK PIER-600FT LONG X 120 FT WIDE-11 DELONG B:S SHEET 2	8,227	12,376	18,492,308	6,878	21,839	9,715	36,452	
15150EC	DELONG FLOATING RO/RO STAGE W/RAMPS,600FT LONG X 160 FT WIDE -3 DELONG A:S 3 DELONG B:S 1 MACBRIDGE RAMP & 2 CONNECTING RAMPS FOR DELONG A:S,SHEET 2	3,754	7,405	14,097,294	2,330	11,341	4,733	18,404	
15150ED	DELONG LIGHTERAGE PIER-300FT LONG X 120FT WIDE-3 DELONG B:S SHEET 3	2,519	3,452	5,201,227	1,521	5,244	2,484	9,249	
15150EE	DELONG SERVICE PIER-450FT LONG X 60FT WIDE-3 DELONG B:S SHEET 3	2,502	3,080	5,251,646	1,857	4,545	1,435	7,837	
15150EF	AMMI PORT VESSEL PIER -180FT LONG X 30FT WIDE, 3 AMMIS SHEET 3	3,007	8,234	8,413,499	605	1,987	497	3,089	
15150EG	AMMI SERVICE VESSEL PIER-240FT LONG X 30FT WIDE, 7 AMMIS SHEET 3	3,207	9,266	8,793,543	782	2,691	690	4,163	
15150EH	DELONG TRESTLE W/12-INCH TIMBER DECK -1 DELONG:B:BARGE SHEET 1	633	1,036	1,586,429	308	1,290	531	2,129	
15150EJ	AMMI TRESTLE W/12-INCH TIMBER DECK -1 AMMI 30FTX60FT BARGE SHEET 5	59	274	97,050	90	359	154	603	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL MEAS	COST TONS	CONST EFFORT IN MAN-HOURS			
		TONS	TONS	\$	HOR	VERT	GENL	TOT
15150EK	AMMI TRESTLE W/4-INCH TIMBER DECK - 1 AMMI 30FTX60FT BARGE SHEET 3	50	238	94,661	85	235	110	430
15150EL	DELONG CONTAINER PIER,TRESTLE & CAUSEWAY,20-FT TIDE,15 PER CENT GROUND SLOPE-TRESTLE 1 DELONG B PLUS 3 AMMI BARGES, CAUSEWAY HEAD[SHEET PILE CELLS, TRUNK[SHEET PILE BLKHD[70LF & COMPACTED LANDFILL 100LF DWG FP1105-1115,SHEET 1	13,100	18,399	23,001,817	7,710	29,711	12,090	49,511
15150EM	DELONG BREAKBULK PIER,TRESTLE & CAUSEWAY,20-FT TIDE,15 PER CENT GROUND SLOPE-TRESTLE 1 DELONG B PLUS 3 AMMI BARGES,- CAUSEWAY HEAD[SHEET PILE CELLS, TRUNK[SHEET PILE BLKHD[70 LF & COMPACTED LANDFILL 100LF DWG FP1105-1115,SHEET 1	12,990	16,848	20,522,368	6,088	25,056	10,986	42,130
15150EN	DELONG BREAKBULK-RO/RO PIER,TRESTLE & CAUSEWAY,20-FT TIDE,15 PERCENT GROUND SLOPE-TRESTLE 1 DELONG B & 3 AMMI BARGES,-15 CAUSEWAY HEAD[SHEET PILE CELLS,TRUNK[SHEET PILE BLKHD[70 LF & COMPACTED LANDFILL 100LF DWG FP1105-1115,SHEET 1	16,744	24,253	34,619,662	8,418	36,398	15,719	60,535
15150EP	DELONG LIGHTERAGE PIER,TRESTLE & CAUSEWAY,20-FT TIDE,15 PER CENT GROUND SLOPE-TRESTLE 3 AMMI BARGES-CAUSEWAY HEAD[SHEETPILE CELLS,TRUNK[SHEET PILE BLKHD[70LF & COMPACTED LANDFILL 100 LF, DWG FP1105-1115,SHEET 1	6,649	6,888	5,644,858	2,623	7,151	3,223	12,797
15150ER	DELONG SERVICE PIER,TRESTLE & CAUSEWAY,20-FT TIDE,15 PERCENT GROUND SLOPE-TRESTLE 3 AMMI BARGES- CAUSEWAY HEAD[SHEET PILE CELLS, TRUNK[SHEET PILE BLKHD[70LF & COMPACTED LANDFILL 100 LF, DWG FP1105-1115,SHEET 1	6,605	6,468	5,688,110	2,745	6,079	2,044	10,865
15150ET	AMMI PORT AND SERVICE VESSEL PIERS,TRESTLE & CAUSEWAY,20-FT TIDE,15 PERCENT GROUND SLOPE - TRESTLE 6 AMMI BARGES - CAUSEWAY HEAD[SHEET PILE CELLS, TRUNK[SHEET PILE BLKHD[70 LF & COMPACTED LANDFILL 100 LF, DWG FP1105-1115,SHEET 1	10,467	21,662	17,927,489	2,530	6,916	2,126	11,572
15191AA	DE LONG PIER A-300 FB. THIS FACILITY SATISPIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.	3	250	2,305,916	69	29	98	196

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS	COST \$	CONST HOR	EFFORT VERT	IN GENL	HOURS TOT
151918A	DE LONG PIER B-150 FB. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.	10	250	1,193,015	55	23	78	156
15250AU	BOMB DAMAGE REPAIR OF CARGO WHARF	29	26	2,546	449	1,173	1,173	2,795
16390AA	TANKER MOORING, POL, 3 LEGS-60 FT DEPTH	61	157	103,495	460	506	345	1,311
16390AB	TANKER MOORING, POL, 3 LEGS - 90 FT DEPTH	64	158	118,762	352	598	357	1,507
16390AC	TANKER MOORING, POL, 3 LEGS - 120 FT DEPTH	71	160	129,572	610	725	391	1,726
16390AD	TANKER MOORING, POL, 5 LEGS - 60 FT DEPTH	98	254	169,468	690	771	460	1,921
16390AE	TANKER MOORING, POL, 5 LEGS - 90 FT DEPTH	105	256	194,913	805	886	68	1,739
16390AF	TANKER MOORING, POL, 5 LEGS - 120 FT DEPTH	116	258	212,622	897	1,012	506	2,415
16390AG	TANKER MOORING, POL, 7 LEGS 60 FT DEPTH	136	351	235,307	966	1,035	644	2,645
16390AH	TANKER MOORING, POL, 7 LEGS-90 FT DEPTH	145	354	271,130	1,150	1,234	690	3,094
16390AJ	TANKER MOORING, POL, 7 LEG - 120 FT DEPTH	160	357	295,471	1,277	1,392	759	3,628
16440AA	JETTY, POL, 14-FT X 1000 FT WALK AND PIPEWAY WITH 40X70 WHARF, TIMBER PILING, DECK AND MOORING FACILITIES.	695	718	278,329	4,945	8,050	219	13,214
16440AB	HOSE DERRICK PARTS FOR POL WHARFS.	2	1	2,709		104	104	208
21330BD	SMALL BOAT REPAIR FACILITY 2800SQ FT PRE-ENGINEERED METAL BUILDING 40 FT X 70 FT WITH INTERIOR, TEMPERATE, DESERT AND FRIGID CLIMATE	28	52	33,764	9	32	41	82
21330BG	SMALL BOAT REPAIR FACILITY 2880SQ FT PANELIZED WOOD BUILDING 48 FT X 60 FT ONE STORY CONCRETE FLOOR 12 FT HIGH WOOD PANEL CLADDING AND WOOD PANEL ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE	204	897	79,053	25	1,234	454	1,713

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					HOR	VERT	GENL	TOT
21330BH	INTERIOR FOR SMALL BOAT REPAIR FACILITY 3072SQ FT WOOD FRAME BUILDING TEMPERATE; FRIGID AND DESERT CLIMATE	10	16	6,529		31	14	45
21330BK	ELECTRICAL WIRING KIT, FLUORESCENT LIGHTING AND RECEPTACLE OUTLETS, 20 FOOTCANDLES, 3000 SQ FT, 8 TO 14 FEET MOUNTING HEIGHT, INCLUDING WIRING FOR VENTILATION EXHAUST FANS	1	4	3,172		246	41	287
21410BW	TRACKED VEHICLE TURNING PAD	20	15	1,312		36	54	90
21410BY	VEHICLE WASH RACK	21	15	1,598	5	68	94	167
21410EC	END REPAIR BAY - WOOD FRAME CONSTRUCTION; WOOD CLADDING AND ROOF DECKS; OPEN ONE SIDE; ONE COLUMN; 20X60FT DESERT-TROPIC CLIMATES	364	314	24,093	70	872	237	1,179
21410ED	END REPAIR BAY - PREFABRICATED METAL FRAME CONSTRUCTION; CONCRETE FLOOR AND FOUNDATIONS; CORRUGATED METAL CLADDING AND ROOF DECK; OPEN ONE SIDE; ONE ROOF FRAME; 20X60FT DESERT/TROPIC CLIMATES	18	15	14,137	62	742	335	1,139
21410EH	END REPAIR BAY - WOOD FRAME CONSTRUCTION; WOOD CLADDING AND ROOF DECKS; OPEN ONE SIDE; TWO COLUMNS; 20X60FT DESERT/TROPIC CLIMATES	374	321	25,381	72	898	262	1,212
21410EJ	END REPAIR BAY - PREFABRICATED METAL FRAME CONSTRUCTION; CONCRETE FLOOR AND FOUNDATIONS; CORRUGATED METAL CLADDING OPEN ONE SIDE; TWO ROOF FRAMES; 20X60FT DESERT/TROPIC CLIMATES	18	15	14,137	72	865	386	1,303
21410EM	END REPAIR BAY - WOOD FRAME CONSTRUCTION; WOOD CLADDING AND ROOF DECK; CLOSED ALL SIDES; TWO COLUMNS; 20X60 FT DESERT/TROPIC CLIMATES	435	390	29,007	139	1,734	434	2,307
21410EN	END REPAIR BAY - PREFABRICATED METAL FRAME CONSTRUCTION; CONCRETE FLOOR AND FOUNDATIONS; CORRUGATED METAL CLADDING CLOSED ALL SIDES; TWO ROOF FRAMES; 20X60FT DESERT/TROPIC CLIMATES	18	15	14,137	78	897	413	1,388

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST \$	CONST HOR	EFFORT VERT	IN HAN-HOURS GENL	TOT
21410ET	END REPAIR BAY - WOOD FRAME CONSTRUCTIONS; WOOD CLADDING AND AND ROOF DECKS; OPEN TWO SIDES; ONE COLUMN; 20X60FT DESERT/TROPIC CLIMATES	290	236	T6/130	41	361	135	797	
21410EU	INTERIOR REPAIR BAY - PREFABRICATED METAL FRAME CONSTRUCTION; CONCRETE FLOOR AND FOUNDATIONS; CORRUGATED METAL CLADDING; OPEN TWO SIDES; ONE ROOF FRAME DESERT/TROPIC CLIMATES	18	15	T2/137	52	638	283	973	
21410EY	1200 SQUARE FOOT CORE - WOOD FRAME CONSTRUCTION; WOOD CLADDING AND ROOF DECK; GABLE WITH ONE END WALL; ONE COLUMN DESERT/TROPIC CLIMATES	277	245	24,333	250	1,509	651	2,410	
21410FA	1200 SQUARE FOOT CORE LEAN-TO; PREFABRICATED METAL FRAME CONCRETE FLOOR AND FOUNDATIONS; CORRUGATED METAL CLADDING DESERT/TROPIC CLIMATES	15	15	16,771	131	692	284	1,107	
21410FD	1200 SQUARE FOOT CORE-WOOD FRAME CONSTRUCTION W/WOOD CLADDING AND ROOF DECK (JOIN TO SUBFACILITY EY ONLY. 20X60 FEET DESERT/TROPIC CLIMATE.	286	252	25,573	252	1,535	653	2,440	
21410FE	1200 SQUARE FOOT CORE SUBFACILITY; PREFABRICATED METAL FRAME; CONCRETE FLOOR AND FOUNDATIONS; CORRUGATED METAL CLADDING (W/RIDGE SUPPORT - JOIN TO SUBFACILITY FA ONLY) DESERT/TROPIC CLIMATES	15	15	16,771	97	966	483	1,546	
21410FH	1200 SQUARE FOOT CORE WOOD FRAME CONSTRUCTION WITH WOOD CLADDING AND ROOF DECK; GABLE WITH NO END WALLS; ONE COLUMN DESERT/TROPIC CLIMATES	3	7	3,654	131	946	229	1,306	
21410FJ	2400 SQUARE FOOT CORE LEAN-TO, PREFABRICATED METAL FRAME, CONCRETE FLOOR AND FOUNDATIONS, CORRUGATED METAL CLADDING AND ROOF DECK DESERT/TROPIC CLIMATES	30	28	31,701	121	1,208	604	1,933	
21410FN	2400 SQUARE FOOT CORE SUBFACILITY, PREFABRICATED METAL FRAME, CONCRETE FLOOR AND FOUNDATIONS, CORRUGATED METAL CLADDING AND ROOF DECK, (W/RIDGE SUPPORT - JOIN TO SUBFACILITY FJ ONLY), 40X60 FT DESERT/TROPIC CLIMATES MAINT.CORE 00002400SQFT	30	28	31,701	245	1,558	677	2,480	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		HOR	VERT	GENL	TOT			
214106G	2400 SQUARE FOOT BUILDING, PLAN TYPE 2, 2 REPAIR BAYS, 1200 SQ. FT. CORE, WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, 40X60 FT DESERT/TROPIC CLIMATES	712	636	54,627	423	3,368	1,102	4,893
214106H	2400 SQUARE FOOT BUILDING, PLAN TYPE 2, 2 REPAIR BAYS, 1200 SQ. FT. CORE, PREFABRICATED METAL CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, CORRUGATED METAL CLADDING, ROOF DECK DESERT, TROPIC CLIMATES	36	31	27,561	199	1,639	713	2,551
214106T	3600 SQUARE FOOT CORE BUILDING, PLAN TYPE 4, 4 REPAIR BAYS, 1200 SQ. FT. CORE, WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATION, WOOD CLADDING AND ROOF DECK, 60X60 FT DESERT/TROPIC CLIMATES	1,015	881	75,577	426	3,393	1,106	4,925
214106U	3600 SQUARE FOOT BUILDING, PLAN TYPE 4, 4 REPAIR BAYS, 1200 SQ. FT. CORE, PREFABRICATED METAL CONSTRUCTION, CONCRETE FLOOR AND FOUNDATION, CORRUGATED METAL CLADDING AND ROOF DECK, 60X60 FT DESERT/TROPIC CLIMATES MAINT.FACLT00003600SQFT	51	46	46,815	271	2,432	1,049	3,752
21410HN	4800 SQUARE FOOT BUILDING, PLAN TYPE 8/6 REPAIR BAYS 1200 SQ FT,CORE,WOOD FRAME CONSTRUCTION,CONCRETE FLOOR AND FOUNDATION,WOOD CLADDING AND ROOF DECK,TROPIC/DESERT CLIMATES.	1,305	1,117	97,628	658	3,933	1,233	5,624
21410HP	4800 SQUARE FOOT BUILDING,PLAN TYPE 8/6 REPAIR BAYS,1200 SQ FT,CORE,PREFAB METAL CONSTRUCTION CONCRETE FLOOR AND FOUNDATION,CORRUGATED METAL CLADDING AND ROOF,TROP/DESERT CLIMS.	69	61	58,873	350	2,760	1,132	4,242
21410JE	4800 SQUARE FOOT CORE BUILDING, PLAN TYPE 11, 4 REPAIR BAYS , 2400 SQ. FT. CORE, WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATION, WOOD CLADDING AND ROOF DECK, 80X60 FT DESERT/TROPIC CLIMATES	741	643	54,819	273	2,826	685	3,784
21410JF	4800 SQUARE FOOT BUILDING, PLAN TYPE 11, 4 REPAIR BAYS, 2400 SQ. FT. CORE, PREFABRICATED METAL CONSTRUCTION, CONCRETE FLOOR AND FOUNDATION, CORRUGATED METAL CLADDING AND ROOF DECK, 80X60 FT DESERT/TROPIC CLIMATES MAINT.FACLT00004800SQFT	66	59	61,666	256	2,977	1,287	4,520

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION	CONSTRUCTION MATERIAL						CONST EFFORT IN MAN-HOURS		
		WT TONS	SHT TONS	VOL MEAS TONS	COST \$	HOR	VERY GENL	TOT	HOR	VERY GENL
21410NA	CORE - 1200 SQUARE FOOT MODULAR INTERIOR CORE PARTITIONS WITH THREE DOORS ALL CLIMATES	2	3	1,304	124	51	12	177		
21410NB	CORE - 2400 SQUARE FOOT MODULAR INTERIOR CORE PARTITIONS WITH 4 DOORS ALL CLIMATES	4	4	2,059	28	9	2	39		
21410NC	CORE - DX/TS PARTITION ALL CLIMATES	1	1	432		85	17	102		
21411AA	LUBRICATION RACK/VEHICLE,12X56 W/RAMP+PLATFORM	7	5	865		414	69	483		
21430AG	CRANE SUPPORT FOR 10 TON CRANE, 100 FT OF CRANEWAY	24	27	9,397	23	529	184	736		
21430BD	SHOP, ORDNANCE GENERAL PURPOSE REBUILD, LIGHTWEIGHT TENSION FABRIC MEMBRANE BUILDING, 124 BY 244 BY 16/42	240	180	159,420						
21710AA	COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 1000 SQ FT WOOD FRAME BUILDING 20 FT X 50 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	28	39	8,764	30	1,072	271	1,373		
21710AB	INTERIOR FOR COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 1000 SQ FT WOOD FRAME BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	5	12	4,705		807	184	991		
21710AC	COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 1000 SQ FT PRE-ENGINEERED METAL BUILDING 20 FT X 50 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE , FRIGID AND DESERT CLIMATE	13	66	15,969	71	1,538	568	2,177		
21710AD	INTERIOR FOR COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 1000 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	6	14	5,339		831	196	1,027		
21710AE	COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 2000 SQ FT WOOD FRAME BUILDING 40 FT X 50 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	53	66	13,760	37	1,740	612	2,189		

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

21710AF INTERIOR FOR COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP
FACILITY 2000 SQ FT WOOD FRAME BUILDING TEMPERATE , FRIGID
AND DESERT CLIMATE

21710AG COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 2000 SQ
FT PRE-ENGINEERED METAL BUILDING 40 FT X 50 FT ONE STORY
CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH
INTERIOR TEMPERATE , FRIGID AND DESERT CLIMATE

21710AH INTERIOR FOR COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP
FACILITY 2000 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE
, FRIGID AND DESERT CLIMATE

21710AJ COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 4000 SQ
FT WOOD FRAME BUILDING 40 FT X 100 FT ONE STORY CONCRETE
FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT
ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE

21710AK INTERIOR FOR COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP
FACILITY 4000 SQ FT WOOD FRAME BUILDING TEMPERATE , FRIGID
AND DESERT CLIMATE

21710AL COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 4000 SQ
FT PRE-ENGINEERED METAL BUILDING 40 FT X 100 FT ONE STORY
CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH
INTERIOR TEMPERATE , FRIGID AND DESERT CLIMATE

21710AM INTERIOR FOR COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP
FACILITY 4000 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE
, FRIGID AND DESERT CLIMATE

21710BH COMMUNICATION-ELECTRONIC SHOP SLIDING DOOR,PAIRS WITH TRACK
FOR OPENING. 8 FOOT WIDE BY 6FOOT-10INCH HIGH.

21710BM COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 1152 SQ
FT PANELIZED WOOD BUILDING 24 FT X 48 FT ONE STORY WOOD
FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR DESERT AND
TROPIC CLIMATE

CONSTRUCTION MATERIAL

WT
SHT
TONSVOL
MEAS
TONSCOST
\$CONST
EFFORT
HORIN MAN-HOURS
VERT
GENL
TOT

9	20	7,504	1,225	283	1,508
---	----	-------	-------	-----	-------

24	129	29,109	131	2,566	1,001	3,698
----	-----	--------	-----	-------	-------	-------

11	24	8,666	1,268	313	1,581
----	----	-------	-------	-----	-------

102	123	25,195	48	3,246	722	4,016
-----	-----	--------	----	-------	-----	-------

16	35	12,850	2,119	483	2,602
----	----	--------	-------	-----	-------

46	93	53,414	262	4,789	1,893	6,944
----	----	--------	-----	-------	-------	-------

20	40	14,722	2,194	518	2,712
----	----	--------	-------	-----	-------

1	1	192	18	9	27
---	---	-----	----	---	----

36	45	24,863	9	1,557	1,170	2,736
----	----	--------	---	-------	-------	-------

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

21710BN COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 2160 SQ FT PANELIZED WOOD BUILDING 36 FT X 60 FT ONE STORY WOOD FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE

21710BP COMMUNICATIONS-ELECTRONIC MAINTENANCE SHOP FACILITY 4800 SQ FT PANELIZED WOOD BUILDING 48 FT X 100 FT ONE STORY WOOD FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE

21710CD COMMUNICATIONS, ELECTRONIC SHOP, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, DESERT/TROPIC CLIM

21710CE COMMUNICATIONS, ELECTRONIC SHOP, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 50 BY 8, DESERT/TROPIC CLIM

21710CF COMMUNICATIONS, ELECTRONIC SHOP, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 100 BY 8, DESERT/TROPIC CLIM

21720BC SHOP, SIGNAL MAINTENANCE, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 100 BY 12, DESERT/TROPIC CLIM

21810AA PARACHUTE PACKING AND DRYING FACILITY 5200 SQ FT WOOD FRAME BUILDING 40 FT X 130 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR AND 400 SQ FT WOOD FRAME PARACHUTE DRYING TOWER AND 64 SQ FT WOOD FRAME BLOWER SHED, TEMPERATE AND DESERT CLIMATES

21810AD PARACHUTE PACKING AND DRYING FACILITY 5200 SQ FT PRE-ENGINEERED METAL BUILDING 40 FT X 130 FT ONE STORY CONCRETE FLOOR CORRUGATED METAL CLADDING AND ROOF WITH INTERIOR AND 400 SQ FT WOOD FRAME PARACHUTE DRYING TOWER AND 64 SQ FT WOOD FRAME BLOWER SHED, TEMPERATE, FRIGID AND DESERT CLIMATES

21810AG PARACHUTE PACKING AND DRYING FACILITY 4320 SQ FT PANELIZED WOOD BUILDING 36 FT X 120 FT ONE STORY CONCRETE FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR AND 400 SQ FT WOOD FRAME PARACHUTE DRYING TOWER AND 64 SQ FT WOOD FRAME BLOWER SHED, DESERT AND TROPIC CLIMATES

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
			HOR	VERT	GENL	TOT

173	957	98,015	21	2,197	675	2,893
-----	-----	--------	----	-------	-----	-------

217	951	121,963	29	3,942	1,225	5,196
-----	-----	---------	----	-------	-------	-------

17	24	6,776	8	960	322	1,290
----	----	-------	---	-----	-----	-------

37	42	9,563	65	1,531	576	2,152
----	----	-------	----	-------	-----	-------

72	79	20,029	75	2,638	991	3,726
----	----	--------	----	-------	-----	-------

42	46	12,252	69	2,050	530	2,649
----	----	--------	----	-------	-----	-------

156	174	38,984	58	3,522	654	4,234
-----	-----	--------	----	-------	-----	-------

84	136	78,421	359	5,672	2,266	8,297
----	-----	--------	-----	-------	-------	-------

454	1,996	174,907	38	3,813	1,205	5,056
-----	-------	---------	----	-------	-------	-------

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	HOR	VERT	GENL	TOT
21810AH	INTERIOR FOR PARACHUTE PACKING AND DRYING FACILITY 5200 SQ FT WOOD FRAME AND PRE-ENGINEERED METAL BUILDINGS, TEMPERATE FRIGID AND DESERT CLIMATES	8	21	8,157		8	2		10
21810AK	PARACHUTE DRYING FACILITY WITH 400 SQ FT WOOD FRAME PARACHUTE DRYING TOWER BUILDING 42 FT 5 IN HIGH AND 64 SQ FT WOOD FRAME BLOWER SHED EACH WITH CONCRETE FOUNDATION AND WOOD FLOORS AND WOOD AND FELT CLADDING AND ROOFS WITH INTERIORS, TEMPERATE, FRIGID, DESERT AND TROPIC CLIMATES	42	45	15,827		2	2,130	394	2,526
21830AC	DRUM REPAIR & PUMP-COMPRESSOR BLDG, POL, 32X64, WOOD FRAME BLDG WITH METAL CLADDING, INTERIOR & VENTILATION, DESERT ZONE	37	64	78,668		58	1,841	323	2,222
21830AF	DRUM CLEANING BLDG, POL, 83X200, STEEL FRAME BLDG W/METAL CLADDING, INTERIOR & VENTILATION FOR DESERT ZONE	435	390	282,688		828	14,889	3,398	19,115
21850AA	INTERIOR FOR BATTERY CHARGE FACILITY 20X24	1	3	2,601		178			178
21850AB	BATTERY CHARGE FACILITY STL FRAME BLDG W/INTERIOR 20X24X8	4	9	6,858		450	150		625
21850AC	BATTERY CHARGE FACILITY WOOD FRAME BLDG W/INTERIOR 20X24X8	11	14	4,284		426	75		527
21850AD	BATTERY CHARGE FACILITY PANEL WOOD BLDG W/INTERIOR 20X24X8	179	103	8,995		673	256		735
21850BB	BATTERY CHARGE SHOP, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 24 BY 8, DESERT/TROPIC CLIM	3	4	2,663		239	48		293
21885AA	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 600 SQ FT WOOD FRAME BUILDING 20 FT X 30 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	16	21	5,354		984	193		7,217
21885AB	INTERIOR FOR GENERAL PURPOSE MAINTENANCE SHOP FACILITY 600 SQ FT WOOD FRAME BUILDING TEMPERATE, FRIGID AND DESERT CLIMATE	1	4	2,751		411	91		502

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
21885AC	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 600 SQ FT PRE-ENGINEERED METAL BUILDING 20 FT X 30 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE / FRIGID AND DESERT CLIMATE
21885AD	INTERIOR FOR GENERAL PURPOSE MAINTENANCE SHOP FACILITY 600 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE / FRIGID AND DESERT CLIMATE
21885AE	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 1000 SQ FT WOOD FRAME BUILDING 20 FT X 50 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE
21885AF	INTERIOR FOR GENERAL PURPOSE MAINTENANCE SHOP FACILITY 1000 SQ FT WOOD FRAME BUILDING TEMPERATE / FRIGID AND DESERT CLIMATE
21885AG	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 1000 SQ FT PRE-ENGINEERED METAL BUILDING 20 FT X 50 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE / FRIGID AND DESERT CLIMATE.
21885AH	INTERIOR FOR GENERAL PURPOSE MAINTENANCE SHOP FACILITY 1000 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE / FRIGID AND DESERT CLIMATE
21885AJ	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 2000 SQ FT WOOD FRAME BUILDING 40 FT X 50 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE
21885AK	INTERIOR FOR GENERAL PURPOSE MAINTENANCE SHOP FACILITY 2000 SQ FT WOOD FRAME BUILDING TEMPERATE / FRIGID AND DESERT CLIMATE
21885AL	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 2000 SQ FT PRE-ENGINEERED METAL BUILDING 40 FT X 50 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE / FRIGID AND DESERT CLIMATE.

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
			HOR	VERT	BENL	TOT
23	13	10,980	37	782	288	1,107
2	5	3,174	427	98	525	
24	32	7,606	52	1,379	271	1,702
1	3	3,547	529	118	647	
9	20	16,248	71	1,255	500	1,826
2	7	4,075	549	128	677	
45	52	10,623	70	2,093	391	2,554
1	6	4,367	660	150	810	
16	114	25,550	131	1,985	830	2,966

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>								
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			<u>GEHL</u>	<u>TOT</u>	
					<u>HOR</u>	<u>VERT</u>	<u>GELH</u>			
21885AM	INTERIOR FOR GENERAL PURPOSE MAINTENANCE SHOP FACILITY 2000 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE.	3	9	5,107				688	162	850
21885AN	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 4000 SQ FT WOOD FRAME BUILDING 40 FT X 100 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	87	99	19,731	108	3,881	703	4,694		
21885AP	INTERIOR FOR GENERAL PURPOSE MAINTENANCE SHOP FACILITY 4000 SQ FT WOOD FRAME BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	3	13	7,770				1,213	273	1,486
21885AR	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 4000 SQ FT PRE-ENGINEERED METAL BUILDING 40 FT X 100 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE , FRIGID AND DESERT CLIMATE.	32	70	47,942	262	3,863	1,673	5,798		
21885AT	INTERIOR FOR GENERAL PURPOSE MAINTENANCE SHOP FACILITY 4000 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	6	17	9,250				1,268	298	1,566
21885CC	GENERAL PURPOSE MAINTENANCE SHOP FACILITY 216036 FT PANELIZED WOOD BUILDING 36 FT X 60 FT ONE STORY WOOD FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE	164	942	96,319	94	837	94	1,025		
21885DA	OPTICAL FABRICATING SHOP;WOOD FRAME CONSTRUCTION;BASIC BUILDING 30FT X 60FT;WOOD AND ASPH ROOFING;PLYWOOD SIDING 4IN CONC FLOOR;TEMP CLIM	78	106	18,452						
21885DB	OPTICAL FABRICATING SHOP;WOOD FRAME CONSTRUCTION;BASIC BUILDING 30FT X 60FT;WOOD AND ASPH ROOFING;PLYWOOD SIDING 4IN CONC FLOOR;TROP CLIMATE	64	74	17,750						
21885DC	OPTICAL FABRICATING SHOP;WOOD FRAME CONSTRUCTION;BASIC BUILDING 30FT X 60FT;WOOD AND ASPH ROOFING;PLYWOOD SIDING 6IN CONC FLOOR;DES CLIMATE	64	74	17,750						

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HRS	EFFORT VERT	IN GENL MAN-HOURS	TOT
21885DD	OPTICAL FABRICATING SHOP;WOOD FRAME CONSTRUCTION;BASIC BUILDING 30FT X 60FT;WOOD AND ASPH ROOFING;PLYWOOD SIDING 4IN CONC FLOOR;FRIG CLIMATE	78	106	18,452				
21885DE	OPTICAL FABRICATING SHOP;METAL FRAME;TYPE IV;30FT X 60FT; 8FT CLEARANCE;TEMP	37	53	28,247				
21885DF	OPTICAL FABRICATING SHOP;METAL FRAME;TYPE IV;30FT X 60FT; 8FT CLEARANCE;TROP	36	53	27,723				
21885DG	OPTICAL FABRICATING SHOP;METAL FRAME;TYPE IV;30FT X 60FT; 8FT CLEARANCE;DES	37	53	28,247				
21885DH	OPTICAL FABRICATING SHOP;METAL FRAME;TYPE IV;30FT X 60FT; 8FT CLEARANCE;FRIG	37	53	28,247				
21885DJ	MEDICAL MAINTENANCE BUILDING;WOOD FRAME CONSTRUCTION;BASIC BUILDING 40FT X 80FT;WOOD ROOF AND ASPH ROOFING;CONCRETE FOOTING;6IN CONC FLOOR;8FT MIN CLEARANCE;TEMPERATE	100	117	24,816				
21885DK	MEDICAL MAINTENANCE BUILDING;WOOD FRAME CONSTRUCTION;BASIC BUILDING 40FT X 80FT;WOOD ROOF AND ASPH ROOFING;CONCRETE FOOTING;6IN CONC FLOOR;8FT MIN CLEARANCE TROPIC	103	122	26,622				
21885DL	MEDICAL MAINTENANCE BUILDING;WOOD FRAME CONSTRUCTION;BASIC BUILDING 40FT X 80FT;WOOD ROOF AND ASPH ROOFING;CONCRETE FOOTING;6IN CONC FLOOR;8FT MIN CLEARANCE;DESERT	193	220	42,452				
21885DM	MEDICAL MAINTENANCE BUILDING;WOOD FRAME CONSTRUCTION;BASIC BUILDING 40FT X 80FT;WOOD ROOF AND ASPH ROOFING;CONCRETE FOOTING;6IN CONC FLOOR;8FT MIN CLEARANCE;FRIGID	105	129	27,236				
21885DN	MEDICAL MAINTENANCE BUILDING;METAL FRAME;TYPE IV; 40FT X 80FT;6IN CONC FLOOR;8FT CLEARANCE;TEMP/DES	64	101	53,563				
21885DP	MEDICAL MAINTENANCE BUILDING;METAL FRAME;TYPE IV; 40FT X 80FT;6IN CONC FLOOR;8FT CLEARANCE;TROP/FRIG	72	117	56,951				

DHDXR1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
21910AA	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 2000 SQ FT WOOD FRAME BUILDING 40 FT X 50 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	53	64	13,922	70	3,137	553	3,760
21910AB	INTERIOR FOR FACILITY ENGINEER MAINTENANCE SHOP FACILITY 2000 SQ FT WOOD FRAME BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	11	20	8,050	1,741	330	2,071	
21910AC	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 2000 SQ FT PRE-ENGINEERED METAL BUILDING 40 FT X 50 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE , FRIGID AND DESERT CLIMATE	28	130	30,382	136	3,104	1,049	4,289
21910AD	INTERIOR FOR FACILITY ENGINEER MAINTENANCE SHOP FACILITY 2000 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE ,FRIGID AND DESERT CLIMATE	15	25	9,939	1,807	361	2,168	
21910AL	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 2160 SQ FT PANELIZED WOOD BUILDING 36 FT X 60 FT ONE STORY CONCRETE FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE	173	935	98,177	46	3,161	720	3,927
21910AM	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 4000 SQ FT WOOD FRAME BUILDING 40 FT X 100 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	121	150	31,678	108	6,095	1,102	7,303
21910AN	INTERIOR FOR FACILITY ENGINEER MAINTENANCE SHOP FACILITY 4000 SQ FT WOOD FRAME BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	39	66	20,101	5,684	688	4,152	
21910AP	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 4000 SQ FT PRE-ENGINEERED METAL BUILDING 40 FT X 100 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE, FRIGID AND DESERT CLIMATE	73	131	62,916	262	6,211	2,134	8,607

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		HOR	VERT	GENL	TOT			
21910AR	INTERIOR FOR FACILITY ENGINEER MAINTENANCE SHOP FACILITY 4000 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE, FRIGID AND DESERT CLIMATE	47	78	24,224	3,617	759	4,376	
21910BB	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 4800 SQ FT PANELIZED WOOD BUILDING 48 FT X 100 FT ONE STORY CONCRETE FLOOR 12 FT HIGH WOOD PANEL CLADDING AND WOOD PANEL ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE	236	978	128,646	87	6,653	1,478	5,278
21910BC	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 6144 SQ FT WOOD FRAME BUILDING 48 FT X 128 FT ONE STORY CONCRETE FLOOR 13 FT 9 IN HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	194	224	43,665	175	7,423	1,459	9,057
21910BD	INTERIOR FOR FACILITY ENGINEER MAINTENANCE SHOP FACILITY 6144 SQ FT WOOD FRAME BUILDING TEMPERATE, FRIGID AND DESERT CLIMATE	40	69	26,320	2,962	675	3,637	
21910BJ	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 6000 SQ FT PANELIZED WOOD BUILDING 60 FT X 100 FT ONE STORY CONCRETE FLOOR 12 FT HIGH WOOD PANEL CLADDING AND WOOD PANEL ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE	365	1,236	124,770	161	11,011	2,747	13,919
21910BK	FACILITY ENGINEER MAINTENANCE SHOP FACILITY 6000 SQ FT PRE-ENGINEERED METAL BUILDING 60 FT X 100 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE, FRIGID AND DESERT CLIMATE	79	256	51,508	419	6,969	2,796	10,186
22890BB	LABORATORY, MOTION PICTURE, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 100 BY 14, DESERT/TROPIC CLIM	47	55	22,373	75	6,765	521	9,341
22892AA	SAW HORSE TO BE USED IN THE FABRICATION OF PANELIZED WOOD BUILDING SUB-ASSEMBLIES			29		2	2	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
22892AB	FABRICATION JIG FOR WOOD FLOOR PANELS. USED IN THE PANELIZED WOOD BUILDING SUB-FACILITY ASSEMBLY INSTALLATION.	1	1	163		18		18
22892AC	FABRICATION JIG FOR WALL PANELS 6FT. AND 8FT. HIGH. USED IN THE PANELIZED WOOD BUILDING SUB-FACILITY ASSEMBLY INSTALLATION.		1	144		16		16
22892AD	FABRICATION JIG FOR WALL PANELS 12 FEET HIGH. USED IN THE PANELIZED WOOD BUILDING SUB-FACILITY ASSEMBLY INSTALLATION.	1	1	160		18		18
22892AE	FABRICATION JIG FOR 24 FOOT TRUSSES. USED IN THE PANELIZED WOOD BUILDING SUB-FACILITY ASSEMBLY INSTALLATION.	1	2	374		41		41
22892AF	FABRICATION JIG FOR 30 FOOT TRUSSES. USED IN THE PANELIZED WOOD BUILDING SUB FACILITY ASSEMBLY INSTALLATION.	2	3	541		46		46
22892AG	FABRICATION JIG FOR 36 FOOT TRUSSES. USED IN THE PANELIZED WOOD BUILDING SUB-FACILITY ASSEMBLY INSTALLATION.	2	3	499		44		44
22892AH	FABRICATION JIG FOR ROOF PANELS. USED IN THE PANELIZED WOOD BUILDING SUB-FACILITY ASSEMBLY INSTALLATION.	1	1	198		23		23
22892AJ	FABRICATION JIG FOR BOX BEAMS. USED IN THE PANELIZED WOOD BUILDING SUB-FACILITY ASSEMBLY INSTALLATION.	1	1	326		14		14
22901AA	AGGREGATE PRODUCTION, 1000CU YD, 150 TON PER HOUR PLANT AND 50 PERCENT EFFICIENCY		1	361	207	437	345	989
22901AB	HOT MIX ASPHALT PRODUCTION 100 TON PER HOUR PLANT-1000 CY	577	793	29,226	506	637	616	1,357
22901AC	AGGREGATE PRODUCTION 50 TON PER HOUR PLANT 50 PERCENT EFFICIENCY 100 CU YD			56	151		63	214
22990AA	INTERIOR FOR CARPENTER SHOP, PRECUT STANDARD WORK, 40 X 100 100	6	9	6,758		796	276	1,070
22990AB	INTERIOR FOR CARPENTER SHOP, PANEL TYPE WORK , 40 X 120	6	9	6,751		863	253	1,116

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
22990AC	CARPENTER SHOP FOR PRECUT STANDARD WORK, WOOD FRAME BLDG W/ INTERIOR, 48X96X14, TEMP CLIM	122	126	17,817	31	1,969	534	22,554
22990AD	CARPENTER SHOP FOR PANEL TYPE WORK, WOOD FRAME BLDG W/INTERIOR, 48X128X14, TEMP CLIMATE	160	164	22,096	64	2,431	612	3,107
22990BC	CARPENTER SHOP FOR PRECUT STANDARD WORK, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 100 BY 14, DESERT/TROPIC CLIM	31	74	17,442	72	1,061	587	17,700
22990BD	CARPENTER SHOP FOR PANEL TYPE WORK, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 120 BY 14, DESERT/TROPIC CLIM	25	19	5,154	85	1,156	619	12,860
41180AA	TANK, POL, 100 BARREL, W/4 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	3	16	5,628	29	86	35	150
41180AB	TANK, POL, 250 BARREL, W/4 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	5	10	5,202	29	115	32	196
41180AC	TANK, POL, 500 BARREL, W/4 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	1	7	6,442	52	207	86	345
41180AD	TANK, POL, 500 BARREL, W/6 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	2	8	5,863	52	207	86	345
41180AE	TANK, POL, 1000 BARREL, W/4-INCH PIPE AND FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY.	1	13	9,258	92	368	150	610
41180AF	TANK, POL, 1000 BARREL, W/6 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	1	14	8,663	92	357	173	622
41180AG	TANK, POL, 3000 BARREL, W/6 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	2	32	12,538	104	357	242	703
41180AH	TANK, POL, 3000 BARREL, W/8 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	2	32	12,044	104	357	253	714

DHDXR1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL	TOT
41180AJ	TANK, POL, 10000 BARREL, W/6 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	2	40	20,746	161	978	483	1,622
41180AK	TANK, POL, 10000 BARREL, W/8 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	3	40	20,115	161	978	495	1,634
41180AL	TANK, POL, 10000 BARREL, W/12 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	3	41	28,384	167	978	300	1,645
41180AM	TANK, POL, 50000 BARREL, W/8 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	6	193	52,847	345	5,095	2,300	7,740
41180AN	TANK, POL, 50000 BARREL, W/12 IN PIPE & FITTINGS TO TANK BERM & BERM DRAIN ASSEMBLY	4	193	60,922	345	5,106	2,300	7,751
42283AA	MAGAZINE, STEEL ARCH 16X18	15	31	4,280	89	127	115	331
42283AB	MAGAZINE, STEEL ARCH 16X24	16	32	4,354	115	166	153	434
42283AC	MAGAZINE, STEEL ARCH 16X36	14	31	4,453	170	179	173	522
42283AD	MAGAZINE, STEEL ARCH 25X32	27	44	3,355	213	207	253	673
42283AE	MAGAZINE, STEEL ARCH 25X40	31	46	3,473	271	230	316	817
42283AF	MAGAZINE, STEEL ARCH 25X48	34	48	3,427	324	253	380	957
43190AA	REFRIGERATOR 8.6 CF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.						1	3
43190AB	REFRIGERATOR 12.5 CF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.						1	3
43190AC	REFRIGERATOR 20 CF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.						5	12
								17

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL									
FACILITY NUMBER	DESCRIPTION	TONS	TONS	WT SHT	VOL MEAS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	VERY	GENL	TOT
43190AD	REFRIGERATOR 65 CF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.		3			1,632			5	17	22
43191AA	REFRIGERATOR W/O UNIT 600 CF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.		2		11	9,913			41	28	69
43191AB	REFRIGERATOR W/O UNIT 1,200 CF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.		2		21	10,656			69	55	124
43191AC	REFRIGERATOR W/O UNIT 1,800 CF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.		6		25	13,140			69	69	138
43191AD	REFRIGERATOR W/O UNIT 4,000 CF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.		60			49,714			110	83	193
43192AA	REFRIGERATOR UNIT MECHANISM. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.		1		4	5,046			69	46	115
44110AA	INTERIOR FOR STOREHOUSE, 20 X 50		1			1,030			92		92
44110AB	INTERIOR FOR STOREHOUSE, 20 X 100		1		2	1,712			179		179
44110AC	INTERIOR FOR WAREHOUSE, CLOSED, 40 X 100		3			1,408			46		46
44110AD	INTERIOR FOR WAREHOUSE, CLOSED, 80 X 220		2		11	5,697			338		338
44110AE	INTERIOR FOR STOREHOUSE, 20 X 20					260			69		69
44110AF	INTERIOR FOR STOREHOUSE, 20 X 30					260			76		76
44110AL	STOREHOUSE, STL FRAME BLDG W/INTERIOR, 20X50X8,	10	56			11,736			31	370	390

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL TOT	
44110AM	STOREHOUSE, STL FRAME BLDG W/INTERIOR, 20X100X8,	20	107	21,350	61	706	374	1,141
44110AN	WAREHOUSE, CLOSED, STL FRAME BLDG W/INTERIOR, 40X100X12	53	229	37,328	90	835	531	1,656
44110AP	WAREHOUSE, CLOSED, STL FRAME BLDG W/INTERIOR, 80 X 220 X 12	231	350	151,045	342	3,338	2,144	5,824
44110AR	STOREHOUSE, STL FRAME BLDG W/INTERIOR, 20X20X8	4	7	4,539	12	199	79	290
44110AT	STOREHOUSE, STL FRAME BLDG W/INTERIOR, 20X30X8,	5	10	6,172	18	254	115	387
44110BA	STOREHOUSE, WOOD FRAME BLDG W/INTERIOR, 20X50X8,	22	27	6,897	37	550	156	723
44110BB	STOREHOUSE, WOOD FRAME BLDG W/INTERIOR, 20X100X8,	43	53	9,219	52	930	260	1,242
44110BC	WAREHOUSE, CLOSED, WOOD FRAME BLDG W/INTERIOR, 48X96X14	116	120	14,467	81	1,743	645	2,469
44110BD	WAREHOUSE, CLOSED, WOOD FRAME BLDG W/INTERIOR, 80 X 224 X 14	415	412	46,788	228	6,297	2,410	8,935
44110BE	STOREHOUSE, WOOD FRAME BLDG W/INTERIOR, 20X20X8,	10	11	1,943	26	301	61	388
44110CF	STOREHOUSE, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 20 BY 8, DESERT/TROPIC CLIM	3	2	324	5	125	47	177
44110CG	STOREHOUSE, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 30 BY 8, DESERT/TROPIC CLIM	4	3	356	7	154	71	232
44110CH	STOREHOUSE, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, DESERT/TROPIC CLIM	4	3	1,114	9	200	64	275
44110CJ	STOREHOUSE, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 100 BY 8, DESERT/TROPIC CLIM	9	6	1,880	16	381	162	559
44110CK	WAREHOUSE, CLOSED, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 100 BY 16, DESERT/TROPIC CLIM	44	35	2,900	87	374	305	1,160

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT TOT
44220AC	WAREHOUSE, GENERAL USE, WOOD FRAME CONSTRUCTION, BASIC BUILDING, 80FT X 240FT, CORRUGATED STEEL ROOF, CONCRETE FOOTINGS, 6IN CONCRETE FLOOR, 13FT 9IN MIN CLEARANCE DESERT CLIMATE	479	329	103,247	581	3,180	212	3,973
44220AE	WAREHOUSE, GENERAL USE, METAL FRAME TYPE II, 80FT X 240FT, 6IN CONCRETE FLOOR, 12FT CEILING HGT-16FT EAVE HGT, 18 3FTX4FT COM PROJ WINDOWS, 7 2-3FTX7FT PERS DOORS, 7 10FTX12FT SINGLE SLIDE DOORS, CONT RIDGE ROOF VENT PRE-ENGINEERED METAL BLDG TEMPERATE CLIMATE	259	386	215,804	209	2,016	209	2,434
44220AL	WAREHOUSE, SPECIAL USE, WOOD FRAME CONSTRUCTION, BASIC BUILDING 80FT BY 240FT, WOOD ROOF + ASPHALT ROOFING, CONCRETE FOOTINGS, 6IN CONCRETE FLOOR, 13FT 9IN MIN CLEARANCE DESERT CLIMATE	483	534	103,025	628	3,735	212	4,575
44220AP	WAREHOUSE SPECIAL USE, METAL FRAME TYPE II, 80FT X 240FT, 6IN CONCRETE FLOOR, 12FT CEILING HGT-16FT EAVE HGT, 18 3FTX4FT COM PROJ WINDOWS, 7 2-3FTX7FT PERS DOORS, 7 10FTX12FT SINGLE SLIDE DOORS, CONT RIDGE ROOF VENT PRE-ENGINEERED METAL BLDG TROPICAL-DESERT CLIMATES	262	428	212,757	225	3,158	304	3,687
44222AC	SHED STORAGE, WOOD FRAME CONSTRUCTION, BASIC BUILDING 20FT X 100FT, WOOD ROOF + ASPHALT ROOFING, CONCRETE FOOTINGS, 6IN CONCRETE FLOOR, 8FT MIN CLEARANCE DESERT CLIMATE	55	69	15,375	86	590	86	762
44240AB	ACID-FLAMMABLE STORAGE BUILDING, WOOD FRAME CONSTRUCTION, WOOD ROOF, ASPH ROOFING, PLYWOOD SIDING, BASIC BUILDING 20X90 ONE STORY, CONCRETE FLOOR TROPIC-DESERT CLIMATES	48	57	10,362	120	704	120	944
44240AE	ACID-FLAMMABLE STORAGE BUILDING, METAL FRAME TYPE IV, 30FT X 60FT, 6IN CONCRETE FLOOR, 8FT CEILING HEIGHT, 10FT EAVE HGT, 4 2-3FTX7FT PERS DOORS, ROUND ROOF VENT W/POWER FAN TROPICAL-DESERT CLIMATES	17	29	16,709	25	470	25	520

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	TONS	WT SHT	VOL MEAS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
44270HJ	SUPPLY STOREHOUSE, BUILDING NUMBER 3, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 70 BY 8, FOR 500 AND 1000 BED HOSPITALS, DESERT/TROPIC CLIM	9		11	3,914	38	773	227	1,038
44270HK	SUPPLY STOREHOUSE BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 90 BY 8, FOR 500 TO 1000 BED HOSPITAL, DESERT/TROPIC CLIM	20		24	6,658	45	1,363	258	1,666
44270HL	SUPPLY STOREHOUSE BUILDING NUMBER 4, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 100 BY 8 FOR 750 BED HOSPITAL, DESERT/TROPIC CLIM	13		16	5,159	47	798	276	1,121
44270HM	SUPPLY STOREHOUSE BUILDING NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 110 BY 8, FOR 300 BED HOSPITAL, DESERT/TROPIC CLIM	21		27	7,699	53	1,427	309	1,789
44270HN	LINEN EXCHANGE AND SUPPLY BUILDING NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 90 BY 8, FOR 100 BED HOSPITAL, DESERT/TROPIC CLIM	26		34	9,993	45	1,363	258	1,666
44270HP	LINEN EXCHANGE AND SUPPLY BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 110 BY 8, FOR 200 BED HOSPITAL, DESERT/TROPIC CLIM	29		39	11,071	53	1,427	309	1,789
44270HR	LINEN EXCHANGE BUILDING NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 40 BY 8, FOR 300 AND 500 BED HOSPITALS, DESERT/TROPIC CLIM	15		20	6,830	23	1,502	182	1,707
44270HT	LINEN EXCHANGE BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 50 BY 8, FOR 750 AND 1000 BED HOSPITAL, DESERT/TROPIC CLIM	17		33	11,240	30	1,640	174	1,864
51010NB	CENTRALIZED MATERIAL SECTION BUILDING NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 100 BY 8, FOR 300 AND 500 BED HOSPITALS, DESERT/TROPIC CLIM	41		55	20,310	70	3,859	378	4,307
51010NL	ADMISSION AND DISPOSITION BUILDING NUMBER 3, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 90 BY 8, FOR 500 BED HOSPITAL, DESERT/TROPIC CLIM	28		33	9,198	67	1,947	297	2,311

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST EFFORT IN MAN-HOURS	GENL TOT		
						HOR	VERT	
51010NM	ADMISSION AND DISPOSITION BUILDING NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 110 BY 8, FOR 750 BED HOSPITAL, DESERT/TROPIC CLIM	33	37	10,439	78	2,109	353	2,340
51010NN	ADMISSION AND DISPOSITION BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 120 BY 8, FOR 1000 BED HOSPITAL, DESERT/TROPIC CLIM	36	36	8,491	81	2,320	370	2,771
51010NP	ADMISSION AND DISPOSITION BUILDING NUMBER 3, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 90 BY 8, FOR 500 BED HOSPITAL, DESERT/TROPIC CLIM	27	34	8,901	67	1,843	297	2,207
51010NR	ADMISSION AND DISPOSITION BUILDING NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 110 BY 8, FOR 750 BED HOSPITAL, DESERT/TROPIC CLIM	32	36	9,296	78	1,914	353	2,345
51010NT	ADMISSION AND DISPOSITION BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 120 BY 8, FOR 1000 BED HOSPITAL, DESERT/TROPIC CLIM	36	43	10,782	82	1,885	374	2,341
51010NU	ADMISSION AND DISPOSITION BUILDING NUMBER 4, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 90 BY 8, FOR 200 AND 300 BED HOSPITAL, DESERT/TROPIC CLIM	21	25	8,112	45	2,301	258	2,806
51020AC	CLINIC OPD/ER ADMISSION TYPE IV 60 FT WIDE BUILDING 140 FT LONG 8400 SQ FT; TROP/DES THE THEATER CONVERSION HOSPITAL COMPLEX.	438	1,299	127,170	787	6,899	6,777	10,463
53010AA	PREVENTIVE MEDICAL FACILITY, ENTOMOLOGY, FOR TOE 8-620H, PANELIZED WOOD BLDG 48 FT WIDE X 80 FT LONG, DESERT/TROPICAL.	216	950	93,580				
53010AB	PREVENTIVE MEDICAL FACILITY, ENTOMOLOGY, FOR TOE 8-620H, PANELIZED WOOD BLDG 48 FT WIDE X 80 FT LONG, TEMPERATE/FRIGID.	1,232	1,433	112,202				
53010AC	PREVENTIVE MEDICAL FACILITY, ENTOMOLOGY, FOR TOE 8-620H, PRE-ENGINEERED METAL BLDG 50 FT WIDE X 80 FT LONG, DESERT/TROPICAL.	60	120	50,458				

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL MEAS	COST	CONST EFFORT IN MAN-HOURS		
		TONS	TONS	S	HOR	VERT	GENL TOT
53010AD	PREVENTIVE MEDICAL FACILITY, ENTOMOLOGY, FOR TOE 8-620H, PRE-ENGINEERED METAL BLDG 50 FT WIDE X 80 FT LONG, TEMPERATE/FRIGID.	62	123	63,423			
53010AE	INTERIOR FOR PREVENTIVE MEDICAL FACILITY, ENTOMOLOGY, 48 FT WIDE X 80 FT LONG.	8	52	13,671			
53010BA	PREVENTIVE MEDICAL FACILITY FOR ENVIRONMENTAL SANITATION AND ENGINEERING SERVICE, EPIDEMIOLOGY SERVICE, AND ENTOMOLOGY LAB, FOR TOE 8-620H, PANELIZED WOOD BLDG AND PRE-ENGINEERED METAL BLDG 24 FT WIDE X 36 FT LONG, DESERT/TROPICAL.	31	68	35,102			
53020BC	RADIOLOGY LAB/PHARMACY FOR TROPIC-DESERT CLIMATIC ZONES 120 FT LONG 7200 SQ FT; DESERT/TROPICAL CONVERSION HOSPITAL COMPLEX.	366	1,207	104,318	945	6,147	5,402 12,494
53020CA	INTERIOR FOR X-RAY BLDG NO. 2:40X80 FOR 500-750 BED HOSPITAL	23	24	13,702		2,300	2,300
53040AA	VETERINARY FACILITY, FOR TOE 8-680H8, PANELIZED WOOD BLDG 24 FT WIDE X 60 FT LONG, TEMPERATE/FRIGID.	88	124	51,222			
53040AB	VETERINARY FACILITY, FOR TOE 8-680H8, PANELIZED WOOD BLDG 24FT WIDE X 60 FT LONG, DESERT/TROPICAL.	693	403	50,915			
53040AC	VETERINARY FACILITY, FOR TOE 8-680H8, PRE-ENGINEERED METAL BLDG 20 FT WIDE X 60 FT LONG, TEMPERATE/FRIGID.	38	87	35,708			
53040AD	VETERINARY FACILITY, FOR TOE 8-680H8, PRE-ENGINEERED METAL BLDG 20 FT WIDE X 60 FT LONG, DESERT/TROPICAL.	38	85	51,600			
53040AE	INTERIOR FOR VETERINARY FACILITY, 24 FT WIDE X 60 FT LONG.	29	65	37,669			
53040BA	VETERINARY FACILITY FOR ANIMAL DISPENSARY, FOR TOE 8-680H8, PANELIZED WOOD BLDG 60 FT WIDE X 80 FT LONG, DESERT/TROPICAL.	342	1,354	259,739			

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST \$	CONST EFFORT IN MAN-HOURS	
		TONS	TONS	HHR	VERT	GENL	TOT
53040BB	VETERINARY FACILITY FOR ANIMAL DISPENSARY, FOR TOE 8-680H8, PANELIZED WOOD BLDG 60 FT WIDE X 80 FT LONG, TEMPERATE/ FRIGID.	1,779	2,018	257,180			
53040BC	VETERINARY FACILITY FOR ANIMAL DISPENSARY, FOR TOE 8-680H8,, PRE-ENGINEERED METAL BLDG 60 FT WIDE X 80 FT LONG, DESERT/ TROPICAL.	97	282	200,577			
53040BD	VETERINARY FACILITY FOR ANIMAL DISPENSARY, FOR TOE 8-680H8, PRE-ENGINEERED METAL BLDG 60 FT WIDE X 80 FT LONG, TEMPERATE/FRIGID.	97	279	189,887			
53040BE	INTERIOR FOR VETERINARY FACILITY FOR ANIMAL DISPENSARY, 60 FT WIDE X 80 FT LONG.	66	208	150,193			
53040CA	VETERINARY FACILITY FOR SMALL ANIMAL HOSPITAL, FOR TOE 8-680H8, PANELIZED WOOD BLDG 48 FT WIDE X 80 FT LONG, AND PEN AREA OF 36 FT WIDE X 80 FT LONG, DESERT/TROPICAL.	630	2,583	365,406			
53040CB	VETERINARY FACILITY FOR SMALL ANIMAL HOSPITAL, FOR TOE 8-680H8, PANELIZED WOOD BLDG 48 FT WIDE X 80 FT LONG, AND PEN AREA OF 36 FT WIDE X 80 FT LONG, TEMPERATE/FRIGID.	2,377	3,402	362,648			
53040CC	VETERINARY FACILITY FOR SMALL ANIMAL HOSPITAL, FOR TOE 8-680H8, PRE-ENGINEERED METAL BLDG 50 FT WIDE X 80 FT LONG, AND PEN AREA OF 40 FT WIDE X 80 FT LONG,DESERT/ TROPICAL.	208	481	247,555			
53040CD	VETERINARY FACILITY FOR SMALL ANIMAL HOSPITAL, FOR TOE 8-680H8, PRE-ENGINEERED METAL BLDG 50FT WIDE X 80 FT LONG, AND PEN AREA OF 40 FT WIDE X 80 FT LONG, TEMPERATE/ FRIGID.	208	478	236,736			
53040CE	INTERIOR FOR VETERINARY FACILITY FOR SMALL ANIMAL HOSPITAL, 48 FT WIDE X 80 FT LONG AND PEN AREA OF 36FT WIDE X 80 FT LONG.	133	360	163,611			

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL TOT
55009EA	EXTERIOR CONSTRUCTION TYPE ELEVATOR WITH CONCRETE PIT AND WOOD LANDINGS-ALL CLIMATIC ZONES-TEMPORARY STANDARD OF CONSTRUCTION	28	20	91,961	70	302	372
55010AC	DISPENSARY-FIRST AID FACILITY TROPIC/DESERT CLIMATE ZONES 36X100 FOOT PANELIZED WOOD BUILDING.	337	1,607	125,674	294	3,361	2,454 6,109
55010AH	INTERIOR FOR DISPENSARY, TROOP, 20 X 60, W/O WARD FACILITIES	8	17	8,156			
55010AY	INTERIOR FOR DISPENSARY, TROOP, 20 X 80, W/O WARD FACILITIES	9	21	9,803			
55010BA	DISPENSARY,TROOP,STL FRAME BLDG W/INTERIOR 20X60X8,W/O WARD FACILITIES,TEMP CLIM	14	33	22,021			
55010BB	DISPENSARY,TROOP,STL FRAME BLDG W/INTERIOR 20X80X8,W/O WARD FACILITIES,TEMP CLIM	20	42	28,045			
55010BC	DISPENSARY,TROOP,WOOD FRAME BLDG W/INTERIOR 20X60X8,W/O WARD FACILITIES,TEMP CLIM	34	48	12,751			
55010BD	DISPENSARY,TROOP,WOOD FRAME BLDG W/INTERIOR 20X80X8,W/O WARD FACILITIES,TEMP CLIM	43	62	15,854			
55020DC	DISPENSARY, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 70 BY 8, WITH 6 WARD BEDS, DESERT/TROPIC CLIM	12	14	5,206	12	1,190	117 1,319
55020DD	DISPENSARY, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 100 BY 8, WITH 10 WARD BEDS, DESERT/TROPIC CLIM	17	24	10,789	16	3,002	162 3,180
61025BC	ADMINISTRATION BUILDING,WOOD FRAME CONSTRUCTION,BASIC BUILDING 40FT X 110FT;WOOD ROOF < ASPHALT ROOFING;CONCRETE FOUNDATION;WOOD FLOOR;8FT MIN CLEARANCE DESERT CLIMATE	75	134	31,510	174	984	174 1,332
61025BG	ADMINISTRATION BUILDING,METAL FRAME TYPE IV 40FT X 110FT, 4IN CONCRETE FLOOR,8FT CEILING HGT,10FT EAVE HGT,27 4FT X 4FT COMM PROJ WINDOWS,3-3FT X 7FT PERS DOORS,2 ROUND ROOF VENT,PRE-ENGINEERED METAL BUILDING DESERT CLIMATE	45	92	54,613	72	800	99 971

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT	IN MAN-HOURS	GENL TOT
61027BB	FINANCE OFFICE, 13000 MAN, TWO 40 BY 110 LIGHTWEIGHT STEEL PANEL BUILDING WITH COVERED WALKWAY BETWEEN, DESERT/TROPIC CLIM (-20 DEG F)	125	377	98,667	168	2,591	706	3,465
61050D6	ADMINISTRATION BUILDING, LIGHTWEIGHT STEEL PANEL WITH INTERIOR 20 BY 30 BY 8, WITH SUPPLY ROOM, DESERT/TROPIC CLIM	3	6	1,345	7	264	58	309
61050DH	HEADQUARTERS AND UNIT SUPPLY BUILDING COMPANY, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 40 BY 8M DESERT/TROPIC CLIM	4	3	1,367	8	236	72	316
61050DJ	ADMINISTRATION BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8 WITH SUPPLY ROOM, DESERT/TROPIC CLIM	5	6	2,286	9	315	85	409
61050DK	HEADQUARTERS AND UNIT SUPPLY BUILDING BATTALION, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 100 BY 8, DESERT/TROPIC CLIM	10	13	4,397				
61050DL	ADMINISTRATION HEADQUARTERS BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 70 BY 8, USED IN 5000 SF INSTALLATION, DESERT/TROPIC CLIM	14	39	13,196	56	1,094	274	1,426
61050DM	ADMINISTRATION BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 100 BY 8, WITH SUPPLY ROOM, DESERT/TROPIC CLIM	21	24	8,074	70	1,862	317	1,849
61050EH	ADMINISTRATION BUILDING NUMBER 3, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 80 BY 8, FOR 200 AND 300 BED HOSPITAL, DESERT/TROPIC CLIM	15	18	5,272	39	833	223	1,095
61050EJ	ADMINISTRATION BUILDING NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 90 BY 8, FOR 500 BED HOSPITAL, DESERT/TROPIC CLIM	17	16	6,812	43	909	258	1,212
61050EK	ADMINISTRATION BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 110 BY 8, FOR 750 AND 1000 BED HOSPITALS, DESERT/TROPIC CLIM	19	23	7,052	53	1,105	309	1,487

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	SHT TONS	WT VOL	MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
						HOR	VERT	GENL TOT
61050EL	ADMINISTRATION, ADMISSION AND DISPOSITION BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 110 BY 8, FOR 100 BED HOSPITAL, DESERT/TROPIC CLIM	23	29	8,775	53	1,796	309	2,158
61050EM	ADMINISTRATION, ADMISSION AND DISPOSITION BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 110 BY 8, FOR 100 BED HOSPITAL, DESERT/TROPIC CLIM	23	29	9,835	53	1,375	309	1,737
61050EN	ADMINISTRATION, HEADQUARTERS BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 70 BY 8, USED IN 5000 SF INSTALLATION, DESERT/TROPIC CLIM	12	23	8,902	38	1,025	205	1,268
61050EP	ADMINISTRATION, HEADQUARTERS BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 70 BY 8, USED IN 10,000 SF INSTALLATION, DESERT/TROPIC CLIM	12	27	9,800	38	1,094	205	1,337
61050ER	ADMINISTRATION, SUPPORT BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 70 BY 8, USED IN THE 10,000 SF INSTALLATION, DESERT/TROPIC CLIM	10	8	2,418	38	845	205	1,088
61050ET	ADMINISTRATION, SUPPORT BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 50 BY 8, USED IN THE 5000 SF INSTALLATION, DESERT/TROPIC CLIM	8	6	1,817	28	607	752	787
71430AA	SINGLE, TRAILER MOUNTED LAUNDRY OR BATH ASSEMBLY CAPABLE OF PROVIDING THE LAUNDRY SUPPORT FOR 5200 TROOPS WHEN OPERATING 20HRS/DAY/7 DAYS/WK OR PROVIDING THE BATH AND CLOTHES EXCHANGE SUPPORT FOR 3500 TROOPS WHEN OPERATING 8HR/DAY/7 DAYS/WK	8	35	24,038	92	41	133	
72111AU	PORTABLE BUILDING, 10X24, COMPLETE WITH ELECTRIC WALL MOUNTED HEATER, 5100 BTU, 220 VOLT, 60 HERTZ. TOTAL KW REQUIREMENT-1.3 KW. SHIPPED IN KNOCK-DOWN CONFIGURATION.	4	5	4,000	1	1	2	6
72111CG	TROOP HOUSING; ENLISTED; WOOD FRAME CONSTRUCTION; BASIC BLDG. 20X100; WOOD ROOF; WOOD FRAME; 8FT CEILING; CONC FLOOR DESERT CLIMATE	55	66	13,005	25	311	51	387

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HHR	EFFORT VERT	IN GENL MAN-HOURS	TOT
72111CH	TROOP HOUSING;ENLISTED;STEEL FRAME BLDG W/INTERIOR 20X100; DESERT CLIMATE	23	37	23,614	131	1,461	734	2,326
72111CJ	TROOP HOUSING;ENLISTED;PANELIZED WOOD BUILDING;24X84 DESERT CLIMATE	63	68	41,776	9	851	967	1,827
72141BC	QUARTERS, FEMALE EMPLOYEES, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 30 BY 8, WITH 4 SINGLE BEDROOMS AND LIVING ROOM, DESERT/TROPIC CLIM	4	4	1,420	7	344	38	409
72141BD	QUARTERS, FEMALE EMPLOYEES, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 40 BY 8, WITH 8 SINGLE BEDROOMS AND LIVING ROOM, DESERT/TROPIC CLIM	6	7	1,836	8	536	72	616
72210EA	INTERIOR FOR KITCHEN AND DINING FACILITY 200-500 MAN.FOR THE TEMPERATE,DESERT AND FRIGID BUILDINGS,TEMPORARY STD.	14	37	69,221	2,584	148	2,732	
72210EL	KITCHEN AND DINING FACILITY 200-500 MAN,PANELIZED WOOD BUILDING WITH INTERIOR 48 BY 60 FOOT BUILDING. DESERT CLIMATE	959	1,292	146,463	69	3,450	206	3,725
72210FJ	KITCHEN AND DINING FACILITY 200-500 MAN WOOD FRAME BUILDING WITH INTERIOR 40X70FEET,FOR THE DESERT CLIMATE	75	122	79,260	69	3,519	198	3,786
72210FK	KITCHEN AND DINING FACILITY 200-500MAN PRE-ENG STEEL FRAME BUILDING WITH INTERIOR 40X70FEET FOR THE DESERT CLIMATE	41	101	96,869	69	3,364	173	3,608
72210GB	INTERIOR FOR KITCHEN + DINING FACILITY 500-1100 MAN 60X120 FOOT DESERT/TROPIC	38	88	196,536	3,647	601	4,048	
72210GD	KITCHEN + DINING FACILITY 500-1100 MAN WOOD FRAME BUILDING W/INTERIOR 60X120FOOT DESERT/TROPIC ZONE	123	191	218,146	118	6,088	1,625	7,831
72210GG	KITCHEN + DINING FACILITY 500-1100 MAN STEEL FRAME BUILDING W/INTERIOR 60X120FOOT DESERT/TROPIC ZONE	116	493	289,770	331	7,684	2,400	10,415
72210GL	KITCHEN + DINING FACILITY 500-1100 MAN PANELIZED WOOD BUILDING W/INTERIOR 60X120FOOT DESERT/TROPIC	404	1,295	298,834	104	9,647	3,924	13,675

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		CONSTRUCTION MATERIAL							
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	WT TONS	VOL SHT TONS	MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
						HOR	VERT	GENL	TOT
72210HC	KITCHEN AND DINING FACILITY 200-500 MAN, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR 40 BY 80 FT. TROP/DESR CLIM	64	137	81,868	69	978	89	1,136	
72210HD	KITCHEN AND DINING FACILITY 500-1100 MAN, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR 50 BY 150 FEET TRP/DESRT CLIM	144	259	209,450	69	1,380	115	1,564	
72321AA	PORATA-KAMP LATRINE TEMPERATE AND DESERT	1	1	248	3	18	17	38	
72321AC	MONOGRAM CHEMICAL LATRINE			119		?	?	14	
72321BB	LATRINE, PIT TYPE, 2 SEATS, 4X5X8, WOOD FRAME BLDG	1	1	94		46	9	55	
72321BC	LATRINE, PIT TYPE, FEMALE, 2 SEATS, 10X10X8, WOOD FRAME BLDG W/INTERIOR	5	6	1,028		129	18	147	
72321BD	LATRINE, PIT TYPE, 160 EM OR 80 OFFICERS, 8 SEATS, 10X20X8, WOOD FRAME BLDG W/INTERIOR	8	9	1,559	2	230	37	269	
72321BE	LATRINE, 250 MAN, BUCKET TYPE, 12 SEATS, 10X30X8, WOOD FRAME BLDG W/INTERIOR	10	11	1,869	5	296	56	357	
72321CA	LATRINE, PIT TYPE, 160 EM OR 80 OFFICERS, 8 SEATS, 20 BY 10 BY 8 LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, TROPIC CLIMATE	2	1	448	10	202	16	228	
72321CB	LATRINE, PIT TYPE, 160 EM OR 80 OFFICERS, 8 SEATS, 20 BY 10 BY 8 LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, TROPIC AND DESERT CLIMATE	2	1	448	15	293	23	331	
72321CC	LATRINE, PIT TYPE, 160 EM OR 80 OFFICERS, 8 SEATS, 20 BY 10 BY 8 LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, FRIGID CLIM	2	1	448	36	520	41	597	
72323BD	INTERIOR FOR BATHHOUSE & LATRINE, 500 MAN, 20 X 80, WATER BORNE TYPE, W/24 SHOWER HEADS, 24 SEATS & SANITARY SEWER CONNECTION CHANGE SUPPORT FOR 3500 TROOPS WHEN OPERATING 8 HR/DAY/76DAYS /WK	9	16	17,566		1,417		1,417	

DHDXER1

RUN DATE 860128

FACILITY NUMBER	DESCRIPTION	CONSTRUCTION MATERIAL.					
		WT SHT	VOL MEAS	COST	CONST EFFORT IN MAN-HOURS		
		TONS	TONS	\$	HOR	VERT	GENL
72323BU	PORTABLE BLDG, 20-MAN BATH W/HALL, 10X24. COMPLETE W/1 CONNECTING CANOPY, 3 SHOWERS W/SLIDING CURTAINS, 12 COMMODES, TANK-TYPE W/PARTITIONS & DOORS, 3 LAVATORIES W/SHELVES, MIRRORS & LIGHTS, 1 URINAL, 1 42-GAL WTR HEATER, GLASS LINED TANK, 220V, 60 HERTZ, 2 16-IN EXH FANS, 1 STEEL STORAGE LOCKER, 1 DBL LAUN-DRY TUB. TOTAL KW REQUIREMENT 6.7 KW. SHIPPED ERECTED.	4	5	3,835	1	1	1
72323BV	PORTABLE BUILDING, 60-MAN BATH, 10X30. COMPLETE WITH 10 LAVATORIES, SHELVES, MIRRORS AND LIGHTS, 7 SHOWERS WITH SLIDING CURTAINS, 7 COMMODES, TANK-TYPE, WITH PARTITIONS AND DOORS, 1 120-GAL WATER HEATER AND 1 16-INCH EXHAUST FAN. TOTAL KW REQUIREMENT-6.0 KW. SHIPPED ERECTED	4	8	2,095	1	1	1
72323DJ	BATHHOUSE FOR 160 EM OR 80 OFFICERS, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR 20 BY 20 BY 8, WITH 8 SHOWER HEADS AND SEWER CONNECTION, DESERT/TROPIC CLIM	6	11	6,778	5	538	35
72323DK	BATHHOUSE AND LATRINE, 160 EM OR 80 OFFICERS, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 30 BY 8, WATER BORNE TYPE WITH 8 SHOWER HEADS, 8 SEATS AND SANITARY SEWER CONNECTION, DESERT/TROPIC CLIM	8	12	8,925	7	906	58
72323DL	BATHHOUSE, 250 MAN, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 40 BY 8, WITH 12 SHOWER HEADS AND SEWER CONNECTION, DESERT/TROPIC CLIM	7	11	6,772	8	1,116	72
72323DM	BATHHOUSE, 500 MAN, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8 WITH 24 SHOWER HEADS AND SEWER CONNECTION, DESERT/TROPIC CLIM	8	10	7,948	9	864	87
72323DN	BATHHOUSE, 720 MAN, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8 WITH 30 SHOWER HEADS AND SEWER CONNECTION, DESERT/TROPIC CLIM	11	13	9,616	9	2,169	87
72323DP	BATHHOUSE AND LATRINE, 250 MAN, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 60 BY 8, WATER BORNE TYPE, WITH 12 SHOWER HEADS, 14 SEATS AND SANITARY SEWER CONNECTION, DESERT/TROPIC CLIM	11	14	11,021	10	1,191	102

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	SHT TONS	WT VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
					HOR	VERT	GENL TOT
72323DR	BATHHOUSE AND LATRINE, 720 MAN, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 100 BY 8, WATER BORNE TYPE, WITH 30 SHOWER HEADS, 36 SEATS AND SANITARY SEWER CONNECTION, DESERT/TROPIC CLIM	21	24	23,300	16	2,262	162 2,440
72323EC	BATHHOUSE AND LATRINE, 500 MAN, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 80 BY 8, WATER BORNE TYPE, WITH 24 SHOWER HEADS, 24 SEATS AND SANITARY SEWER CONNECTION, DESERT/TROPIC CLIM	15	19	17,700	14	1,580	132 1,726
72360AA	DAYROOM FACILITY 600 SQ FT WOOD FRAME BUILDING 20 FT X 30 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD CLADDING WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	17	22	5,154	25	624	150 799
72360AB	INTERIOR FOR DAYROOM FACILITY 600 SQ FT WOOD FRAME BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	3	6	2,743		431	99 350
72360AC	DAYROOM FACILITY 600 SQ FT PRE-ENGINEERED METAL BUILDING 20 FT X 30 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE , FRIGID AND DESERT CLIMATE	6	15	9,061	37	826	298 1,161
72360AD	INTERIOR FOR DAYROOM FACILITY 600 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE , FRIGID AND DESERT CLIMATE	3	7	3,193		470	108 578
72360AL	DAYROOM FACILITY 864 SQ FT PANELIZED WOOD BUILDING 24 FT X 36 FT ONE STORY CONCRETE FLOOR WOOD PANEL CLADDING AND ROOF WITH INTERIOR DESERT AND TROPIC CLIMATE	27	32	18,628	8	1,040	879 1,927
72360BB	DAY ROOM, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 30 BY 8, DESERT/TROPIC CLIM	5	8	3,245	7	542	147 696
72410AA	BOQ, MALE	14	1	21,648	61	1,286	292 1,639
72410AG	BOQ, MALE/FEMALE	8	17	29,000	89	1,380	327 1,776
72410CE	QUARTERS, MALE OFFICERS NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 60 BY 8, 14 MALE OFFICERS FOR HOSPITALS, DESERT/TROPIC CLIM	14	19	4,839	31	1,046	170 1,245

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT TOT
72410CF	QUARTERS, MALE OFFICERS NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 100 BY 8, 24 MALE OFFICERS, FOR HOSPITALS, DESERT/TROPIC CLIM	23	27	6,855	47	1,425	276	1,748
72410CG	QUARTERS, 16 OFFICERS, LIGHTWEIGHT STEEL PANEL BUILDING BUILDING WITH INTERIOR, 20 BY 70 BY 8, 2 DORMITORY ROOMS WITH RECREATION AREAS, DESERT/TROPIC CLIM	12	8	2,401	12	374	117	503
72410CH	QUARTERS, 24 OFFICERS, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 100 BY 8, 3 DORMITORY ROOMS WITH RECREATION AREAS, DESERT/TROPIC CLIM	16	35	17,245	16	675	162	653
72411AA	QUARTERS RECONDITIONING PANELIZED METAL BUILDING DESIGN WITH FLOOR SLAB ON GRADE TEMPERATE CLIMATE, TEMPORARY STANDARD OF CONSTRUCTION UNDER DESIGN	13	6	42,860	152	4,916	1,418	6,486
72420AA	BQQ, FEMALE	14	1	21,648	61	1,286	292	1,639
72420BC	QUARTERS, FEMALE OFFICERS NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 60 BY 8, 13 FEMALE OFFICERS, FOR HOSPITALS, DESERT/TROPIC CLIM	14	19	5,273	31	1,125	170	1,326
72420BD	QUARTERS, FEMALE OFFICERS NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 100 BY 8, 23 FEMALE OFFICERS, FOR HOSPITALS, DESERT/TROPIC CLIM	20	24	6,841	47	1,767	276	2,070
72520AA	TENTAGE, 10 EACH, GENERAL PURPOSE, MEDIUM, W/O WINDOWS, COTTON DUCK, 9.850Z, FIRE, MILDEW, WATER, WEATHER RESISTANT, OD, W/O FLR FLOOR AREA DIM, 32FT8IN LONG AND 16 FT WIDE, RIDGE, 17FT4-1/2IN LONG AND 10 FT HIGH, SIDE WALLS, 5FT6IN HIGH.	10	11,700				46	46
72520AC	WOOD FRAME, TENT, W/EARTH FLOOR FOR 16X32 SQUAD TENT	1	1	68	2	9	7	18
72520AD	WOOD FRAME, TENT, W/WOOD FLOOR FOR 16X32 SQUAD TENT	1	2	397	6	127	86	219
72520AE	WOOD FRAME, TENT, W/CONC FLOOR FOR 16X32 SQUAD TENT	7	3	204	3	23	14	42

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
		HOR	VERT	GENL	TOT		
72520AF	TENT,GENERAL PURPOSE MEDIUM W/O WINDOWS COTTON DUCK 9.850Z. FIRE,MILDEW,WATER AND WEATHER RESISTANT.OD ARMY SHADE 7,W/O FLOOR. FLOOR AREA 32FT8IN.LONG 16FT WIDE. WITH COVER,LINES, PINS,POLES,SLIP LINES AND TENT LINER. MIL-T-1712,TYPE 1	1		1,170		5	5
72520AG	WOOD FRAME, TENT, W/EARTH FLOOR FOR 18 BY 52 TENT	1	1	87			
72520AH	WOOD FRAME, TENT, W/WOOD FLOOR FOR 18 BY 52 TENT	1	2	145			
72520AJ	WOOD FRAME, TENT, W/CONCRETE FLOOR FOR 18 BY 52 TENT	12	9	319			
72522AA	TENTAGE,10 EACH,GENERAL PURPOSE,SMALL,COTTON DUCK,9.850Z. FIRE,MILDEW,WATER,WEATHER RESISTANT.OD.W/O FLOOR,FLOOR AREA DIM.17FT6IN LONG & 17FT6IN WIDE.HEXAGONAL.EACH LATERAL SIDE 8FT9IN LONG.PEAK 10FT6IN HIGH.SIDE WALLS 5 FT HIGH.	1	5	6,790		23	23
72523AA	TENT ASSY,M-1942,SECTIONAL,COTTON DUCK,9.850Z.FIRE,MILDEW, WATER,WEATHER RESISTANT.OD.W/O FLOOR,FLOOR AREA DIM.80 FT LONG AND 40 FT WIDE.RIDGE,40 FT LONG AND 18 FT HIGH.SIDE WALLS 8 FT HIGH.2 END,2 MIDDLE AND 4 WALL SECTIONS.	1	3	3,124		35	35
72524AA	TENT,KITCHEN,FLY PROOF,M-1948,COTTON DUCK.9.850Z.FIRE, MILDEW,WATER,WEATHER RESIST.OD.W/O FLR,FLR AREA DIM.18 FT LONG AND 12 FT WIDE.TENT RIDGE,11FT11-1/2IN LONG AND 9 FT HIGH.STACK RIDGE,6 FT LONG AND T2 FT HIGH.TENT SIDE WALLS 6 FT HIGH.STACK SIDE WALLS 9 FT HIGH.	1		723		12	12
72590AB	WOOD FRAME WITH EARTH FLOOR FOR GP LARGE TENT.FLOOR AREA IS 18X52FEET	1	1	116	1	7	8
72590AC	WOOD FRAME WITH WOOD FLOOR FOR GP LARGE TENT. FLOOR AREA IS 18X52FEET PLYWOOD DECK.	3	4	910	1	12	13
72590AD	WOOD FRAME WITH CONCRETE FLOOR FOR GP LARGE TENT FLOOR AREA IS 18X52FEET	3	3	173	1	61	42
72590AF	INTERIOR ELECTRICAL AND HEATING SUB FACILITY FOR THE GP LARGE TENT.ELECTRICAL CONTAINS MATERIAL FOR 3 LIGHTING FIXTURES AND 6 RECEPTACLES.HEATING IS 3 EACH 70000 BTU DIESEL HEATERS.	1		1,357	1	5	6

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT SHY	VOL MEAS	COST TONS	CONST HOR	EFFORT IN MAN-HOURS	VERT	SENL	TOT
73010AA	FIRE STATION FACILITY 6146 SQ FT WOOD FRAME BUILDING OPTION A 48 FT X 128 FT ONE STORY CONCRETE FLOOR 13 FT 9 IN HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	192	272	38,303	141	3,545	882	6,588	
73010AD	FIRE STATION FACILITY 6146 SQ FT WOOD FRAME BUILDING OPTION B 48 FT X 128 FT ONE STORY CONCRETE FLOOR 13 FT 9 IN HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	182	238	33,190	116	4,507	772	5,395	
73010AF	FIRE STATION FACILITY 5400 SQ FT PRE-ENGINEERED METAL BUILDING OPTION A 40 FT X 135 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE FRIGID AND DESERT CLIMATE	44	83	73,049	243	3,974	1,846	6,063	
73010AH	FIRE STATION FACILITY 5400 SQ FT PRE-ENGINEERED METAL BUILDING OPTION B 40 FT X 135 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE	43	81	72,487	243	3,118	1,818	7,179	
73010AK	INTERIOR FOR FIRE STATION FACILITY 6144 SQ FT WOOD FRAME BUILDING OPTION A TEMPERATE , FRIGID AND DESERT CLIMATE	14	26	10,864		1,385	322	1,707	
73010AM	INTERIOR FOR FIRE STATION FACILITY 6144 SQ FT WOOD FRAME BUILDING OPTION B TEMPERATE AND DESERT CLIMATE	12	23	9,158		1,205	277	1,482	
73010AP	INTERIOR FOR FIRE STATION FACILITY 5400 SQ FT PRE-ENGINEERED METAL BUILDING OPTION A TEMPERATE , FRIGID AND DESERT CLIMATE	10	22	8,595		1,415	316	1,731	
73010AT	INTERIOR FOR FIRE STATION FACILITY 5400 SQ FT PRE-ENGINEERED METAL BUILDING OPTION B TEMPERATE AND DESERT CLIMATE	9	20	8,033		1,106	256	1,7362	
73010CC	FIRE STATION, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 50 BY 130 BY 14, DESERT/TROPIC CLIM	86	78	13,089	2,069	2,259	1,219	3,547	
73010CD	FIRE STATION, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 50 BY 130 BY 14, DESERT/TROPIC CLIM	84	99	15,818	2,089	2,079	1,176	3,522	

DHDXER1

RUN DATE 860128

DESERT CLIMATEFACILITY
NUMBERDESCRIPTION

			CONSTRUCTION MATERIAL							
			WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	HOR	VERT	GENL	TOT
73015FB	GUARDHOUSE, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 60 BY 8, WITH GUARD ROOM, OFFICE AND 380 SF PRISONER ROOM, DESERT/TROPIC CLIM		7	7	2,796	10	344	102	456	
73016AA	MILITARY POLICE HEADQUARTERS FACILITY 1200 SQ FT WOOD FRAME BUILDING 30 FT X 40 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE		33	40	9,084	33	1,266	251	1,552	
73016AB	INTERIOR FOR MILITARY POLICE HEADQUARTERS FACILITY 1200 SQ FT WOOD FRAME BUILDING TEMPERATE, FRIGID AND DESERT CLIMATE		6	11	5,150		944	189	1,133	
73016AC	MILITARY POLICE HEADQUARTERS FACILITY 1200 SQ FT PRE-ENGINEERED METAL BUILDING 30 FT X 40 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE, FRIGID AND DESERT CLIMATE		17	32	20,826	84	1,840	658	2,582	
73016AD	INTERIOR FOR MILITARY POLICE HEADQUARTERS FACILITY 1200 SQ FT PRE-ENGINEERED METAL BUILDING TEMPERATE, FRIGID AND DESERT CLIMATE		9	16	7,052		1,013	222	1,237	
73016AE	MILITARY POLICE HEADQUARTERS FACILITY 2400 SQ FT WOOD FRAME BUILDING 40 FT X 60 FT ONE STORY CONCRETE FLOOR 8 FT HIGH WOOD AND FELT CLADDING AND WOOD AND FELT ROOF WITH INTERIOR TEMPERATE AND DESERT CLIMATE		60	74	16,474	39	2,378	467	2,884	
73016AF	INTERIOR FOR MILITARY POLICE HEADQUARTERS FACILITY 2400 SQ FT WOOD FRAME BUILDING TEMPERATE, FRIGID AND DESERT CLIMATE		10	22	9,401		1,766	338	2,106	
73016AG	MILITARY POLICE HEADQUARTERS FACILITY 2400 SQ FT PRE-ENGINEERED METAL BUILDING 40 FT X 60 FT ONE STORY CONCRETE FLOOR CORRUGATED STEEL CLADDING AND ROOF WITH INTERIOR TEMPERATE, FRIGID AND DESERT CLIMATE		31	63	33,682	155	3,418	1,208	4,781	
73016AH	INTERIOR FOR MILITARY POLICE HEADQUARTERS FACILITY 2400 SQ FT WOOD FRAME BUILDING TEMPERATE, FRIGID AND DESERT CLIMATE		16	31	12,572		1,884	393	2,277	

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

CONSTRUCTION MATERIAL

SHT	WT TONS	VOL TONS	COST \$	CONST HOR	EFFORT VERV	IN MAN-HOURS GENL	TOT
73016BC	17	18	3,604	23	1,116	357	1,494
73016BD	39	108	30,369	46	2,042	599	2,687
74018BE	5	7	2,180	9	488	67	564
74018BF	8	10	2,761	9	752	87	848
74018BG	16	18	3,248	31	1,282	192	1,503
74018BH	27	34	7,206	58	1,832	262	2,152
74025BD	6	6	2,256	9	364	87	460
74059CJ	41	33	8,263	44	668	185	897
74059CK	16	25	8,916	46	913	206	1,165
74059CL	57	46	8,946	55	899	242	1,196
74059CM	61	30	10,916	67	1,099	297	1,463

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						CONST EFFORT IN MAN-HOURS			
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$		HOR	VERT	GENL	TOT		
74059CN	ARMY POST OFFICE BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 100 BY 8, WITH LOBBY, 9 MAIL AND STAMP WINDOWS, OFFICE AND WORK ROOM, DESERT/TROPIC CLIM	24	28	9,102		70	1,186	317	1,573		
74068BE	UTILITY BUILDING NUMBER 1, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 40 BY 60 BY 8, FOR 148 EM AND 2 NCO, DESERT/TROPIC CLIM	27	32	16,679		46	2,834	206	3,086		
74068BF	UTILITY BUILDING NUMBER 2, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 30 BY 60 BY 8, FOR 84 EM AND 2 NCO, DESERT/TROPIC CLIM	19	28	14,108		31	2,225	192	2,468		
74068BH	SERVICE CLUB, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 60 BY 100 BY 14, DESERT/TROPIC CLIM	30	31	8,430		83	1,249	348	1,680		
75013AA	ATHLETIC COURT, OUTDOOR, 60 X 120, TENNIS VOLLEY-BALL COMBINATION W/SEPARATE BADMINTON COURT, GENERAL CONSTRUCTION W/O LIGHTING	8	9	1,614		29	150	121	300		
81110AA	GENERATING PLANT, 15 KW FIRM, 2-15 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 12.5 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	6	18	26,441				516	18	534	
81110AB	GENERATING PLANT, 30 KW FIRM, 3-15 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 25 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	9	20	35,487				743	18	761	
81110AC	GENERATING PLANT, 45 KW FIRM, 4-15 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 37.5 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	12	27	47,551				1,040	18	1,058	
81110AD	GENERATING PLANT, 60 KW FIRM, 2-60 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 50 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	8	16	38,003				506	18	524	
81110AE	GENERATING PLANT, 100 KW FIRM, 2-100 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 83 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	13	20	23,950				537	18	555	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	IN HRS	VERT GENL	TOT
81110AF	GENERATING PLANT, 200 KW FIRM, 3-100 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 167 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	19	30	36,179	895	18	913	
81110AG	GENERATING PLANT, 300 KW FIRM, 4-100 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 250 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	24	40	47,996	1,181	28	1,209	
81110AH	GENERATING PLANT, 400 KW FIRM, 3-200 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 333 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	11	113	104,831	2,124	46	2,170	
81110AJ	GENERATING PLANT, 600 KW FIRM, 4-200 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 500 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	13	130	139,785	2,696	69	2,765	
81110AK	GENERATING PLANT, 800 KW FIRM, 5-200 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 667 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	17	188	176,870	2,973	69	3,042	
81110AL	GENERATING PLANT CONVERSION, 100 KW TO 200 KW FIRM, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 167 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	7	10	12,183	383	18	601	
81110AM	GENERATING PLANT CONVERSION FROM 200 KW TO 300 KW FIRM, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 250 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	7	10	12,272	14	383	18	615
81110AN	GENERATING PLANT CONVERSION FROM 400 KW TO 600 KW FIRM, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 500 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	4	37	35,118	14	722	18	734
81110AP	GENERATING PLANT CONVERSION, 600 KW TO 800 KW FIRM, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 667 KW, OUTDOOR, FOR TEMPERATE, TROPICAL, OR DESERT CLIMATES.	4	37	33,001	759	23	782	
81110BJ	GENERATING PLANT, 15 KW FIRM, 2-15 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 12.5 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	31	54	38,418	92	2,144	961	3,197

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT	
81110BK	GENERATING PLANT, 30 KW FIRM, 3-15 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 25 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	35	52	47,365	92	2,381	966	3,639
81110BL	GENERATING PLANT, 45 KW FIRM, 4-15 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 37.5 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	37	55	58,180	92	2,981	966	4,039
81110BM	GENERATING PLANT, 60 KW FIRM, 2-60 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 50 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	36	52	56,173	94	2,316	968	3,378
81110BN	GENERATING PLANT, 100 KW FIRM, 2-100 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 83 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	46	65	48,246	113	2,974	1,157	4,244
81110BP	GENERATING PLANT, 200 KW FIRM, 3-100 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 167 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	32	78	63,407	113	3,563	1,162	4,838
81110BR	GENERATING PLANT, 300 KW FIRM, 4-100 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 250 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	68	82	72,577	122	4,078	1,198	5,398
81110BT	GENERATING PLANT, 400 KW FIRM, 3-200 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 333 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	85	196	156,062	219	7,312	559	8,090
81110BU	GENERATING PLANT, 600 KW FIRM, 4-200 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 500 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	96	250	198,466	225	8,683	584	9,492

DHDXER1

RUN DATE 860128

DESERT CLIMATE FACILITY NUMBER	DESCRIPTION	CONSTRUCTION MATERIAL					
		WT SHT TONS	VOL MEAS TONS	COST \$	CONST. EFFORT IN MAN-HOURS HOR. VERT. GENL	TOT	
81110BV	GENERATING PLANT, 800 KW FIRM, 5-200 KW INSTALLED, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 667 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	73	250	225,968	228	9,419	603 10,250
81110BW	GENERATING PLANT CONVERSION FROM 100 KW TO 200 KW FIRM, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 167 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	38	46	32,143	14	631	48 713
81110BY	GENERATING PLANT CONVERSION FROM 200 KW TO 300 KW FIRM, 208Y/120 OR 416Y/240 VOLTS, 60 HERTZ OR 50 HERTZ AT 250 KW, IN PREFABRICATED STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	39	47	32,226	16	656	48 718
81110CA	GENERATING PLANT CONVERSION FROM 400 KW TO 600 KW FIRM, 208Y/120 OR 416Y/240 VOLTS, 60 HZ (OR 50 HZ AT 5/6 RATED KW) IN PREFAB STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	68	112	80,656	1,346	25	1,371
81110CB	GENERATING PLANT CONVERSION FROM 600 KW TO 800 KW FIRM, 208Y/120 OR 416Y/240 VOLTS, 60 HZ (OR 50 HZ AT 5/6 RATED KW) IN PREFAB STEEL BUILDING FOR TROPICAL OR DESERT CLIMATES.	68	112	80,724	1,323	25	1,348
81110D6	GENERATOR PLANT 1000KW NOMINAL SIZE 1500KW UNINSTALLED CAPACITY,USING THREE SKID MTD 4160-VOLT 500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	144	237	302,327	202	12,328	2,760 15,290
81110DH	GENERATOR PLANT 1500KW NOMINAL SIZE 2000KW INSTALLED CAPACITY,USING FOUR SKID MTD 4160-VOLT 500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	139	305	331,097	202	12,871	2,760 15,833
81110DJ	GENERATOR PLANT 2500KW NOMINAL SIZE 3000KW INSTALLED CAPACITY,USING SIX SKID MTD 4160-VOLT 500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	246	416	511,086	306	19,111	5,290 24,707
81110DK	GENERATOR PLANT 3000KW NOMINAL SIZE 4000KW INSTALLED CAPACITY,USING EIGHT SKID MTD 4160-VOLT 500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	247	564	619,356	338	19,766	5,566 23,670

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
81110DL	GENERATOR PLANT 3000KW NOMINAL SIZE 4500KW INSTALLED CAPACITY,USING THREE SKID MTD 4160-VOLT 1500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	217	443	685,135	281	9,485	3,910	13,676
81110DM	GENERATOR PLANT 3500KW NOMINAL SIZE 4500KW INSTALLED CAPACITY,USING NINE SKID MTD 4160-VOLT 500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	262	526	724,211	343	21,257	5,750	27,350
81110DN	GENERATOR PLANT 4500KW NOMINAL SIZE 6000KW INSTALLED CAPACITY,USING TWELVE SKID MTD 4160-VOLT 500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	193	704	918,384	405	28,396	8,303	37,106
81110DP	GENERATOR PLANT 6000KW NOMINAL SIZE 7500KW INSTALLED CAPACITY,USING FIVE SKID MTD 4160-VOLT 1500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	276	268	108,178	375	11,150	4,352	15,877
81110DR	GENERATOR PLANT 7500KW NOMINAL SIZE 9000KW INSTALLED CAPACITY,USING SIX SKID MTD 4160-VOLT 1500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	378	827	1,331,819	451	13,269	5,014	18,734
81110DT	GENERATOR PLANT 10500KW NOMINAL SIZE 13500KW INSTALLED CAPACITY,USING NINE SKID MTD 4160-VOLT 1500KW DIESEL ENGINE GENERATOR SETS,FOR TROPICAL AND DESERT CLIMATES	555	1,213	1,939,253	610	15,686	5,842	22,138
81110FA	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 15 KW FIRM, 2-15KW INSTALLED, TEMP CLIM FOR INT SEC 06-12; SEE FAC NO 81110AR	11	8	373				
81110FB	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 30 KW FIRM, 3-15KW INSTALLED, TEMP CLIM FOR INT SEC 06-12; SEE FAC NO 81110AT	11	8	373				
81110FC	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 45 KW FIRM, 4-15KW INSTALLED, TEMP CLIM FOR INT SEC 06-12; SEE FAC NO 81110AU	11	8	373				

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	SHT TONS	WT VOL TONS	MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
						HOR	VERT	GENL TOT
81110FD	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 60 KW FIRM, 2-60KW INSTALLED, TEMP CLIM FOR INT SEC 06-12; SEE FAC NO 81110AV	11	8		373			
81110FE	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 60 BY 8, 100 KW FIRM, 2-100KW INSTALLED, TEMP CLIM FOR INT SEC 06-12; SEE FAC NO 81110AW	13	10		448			
81110FF	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 60 BY 8, 200 KW FIRM, 3-100KW INSTALLED, TEMP CLIM FOR INT SEC 06-12; SEE FAC NO 81110AY	13	10		448			
81110FG	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 15 KW FIRM, 2-15KW INSTALLED, DESERT/TROPIC CLIM FOR INT SEC 06-12; SEE FAC NO 81110AR	11	8		373			
81110FH	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 30 KW FIRM, 3-15KW INSTALLED, DESERT/TROPIC CLIM FOR INT SEC 06-12; SEE FAC NO 81110AT	11	8		373			
81110FJ	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 45 KW FIRM, 4-15KW INSTALLED, DESERT/TROPIC CLIM FOR INT SEC 06-12; SEE FAC NO 81110AU	14	9		491			
81110FK	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 60 KW FIRM, 2-60KW INSTALLED, DESERT/TROPIC CLIM FOR INT SEC 06-12; SEE FAC NO 81110AV	11	8		373			
81110FL	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 60 BY 8, 100 KW FIRM, 2-100KW INSTALLED, DESERT/TROPIC CLIM FOR INT SEC 06-12; SEE FAC NO 81110AW	13	10		448			

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
81110FM	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 60 BY 8, 200 KW FIRM, 3-100KW INSTALLED, DESERT/TROPIC CLIM FOR INT SEC 06-12; SEE FAC NO 81110AY
81110FN	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 15 KW FIRM, 2-15KW INSTALLED, FRIGID CLIM FOR INT SEC 06-12; SEE FAC NO 81110AR
81110FP	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 30 KW FIRM, 3-15KW INSTALLED, FRIGID CLIM FOR INT SEC 06-12; SEE FAC NO 81110AT
81110FR	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 45 KW FIRM, 4-15KW INSTALLED, FRIGID CLIM FOR INT SEC 06-12; SEE FAC NO 81110AU
81110FT	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 48 BY 8, 60 KW FIRM, 2-60KW INSTALLED, FRIGID CLIM FOR INT SEC 06-12; SEE FAC NO 81110AV
81110FU	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 60 BY 8, 100 KW FIRM, 2-100KW INSTALLED, FRIGID CLIM FOR INT SEC 06-12; SEE FAC NO 81110AW
81110FV	GENERATING PLANT, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 60 BY 8, 200 KW FIRM, 3-100KW INSTALLED, FRIGID CLIM FOR INT SEC 06-12; SEE FAC NO 81110AY
81111AA	CONTROLLED NOISE SYSTEM FOR 100KW GENERATOR SET

CONSTRUCTION MATERIAL		SHT TONS	MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
WT TONS	VOL TONS				HOR	VERT	GENL
13	10			448			
11	10			1,437			
11	8			373			
11	8			373			
13	10			448			
13	10			448			
209	166			14,596	191	1,303	299 1,793

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
81230AF	POLE-MOUNTED FLOODLIGHTING ASSEMBLY, SINGLE FLOODLIGHT
81230AG	POLE-MOUNTED FLOODLIGHTING ASSEMBLY, TWO FLOODLIGHTS
81230AH	POLE-MOUNTED FLOODLIGHTING ASSEMBLY, FOUR FLOODLIGHTS
81230AJ	OUTDOOR LIGHTING CIRCUIT SOURCE POLE TOP ASSEMBLY.
81230AK	CONSTRUCTION LIGHTING EQUIPMENT, PORTABLE, WITH GENERATORS, FLOODLIGHTS, LAMPHOLDERS AND ACCESSORIES FOR 31.5 KILOWATTS OF LIGHTING.
81231AA	ELECTRICAL WIRING KIT, FLUORESCENT LIGHTING AND RECEPTACLE OUTLETS, 10 FOOTCANDLES, 480 SQUARE FEET, 8 TO 14 FEET MOUNTING HEIGHT, INCLUDING WIRING FOR VENTILATION EXHAUST FANS. THIS KIT ALSO IDENTIFIED WITH NSN 5410-00-773-6137.
81231AB	ELECTRICAL WIRING KIT, FLUORESCENT LIGHTING AND RECEPTACLE OUTLETS, 20 FOOTCANDLES, 480 SQUARE FEET, 8 TO 14 FEET MOUNTING HEIGHT, INCLUDING WIRING FOR VENTILATION EXHAUST FANS. THIS KIT ALSO IDENTIFIED WITH NSN 5410-00-773-6147.
81231AC	ELECTRICAL WIRING KIT, INCANDESCENT LIGHTING AND RECEPTACLE OUTLETS, 10 FOOTCANDLES, 480 SQUARE FEET, 8 TO 14 FEET MOUNTING HEIGHT, INCLUDING WIRING FOR VENTILATION FANS
81231AD	ELECTRICAL WIRING KIT, INCANDESCENT LIGHTING AND RECEPTACLE OUTLETS, 20 FOOTCANDLES, 480 SQUARE FEET, 8 TO 14 FEET MOUNTING HEIGHT, INCLUDING WIRING FOR VENTILATION FANS
81231AE	ELECTRICAL WIRING KIT, MERCURY VAPOR LIGHTING AND RECEPTACLE OUTLETS, 20 FOOTCANDLES, 1600 SF, 20 FT MOUNTING HEIGHT
81231AF	ELECTRICAL WIRING KIT, FLUORESCENT LIGHTING AND RECEPTACLE 150 SQUARE FEET, 8 TO 10 FT. MOUNTING HEIGHT. CORRIDOR LIGHT. MOUNTING HEIGHTS, INCLUDING WIRING FOR VENTILATION EXHAUST FANS.

CONSTRUCTION MATERIAL		SHT TONS	MEAS TONS	WT VOL	COST \$	CONST EFFORT IN MAN-HOURS		
HOR	VERY					BENL	TOT	
				39		8		8
				39		74		74
				66		22		22
				9		3		3
4	13			36,313				
1	613				97	24	721	
1	657				106	26	132	
	530				63		63	
	531				63		63	
	1,389				90		90	
1	438				58	12	70	

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		HOR	VERT	GENL	TOT			
81231AG	ELECTRICAL WIRING KIT, FLUORESCENT LIGHTING, 20 FOOT CANDLES, 150 SQUARE FEET, 8 TO 10 FOOT MOUNTING HEIGHT. MOUNTING HEIGHTS, INCLUDING WIRING FOR VENTILATION EXHAUST FANS. OFFICE LIGHTING.		1	436		58	12	70
81231AH	ELECTRICAL KIT, GENERAL CONSTRUCTION MATERIAL TO SUPPORT WIRING OF FACILITY INTERIOR LAYOUTS.			17		7	2	9
81231AK	COMPLETER ELECTRICAL KIT FOR 2400 SQUARE FOOT VEHICLE MAINTENANCE BUILDING PLAN TYPE 2			552		74	14	88
81231AL	COMPLETER ELECTRICAL KIT - 3600 SQUARE FOOT VEHICLE MAINTENANCE BUILDING, PLAN TYPE 4			667		91	18	109
81231AM	COMPLETER ELECTRICAL KIT - 4800 SQUARE FOOT VEHICLE MAINTENANCE BUILDING, PLAN TYPE 11			588		124	24	148
81231AP	ELECTRICAL KIT FOR VEHICLE REPAIR BAY SUBFACILITY-(WOOD OR METAL CONSTRUCTION) ALL CLIMATES	1	3	1,689		177	36	213
81231AR	ELECTRICAL KIT FOR 1200 SQUARE FOOT CORE SUBFACILITY-(WOOD OR METAL CONSTRUCTION) ALL CLIMATES	1	4	2,275		309	62	371
81231AT	ELECTRICAL KIT FOR 2400 SQUARE FOOT CORE SUBFACILITY-(WOOD OR METAL CONSTRUCTION) ALL CLIMATES	2	8	4,258	7	987	62	1,056
81231BA	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; MEDIUM; USED AS BARRACKS. ONE 2 ELEMENT LIGHTING FIXTURE AND 4 DUPLEX OUTLETS. 120/240 VOLT SERVICE			274				
81231BB	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; LARGE; USED AS QUARTERS. ONE 2 ELEMENT LIGHTING FIXTURE AND 8 DUPLEX OUTLETS. 120/240 VOLT SERVICE			386				

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL TONS	MEAS	COST \$	CONST EFFORT IN MAN-HOURS	
		HOR	VERT	GENL	TOT		
81231BC	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; LARGE; USED AS STORAGE; WARD AND WAREHOUSE. TWO 2 ELEMENT LIGHTING FIXTURES AND 8 DUPLEX OUTLETS. 120/240 VOLT SERVICE				414		
81231BD	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; MEDIUM; USED AS MESS. TWO 2 ELEMENT LIGHTING FIXTURES AND 4 DUPLEX OUTLETS 120/240 VOLT SERVICE				298		
81231BE	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; LARGE; USED AS WRITING AREAS. FOUR 2 ELEMENT LIGHTING FIXTURES AND 8 DUPLEX OUTLETS. 120/240 VOLT SERVICE			1	470		
81231BF	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; LARGE; USED AS RECREATION; BATH; KITCHEN AND GENERAL WORK AREA. SIX 2 ELEMENT LIGHTING FIXTURES AND 8 DUPLEX OUTLETS 120/2140 VOLT SERVICE			1	525		
81231BG	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; MEDIUM; USED AS LABORATORY; READING AND PX. FIVE 2 ELEMENT LIGHTING FIXTURES AND 4 DUPLEX OUTLETS 120/240 VOLT SERVICE			1	372		
81231BH	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; LARGE; USED AS PHARMACY. NINE 2 ELEMENT LIGHTING FIXTURES AND 8 DUPLEX OUTLETS. 120/214 VOLT SERVICE			1	608		
81231BJ	ELECTRICAL KIT FOR GENERAL PURPOSE TENT; LARGE; USED AS OFFICE; LAUNDRY AND SHOPS. TWELVE 2 ELEMENT LIGHTING FIXTURES AND 8 DUPLEX OUTLETS. 120/240 VOLT SERVICE			2	690		
81240AB	ELECTRICAL GENERATION & DISTRIBUTION FOR POL PUMP STATION, 6 IN PIPELINE, WITH ONE OR TWO DIESEL ENGINE DRIVEN PUMPS. SERVES HEATING & LIGHTING IN PUMP SHED, ADMIN. BLDG., LATRINE, OUTDOOR LIGHTING, AND AUXILIARY MOTORS.	3	6	14,092	81	276	173 332
81240AG	ELECTRICAL DISTRIBUTION FOR MARINE RAILWAY REPAIR INSTALLATION INCLUDING OUTSIDE LIGHTING.	5	7	4,589	58	920	403 1,381

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	IN MAN-HOURS	GENL	TOT
HOR	VERT							
81240AJ	ELECTRICAL DISTRIBUTION FOR DRY CARGO COVERED STORAGE, 12000 SF, TEMPORARY STANDARD	1		526	8	26	23	55
81240AK	ELECTRICAL DISTRIBUTION FOR DRY CARGO COVERED STORAGE, 25000 SF, TEMPORARY STANDARD	1	1	793	7	33	29	69
81240AL	ELECTRICAL DISTRIBUTION FOR DRY CARGO COVERED STORAGE, 50000 SF, TEMPORARY STANDARD	1	2	1,146	9	35	46	90
81240AM	ELECTRICAL DISTRIBUTION FOR DRY CARGO COVERED STORAGE, 100000 SF, TEMPORARY STANDARD	2	2	1,769	14	94	98	206
81240DC	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, SINGLE PRIMARY SUPPORT, 0 TO 5 DEGREE ANGLE.			53		8		8
81240DD	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, HEAVY CONDUCTOR, 0 TO 5 DEGREE ANGLE.			62		10		10
81240DE	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, DOUBLE PRIMARY SUPPORT, 5 TO 30 DEGREE ANGLE.			100		14		14
81240DF	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, DOUBLE PRIMARY SUPPORT, HEAVY CONDUCTOR, 5 TO 30 DEGREE ANGLE.			64		16		16
81240DG	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE VERTICAL CONSTRUCTION, 30 TO 60 DEGREE ANGLE, FOR COPPER CONDUCTORS NO. 6 THRU 000			67		6		6
81240DH	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE VERTICAL CONSTRUCTION, 60 TO 90 DEGREE ANGLE, FOR COPPER CONDUCTORS NO. 6 THRU 2.			146		14		14
81240DJ	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, 30 TO 60 DEGREE ANGLE, FOR COPPER CONDUCTORS NO. 6 THRU 2.			111		14		14
81240DK	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, DOUBLE DEADEND, LARGE CONDUCTORS.			184		16		16

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL TONS	MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	
		HOR	VERT	GENL	TOT		
81240DL	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, DOUBLE CIRCUIT, SINGLE PRIMARY SUPPORT, 0 TO 5 DEGREE ANGLE.				65	16	16
81240DM	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, DOUBLE CIRCUIT, DOUBLE PRIMARY SUPPORT, 0 TO 5 DEGREE ANGLE.				134	29	29
81240DN	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, DOUBLE CIRCUIT, DOUBLE PRIMARY SUPPORT, 5 TO 30 DEGREE ANGLE.				134	29	29
81240DP	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE VERTICAL CONSTRUCTION, DOUBLE CIRCUIT, 30 TO 60 DEGREE ANGLE. FOR COPPER CONDUCTORS AWG NO. 00 THROUGH 350 MCM.				146	10	10
81240DR	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE VERTICAL CONSTRUCTION, DOUBLE CIRCUIT, 60 TO 90 DEGREE ANGLE. FOR COPPER CONDUCTORS AWG NO. 00 THROUGH 350 MCM.				470	31	31
81240DT	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, DOUBLE CIRCUIT, DOUBLE DEADEND.				365	37	37
81240DU	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, DOUBLE CIRCUIT, 3-PHASE TAP AT 0 TO 5 DEGREE ANGLE.				171	31	31
81240DV	DOWN GUY ASSEMBLY, 3/8 INCH STRAND, FOR PRIMARY AND SECONDARY LINES.				55	3	3
81240DW	OVERHEAD GUY ASSEMBLY, 3/8 INCH STRAND, FOR PRIMARY AND SECONDARY LINES.				70	3	3
81240DY	DOUBLE DOWN GUY ASSEMBLY, 3/8 INCH STRAND, FOR PRIMARY AND SECONDARY LINES.				77	6	6
81240EA	LINE ANCHOR ASSEMBLY, EXPANDING TYPE, 10000 LBS. (4536 KG.) NOMINAL HOLDING POWER.				4	3	3
81240EB	LINE ANCHOR ASSEMBLY, LOG TYPE, 10000 LBS. (4536 KG.) NOMINAL HOLDING POWER.				8	3	6

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL MEAS	COST TONS	CONST EFFORT IN MAN-HOURS			
		TONS	TONS	\$	HOR	VERT	GENL	TOT
81240EC	POLE TOP OR UNDERBUILD ASSEMBLY, SECONDARY LINE, TWO ATTACHMENTS.			121			8	8
81240ED	POLE TOP OR UNDERBUILD ASSEMBLY, SECONDARY LINE, FOUR ATTACHMENTS.			200			8	8
81240EE	POLE TOP OR UNDERBUILD ASSEMBLY, SECONDARY LINE, SIX ATTACHMENTS.			324			756	756
81240EF	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, 30 TO 60 DEGREE ANGLE, FOR COPPER CONDUCTORS AWG NO. 0 THROUGH 350 MCM.			156			14	14
81240EG	POLE TOP ASSEMBLY 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, 30 TO 60 DEGREE ANGLE, FOR ACSR CONDUCTORS AWG NO. 2 THROUGH 336.4 MCM.			156			14	14
81240EH	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE CROSSARM CONSTRUCTION, 30 TO 60 DEGREE ANGLE, FOR ACSR CONDUCTORS 477 MCM THROUGH 636 MCM.			108			14	14
81240EJ	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE VERTICAL CONSTRUCTION, 60 TO 90 DEGREE ANGLE, FOR COPPER CONDUCTORS AWG NO. 0 THROUGH 350 MCM.			237			14	14
81240EK	POLE TOP ASSEMBLY, 13.8 KV, 3-PHASE VERTICAL CONSTRUCTION, 60 TO 90 DEGREE ANGLE, FOR ACSR CONDUCTORS AWG NO. 2 THROUGH 336.4 MCM.			237			14	14
81240EL	POLE TOP ASSEMBLY 13.8 KV 3 PHASE VERTICAL CONSTRUCTION,			141			14	14
81240EM	POLE TOP ASSEMBLY 13.8 KV 3 PHASE VERTICAL CONSTRUCTION,			73			6	6
81240EN	POLE TOP ASSEMBLY 13.8 KV 3 PHASE VERTICAL CONSTRUCTION,			71			6	6
81240EP	POLE TOP ASSEMBLY 13.8 KV 3 PHASE VERTICAL CONSTRUCTION,			70			6	6

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL TONS	MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	IN MAN-HOURS	GENL TOT
HOR	VERT							
812406A	ELECTRICAL DISTRIBUTION SYSTEM, ONE MILE PRIMARY LINE, 3-PHASE, 3-WIRE, 15 KV, NO. 6 COPPER.	15	16	8,618	121	1,087	598	1,806
812406B	ELECTRICAL DISTRIBUTION SYSTEM, ONE MILE PRIMARY LINE, 3-PHASE, 3-WIRE, 15 KV, NO. 4 COPPER.	18	36	7,479	144	1,190	736	2,070
812406C	ELECTRICAL DISTRIBUTION SYSTEM, ONE MILE PRIMARY LINE, 3-PHASE, 3-WIRE, 15 KV, NO. 2 COPPER.	18	19	8,288	155	1,300	771	2,226
812406D	ELECTRICAL DISTRIBUTION SYSTEM, ONE MILE PRIMARY LINE, 3-PHASE, 3-WIRE, 15 KV, NO. 0 COPPER.	19	25	11,821	178	1,484	843	2,507
812406E	REEFERS AND LOADED CONTAINERS-POWER AND LIGHTNING,GENERAL CARGO PORT-TEMPERATE CLIMATE DWG 1105-1115,SHT 1	713	949	2,829,933	1,617	41,600	2,300	45,317
812406F	AREA ILLUMINATION, GENERAL CARGO PORT - TEMPERATE CLIMATE DWG 1105-1115,SHT 1	27	30	93,469	66	1,352		1,416
812406G	ELEC AERIAL DISTRIBUTION - GENERAL CARGO PORT - TEMPERATE CLIMATE DWG 1105-1115,SHT 1	29	23	60,429	18	1,840		1,858
812406H	FIRE PUMP STATION, GENERAL CARGO PORT - TEMPERATE CLIMATE DWG 1105-1115,SHT 1	10	19	53,428	28	938		966
812406J	PIERS-MAIN FEEDERS AND DISTRIBUTION EQUIPMENT,GENERAL CARGO PORT - TEMPERATE CLIMATE DWG 1105-1115,SHT 1	27	57	103,840	75	1,665		1,740
812406K	POWER DISTRIBUTION,DISTRIBUTION EQUIPMENT AND ROADWAY LIGHTING, AMMUNITION CARGO PORT - TEMPERATE CLIMATE DWG 1105-1115,SHT 2	1,794	2,106	2,393,611	6,606	52,918		59,524
812406L	LOADED CONTAINER AREA ILLUMINATION,AMMUNITION CARGO PORT TEMPERATE CLIMATE DWG 1105-1115,SHT 2	89	95	333,681	745	4,692		5,437
812406M	FIRE PUMP STATION, AMMUNITION CARGO PORT TEMPERATE CLIMATE DWG 1105-1115,SHT 2	6	6	36,943	9	474		423

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS TOT
81240GN	PIERS-MAIN FEEDERS, AMMUNITION CARGO PORT TEMPERATE CLIMATE DWG 1105-1115,SHT 2	27	28	74,971	9	1,518	1,527
81240GP	FENCE LIGHTING, AMMUNITION CARGO PORT - TEMPERATE CLIMATE DWG 1105-1115,SHT 2	58	65	293,348	575	4,186	4,761
81240HA	ELECTRICAL DISTRIBUTION SYSTEM FOR 10 REPAIR BAY VEHICLE MAINTENANCE INSTALLATION	19	21	15,370	13	1,972	122 25107
81240HB	ELECTRICAL DISTRIBUTION SYSTEM FOR 20 REPAIR BAY VEHICLE MAINTENANCE INSTALLATION	28	42	27,991	2	26	2 30
81240HC	ELECTRICAL DISTRIBUTION SYSTEM FOR 375 MAN TROOP CAMP, TEMPORARY STANDARD,ALL CLIMATES,154 KVA	11	12	9,205	69	690	46 805
81240HD	ELECTRICAL SYSTEM FOR 500 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD,ALL CLIMATES	3	4	993	21	230	28 279
81240HE	ELECTRICAL DISTRIBUTION SYSTEM FOR 500 MAN TROOP CAMP CORRIDORS,TEMPORARY STANDARD,ALL CLIMATES,321 KVA	8	8	3,274	18	207	23 268
81240HF	ELECTRICAL SYSTEM FOR 1000 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD,ALL CLIMATES	5	5	3,777	28	253	41 322
81240HG	ELECTRICAL DISTRIBUTION SYSTEM FOR 1000 MAN TROOP CAMP CORRIDORS,TEMPORARY STANDARD,ALL CLIMATES,590 KVA	10	11	1,942	25	230	37 292
81240HH	ELECTRICAL SYSTEM FOR PARKING AND MAINTENANCE TEMPORARY STANDARD,ALL CLIMATES	4	4	1,866	21	230	28 279
81240HJ	ELECTRICAL SYSTEM FOR 3000 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD,ALL CLIMATES	5	5	2,797	55	288	66 369
81240HK	ELECTRICAL DISTRIBUTION SYSTEM FOR 3000 MAN TROOP CAMP	11	10	7,908	32	276	44 352
81240HL	ELECTRICAL DIST SYSTEM FOR 5000 MAN TROOP CAMP HEADQUARTERS TEMPORARY STANDARD,ALL CLIMATES	3	4	2,346	41	313	69 423

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
81240HM	ELECTRICAL DISTRIBUTION SYSTEM FOR 3000 MAN TROOP CAMP CORRIDORS, TEMPORARY STANDARD, ALL CLIMATES, 2.9 MVA	18	78	8,515	37	304	55	396
81241AA	ELECTRICAL DISTRIBUTION SYSTEM FOR MEDICAL SUPPLY, OPTICAL AND MAINTENANCE UNIT, ALL CLIMATES	39	239	68,886	263	1,313	263	1,839
81242BE	ELECTRICAL DISTRIBUTION FOR SIGINT INSTALLATION ALL CLIMATES, TEMPORARY STANDARD.	29,174	332,893	43,114,371	230	690	690	1,610
81242BF	ELECTRICAL DISTRIBUTION FOR SIGINT STATION	46,648	231,959	73,694,001	115	345	345	805
81260AA	TRANSFORMER ASSEMBLY, 5 KVA SINGLE PHASE, 4160-120/240 VOLTS FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	1	733		55		55
81260AB	TRANSFORMER ASSEMBLY, 10 KVA SINGLE PHASE, 4160-120/240 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	1	790		58		58
81260AC	TRANSFORMER ASSEMBLY, 15 KVA SINGLE PHASE, 4160-120/240 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	1	787		60		60
81260AD	TRANSFORMER ASSEMBLY, 25 KVA SINGLE PHASE, 4160-120/240 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	1	592		63		63
81260AE	TRANSFORMER ASSEMBLY, 5KVA SINGLE PHASE, 4160-120/240 VOLTS, FOR SELF-PROTECTED TRANSFORMERS	1	1	838		55		55
81260AF	TRANSFORMER ASSEMBLY, 10 KVA SINGLE PHASE, 4160-120/240 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	1	1	716		58		58
81260AG	TRANSFORMER ASSEMBLY, 15 KVA SINGLE PHASE, 4160-120/240 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	1	1	731		60		60
81260AH	TRANSFORMER ASSEMBLY, 25 KVA SINGLE PHASE, 4160-120/240 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	1	1	668		63		63
81260AJ	TRANSFORMER ASSEMBLY, 15 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	2	1,276		81		81

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
		HOR	VERT	GENL	TOT		
81260AK	TRANSFORMER ASSEMBLY, 30 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	2	1,252	86		86
81260AL	TRANSFORMER ASSEMBLY, 45 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	2	1,563	91		91
81260AM	TRANSFORMER ASSEMBLY, 75 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	2	2	1,650	97		97
81260AN	TRANSFORMER ASSEMBLY, 112 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	2	2	1,530	104		104
81260AP	TRANSFORMER ASSEMBLY, 150 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	2	2	2,259	112		112
81260AR	TRANSFORMER ASSEMBLY, 225 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	3	3	2,898	120		120
81260AT	TRANSFORMER ASSEMBLY, 300 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	3	4	3,491	128		128
81260AU	TRANSFORMER ASSEMBLY, 30 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	1	2	1,574	86		86
81260AV	TRANSFORMER ASSEMBLY, 45 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	1	2	1,626	91		91
81260AW	TRANSFORMER ASSEMBLY, 75 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	2	2	1,922	97		97
81260AY	TRANSFORMER ASSEMBLY, 112 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	2	2	1,607	104		104
81260BA	TRANSFORMER ASSEMBLY, 150 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	2	2	2,674	112		112
81260BB	TRANSFORMER ASSEMBLY, 225 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	3	3	3,491	120		120

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
					HOR	VERT	GENL TOT
81260BC	TRANSFORMER ASSEMBLY, 300 KVA THREE PHASE, 4160-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	3	4	4,049		128	128
81260BD	TRANSFORMER ASSEMBLY, 5 KVA SINGLE PHASE, 13800-120/240 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	1	684		55	55
81260BE	TRANSFORMER ASSEMBLY, 10 KVA SINGLE PHASE, 13800-120/240 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	1	739		58	58
81260BF	TRANSFORMER ASSEMBLY, 15 KVA SINGLE PHASE, 13800-120/240 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	1	824		60	60
81260BG	TRANSFORMER ASSEMBLY, 25 KVA SINGLE PHASE, 13800-120/240 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	1	672		63	63
81260BH	TRANSFORMER ASSEMBLY, 10 KVA SINGLE PHASE, 13800-120/240 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	1	1	683		58	58
81260BJ	TRANSFORMER ASSEMBLY, 15 KVA SINGLE PHASE, 13800-120/240 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	1	1	730		60	60
81260BK	TRANSFORMER ASSEMBLY, 25 KVA SINGLE PHASE, 13800-120/240 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.	1	1	815		63	63
81260BL	TRANSFORMER ASSEMBLY, 15 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	2	1,456		81	81
81260BM	TRANSFORMER ASSEMBLY, 30 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	1	2	1,435		86	86
81260BN	TRANSFORMER ASSEMBLY, 45 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	2	2	1,630		91	91
81260BP	TRANSFORMER ASSEMBLY, 75 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	2	2	1,839		97	97
81260BR	TRANSFORMER ASSEMBLY, 112 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.	2	3	2,279		104	104

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
81260BT	TRANSFORMER ASSEMBLY, 150 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.
81260BU	TRANSFORMER ASSEMBLY, 225 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.
81260BV	TRANSFORMER ASSEMBLY, 300 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR EXISTING CONVENTIONAL TRANSFORMERS.
81260BW	TRANSFORMER ASSEMBLY, 30 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.
81260BY	TRANSFORMER ASSEMBLY, 45 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.
81260CA	TRANSFORMER ASSEMBLY, 75 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.
81260CB	TRANSFORMER ASSEMBLY, 112 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.
81260CC	TRANSFORMER ASSEMBLY, 150 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.
81260CD	TRANSFORMER ASSEMBLY, 225 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.
81260CE	TRANSFORMER ASSEMBLY, 300 KVA THREE PHASE, 13800-208Y/120 VOLTS, FOR SELF-PROTECTED TRANSFORMERS.
81320AA	SUBSTATION FOR GENERATING PLANT WITH THREE OR FIVE 1500 KW UNITS - 3 FEEDERS AT 4160 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.
81320AB	SUBSTATION FOR GENERATING PLANT WITH THREE 1500 KW UNITS - 3 FEEDERS AT 13800 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.

SHT TONS	WT VOL TONS	MEAS TONS	COST \$	CONSTR EFFORT IN MAN-HOURS		
				HOR	VERT	GENL TOT
2	3	2,456		TT2		TT2
3	3	3,155		120		120
3	4	3,746		128		128
1	2	1,466		86		86
2	2	1,649		91		91
2	2	1,865		97		97
2	2	2,320		104		104
2	3	2,504		112		112
3	3	3,230		120		120
3	4	3,788		128		128
18	16	11,712	248	2,237	130	2,615
26	21	12,841	196	2,407	131	2,734

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	IN MAN-HOURS		
		HHR	VERT	GENL	TOT			
81320AC	SUBSTATION FOR GENERATING PLANT WITH NINE OR TWELVE 300 KW UNITS - 4 FEEDERS AT 4160 VOLTS; 3 FEEDERS AT 13800 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	24	18	10,813	36	2,303	107	2,400
81320AD	SUBSTATION FOR GENERATING PLANT WITH FIVE 1500 KW UNITS - 3 FEEDERS AT 4160 VOLTS; 3 FEEDERS AT 13800 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	52	41	23,374	416	4,168	437	5,001
81320AE	SUBSTA 6 MW 6-13800V FDRS CLIM 5 6 FEEDERS AT 13800 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	53	42	23,893	413	4,164	427	5,004
81320AF	SUBSTATION FOR GENERATING PLANT WITH SIX 1500 KW UNITS - 6 FEEDERS AT 4160 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	37	31	29,898	431	5,402	466	6,299
81320AG	SUBSTATION FOR GENERATING PLANT WITH SIX 1500 KW UNITS - 2 FEEDERS AT 4160 VOLTS; 3 FEEDERS AT 13800 VOLTS FOR TEMPORATE, TROPICAL, AND DESERT CLIMATES.	54	42	28,692	507	4,773	642	5,722
81320AH	SUBSTATION FOR GENERATING PLANT WITH SIX 1500 KW UNITS - 6 FEEDERS AT 13800 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	54	42	24,825	508	4,334	437	5,277
81320AJ	SUBSTATION FOR GENERATING PLANT WITH NINE 1500 KW UNITS - 5 FEEDERS AT 4160 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	56	46	43,031	7,346	7,345	507	9,198
81320AK	SUBSTATION FOR GENERATING PLANT WITH NINE 1500 KW UNITS - 6 FEEDERS AT 4160 VOLTS; 3 FEEDERS AT 13800 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	61	50	39,306	986	6,678	530	8,194
81320AL	SUBSTATION FOR GENERATING PLANT WITH NINE 1500 KW UNITS - 3 FEEDERS AT 4160 VOLTS; 6 FEEDERS AT 13800 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	70	55	41,890	952	6,903	738	8,395
81320AM	SUBSTATION FOR GENERATING PLANT WITH NINE 1500 KW UNITS - 9 FEEDERS AT 13800 VOLTS FOR TEMPERATE, TROPICAL, AND DESERT CLIMATES.	76	59	42,067	727	6,826	596	8,143

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	SHT TONS	WT VOL	MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT
82140FA	WATER DISTRIBUTION SYSTEM, ALL CLIMATES	2		1	5,869	21	61	61 103
82190AA	HEATER 70,000 BTU. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.				368		23	23
82191BB	BARRACKS, ARCH, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, DESERT/TROPIC CLIM	6		4	920	17	428	133 578
82209AA	STEAM SYSTEM-GEN. CARGO PORT/ONSHORE DWG FP1105-1115,SHT3	19	125	47,913	676	2,329	1,352	4,357
82209AB	STEAM SYSTEM BREAKBULK/RO-RO PIER DWG FP1105-1115,SHT3	19	133	64,284	856	1,978	1,334	4,168
82209AC	STEAM SYSTEM-CONTAINER PIER DWG FP1105-1115,SHT 3	23	95	50,430	559	1,312	874	2,745
82610CB	COMFORT ROOF VENTILATION SET FOR 20X48FT WOOD FRAME BARRACK CONSISTING OF THREE 16-IN DIA FANS RATED AT 1600 CFM EACH COMPLETE W/INSTL ACCESSORIES TOTAL AIR EXHAUSTED FROM SPACE 4800 CFM			1	189		5	5
83110AA	SEWAGE PACKAGE PLANT, COMPLETE MIX ACTIVATED SLUDGE. PRIMARY AND SECONDARY TREATMENT, 25000 GPD SINGLE UNIT	140	302	83,420	79	5,213	345	5,637
83110AB	SEWAGE PACKAGE PLANT, COMPLETE MIX ACTIVATED SLUDGE PRIMARY AND SECONDARY TREATMENT 50000 GPD SINGLE UNIT	172	392	107,220	84	5,819	518	6,421
83110AC	SEWAGE PACKAGE PLANT, COMPLETE MIX ACTIVATED SLUDGE PRIMARY AND SECONDARY TREATMENT 75000 GPD USING 1-25000 GPD AND 1-50000 GPD PLANTS PLACED IN SERIES WITH ALL ANCILLARY EQUIPMENT	263	526	146,585	104	6,739	692	7,535
83110AD	SEWAGE PACKAGE PLANT COMPLETE MIX ACTIVATED SLUDGE PRIMARY AND SECONDARY TREATMENT, 100000 GPD USING 2-50000 GPD PLANTS PLACED IN SERIES WITH ALL ANCILLARY EQUIPMENT	309	625	169,902	112	7,132	853	8,097

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS VERT GENL TOT	
83110AE	SEWAGE PACKAGE PLANT, COMPLETE MIX ACTIVATED SLUDGE PRIMARY AND SECONDARY TREATMENT, 150000 GPD PLANT USING 3-50000 GPD PLANTS PLACED IN SERIES WITH ALL ANCILLARY EQUIPMENT	413	830	218,335	140	6,724	1,196 10,060
83110AV	SLUDGE DRYING BED, 30000 GAL PER DAY, UNIT FOR SEWAGE DISPOSAL PLANT	1	1	425	14	44	219 277
83110AW	SLUDGE DRYING BED, 100000 GAL PER DAY, UNIT FOR SEWAGE DISPOSAL PLANT	1	2	1,135	21	131	334 486
83110BA	CHLORINATION, VOLUMETRIC METERING FOR 25000 GPD PLANT	5	7	5,578	2	71	32 105
83110BB	CHLORINATION, VOLUMETRIC METERING FOR 50000 GPD PLANT	6	10	10,584	2	71	32 105
83110BC	CHLORINATION, VOLUMETRIC METERING FOR 100000 GPD PLANT	8	17	20,649	2	81	46 129
83110BD	CHLORINATION, VOLUMETRIC METERING FOR 200000 GPD PLANT	11	32	40,829	3	86	35 166
83110BE	CHLORINATION, VOLUMETRIC METERING FOR 300000 GPD PLANT	13	43	48,921	3	98	64 165
83120AA	SEPTIC TANK 500 GPD, CONCRETE	6	3	740	3	75	14 92
83120AB	SEPTIC TANK 1000 GPD, CONCRETE	11	9	2,540	3	136	21 180
83120AC	SEPTIC TANK 10000 GPD, CONCRETE	27	20	45,526	8	247	37 292
83120AE	SEPTIC TANK, USALWL, 4FT X 4FT X 2FT, 200 GAL. WITH TANK LID, INLET ASSEMBLY AND PIPES	1	1	231			5 5
83120AF	SEPTIC TANK, 500 GALLONS, COMPLETE W/DRAIN FIELD	1	1	1,261	29	345	374

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
83120BA	SIPHON CHAMBER, 1000 GPD, 60 MINUTE GROUND PERCOLATION TIME	2	2	800	2	69	10	81
83120BB	SIPHON CHAMBER, 10000 GPD, 1 MINUTE GROUND PERCOLATION TIME	6	4	1,518	2	95	14	111
83120BC	SIPHON CHAMBER, 10000 GPD, 15 MINUTE GROUND PERCOLATION TIME	6	5	1,688	2	108	21	131
83120BD	SIPHON CHAMBER 10000 GPD 60 MINUTE GROUND PERCOLATION TIME	13	11	2,472	3	167	28	198
83120BE	CHLORINE CONTACT CHAMBER,WOOD CONSTRUCTION.LENGTH 4FT. 8IN DEPTH 2FT.6IN. 25000 GAL. PER DAY DESIGN FLOW	2	3	476	2	69	9	80
83120BF	CHLORINE CONTACT CHAMBER,WOOD CONSTRUCTION LENGTH 4FT 8IN DEPTH 4FT. 9IN. 50000 GAL. PER DAY DESIGN FLOW.	3	3	526	2	83	9	94
83120BG	CHLORINE CONTACT CHAMBER,WOOD CONSTRUCTION.LENGTH 8FT.10IN DEPTH 5FT.0IN.100000 GAL. PER DAY DESIGN FLOW	4	5	784	2	92	12	106
83120BH	CHLORINE CONTACT CHAMBER,WOOD CONSTRUCTION LENGTH 17FT 5IN DEPTH 5FT. 0IN. 200000 GAL. PER DAY DESIGN FLOW.	7	8	1,212	2	101	12	115
83120BJ	CHLORINE CONTACT CHAMBER,WOOD CONSTRUCTION.LENGTH 25FT.11IN DEPTH 5FT.0IN.300000 GAL. PER DAY DESIGN FLOW	9	11	1,628	2	110	14	126
83120BK	DOSING TANK,WOOD CONSTRUCTION 1000GAL. PER DAY.EFFECTIVE TANK VOLUME 36.36 CUBIC FEET LENGTH 4FT-4IN. 60MINUTES PERC TIME FOR 1INCH FALL	1	2	467	2	92	12	106
83120BL	DOSING TANK,WOOD CONSTRUCTION 10000GAL PER DAY EFFECTIVE TANK VOLUME 63.45CUBIC FEET LENGTH 4FT 4IN. 1 MINUTE PERC TIME FOR 1INCH FALL.	2	2	776	2	101	14	117
83120BM	DOSING TANK,WOOD CONSTRUCTION 10000GAL. PER DAY.EFFECTIVE TANK VOLUME 93.50CUBIC FEET LENGTH 6FT-2IN. 2 MINUTES PERC TIME FOR 1INCH FALL	2	3	818	2	110	16	128

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	IN HRS	VERT	GENL	TOT
83120BN	DOSING TANK,WOOD CONSTRUCTION 10000GAL PER DAY EFFECTIVE TANK VOLUME 112.84CUBIC FEET LENGTH 7FT 5IN. 3 MINUTES PERC TIME FOR 1INCH FALL.	2	3	855	2	120	18	160	
83120BP	DOSING TANK,WOOD CONSTRUCTION 10000GAL.PER DAY.EFFECTIVE TANK VOLUME 130.90CUBIC FEET LENGTH 8FT-8IN. 4 MINUTES PERC TIME FOR 1INCH FALL	3	3	893	3	129	21	193	
83120BR	DOSING TANK,WOOD CONSTRUCTION 10000GAL PER DAY EFFECTIVE TANK VOLUME 148.75CUBIC FEET LENGTH 9FT10IN. 5 MINUTES PERC TIME FOR 1INCH FALL.	3	3	923	3	138	21	182	
83120BT	DOSING TANK,WOOD CONSTRUCTION 10000 GAL.PER DAY.EFFECTIVE TANK VOLUME 136.35CUBIC FEET LENGTH 9FT-0IN. 10 MINUTES PERC TIME FOR 1INCH FALL	3	3	901	3	147	23	173	
83120BU	DOSING TANK,WOOD CONSTRUCTION 10000 GAL PER DAY EFFECTIVE TANK VOLUME 167.82CUBIC FEET LENGTH11FT-0IN. 15 MINUTES PERC TIME FOR 1INCH FALL.	3	4	962	3	156	23	182	
83120BV	DOSING TANK,WOOD CONSTRUCTION 10000 GAL.PER DAY EFFECTIVE TANK VOLUME 242.41 CUBIC FEET LENGTH15FT-10IN. 30MINUTES PERC TIME FOR 1INCH FALL	4	5	1,104	3	166	25	196	
83120BW	DOSING TANK,WOOD CONSTRUCTION 10000 GAL PER DAY EFFECTIVE TANK VOLUME 272.71 CUBIC FEET LENGTH17FT-10IN. 45MINUTES PERC TIME FOR 1INCH FALL.	4	5	1,163	5	175	25	205	
83120BY	DOSING TANK,WOOD CONSTRUCTION 10000 GAL.PER DAY EFFECTIVE TANK VOLUME 363.61 CUBIC FEET LENGTH23FT-9IN. 60 MINUTES PERC TIME FOR 1INCH FALL	5	6	1,284	5	184	25	214	
83120CA	SEPTIC TANK,WOOD CONSTRUCTION. 500 GAL.PER DAY FLOW LENGTH 6FT- 0IN. WIDTH 4FT- 0IN WATER DEPTH 4FT-2IN	2	3	612	3	83	12	98	
83120CB	SEPTIC TANK,WOOD CONSTRUCTION. 1000 GAL.PER DAY FLOW LENGTH 5FT- 6IN. WIDTH 5FT- 0IN WATER DEPTH 5FT-0IN	3	4	1,127	3	166	18	187	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
		HOR	VERT	GENL	TOT		
83120CC	SEPTIC TANK,WOOD CONSTRUCTION.10000 GAL.PER DAY FLOW LENGTH 14FT-10IN WIDTH 8FT- 0IN WATER DEPTH 6FT-6IN	9	11	2,525	8	288	30 326
83120DA	SEWAGE, OPTICAL FABRICATING SHOP AND MEDICAL MAINTENANCE SHOPS, ALL CLIMATES			176	12	18	23 53
83140AA	AERATED SEWAGE LAGOON 1 ROW 2-5 HP AERATORS WITHOUT LINER	70	134	35,878	304	5,817	311 6,432
83140AB	AERATED SEWAGE LAGOON 1 ROW 3-5 HP AERATORS WITHOUT LINER	74	157	42,101	315	6,802	317 7,434
83140AC	AERATED SEWAGE LAGOON 1 ROW 2-10 HP AERATORS WITHOUT LINER	69	131	35,639	432	5,819	324 6,575
83140AD	AERATED SEWAGE LAGOON 1 ROW 3-10 HP AERATORS WITHOUT LINER	73	155	41,761	385	6,808	352 7,745
83140AE	AERATED SEWAGE LAGOON 1 ROW 2-20 HP AERATORS WITHOUT LINER	70	133	35,989	822	5,829	386 7,037
83140AF	AERATED SEWAGE LAGOON 1 ROW 3-20 HP AERATORS WITHOUT LINER	74	158	42,325	1,152	6,822	435 8,409
83140AG	AERATED SEWAGE LAGOON 2 ROW 3-20 HP AERATORS WITHOUT LINER	81	183	42,732	2,338	8,011	616 10,965
83140AH	AERATED SEWAGE LAGOON 1 ROW 2-30 HP AERATORS WITHOUT LINER	71	135	36,385	1,221	5,837	435 7,493
83140AJ	AERATED SEWAGE LAGOON 1 ROW 3-30 HP AERATORS WITHOUT LINER	75	158	42,7412	1,639	6,822	507 8,968
83140AK	AERATED SEWAGE LAGOON 2 ROW 3-30 HP AERATORS WITHOUT LINER	89	226	63,021	3,240	8,018	756 12,014
83140BA	AERATED SEWAGE LAGOON 1 ROW 2-5 HP AERATORS WITH LINER	78	175	41,611	308	5,834	690 6,832

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT	TOT
83140BB	AERATED SEWAGE LAGOON 1 ROW 3-5 HP AERATORS WITH LINER	81	197	37,237	320	6,820	702	7,842
83140BC	AERATED SEWAGE LAGOON 1 ROW 2-10 HP AERATORS WITH LINER	80	188	43,903	437	5,848	628	7,113
83140BD	AERATED SEWAGE LAGOON 1 ROW 3-10 HP AERATORS WITH LINER	86	227	31,683	391	6,833	7,007	7,437
83140BE	AERATED SEWAGE LAGOON 1 ROW 2-20 HP AERATORS WITH LINER	87	227	48,598	828	5,863	1,256	7,949
83140BF	AERATED SEWAGE LAGOON 1 ROW 3-20 HP AERATORS WITH LINER	96	282	59,023	1,739	6,912	1,373	9,644
83140BG	AERATED SEWAGE LAGOON 2 ROW 3-20 HP AERATORS WITH LINER	121	417	74,480	2,348	8,072	2,760	13,180
83140BH	AERATED SEWAGE LAGOON 1 ROW 2-30 HP AERATORS WITH LINER	92	260	33,234	1,228	5,897	1,587	8,712
83140BJ	AERATED SEWAGE LAGOON 1 ROW 3-30 HP AERATORS WITH LINER	104	328	65,168	1,647	6,897	2,061	10,605
83140BK	AERATED SEWAGE LAGOON 2 ROWS 3-30 HP AERATORS WITH LINER	136	502	86,118	3,251	8,087	3,671	15,009
83140CA	CONVENTIONAL SEWAGE LAGOON 1/2 ACRE WITHOUT LINER	57	117	26,878	137	4,491	221	4,849
83140CB	CONVENTIONAL SEWAGE LAGOON 1 ACRE WITHOUT LINER	57	117	26,878	250	4,494	242	4,986
83140CC	CONVENTIONAL SEWAGE LAGOON 2 ACRES WITHOUT LINER	57	118	27,433	469	4,505	304	5,278
83140CD	CONVENTIONAL SEWAGE LAGOON 3 ACRES WITHOUT LINER	57	118	27,041	685	4,515	366	5,566
83140DA	CONVENTIONAL SEWAGE LAGOON 1/2 ACRE WITH LINER	63	147	30,726	140	4,513	469	5,122

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GEHL TOT
83140DB	CONVENTIONAL SEWAGE LAGOON 1 ACRE WITH LINER	67	168	34,101	254	6,561	699 5,694
83140DC	CONVENTIONAL SEWAGE LAGOON 2 ACRES WITH LINER	74	210	39,352	475	6,569	1,730 6,194
83140DD	CONVENTIONAL SEWAGE LAGOON 3 ACRES WITH LINER	80	249	44,650	692	6,567	1,578 6,837
83190AA	CESSPOOLS 20 PLACED IN GRID, 55 GAL DRUMS PROCURED LOCALLY.	10	8	996	13	115	179 307
83190AB	CESSPOOLS 30 PLACED IN GRID, 55 GAL DRUMS PROCURED LOCALLY.	15	12	1,387	18	181	276 475
83190AC	CESSPOOLS 100 PLACED IN GRID, 55 GAL DRUMS PROCURED LOCALLY.	49	41	4,199	61	303	856 1,420
83190AD	CESSPOOLS 200 PLACED IN GRID, 55 GAL DRUMS PROCURED LOCALLY	96	81	8,387	127	1,120	1,904 3,151
83201AA	SEWAGE COLLECTION SYSTEM, MATERIAL FOR ONE MILE OF 4 IN PIPE	2	4	4,117	522	1,019	596 2,137
83201AB	SEWAGE COLLECTION SYSTEM, MATERIAL FOR ONE MILE OF 6 IN PIPE	15	50	17,963	522	1,019	596 2,137
83210AA	SANITARY SYSTEM-GEN CARGO PORT, ONSHORE DWG FPT105-7113, SHT3	3	27	21,840	869	635	1,304
83210BA	PNEUMATIC EJECTOR LIFT STATION FOR 25000 GPD PLANT	13	48	11,951	9	230	55 294
83210BB	PNEUMATIC EJECTOR LIFT STATION FOR 50000 GPD PLANT	13	47	14,283	9	230	55 294
83210BC	PNEUMATIC EJECTOR LIFT STATION FOR 75000 GPD PLANT	14	47	16,777	9	230	55 294
83210BD	PNEUMATIC EJECTOR LIFT STATION FOR 100000 GPD PLANT	14	47	19,777	9	230	55 294
83210BE	PNEUMATIC EJECTOR LIFT STATION FOR 150000 GPD PLANT	14	47	21,831	9	239	55 303
83210DA	SANITARY SYSTEM FOR 125 MAN TROOP CAMP, TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD	4	9	3,787	37	98	86 221

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
83210DB	SANITARY SYSTEM FOR 250 MAN TROOP CAMP TEMPORARY STANDARD ALL CLIMATES 30 GPD	4	9	6,025	58	201	173	632
83210DC	SANITARY DISTRIBUTION SYSTEM FOR 375 MAN TROOP CAMP, TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD	4	10	4,269	86	334	288	708
83210DD	SANITARY SYSTEM FOR 500 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD	1	1	617	32	104	92	228
83210DE	SANITARY DISTRIBUTION SYSTEM FOR 500 MAN TROOP CAMP CORRIDORS, TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD	4	10	4,190	28	83	78	189
83210DF	SANITARY SYSTEM FOR 1000 MAN TROOP CAMP HEADQUARTERS TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD	1	2	967	74	207	138	619
83210DG	SANITARY DISTRIBUTION SYSTEM FOR 1000 MAN TROOP CAMP CORRIDORS, TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD	4	13	5,100	101	253	230	584
83210DH	SANITARY SYSTEM FOR PARKING " MAINTENANCE, TEMPORARY STANDARD, ALL CLIMATES			73	29	92	83	204
83210DJ	SANITARY SYSTEM FOR 3000 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD		2	810	104	288	253	645
83210DK	SANITARY DISTRIBUTION SYSTEM FOR 3000 MAN TROOP CAMP CORRIDORS, TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD	60	37	38,102	83	276	242	601
83210DM	SANITARY SYSTEM FOR 5000 MAN TR CP CORR. TEMPORARY STANDARD, ALL CLIMATES, 30 GPCD	101	208	59,306	115	313	313	741
83210DN	SANITARY SYS FOR 5000 MAN TROOP CAMP TEMPORARY STANDARD ALL CLIMATES 30 GPD	3	8	3,399	87	304	253	646
83210HB	SANITARY DISTRIBUTION SYSTEM FOR 250 MAN TROOP CAMP, ALL CLIMATES, TEMPORARY STANDARD, 30 GPCD	3	9	3,844				
84101AA	WATER SUPPLY TRANSMISSION, PIPING & EQUIPMENT FOR ONE MILE OF MAIN FROM EXISTING SOURCE OF SUPPLY	11	20	11,728	759	897	242	1,898

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
84102AA	SAND FILTER FIELD EXPEDIENT			75			5	5
84102AB	WATER STORAGE SUMP, 5000 GAL CAPACITY, MEMBRANE LINED	2	4	549	7	1	39	47
84102AC	WATER STORAGE SUMP, 10000 GAL CAPACITY, MEMBRANE LINED	2	6	715	7	1	60	68
84102AD	WATER STORAGE RESERVOIR, 50000 GAL CAPACITY, MEMBRANE LINED	5	16	2,235	36	8	122	166
84102AE	WATER STORAGE RESERVOIR, 100000 GAL CAPACITY, MEMBRANE LINED	5	15	2,083	40	10	160	190
84102AF	LAUNDRY WASTEWATER RECYCLING FACILITY, 5000 GAL CAPACITY	2	4	13,507			10	10
84102AG	SHOWER WASTEWATER RECYCLING FACILITY, 10000 GAL CAPACITY	2	7	15,556			15	15
84102AH	AIRCRAFT WASHWATER RECYCLING FACILITY, 25 TO 40 AIRCRAFT	15	4	44,085	114		61	135
84102AJ	EXPEDIENT WATER STORAGE TANK, 3500 GAL CAPACITY, WOOD FRAME, MEMBRANE LINED	1	1	258		9		9
84102AK	WATER PURIFICATION PLANT, REVERSE OSMOSIS, 15000GPH, BARGE MTD	418	1,834	3,900,000			104	104
84102AL	WATER PURIFICATION EQUIPMENT SET, REVERSE OSMOSIS, 7500GPH SKID MTD MODEL PD 81166			74	1,010,138		1	1
84102AM	WATER PURIFICATION EQUIPMENT SET, REVERSE OSMOSIS, 3000GPH TRK MTD-TO BE TYPE CLASSIFIED JAN 86 (UNDER DEVELOPMENT)	19	75	610,000			5	5
84102AN	WATER PURIFICATION EQUIPMENT SET, REVERSE OSMOSIS, 600GPH TRLR MTD	4	4,833	235,138			5	5
84102AP	WATER PURIFICATION EQUIPMENT SET, ERDLATOR, 3000GPH, TRK MTD	16	78,226	73,983			6	6
84102AR	WATER PURIFICATION EQUIPMENT SET, ERDLATOR, 1500GPH, TRK MTD	13	67,050	50,132			5	5
84102AT	WATER PURIFICATION EQUIPMENT SET, DIATOMITE FILTER, 420GPH BASE MTD	2	4,975	19,819			3	3

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT	VOL	COST	CONST EFFORT IN MAN-HOURS			TOT
		SHT TONS	MEAS TONS		HOR	VERT	GENL	
84102AU	WATER STORAGE/DISTRIBUTION SYSTEM, POTABLE WATER, 1000000 GAL			107	205,070	233	506	739
84102AV	WATER STORAGE/DISTRIBUTION SYSTEM, POTABLE WATER, 800000 GAL			2	329,869	53	409	462
84102AW	WATER STORAGE/DISTRIBUTION SYSTEM, POTABLE WATER, 320000 GAL				320,318	30	386	416
84102AY	WATER STORAGE/DISTRIBUTION SYSTEM, POTABLE WATER, 40000 GAL			26	73,479	16	29	45
84102BA	WATER STORAGE/DISTRIBUTION SYSTEM, POTABLE WATER, HOSPITAL, 20000 GAL	1	12	60,600	10		18	28
84102BB	TACTICAL WATER DISTRIBUTION SET, 10 MILE SEGMENT W/6IN HOSE AND 600GPM PUMPS				764,570		219	219
84110BA	CHEMICAL STORAGE AND ERDLATOR BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 40 BY 8, 60,000 GPD, TEMP CLIM	20	64	52,843				
84110BB	CHEMICAL STORAGE AND ERDLATOR BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, 120,000 GPD, TEMP CLIM	33	102	96,601				
84110BC	CHEMICAL STORAGE AND ERDLATOR BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 40 BY 8, 60,000 GPD, DESERT/TROPIC CLIM	16	47	46,924				
84110BD	CHEMICAL STORAGE AND ERDLATOR BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, 120,000 GPD, DESERT/TROPIC CLIM	26	89	90,488				
84110BE	CHEMICAL STORAGE AND ERDLATOR BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 40 BY 8, 60,000 GPD, FRIGID CLIM	20	64	52,843				
84110BF	CHEMICAL STORAGE AND ERDLATOR BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, 120,000 GPD, FRIGID CLIM	33	102	96,601				

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL	TOT
84120AA	DEEP WELL WATER SUPPLY UNIT, SMALL, W/3-60 GAL PER MIN PUMPS & 6000 GAL STORAGE	6	12	16,716	435	32	265	772
84120AB	DEEP WELL WATER SUPPLY UNIT, LARGE, W/200 GAL PER MIN PUMP & 500 BARREL STORAGE	21	47	24,204	557	148	253	958
84120AC	WATER TANK AND TOWER, 4200 GAL WITH ACCESSORIES	9	22	7,950		121	5	126
84120AD	WATER TANK AND TOWER, 10500 GAL WITH ACCESSORIES	8	18	7,415		276		276
84120AE	WATER TANK AND TOWER, 21000 GAL WITH ACCESSORIES	19	26	9,012		483		483
84210EH	WATER DISTRIBUTION MAIN, ONE MILE OF 2 IN PIPE W/FITTINGS	10	5	7,601	805	306	230	1,341
84210EJ	WATER DISTRIBUTION MAIN, ONE MILE OF 4 IN PIPE W/FITTINGS	30	19	18,592	753	874	230	1,857
84210EK	WATER DISTRIBUTION MAIN, ONE MILE OF 6 IN PIPE W/FITTINGS	53	52	50,733	817	1,127	230	2,174
84210EL	WATER SUPPLY PIPELINE, SMALL, W/100 GAL PER MIN GED PUMP, ONE MILE OF 4 IN PIPE & FITTINGS	11	20	9,690	759	920	265	1,944
84210EM	WATER SUPPLY PIPELINE, MEDIUM, W/200 GAL PER MIN GED PUMP, ONE MILE OF 6 IN PIPE & FITTINGS	26	43	27,602	822	1,242	288	2,352
84210EN	WATER SUPPLY PIPELINE, LARGE, W/480 GAL PER MIN GED PUMP, ONE MILE OF 8 IN PIPE & FITTINGS	33	79	38,895	863	1,622	374	2,859
84210EP	WATER SUPPLY EQUIPMENT PORTABLE 45,000 GPD, ONE DIVISION, SLICE COMBAT ZONE	15	109	71,684			5	5
84210GA	PORT. WATER SYST-GEN CARGO PORT/ONSHORE DWG FP1105-1115, SHT3	12	245	1,548,649		3,802	3,802	7,604
84210HA	WATER DISTRIBUTION SYSTEM FOR 125 MAN TROOP CAMP, TEMPORARY STANDARD ALL CLIMATES, 50 GPCD	2	3	2,640	115	230	230	575
84210HB	WATER DISTRIBUTION SYSTEM FOR 250 MAN TROOP CAMP, ALL CLIMATES/TEMPORARY STANDARD, 50 GPCD	2	3	2,972	230	575	403	1,208

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS HOR VERT GENL	TOT		
84210HC	WATER DISTRIBUTION SYSTEM FOR 375 MAN TROOP CAMP, TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	3	1,948	288	690	532	1,530	
84210HD	WATER DISTRIBUTION SYSTEM FOR 500 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	1	550	32	115	115	262	
84210HE	WATER DISTRIBUTION SYSTEM FOR 500 MAN TROOP CAMP CORRIDORS TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	3	1,164	28	104	104	236	
84210HF	WATER SYSTEM FOR 1000 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	3	1,142	37	127	127	291	
84210HG	WATER DISTRIBUTION SYSTEM FOR 1000 MAN TROOP CAMP CORRIDORS TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	1	9	1,837	35	115	115	265
84210HH	WATER SYSTEM FOR PARKING " MAINTENANCE MOTOR POOL TEMPORARY STANDARD, ALL CLIMATES			186	147	322	248	717
84210HJ	WATER SYSTEM FOR 3000 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	2	6	1,063	46	184	184	414
84210HK	WATER DISTRIBUTION SYSTEM FOR 3000 MAN TROOP CAMP CORRIDORS TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	1	21	3,191	44	161	161	366
84210HL	WATER SYSTEM FOR 3000 MAN TROOP CAMP HEADQUARTERS, TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	2	2	884	51	207	207	465
84210HM	WATER DISTRIBUTION SYSTEM FOR 5000 MAN TROOP CAMP CORRIDORS TEMPORARY STANDARD, ALL CLIMATES, 50 GPCD	2	29	6,685	48	173	184	605
84210KA	WATER SYSTEM FOR MEDICAL SUPPLY, OPTICAL AND MAINTENANCE UNITS, ALL CLIMATES	1	3	3,799	71	338	71	480
84290AA	TANKER WATERING SERVICE FACILITIES, WITH 42000 GALLON WATER STORAGE TANK, 245 GPM CENTRIFUGAL PUMP AND 3 PHASE POWER-200 AMP RECEPTACLE FOR POL DOCKS AND JETTIES.	8	28	18,849	920	150	1,070	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST. EFFORT IN MAN-HOURS		
		HOR	VERT	GENL	TOT		
84330AA	FIRE FIGHTING EQUIPMENT, SET NUMBER 18		42	38,953		39	39
84330AB	SUMP FOR FIRE PROTECTION, 2000 GAL	2	2	48	5	25	28
84330AC	SUMP FOR FIRE PROTECTION, 10000 GAL	7	5	145	18	124	133
84330AD	FIREFIGHTING SYSTEM EQUIPMENT, FOAM FOR POL, COMPLETE W/3000 GAL WATER STORAGE PUMP&DISPENSING EQUIPMENT.	1	5	17,434		37	37
84330AE	FIREFIGHTING SYSTEM EQUIPMENT, FOAM, FOR POL, COMPLETE W/10000 GAL WATER STORAGE,PUMP&DISPENSING EQUIPMENT	1	5	16,777		39	39
84330AF	FIRE WATER SYST-GEN&CARGO PORT,ONSHORE DWG FP1105-1115,SHT3	206	222	570,022	2,001	3,843	2,001
84330AG	FIRE WATER SYSTEM-LIGHTERAAGE PIER DWG FP1105-1115,SHT3	7	22	11,820	138	227	186
84330AH	FIRE WATER SYSTEM-BREAKBULK/RO-RO PIER DWG FP1105-1115,SHT3	53	185	242,806	559	1,601	1,093
84330AJ	FIRE WATER SYST-SERV&PORT VESSEL PIERS DWG FP1105-1115,SHT3	12	35	22,625	184	458	423
84330AK	FIRE WATER SYSTEM-CONTAINER PIER DWG FP1105-1115,SHT3	38	320	144,298	462	1,369	995
84330AL	FIRE WATER SYST-AMMUNUNIT,PORT,ONSHORE DWG FP1105-1115,SHT4	519	661	3,930,813	2,529	4,830	2,529
84520AA	SEAWATER SYSTEM-GEN CARGO PORT,ONSHORE DWG FP1105-1115,SHT3	1	6	36,484		313	313
84520AB	SEAWATER SYSTEM-BREAKBULK/RO-RO PIER DWG FP1105-1115,SHT3	1	6	6,786	48	269	216
85110AA	ROAD PAVEMENT,TWO 12-FT LANES,CLASS A,ONE MILE,1-1/2-IN. SINGLE BITUMINOUS SURFACE TREATMENT ON PRIMED 4-IN. STABILIZED BASE,COMBAT BN AND SUP CO CONSTR	743	558	7,838	271	48	319
85110AB	ROAD PAVEMENT,TWO 12-FT LANES,CLASS A,ONE MILE,1-IN. MULTIPLE BITUMINOUS SURFACE TREATMENT ON PRIMED 4-IN. STABILIZED BASE,COMBAT BN AND SUP CO CONSTR	776	597	9,088	336	39	395
85110AC	ROAD PAVEMENT,TWO 12-FT LANES,CLASS A,ONE MILE,1-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE,COMBAT BN AND SUP CO CONSTR	945	753	12,618	389	138	527

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	IN HRS	GENL TOT
85110AD	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,104	883	14,851	653	179	632
85110AE	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 2-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,234	993	16,940	301	210	711
85110AF	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,290	1,064	19,548	584	242	826
85110AG	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 3-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,323	1,097	20,433	649	283	932
85110AH	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 4-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,373	1,151	21,940	697	314	1,011
85110AJ	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 4-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,636	1,375	26,479	780	345	1,125
85110AK	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 5-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,668	1,407	27,364	844	386	1,230
85110AL	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 1-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	943	752	12,680	377	138	515
85110AM	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,101	881	14,935	442	179	621
85110AN	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 2-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,231	991	17,044	490	210	700

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT
85110AP	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 3-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,286	1,061	19,673	561	242	803
85110AR	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 4-IN. STABILIZED SURFACE, COMBAT BN CONSTR	785	530	3,925	242	83	325
85110AT	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 6-IN. STABILIZED SURFACE, COMBAT BN CONSTR	1,189	803	5,945	315	87	402
85110AU	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 8-IN. STABILIZED SURFACE, COMBAT BN CONSTR	1,570	1,060	7,850	426	92	518
85110AV	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 1/2-IN. SINGLE BITUMINOUS SURFACE TREATMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	641	480	6,659	235	61	276
85110AW	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 1-IN. MULTIPLE BITUMINOUS SURFACE TREATMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	668	512	7,695	296	52	348
85110AY	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 1-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN ABD SUP CO CONSTR	824	655	10,888	347	124	471
85110BA	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	963	769	12,846	396	155	551
85110BB	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 2-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,077	865	14,668	421	186	607
85110BC	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,126	927	16,926	523	217	740

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
		HOR	VERT	GENL	TOY		
85110BD	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 3-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,154	956	17,697	372	268	820
85110BE	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 4-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,199	1,003	19,016	619	279	898
85110BF	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 4-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,428	1,198	22,963	682	300	982
85110BG	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 5-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,436	1,227	23,735	745	342	1,087
85110BH	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 1-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	822	654	10,943	338	124	462
85110BJ	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	961	767	12,920	386	135	541
85110BK	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 2-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,074	863	14,759	412	166	598
85110BL	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 3-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	1,123	924	17,035	514	217	731
85110BM	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 4-IN. STABILIZED SURFACE, COMBAT BN CONSTR	687	464	3,435	217	74	291
85110BN	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 6-IN. STABILIZED SURFACE, COMBAT BN CONSTR	1,040	702	5,200	277	78	355

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						CONST EFFORT IN MAN-HOURS		
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	HOR	VERT	GENL	TOT		
85110BP	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 8-IN. STABILIZED SURFACE, COMBAT BN CONSTR	1,374	927	6,870	378		83	461		
85110BR	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 1/2-IN. SINGLE BITUMINOUS SURFACE TREATMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	407	299	3,775	155		28	183		
85110BT	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 1-IN. MULTIPLE BITUMINOUS SURFACE TREATMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	399	300	4,186	194		35	229		
85110BU	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 1-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	522	411	6,551	229		83	312		
85110BV	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	612	484	7,808	262		104	366		
85110BW	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 2-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	685	546	8,980	293		124	417		
85110BY	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	715	583	10,319	331		135	466		
85110CA	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 3-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	732	601	10,812	377		166	543		
85110CB	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 4-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	761	631	11,659	396		176	572		
85110CC	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 4-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	907	754	14,086	445		197	642		

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT	VOL	COST	CONST EFFORT IN MAN-HOURS		
		SHT TONS	MEAS TONS		HOR	VERT	GENL
85110CD	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	925	773	14,380	477	217	694
85110CE	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 3-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	521	410	6,387	222	83	308
85110CF	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	611	483	7,835	255	104	359
85110CG	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 2-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	683	544	9,039	286	124	410
85110CH	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 3-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	712	581	10,389	317	135	452
85110CJ	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 4-IN. STABILIZED SURFACE, COMBAT BN CONSTR	442	298	2,210	161	66	187
85110CK	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 6-IN. STABILIZED SURFACE, COMBAT BN CONSTR	669	452	3,345	175	51	226
85110CL	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 8-IN. STABILIZED SURFACE, COMBAT BN CONSTR	883	596	6,475	236	51	287
85110CM	HARDSTAND, 1000 SQ YD, 1/2-IN. SINGLE BITUMINOUS SURFACE TREATMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	45	35	543	38	7	65
85110CN	HARDSTAND, APRON, TAXIWAY OR RUNWAY PAVEMENT 1000 SQ.YDS. 1IN. MULTIPLE BITUMINOUS SURFACE TREATMENT ON PRIMED 4IN. STABIL- IZED BASE.	51	38	498	48	23	71

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
85110CP	HARDSTAND, 1000 SQ YD, 1-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	52	43	776	41		14	55
85110CR	HARDSTAND, 1000 SQ YD, 2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	61	30	891	59		24	83
85110CT	HARDSTAND, 1000 SQ YD, 2-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	68	55	997	59		24	83
85110CU	HARDSTAND, 1000 SQ YD, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	72	60	1,180	61		24	85
85110CV	HARDSTAND, 1000 SQ YD, 3-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	74	62	1,220	76		35	111
85110CW	HARDSTAND, 1000 SQ YD, 4-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	76	65	1,305	77		35	112
85110CY	HARDSTAND, 1000 SQ YD, 4-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	91	78	1,585	82		35	117
85110DA	HARDSTAND, 1000 SQ YD, 5-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	93	80	1,624	98		45	143
85110DB	HARDSTAND, 1000 SQ YD, 1-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	52	43	779	60		14	54
85110DC	HARDSTAND, 1000 SQ YD, 2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE, COMBAT BN AND SUP CO CONSTR	61	50	896	56		24	80

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL MEAS	COST \$	CONST EFFORT IN MAN-HOURS		
		TONS	TONS	HOR	VERT	GENL	TOT
85110DD	HARDSTAND,1000 SQ YD,2-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE,COMBAT BN AND SUP CO CONSTR	68	35	1,003	56	24	80
85110DE	HARDSTAND,1000 SQ YD,3-IN. COLD-MIX BITUMINOUS PAVEMENT ON PRIMED 4-IN. STABILIZED BASE,COMBAT BN AND SUP CO CONSTR	72	60	1,187	39	24	83
85110DF	HARDSTAND,1000 SQ YD,4-IN. STABILIZED SURFACE,COMBAT BN CONSTR	42	28	210	28	9	37
85110DG	HARDSTAND,APRON,TAXIWAY OR RUNWAY PAVEMENT 1000 SQ YDS. STABILIZED SURFACE.	100	68	500	31	12	43
85110DH	HARDSTAND,1000 SQ YD,8-IN. STABILIZED SURFACE,COMBAT BN CONSTR	84	57	420	46	9	55
85110DJ	ROAD PAVEMENT,TWO 12-FT LANES,CLASS A,ONE MILE,1/2-IN. SINGLE BITUMINOUS SURFACE TREATMENT ON MEMBRANE-ENVELOPED SOIL LAYER,COMBAT BN AND SUP CO CONSTR	225	221	8,457	504	403	907
85110DK	ROAD PAVEMENT,TWO 12-FT LANES,CLASS A,ONE MILE,1-IN. MULTIPLE BITUMINOUS SURFACE TREATMENT ON MEMBRANE-ENVELOPED SOIL LAYER,COMBAT BN AND SUP CO CONSTR	259	260	10,052	568	413	981
85110DL	ROAD PAVEMENT,TWO 12-FT LANES,CLASS A,ONE MILE,1-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER,COMBAT BN AND SUP CO CONSTR	428	416	13,063	614	492	1,106
85110DM	ROAD PAVEMENT,TWO 12-FT LANES,CLASS A,ONE MILE,2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER,COMBAT BN AND SUP CO CONSTR	587	546	15,296	679	534	1,213
85110DN	ROAD PAVEMENT,TWO 12-FT LANES,CLASS A,ONE MILE,2-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER,COMBAT BN AND SUP CO CONSTR	717	656	17,385	727	565	1,292

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
		HOR	VERT	GENL	TOT		
85110DP	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	773	727	19,993	810	596	1,406
85110DR	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 3-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	805	760	20,878	874	637	1,511
85110DT	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 4-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	856	813	22,385	922	668	1,590
85110DU	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 4-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANCE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	1,104	1,017	23,964	1,005	699	1,704
85110DV	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 5-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	1,136	1,030	26,849	1,070	741	1,811
85110DW	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 1-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	426	413	13,125	603	492	1,095
85110DY	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	584	566	15,379	667	535	1,201
85110EA	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 2-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	713	653	17,489	715	565	1,280
85110EB	ROAD PAVEMENT, TWO 12-FT LANES, CLASS A, ONE MILE, 3-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	769	724	20,118	783	596	1,379
85110EC	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 1/2-IN. SINGLE BITUMINOUS SURFACE TREATMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	200	202	8,217	488	399	887

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL	TOT
85110ED	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 1-IN. MULTIPLE BITUMINOUS SURFACE TREATMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	226	234	9,342	537		409	946
85110EE	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 1-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	383	377	12,300	393		482	1,075
85110EF	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	522	491	16,258	642		513	1,155
85110EG	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 2-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	636	587	16,079	690		544	1,234
85110EH	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	689	635	18,637	771		575	1,346
85110EJ	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 3-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	717	684	19,409	819		606	1,425
85110EK	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 4-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	762	731	20,728	867		637	1,504
85110EL	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 4-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	987	920	24,375	929		658	1,587
85110EM	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 5-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	1,015	949	25,146	992		699	1,691
85110EN	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 1-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	381	376	12,354	584		482	1,066

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	
					HOR	VERT	GENL TOT
85110EP	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	519	489	14,331	633		513 1,146
85110ER	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 2-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	633	585	16,170	681		564 1,225
85110ET	ROAD PAVEMENT, TWO 10-FT LANES, CLASS B, ONE MILE, 3-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	693	663	19,257	750		375 1,325
85110EU	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 1-1/2-IN. SINGLE BITUMINOUS SURFACE TREATMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	132	135	5,989	328		274 602
85110EV	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 1-IN. MULTIPLE BITUMINOUS SURFACE TREATMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	124	136	6,544	367		281 648
85110EW	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 1-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	247	246	8,691	399		329 728
85110EY	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	337	320	9,948	631		350 781
85110FA	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 2-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	410	381	11,120	663		370 833
85110FB	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	439	418	12,459	501		381 882
85110FC	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 3-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	457	437	12,952	569		412 961

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT
85110FD	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 4-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	486	467	13,799	566	422	988
85110FE	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 4-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	631	590	16,226	613	443	1,058
85110FF	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 5-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	649	608	16,720	667	463	1,110
85110FG	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 1-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	246	246	8,726	392	329	721
85110FH	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	336	319	9,995	426	350	774
85110FJ	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 2-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	408	380	11,179	457	370	827
85110FK	ROAD PAVEMENT, ONE 10-FT LANE, CLASS C, ONE MILE, 3-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	437	417	12,529	488	381	869
85110FL	HARDSTAND, 1000 SQ YD, 1/2-IN. SINGLE-BITUMINOUS SURFACE TREATMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	16	16	586	38	43	101
85110FM	HARDSTAND, 1000 SQ YD, 1-IN. MULTIPLE-BITUMINOUS SURFACE TREATMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	19	19	711	58	43	101
85110FN	HARDSTAND, 1000 SQ YD, 1-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	24	24	806	61	49	110

DHDXR1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL TOT
85110FP	HARDSTAND, 1000 SQ YD, 2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	32	31	921	77		60 137
85110FR	HARDSTAND, 1000 SQ YD, 2-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	39	36	1,027	77		60 137
85110FT	HARDSTAND, 1000 SQ YD, 3-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	43	41	1,210	79		60 139
85110FU	HARDSTAND, 1000 SQ YD, 3-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	45	43	1,250	96		70 164
85110FV	HARDSTAND, 1000 SQ YD, 4-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	47	46	1,335	95		70 165
85110FW	HARDSTAND, 1000 SQ YD, 4-1/2-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR.	62	59	1,615	100		70 170
85110FY	HARDSTAND, 1000 SQ YD, 5-IN. HOT-MIX BITUMINOUS CONCRETE PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	64	61	1,654	116		81 197
85110GA	HARDSTAND, 1000 SQ YD, 1-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	23	24	809	38		49 107
85110GB	HARDSTAND, 1000 SQ YD, 2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	32	30	926	75		60 135
85110GC	HARDSTAND, 1000 SQ YD, 2-1/2-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	39	36	1,032	75		60 135

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HRS	EFFORT VERT	IN MAN-HOURS GENL	TOT
85110GD	HARDSTAND, 1000 SQ YD, 3-IN. COLD-MIX BITUMINOUS PAVEMENT ON MEMBRANE-ENVELOPED SOIL LAYER, COMBAT BN AND SUP CO CONSTR	43	41	1,217	77		60	137
85111AA	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 2-IN. HOT-MIX BITUM CONC ON 4-IN. STABILIZED BASE	704	559	9,144	314		128	442
85111AB	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 3-IN. HOT-MIX BITUM CONC ON 4-IN. STABILIZED BASE	826	677	12,146	386		159	545
85111AC	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 2-IN. HOT-MIX BITUM CONC ON 6-IN. STABILIZED BASE	882	686	10,479	381		138	519
85111AD	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 3-IN. HOT-MIX BITUM CONC ON 6-IN. STABILIZED BASE	1,005	804	13,481	453		169	622
85111AL	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 2-IN. HOT-MIX BITUM CONC ON 4-IN. STABILIZED BASE	95	77	1,359	46		20	66
85111AM	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 3-IN. HOT-MIX BITUM CONC ON 4-IN. STABILIZED BASE	115	97	1,860	58		25	83
85111AN	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 2-IN. HOT-MIX BITUM CONC ON 6-IN. STABILIZED BASE	113	90	1,493	53		21	74
85111AP	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 3-IN. HOT-MIX BITUM CONC ON 6-IN. STABILIZED BASE	133	110	1,993	66		26	92
85111BB	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 8-IN. PORTLAND CEMENT CONCRETE	924	594	61,330	595		1,150	1,769
85111BC	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 10-IN. PORTLAND CEMENT CONCRETE	1,150	745	47,698	677		1,231	1,908
85111BD	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 12-IN. PORTLAND CEMENT CONCRETE	635	416	15,203	760		1,325	2,085

DHDXR1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
85111BE	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 16-IN. PORTLAND CEMENT CONCRETE	1,847	1,188	59,728	999		1,739	2,738
85111BF	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 20-IN. PORTLAND CEMENT CONCRETE	1,028	678	17,858	1,165		1,932	3,097
85111BG	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 24-IN. PORTLAND CEMENT CONCRETE	2,728	1,774	83,536	1,331		2,125	3,456
85111BL	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 6-IN. PORTLAND CEMENT CONCRETE	115	74	4,764	170		408	578
85111BM	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 8-IN. PORTLAND CEMENT CONCRETE	154	100	6,964	184		419	603
85111BN	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 10-IN. PORTLAND CEMENT CONCRETE	192	124	7,960	198		432	630
85111BP	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 12-IN. PORTLAND CEMENT CONCRETE	232	149	7,866	212		447	659
85111BR	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 16-IN. PORTLAND CEMENT CONCRETE	309	199	9,964	274		583	857
85111BY	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 20-IN. PORTLAND CEMENT CONCRETE	388	248	19,270	301		615	916
85111BU	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, 24-IN. PORTLAND CEMENT CONCRETE	465	297	23,075	329		647	976
85111CA	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 4-IN. STABILIZED AGGREGATE	531	358	2,633	166		55	221
85111CB	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 6-IN. STABILIZED AGGREGATE	803	542	4,015	213		60	273
85111CC	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG, 8-IN. STABILIZED AGGREGATE	1,060	716	5,300	279		66	343

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL TOT
85111CL	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH/4-IN. STABILIZED AGGREGATE	50	34	250	17		6 23
85111CM	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH/6-IN. STABILIZED AGGREGATE	75	51	375	22		7 29
85111CN	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH/8-IN. STABILIZED AGGREGATE	99	67	495	29		7 36
85111DA	ROADWAY PAVEMENT, HEAVY WHEEL LOAD BASIC, 12-FT WIDE BY 1 MILE LONG/M8A1 LANDING MAT SURFACED	388	212	287,294	137	438	575
85111DL	ROADWAY PAVEMENT, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH/M8A1 LANDING MAT SURFACED	142	78	100,068	30	94	124
85111EA	ROADWAY, HEAVY WHEEL LOAD BASIC, 12-FT WIDE WITH 4-FT SHOULDERS/1 MILE, SUBBASE THICKNESS- 6-IN., FILL- 2567 CY	3	3	1,434	363	83	446
85111EB	ROADWAY, HEAVY WHEEL LOAD BASIC, 12-FT WIDE WITH 4-FT SHOULDERS/1 MILE, SUBBASE THICKNESS- 12-IN., FILL- 5378 CY	3	3	1,564	697	164	641
85111EC	ROADWAY, HEAVY WHEEL LOAD BASIC, 12-FT WIDE WITH 4-FT SHOULDERS/1 MILE, SUBBASE THICKNESS- 18-IN., FILL- 8434 CY	3	3	1,655	664	207	871
85111ED	ROADWAY, HEAVY WHEEL LOAD BASIC, 12-FT WIDE WITH 4-FT SHOULDERS/1 MILE, SUBBASE THICKNESS- 24-IN., FILL- 11734 CY	4	3	1,765	799	278	1,077
85111EE	ROADWAY, HEAVY WHEEL LOAD BASIC, 12-FT WIDE WITH 4-FT SHOULDERS/1 MILE, SUBBASE THICKNESS- 30-IN., FILL- 15278 CY	4	3	1,875	935	343	1,278
85111EF	ROADWAY, HEAVY WHEEL LOAD BASIC, 12-FT WIDE WITH 4-FT SHOULDERS/1 MILE, SUBBASE THICKNESS- 36-IN., FILL- 19067 CY	4	4	1,986	1,105	422	1,527
85111EL	ROADWAY, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, SUBBASE THICKNESS- 6-IN., FILL- 245 CY			110	67	8	55
85111EM	ROADWAY, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, SUBBASE THICKNESS- 12-IN., FILL- 490 CY			110	39	13	72

DHDXR1

RUN DATE 860128

<u>DESERT CLIMATE</u>		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL	TOT
85111EN	ROADWAY, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, SUBBASE THICKNESS- 18-IN., FILL- 734 CY			110	71		17	88
85111EP	ROADWAY, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, SUBBASE THICKNESS- 24-IN., FILL- 978 CY			110	77		23	100
85111ER	ROADWAY, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, SUBBASE THICKNESS- 30-IN., FILL- 1225 CY			110	93		26	119
85111ET	ROADWAY, HEAVY WHEEL LOAD, 2-FT INCREMENT OF ROADWAY WIDTH, SUBBASE THICKNESS- 36-IN., FILL- 1467 CY			110	105		32	137
85111FA	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 2-IN. HOT-MIX BITUM CONC ON 4-IN. STABILIZED BASE	61	50	891	59		26	85
85111FB	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 3-IN. HOT-MIX BITUM CONC ON 4-IN. STABILIZED BASE	72	60	1,180	61		24	85
85111FC	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 2-IN. HOT-MIX BITUM CONC ON 6-IN. STABILIZED BASE	77	61	1,043	75		28	103
85111FD	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 3-IN. HOT-MIX BITUM CONC ON 6-IN. STABILIZED BASE	87	72	1,332	77		28	105
85111GA	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 6-IN. PORTLAND CEMENT CONCRETE	99	64	4,249	66		123	189
85111GB	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 8-IN. PORTLAND CEMENT CONCRETE	130	84	5,108	77		131	208
85111GC	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 10-IN. PORTLAND CEMENT CONCRETE	163	106	6,020	91		164	235
85111GD	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 12-IN. PORTLAND CEMENT CONCRETE	196	127	6,319	101		156	257
85111GE	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 16-IN. PORTLAND CEMENT CONCRETE	260	168	7,974	131		217	348

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					HOR	VERT	GENL	TOT
85111GF	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 20-IN. PORTLAND CEMENT CONCRETE	325	210	9,695	155		232	387
85111GB	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 24-IN. PORTLAND CEMENT CONCRETE	390	232	11,564	177		259	436
85111HA	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 4-IN. STABILIZED AGGREGATE	42	28	210	28		9	37
85111HB	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 6-IN. STABILIZED AGGREGATE	63	43	315	41		9	50
85111HC	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, 8-IN. STABILIZED AGGREGATE	84	37	620	46		9	35
85111JA	HARDSTAND PAVEMENT, HEAVY WHEEL LOAD, 1000 SY, MBA1 LANDING MAT SURFACED	40	30	32,258	30		94	124
85111KA	HARDSTAND, HEAVY WHEEL LOAD, 1000 SY X4-FT SHOULDERS INCLUDED, SUBBASE THICKNESS-6-IN., FILL-250 CY	2	1	722	44		8	52
85111KB	HARDSTAND, HEAVY WHEEL LOAD, 1000 SY X4-FT SHOULDERS INCLUDED, SUBBASE THICKNESS-12-IN., FILL-510 CY	2	2	735	66		13	79
85111KC	HARDSTAND, HEAVY WHEEL LOAD, 1000 SY X4-FT SHOULDERS INCLUDED, SUBBASE THICKNESS-18-IN., FILL-779 CY	2	2	748	84		17	101
85111KD	HARDSTAND, HEAVY WHEEL LOAD, 1000 SY X4-FT SHOULDERS INCLUDED, SUBBASE THICKNESS-24-IN., FILL-1058 CY	2	2	760	116		25	141
85111KE	HARDSTAND, HEAVY WHEEL LOAD, 1000 SY X4-FT SHOULDERS INCLUDED, SUBBASE THICKNESS-30-IN., FILL-1347 CY	2	2	773	138		30	168
85111KF	HARDSTAND, HEAVY WHEEL LOAD, 1000 SY X4-FT SHOULDERS INCLUDED, SUBBASE THICKNESS-36-IN., FILL-1646 CY	2	2	786	156		35	191
85120AA	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 20 FT SPAN SQUARE ENDS DOUBLE LANE, CLASS 60	25	28	10,142	25	161	44	210

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT	IN MAN-HOURS	
		HOR	VERT	GENL	TOT			
85120AB	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 30 FT SPAN SQUARE ENDS, DOUBLE LANE, CLASS 60	39	39	16,988	43	219	64	326
85120AC	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, TIMBER FRAME ABUTMENT, 30 FT STEEL SPAN, CLASS 60	62	74	27,671	60	302	85	447
85120AD	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 30 FT SPAN SQUARE ENDS, DOUBLE LANE, CLASS 60	121	121	66,277	133	513	106	754
85120AE	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 60 FT SPAN SQUARE ENDS, DOUBLE LANE CLASS 60	101	107	48,129	146	603	129	878
85120AG	ROAD BRIDGE SUPERSTRUCTURE, STEEL STRINGERS, 20 FT SPAN 30 DEG SKEW ENDS, DOUBLE LANE, CLASS 60	24	32	9,731	28	150	46	224
85120AH	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 30 FT SPAN 30 DEG SKEW ENDS, DOUBLE LANE, CLASS 60	38	52	16,543	45	227	67	339
85120AJ	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 40 FT SPAN 30 DEG SKEW ENDS, DOUBLE LANE, CLASS 60	55	72	23,426	62	311	87	460
85120AK	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 50 FT SPAN 30 DEG SKEW ENDS, DOUBLE LANE, CLASS 60	85	91	42,751	137	523	108	768
85120AL	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 60 FT SPAN 30 DEG SKEW ENDS, DOUBLE LANE, CLASS 60	100	107	50,267	168	615	131	892
85120AM	ROAD BRIDGE SUPERSTRUCTURE, TIMBER STRINGERS 18 FT SPAN 30 DEG SKEW DOUBLE LANE CLASS 60	24	35	4,525	5	160	74	239
85120AN	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 20 FT SPAN SQUARE ENDS SINGLE LANE CLASS 60	15	17	5,865	23	136	41	202
85120AP	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 30 FT SPAN SQUARE ENDS SINGLE LANE CLASS 60	23	24	9,781	25	136	41	202
85120AR	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 40 FT SPAN SQUARE ENDS SINGLE LANE CLASS 60	32	38	16,362	36	183	53	272

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL	MAN-HOURS TOT
85120AT	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 30 FT SPAN SQUARE ENDS SINGLE LANE CLASS 60	50	41	22,093	55	262	64	381
85120AU	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 60 FT SPAN SQUARE ENDS SINGLE LANE CLASS 60	39	51	25,774	81	367	78	506
85120AV	ROAD BRIDGE SUPERSTRUCTURE TIMBER STRINGERS 18 FT SPAN SQ ENDS SINGLE LANE CLASS 60	13	19	2,400	2	72	32	106
85120AW	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 20 FT SPAN 30 DEG SKEW ENDS, SINGLE LANE, CLASS 60	17	20	5,805	17	95	30	142
85120AY	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 30 FT SPAN 30 DEG SKEW ENDS, SINGLE LANE, CLASS 60	23	27	8,342	28	146	64	218
85120BA	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 40 FT SPAN 30 DEG SKEW ENDS, SINGLE LANE, CLASS 60	24	24	12,419	38	193	55	286
85120BB	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 50 FT SPAN 30 DEG SKEW ENDS, SINGLE LANE, CLASS 60	49	51	27,645	58	273	67	398
85120BC	ROAD BRIDGE SUPERSTRUCTURE STEEL STRINGERS 60 FT SPAN 30 DEG SKEW ENDS, SINGLE LANE, CLASS 60	59	66	30,110	83	358	81	522
85120BD	ROAD BRIDGE SUPERSTRUCTURE TIMBER STRINGERS 18 FT SPAN 30 DEG SKEW SINGLE LANE CLASS 60	14	21	2,672	2	104	46	192
85120BE	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 20 FT SPAN SQUARE ENDS DOUBLE LANE, CLASS 60	18	25	25,116	28	135	41	204
85120BF	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 30 FT SPAN SQUARE ENDS DOUBLE LANE, CLASS 60	26	39	39,046	49	215	60	324
85120BG	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 40 FT SPAN SQUARE ENDS DOUBLE LANE, CLASS 60	46	55	55,328	60	273	78	411

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT
85120BH	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 50 FT SPAN SQUARE ENDS DOUBLE LANE, CLASS 60	65	78	75,283	75	329	92 496
85120BJ	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 60 FT SPAN SQUARE ENDS DOUBLE LANE, CLASS 60	89	106	101,343	87	386	110 583
85120BK	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 20 FT SPAN 30 SKEW ENDS DOUBLE LANE, CLASS 60	25	30	25,215	38	145	37 220
85120BL	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 30 FT SPAN 30 SKEW ENDS DOUBLE LANE, CLASS 60	40	45	39,560	39	223	55 339
85120BM	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 40 FT SPAN 30 SKEW ENDS DOUBLE LANE, CLASS 60	56	63	55,341	70	281	74 425
85120BN	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 50 FT SPAN 30 SKEW ENDS DOUBLE LANE, CLASS 60	77	87	74,912	84	328	87 499
85120BP	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 60 FT SPAN 30 SKEW ENDS DOUBLE LANE, CLASS 60	101	116	93,536	104	394	106 604
85120BR	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 20 FT SPAN SQUARE ENDS SINGLE LANE, CLASS 60	11	16	13,045	17	79	23 119
85120BT	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 30 FT SPAN SQUARE ENDS SINGLE LANE, CLASS 60	16	25	20,968	28	124	37 189
85120BU	ROAD BRIDGE SUPERSTRUCTURE GLUE LAMINATED TIMBER GIRDERS 40 FT SPAN SQUARE ENDS SINGLE LANE, CLASS 60	27	35	28,948	35	162	51 248

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

SHT TONS	WT TONS	VOL TONS	MEAS	COST \$	CONSTRUCTION MATERIAL			
					HOR	VERT	GENL	TOT
38	48	39,661			63	199	60	302
51	63	53,869			52	251	74	377
16	19	14,345			23	92	28	143
26	28	20,998			35	136	37	208
36	39	31,890			61	171	51	263
50	53	43,269			69	206	60	313
65	69	55,011			59	246	74	379
10	10	4,042			46	96	127	263
9	13	4,677			35	160	133	328
12	13	4,055			53	120	138	313

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						CONST EFFORT IN MAN-HOURS			
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	GENL	TOT			
85120CH	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, TIMBER FRAME ABUTMENT, 30 FT STEEL SPAN, CLASS 60	11	15	4,609	37	166	138	341			
85120CJ	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, TIMBER PILE ABUTMENT, 60 FT STEEL SPAN, CLASS 60	15	16	3,936	55	120	138	313			
85120CK	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 18 FT TIMBER SPAN, CLASS 60	43	31	2,569	53	251	130	456			
85120CL	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT, 18 FT TIMBER SPAN, CLASS 60	45	32	2,376	40	252	132	424			
85120CM	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 30 FT STEEL SPAN, CLASS 60	42	31	2,735	51	244	138	433			
85120CN	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT, 30 FT STEEL SPAN, CLASS 60	43	30	2,403	39	250	164	433			
85120CP	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 60 FT STEEL SPAN, CLASS 60	45	34	3,034	53	254	138	445			
85120CR	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT, 60 FT STEEL SPAN, CLASS 60	48	33	2,510	40	253	161	454			
85120CT	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 18 FT TIMBER SPAN 30 DEG SKEW CLASS 60	48	35	2,912	58	269	150	477			
85120CU	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT, 18 FT TIMBER SPAN 30 DEG SKEW, CLASS 60	53	37	2,753	41	263	155	459			
85120CV	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 60 FT STEEL SPAN, 30 DEG SKEW CLASS 60	47	35	3,305	60	265	150	475			
85120CW	ROAD BRIDGE SUBSTRUCTURE, DOUBLE LANE, REINF CONC ABUTMENT, 60 FT STEEL SPAN, 30 DEG SKEW, CLASS 60	52	36	2,779	40	254	155	449			

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HRS	EFFORT IN MAN-HOURS	VERT	GENL	TOT
85120CY	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, TIMBER PILE ABUTMENT, 18 FT TIMBER SPAN CLASS 60	6	6	2,542	30	33	81	784	
85120DA	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, TIMBER FRAME ABUTMENT, 18 FT TIMBER SPAN, CLASS 60	5	8	2,814	18	90	74	182	
85120DB	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, TIMBER PILE ABUTMENT, 30 FT STEEL SPAN, CLASS 60	7	8	2,431	37	76	104	217	
85120DD	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, TIMBER PILE ABUTMENT, 60 FT STEEL SPAN, CLASS 60	9	10	2,626	41	87	115	243	
85120DE	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 18 FT TIMBER SPAN, CLASS 60	28	21	1,746	40	171	98	309	
85120DF	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE PIER 30 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMB SPANS CLASS 60	67	61	13,219	29	175	92	296	
85120DG	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE REINF CONC ABUTMENT ON TIMBER PILES, 30 FT STEEL SPAN, CLASS 60	26	20	1,783	40	167	98	305	
85120DH	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, REINF CONC ABUTMENT, 30 FT STEEL SPAN, CLASS 60	26	19	1,528	28	170	92	290	
85120DJ	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 60 FT STEEL SPAN, CLASS 60	28	21	1,937	40	167	98	305	
85120DK	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, REINF CONC ABUTMENT, 60 FT STEEL SPAN, CLASS 60	22	16	1,499	28	170	92	290	
85120DL	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 18 FT TIMBER SPAN 30 DEG SKEW CLASS 60	32	24	1,978	43	186	109	338	
85120DM	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, REINF CONC ABUTMENT, 18 FT TIMBER SPAN 30 DEG SKEW, CLASS 60	34	24	1,850	30	182	92	304	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	IN	MAN-HOURS
					HOR	VERT	GENL	TOT
85120DN	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, REINF CONC ABUTMENT ON TIMBER PILES, 60 FT STEEL SPAN, 30 DEG SKEW, CLASS 60	32	24	2,192	45	190	109	344
85120DP	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE, REINF CONC ABUTMENT, 60 FT STEEL SPAN, 30 DEG SKEW, CLASS 60	33	23	1,871	29	182	92	303
85120DR	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE BENT 10 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	8	8	2,408	30	61	98	189
85120DT	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE BENT 15 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	9	9	2,485	30	66	98	194
85120DU	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE BENT 20 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	11	11	2,790	32	76	104	212
85120DV	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE BENT 25 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	11	11	2,647	35	76	104	215
85120DW	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE BENT 30 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	12	12	6,365	35	76	104	215
85120DY	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE PIER 10 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMB SPANS CLASS 60	25	29	6,546	58	76	104	238
85120EA	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE PIER 15 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMB SPANS CLASS 60	28	32	6,879	58	81	104	243
85120EB	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE PIER 20 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMB SPANS CLASS 60	33	38	7,707	58	92	115	265

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
85120EC	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER PILE PIER 25 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMB SPANS CLASS 60
85120ED	ROAD BRIDGE SUPERSTRUCTURE TIMBER STRINGS 18 FT SPAN 80 ENDS DOUBLE LANE CLASS 60
85120EE	ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT ALL BOLTED CONSTR DOUBLE LANE 10 FT HIGH FOR 36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS CLASS 60
85120EF	ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT ALL BOLTED CONSTR DOUBLE LANE 15 FT HIGH FOR 36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS CLASS 60
85120EG	ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT ALL BOLTED CONSTR DOUBLE LANE 20 FT HIGH FOR 36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS CLASS 60
85120EH	ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT ALL BOLTED CONSTR DOUBLE LANE 25 FT HIGH FOR 36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS CLASS 60
85120EJ	ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT ALL BOLTED CONSTR DOUBLE LANE 30 FT HIGH FOR 36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS CLASS 60
85120EK	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER TRESTLE PIER 10 FT HIGH FOR 36 FT TIMBER OR 60 FT STEEL MAX COMB SPANS CLASS 60
85120EL	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER TRESTLE PIER 15 FT HIGH FOR 36 FT TIMBER OR 60 FT STEEL MAX COMB SPANS CLASS 60

CONSTRUCTION MATERIAL

WT TONS	VOL YONS	COST 3	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
35	39	7,697	38	116	121	295
23	34	4,290	3	130	60	195
7	6	5,090	30	86	40	154
7	8	5,646	31	89	40	160
8	7	6,141	31	91	52	174
9	8	6,873	33	97	58	188
10	9	7,614	35	97	58	190
9	13	5,486	32	129	113	276
10	15	5,650	32	133	113	280

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL	TOT
85120EM	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE BENT 10 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	4	4	1,152	18	28	46	92
85120EN	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE BENT 15 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	5	5	1,240	20	30	52	102
85120EP	ROAD BRIDGE SUBSTRUCTURE, SINGLE LANE TIMBER PILE BENT 20 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	7	7	1,444	22	35	58	115
85120ER	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE BENT 25 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL MAX COMBINED SPANS, CLASS 60	7	7	1,363	22	35	58	115
85120ET	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE BENT 30 FT HIGH FOR 36 FT TIMBER OR 50 FT STEEL, MAX COMBINED SPANS, CLASS 60	8	8	2,654	23	41	69	133
85120EU	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE PIER 10 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS CLASS 60	14	16	3,759	37	51	69	157
85120EV	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE PIER 15 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS CLASS 60	16	19	4,101	37	55	69	161
85120EW	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE PIER 20 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS CLASS 60	22	24	4,720	37	62	81	180
85120EY	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE PIER 25 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS CLASS 60	23	25	4,601	37	90	104	231
85120FA	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER PILE PIER 30 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS CLASS 60	26	29	7,981	37	101	115	255

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

85120FB ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT
ALL BOLTED CONSTR, SINGLE LANE 10 FT HIGH FOR
36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS
CLASS 60

85120FC ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT
ALL BOLTED CONSTR SINGLE LANE 15 FT HIGH FOR
36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS
CLASS 60

85120FD ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT
ALL BOLTED CONSTR SINGLE LANE 20 FT HIGH FOR
36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS
CLASS 60

85120FE ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT
ALL BOLTED CONSTR SINGLE LANE 25 FT HIGH FOR
36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS
CLASS 60

85120FF ROAD BRIDGE SUBSTRUCTURE STEEL PILE BENT
ALL BOLTED CONSTR SINGLE LANE 30 FT HIGH FOR
36 FT TIMBER OR 70 FT STEEL MAX COMB SPANS
CLASS 60

85120FG ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER
TRESTLE PIER 10 FT HIGH FOR 36 FT TIMBER OR 60 FT
STEEL MAX COMB SPANS CLASS 60

85120FH ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER
TRESTLE PIER 15 FT HIGH FOR 36 FT TIMBER OR 60 FT
STEEL MAX COMB SPANS CLASS 60

85120FJ ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER
TOWER 10 FT HIGH FOR 36 FT TIMBER OR 120 FT
STEEL MAX COMBINED SPANS, CLASS 60

CONSTRUCTION MATERIAL

SHT TONS	WT TONS	VOL TONS	MEAS	COST \$	CONST EFFORT IN MAN-HOURS		
					HHR	VERY	GENL
					24	60	35
	3	3		5,792	24	60	35
	6	5		4,163	24	60	35
	6	6		4,637	24	60	35
	7	6		5,225	29	74	40
	8	7		5,767	29	74	40
	5	7		2,237	22	74	69
	6	8		2,355	22	78	69
24	33			9,961	213	173	386

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	IN GENL	TOT
85120FK	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER TOWER 20 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	37	51	13,672	68	506	276	828
85120FL	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER TOWER 30 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	49	70	16,971	58	656	345	1,039
85120FM	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER TOWER 40 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	61	86	20,000	69	759	414	1,242
85120FN	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER TOWER 50 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	77	109	23,852	69	897	552	1,518
85120FP	ROAD BRIDGE SUBSTRUCTURE DOUBLE LANE TIMBER TOWER 60 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	89	128	27,145	81	1,047	644	1,772
85120FR	ROAD BRIDGE SUBSTRUCTURE STEEL TOWER DOUBLE LANE 20 FT HIGH FOR 120 FT STEEL MAX COMBINED SPANS CLASS 60	23	22	25,124	39	159	83	281
85120FT	ROAD BRIDGE SUBSTRUCTURE STEEL TOWER DOUBLE LANE 40 FT HIGH FOR 120 FT STEEL MAX COMBINED SPANS CLASS 60	32	30	40,155	53	261	124	460
85120FU	ROAD BRIDGE SUBSTRUCTURE STEEL TOWER DOUBLE LANE 60 FT HIGH FOR 120 FT STEEL MAX COMBINED SPANS CLASS 60	41	38	35,321	71	339	181	571
85120FV	ROAD BRIDGE SUBSTRUCTURE STEEL TOWER DOUBLE LANE 80 FT HIGH FOR 120 FT STEEL MAX COMBINED SPANS CLASS 60	51	46	70,745	91	476	193	700
85120FW	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER TOWER 10 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	13	19	5,480	132	104	236	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT	IN MAN-HOURS	
		SHT TONS	NEAS TONS		HOR	VERT	GENL	TOT
85120FY	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER TOWER 20 FT HIGH FOR 06 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	22	31	7,878	23	305	173	501
85120GA	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER TOWER 30 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	30	43	9,861	35	357	207	599
85120GB	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER TOWER 40 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	38	55	11,963	46	467	262	773
85120GC	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER TOWER 50 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	48	69	14,246	51	524	368	943
85120GD	ROAD BRIDGE SUBSTRUCTURE SINGLE LANE TIMBER TOWER 60 FT HIGH FOR 36 FT TIMBER OR 120 FT STEEL MAX COMBINED SPANS, CLASS 60	56	81	16,361	58	628	460	1,166
85120GE	ROAD BRIDGE SUBSTRUCTURE, 14 CONCRETE FOOTINGS 6FT6IN X 4FT10IN ON TIMBER PILES FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS, DOUBLE LANE	64	49	4,521	69	110	276	455
85120GF	ROAD BRIDGE SUBSTRUCTURE, 14 CONCRETE FOOTINGS 6FT6IN X 4FT10IN ON TWO STEEL PILES FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS, DOUBLE LANE	56	41	73,745	62	87	202	351
85120GG	ROAD BRIDGE SUBSTRUCTURE, 14 CONCRETE FOOTINGS 12FT X 4FT10IN,2500 PSF FOUNDATION SOIL CAPACITY FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS DOUBLE LANE	123	84	3,684	74	159	317	550
85120GH	ROAD BRIDGE SUBSTRUCTURE 14 CONCRETE FOOTINGS 6FT X 4FT 5000 PSF FOUNDATION SOIL CAPACITY FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS DOUBLE LANE	52	36	1,782	41	97	193	331

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
851206J	ROAD BRIDGE SUBSTRUCTURE, 6 CONCRETE FOOTINGS 11FT6IN X 11FT6IN 2500 PSF FOUNDATION SOIL CAPACITY FOR 20, 40, 60, 80 FT STEEL TOWERS, DOUBLE LANE
851206K	ROAD BRIDGE SUBSTRUCTURE, 6 CONCRETE FOOTINGS 8FT X 8 FT 5000 PSF FOUNDATION SOIL CAPACITY FOR 20, 40, 60, 80 FT STEEL TOWERS, DOUBLE LANE
851206L	ROAD BRIDGE SUBSTRUCTURE, 6 CONCRETE FOOTINGS 5FT X 5 FT ON STEEL PILES FOR 20,40,60,80 FT STEEL TOWERS, DOUBLE LANE
851206N	ROAD BRIDGE SUBSTRUCTURE, 8 CONCRETE FOOTINGS 6FT6IN X 6FT10IN ON TWO STEEL PILES FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS, SINGLE LANE
851206P	ROAD BRIDGE SUBSTRUCTURE 8 CONCRETE FOOTINGS 9FT X 6FT 2500 PSF FOUNDATION SOIL CAPACITY FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS SINGLE LANE
851206R	ROAD BRIDGE SUBSTRUCTURE 8 CONCRETE FOOTINGS 6FT X 4FT 5000 PSF FOUNDATION SOIL CAPACITY FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS SINGLE LANE
851206T	ROAD BRIDGE SUBSTRUCTURE, 14 TIMBER FOOTINGS 8FT8IN X 4FT6IN,2500 PSF FOUNDATION SOIL CAPACITY FOR 10 FT THRU 60 FT TIMBER TOWERS, DOUBLE LANE
851206U	ROAD BRIDGE SUBSTRUCTURE, 14 TIMBER FOOTINGS 6FT X 3FT 5000 PSF FOUNDATION SOIL CAPACITY FOR 10 FT THRU 60 FT TIMBER TOWERS, DOUBLE LANE
851206V	ROAD BRIDGE SUBSTRUCTURE, 6 TIMBER FOOTINGS 10FT X 10FT 2500 PSF FOUNDATION SOIL CAPACITY FOR 20, 40, 60, 80 FT STEEL TOWERS, DOUBLE LANE

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT
75	51	2,781	59	159	184 402
39	27	1,498	46	122	138 306
27	21	10,094	45	56	150 231
68	51	10,092	67	71	132 270
66	44	1,965	51	92	193 336
30	20	1,018	28	56	110 194
9	13	1,934	49	97	121 267
5	8	1,295	39	74	92 205
19	24	6,937	25	67	63 149

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT	VOL	COST	CONST EFFORT IN MAN-HOURS			TOT
		SHT TONS	MEAS TONS		HOR	VERT	SEAL	
851206W	ROAD BRIDGE SUBSTRUCTURE 6 TIMBER FOOTINGS 7FT X 7FT 5000 PSF FOUNDATION SOIL CAPACITY FOR 20, 40, 60, 80 FT STEEL TOWERS DOUBLE LANE	11	13	4,671	25	60	38	143
851206Y	ROAD BRIDGE SUBSTRUCTURE, 8 TIMBER FOOTINGS 8FT X 5FT 2500 PSF FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS, SINGLE LANE	5	7	7,087	32	55	69	156
85120HA	ROAD BRIDGE SUBSTRUCTURE, 8 TIMBER FOOTINGS 6FT X 3FT 5000 PSF FOR 10 FT THRU 60 FT HIGH TIMBER TOWERS, SINGLE LANE	3	6	746	26	41	52	119
85120HE	BRIDGE,BAILEY,COMPLETE SET. THE BAILEY BRIDGE IS INCLUDED IN AFCS FOR PLANNING PURPOSES DETAILED DESCRIPTION AND ERECTION INSTRUCTIONS ARE IN TM5-277. AFCS DRAWINGS 85120HE THROUGH 85120LH SHOW FIELD USES.	4	87	78,648	127		146	275
85130AA	ROAD,TWO LANE,CLASS A,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-4 FT,HAUL DISTANCE-2 MI,GRASS,NO ROCK, COMBAT BN CONSTR	5	3	2,769	2,237		825	3,062
85130AB	ROAD,TWO LANE,CLASS A,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-4 FT,HAUL DISTANCE-2 MI,WOODLAND,NO ROCK,COMBAT BN CONSTR	5	3	2,769	2,391		880	3,271
85130AC	ROAD,TWO LANE,CLASS A,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-4 FT,HAUL DISTANCE-2 MI,FOREST,NO ROCK, COMBAT BN CONSTR	5	3	2,769	3,994		2,022	6,016
85130AD	ROAD,TWO LANE,CLASS A,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,HAUL DISTANCE-5 MI,GRASS,NO ROCK, COMBAT BN CONSTR	6	6	3,112	8,887		1,111	9,998
85130AE	ROAD,TWO LANE,CLASS A,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,HAUL DISTANCE-5 MI,WOODLAND,NO ROCK,COMBAT BN CONSTR	6	6	3,112	9,060		1,180	10,240

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		HOR	VERT	GENL	TOT			
85130AF	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, FOREST, NO ROCK, COMBAT BN CONSTR	6	6	3,112	11,063	2,622	13,685	
85130AG	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	4	4	1,986	7,065	360	1,425	
85130AH	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	4	7	2,203	2,366	986	3,352	
85130AJ	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	4	10	2,416	3,659	1,599	5,258	
85130AK	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	4	4	1,986	1,259	439	1,698	
85130AL	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	4	7	2,203	2,560	1,065	3,625	
85130AM	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	4	10	2,416	3,854	1,678	5,532	
85130AN	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	4	6	1,986	2,934	2,033	6,967	
85130AP	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	4	7	2,203	4,234	2,659	6,893	
85130AR	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	4	10	2,416	5,528	3,272	8,800	
85130AT	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	16	5	9,276	1,226	431	1,657	
85130AU	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	16	8	9,492	2,650	7,059	3,709	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
85130AV	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	16	11	9,706	4,061		1,672	5,735
85130AW	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	16	5	9,276	1,356		483	1,837
85130AY	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	16	8	9,492	2,873		1,156	6,031
85130BA	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	16	11	9,706	4,284		1,769	6,053
85130BB	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	16	5	9,276	3,190		2,236	5,426
85130BC	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	16	8	9,492	4,874		3,067	7,941
85130BD	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	16	11	9,706	6,285		3,680	9,965
85130BE	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	22	15	12,199	1,880		685	2,565
85130BF	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	23	18	12,415	4,284		1,887	6,151
85130BG	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	23	21	12,629	6,745		3,123	9,868
85130BH	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	22	15	12,199	2,209		837	3,046
85130BJ	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	23	18	12,415	4,422		1,998	6,420
85130BK	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	23	21	12,629	6,828		3,223	10,051

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
		SHT TONS	HHR	VERT	GENL	TOT	
85130BL	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	22	15	12,199	4,300	3,031	7,351
85130BM	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	23	18	12,415	6,604	4,298	10,902
85130BN	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	23	21	12,629	8,888	5,526	14,474
85130BP	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	30	18	16,740	4,107	1,623	5,730
85130BR	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	30	21	16,957	8,765	3,472	12,237
85130BT	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	30	24	17,171	13,490	5,318	18,808
85130BU	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	30	18	16,740	4,724	1,934	6,658
85130BV	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	30	21	16,957	9,140	3,732	12,872
85130BW	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	30	24	17,171	13,739	5,573	19,314
85130BY	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	30	18	16,740	8,528	6,284	14,812
85130CA	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	30	21	16,957	12,174	7,976	20,150
85130CB	ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	30	24	17,171	16,055	9,815	25,870
85130CC	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, GRASS, NO ROCK, COMBAT BN CONSTR			221	324	62	386

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
85130CD	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, WOODLAND, NO ROCK, COMBAT BN CONSTR
85130CE	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, FOREST, NO ROCK, COMBAT BN CONSTR
85130CF	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, GRASS, NO ROCK, COMBAT BN CONSTR
85130CG	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, WOODLAND, NO ROCK, COMBAT BN CONSTR
85130CH	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, FOREST, NO ROCK, COMBAT BN CONSTR
85130CJ	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR
85130CK	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR
85130CL	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR
85130CM	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR
85130CN	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR

CONSTRUCTION MATERIAL						
WT SHT TONS	VOL MEAS TONS	COST \$/ TON	CONST EFFORT IN MAN-HOURS			
		\$	HHR	VERT	GENL	TOT
			221	333	67	420
			221	332	147	679
			189	927	166	1,093
			189	936	170	1,126
			189	1,135	251	1,386
			221	217	28	243
			1	268	373	98
			1	272	528	168
			221	246	32	278
			1	248	404	102

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	
					HOR	VERT	GENL TOT
85130CP	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR		1	272	557		173 730
85130CK	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR			221	427		113 540
85130CT	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR		1	248	584		183 767
85130CU	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR		1	272	737		253 990
85130CV	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR		1	818	244		36 280
85130CW	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	1	1	846	614		106 520
85130CY	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR		1	870	588		176 764
85130DA	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	1		818	271		40 311
85130DB	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	1	1	846	447		110 557
85130DC	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	1	1	870	616		181 797

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

85130DD ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR

85130DE ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR

85130DF ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR

85130DG ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR

85130DH ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR

85130DJ ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR

85130DK ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR

85130DL ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR

85130DM ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR

85130DN ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$/ TON	CONST EFFORT IN MAN-HOURS			TOT
			HOR	VERT	GENL	
1		818	466		128	594
1	1	846	660		207	867
1	1	870	829		277	1,106
2	1	1,076	375		55	430
2	2	1,104	664		193	857
2	2	1,128	930		332	1,282
2	1	1,076	473		66	477
2	2	1,104	689		200	889
2	2	1,128	974		339	1,313
2	1	1,076	630		171	801

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS TOT
85130DP	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	2	2	1,104	909		312 1,221
85130DR	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	2	2	1,128	1,209		452 1,667
85130DT	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	3	2	1,477	702		128 830
85130DU	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	3	2	1,504	1,256		336 1,592
85130DV	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	3	2	1,528	1,829		347 2,376
85130DW	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	3	2	1,477	746		144 890
85130DY	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	3	2	1,504	1,283		347 1,630
85130EA	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	3	2	1,528	1,838		559 2,397
85130EB	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	3	2	1,477	1,119		350 1,469
85130EC	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	3	2	1,504	1,559		349 2,108

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST	CONST	EFFORT IN MAN-HOURS	
		HOR	VERT	GENL	TOT			
85130ED	ROAD, TWO LANE, CLASS B, IMPROVE TO ROAD, TWO LANE, CLASS A, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	3	2	1,528	2,018	759	2,777	
85130EE	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, GRASS, NO ROCK, COMBAT BN CONSTR	5	3	2,547	2,036	757	2,813	
85130EF	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, WOODLAND, NO ROCK, COMBAT BN CONSTR	5	3	2,547	2,206	808	3,014	
85130EG	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, FOREST, NO ROCK, COMBAT BN CONSTR	5	3	2,547	3,697	1,873	5,568	
85130EH	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, GRASS, NO ROCK, COMBAT BN CONSTR	6	5	2,923	8,164	1,021	9,185	
85130EJ	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, WOODLAND, NO ROCK, COMBAT BN CONSTR	6	5	2,923	8,332	1,087	9,419	
85130EK	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, FOREST, NO ROCK, COMBAT BN CONSTR	6	5	2,923	10,228	2,653	12,881	
85130EL	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	4	3	1,763	989	329	1,318	
85130EM	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	4	6	1,956	2,140	884	3,024	
85130EN	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	4	9	2,145	3,286	1,624	4,710	

DHDXER1

RUN DATE 860128

FACILITY NUMBER	DESCRIPTION	CONSTRUCTION MATERIAL						CONST EFFORT IN MAN-HOURS	
		WT SHT	VOL TONS	MEAS TONS	COST \$	HOR	VERT	GENL	
85130EP	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	4	3	1,765	1,171			401	1,572
85130ER	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	4	6	1,956	2,320			957	3,277
85130ET	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	4	9	2,145	3,467			1,496	4,963
85130EU	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	4	3	1,765	2,719			1,875	4,594
85130EV	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	4	6	1,956	3,873			2,430	6,303
85130EW	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	4	9	2,145	5,015			2,969	7,984
85130EY	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	14	3	8,457	1,742			397	1,539
85130FA	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	14	7	8,648	2,399			955	3,354
85130FB	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	15	10	8,837	3,652			1,494	5,746
85130FC	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	14	5	8,457	1,264			445	1,709
85130FD	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	14	7	8,648	2,605			1,051	5,666
85130FE	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	15	10	8,837	3,863			1,580	5,463
85130FF	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	14	5	8,457	2,980			2,063	5,023

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					HOR	VERT	GENL	TOT
85130FG	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	14	7	8,648	4,461		2,807	7,268
85130FH	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	15	10	8,837	5,710		3,347	9,057
85130FJ	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	21	14	11,122	7,733		627	2,380
85130FK	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	21	17	11,313	3,849		1,699	5,548
85130FL	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	21	19	11,502	6,032		2,777	8,809
85130FM	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	21	14	11,122	2,037		765	2,802
85130FN	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	21	17	11,313	6,001		7,792	5,793
85130FP	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	21	19	11,502	6,136		2,870	9,006
85130FR	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	21	14	11,122	3,992		2,816	6,808
85130FT	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	21	17	11,313	6,039		3,923	9,962
85130FU	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	21	19	11,502	8,053		5,001	13,054
85130FV	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	27	17	15,263	3,778		1,485	5,263
85130FW	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	28	19	15,454	7,878		3,127	11,005

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL	TOT
85130FY	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	28	22	15,643	12,057	6,745	16,802	
85130GA	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	27	17	15,263	4,326	1,769	6,095	
85130GB	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	28	19	15,454	8,226	3,363	11,589	
85130GC	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	28	22	15,643	12,315	6,981	17,296	
85130GD	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	27	17	15,263	7,868	5,812	13,680	
85130GE	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	28	19	15,454	11,091	7,290	18,381	
85130GF	ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	28	22	15,643	14,516	8,908	23,424	
85130GG	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, GRASS, NO ROCK, COMBAT BN CONSTR	1	1	554	753	201	954	
85130GH	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, WOODLAND, NO ROCK, COMBAT BN CONSTR	1	1	554	787	208	995	
85130GJ	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, FOREST, NO ROCK, COMBAT BN CONSTR	1	1	554	1,190	392	1,582	
85130GK	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, GRASS, NO ROCK, COMBAT BN CONSTR	1	1	472	2,067	209	2,276	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL								
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST \$	CONST EFFORT IN MAN-HOURS	IN HRS	VERT	BENL	TOT
851306L	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, WOODLAND, NO ROCK, COMBAT BN CONSTR	1	1		472	2,103			216	2,319
851306M	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-8 FT, HAUL DISTANCE-5 MI, FOREST, NO ROCK, COMBAT BN CONSTR	1	1		472	2,515			400	2,915
851306N	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	1	1		552	469			100	569
851306P	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	1	2		610	840			284	1,124
851306R	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	1	3		674	1,205			459	1,664
851306T	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	1	1		552	509			116	623
851306U	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	1	2		610	888			291	1,179
851306V	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	1	3		662	1,250			466	1,716
851306W	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	1	1		552	918			298	1,216
851306Y	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	1	2		610	1,282			473	1,757

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	SHT TONS	VOL TONS	MEAS	COST \$	CONST EFFORT IN MAN-HOURS		
		HOR	VERT	GENL	TOT			
85130HA	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	1	3		674	1,658	630	2,308
85130HB	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	3	1		1,637	526	120	646
85130HC	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	3	2		1,695	930	308	1,238
85130HD	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	3	3		1,759	1,332	483	1,815
85130HE	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	3	1		1,637	546	130	676
85130HF	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	3	2		1,695	983	313	1,296
85130HG	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	3	3		1,767	1,380	488	1,868
85130HH	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	3	1		1,637	991	332	1,325
85130HJ	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	3	2		1,695	1,647	534	1,981
85130HK	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	3	3		1,759	1,860	708	2,568

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST	CONST EFFORT IN MAN-HOURS		
		HON	VERT	BLNL	TOT			
85130HL	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	6	3	2,153	766	191	935	
85130HN	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	6	4	2,211	1,446	346	1,990	
85130HN	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	6	4	2,275	2,140	896	3,036	
85130HP	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	6	3	2,153	822	219	1,041	
85130HR	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	6	4	2,211	1,479	531	2,030	
85130HT	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	6	4	2,263	2,167	900	3,067	
85130HU	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	6	3	2,153	1,304	669	1,753	
85130HV	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	6	4	2,211	1,955	803	2,798	
85130HW	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	6	4	2,275	2,616	1,152	3,768	
85130HY	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	5	3	2,954	1,495	668	1,941	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	HOR	VERT	GENL	TOT
85130JA	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	5	4	3,013	2,832	1,006			3,838
85130JB	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	5	5	3,076	4,158	1,531			5,689
85130JC	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	5	3	2,954	1,578	503			2,081
85130JD	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	5	6	3,013	2,865	1,010			3,873
85130JE	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	5	5	3,064	4,160	1,536			5,696
85130JF	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	5	3	2,954	2,390	921			3,315
85130JG	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	5	6	3,013	3,439	1,432			4,877
85130JH	ROAD, ONE LANE, CLASS C, IMPROVE TO ROAD, TWO LANE, CLASS B, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	5	5	3,076	4,367	1,956			6,323
85130JJ	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, GRASS, NO ROCK, COMBAT BN CONSTR	4	2	1,993	1,512	555			2,087
85130JK	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, WOODLAND, NO ROCK, COMBAT BN CONSTR	6	2	1,993	1,692	597			2,289

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST	CONST EFFORT IN MAN-HOURS			
					\$	HHR	VERT	GENL	TOT
85130JL	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-4 FT,HAUL DISTANCE-2 MI,FOREST,NO ROCK, COMBAT BN CONSTR	6	2		1,993	2,926			1,473 4,399
85130JM	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,HAUL DISTANCE-5 MI,GRASS,NO ROCK, COMBAT BN CONSTR	5	5		2,452	6,397			872 7,209
85130JN	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,HAUL DISTANCE-5 MI,WOODLAND,NO ROCK,COMBAT BN CONSTR	5	3		2,452	6,364			871 7,615
85130JP	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,HAUL DISTANCE-5 MI,FOREST,NO ROCK, COMBAT BN CONSTR	5	5		2,452	6,178			2,047 10,225
85130JR	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,GRASS,NO ROCK,COMBAT BN CONSTR	2	2		1,214	766			240 1,006
85130JT	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,GRASS,MOD ROCK,COMBAT BN CONSTR	3	4		1,346	1,549			612 2,161
85130JU	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,GRASS,HVY ROCK,COMBAT BN CONSTR	3	6		1,472	2,324			976 3,300
85130JV	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,WOODLAND,NO ROCK,COMBAT BN CONSTR	2	2		1,214	920			302 1,222
85130JW	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,WOODLAND,MOD ROCK,COMBAT BN CONSTR	3	4		1,346	1,791			674 2,465
85130JY	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,WOODLAND,HVY ROCK,COMBAT BN CONSTR	3	6		1,472	2,582			1,038 3,620
85130KA	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,FOREST,NO ROCK,COMBAT BN CONSTR	2	2		1,214	2,180			1,500 3,680

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL MEAS	COST	CONST EFFORT IN MAN-HOURS	IN	GENL	TOT
		TONS	TONS	\$	HOR	VERT		
85130KB	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,FOREST,MOD ROCK,COMBAT BN CONSTR	3	4	1,346	2,962		1,871	4,833
85130KC	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,FLAT PLAIN TERRAIN,FOREST,HVY ROCK,COMBAT BN CONSTR	3	6	1,472	3,738		2,236	5,974
85130KD	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,GRASS,NO ROCK,COMBAT BN CONSTR	12	4	6,820	879		288	1,167
85130KE	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,GRASS,MOD ROCK,COMBAT BN CONSTR	12	6	6,953	1,734		639	2,393
85130KF	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,GRASS,HVY ROCK,COMBAT BN CONSTR	12	7	7,079	2,581		1,024	3,605
85130KG	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,WOODLAND,NO ROCK,COMBAT BN CONSTR	12	4	6,820	996		336	1,332
85130KH	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,WOODLAND,MOD ROCK,COMBAT BN CONSTR	12	6	6,953	2,015		735	2,750
85130KJ	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,WOODLAND,HVY ROCK,COMBAT BN CONSTR	12	7	7,079	2,882		1,099	3,981
85130KK	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,FOREST,NO ROCK,COMBAT BN CONSTR	12	4	6,820	2,379		1,054	4,033
85130KL	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,FOREST,MOD ROCK,COMBAT BN CONSTR	12	6	6,953	3,412		2,170	5,582
85130KM	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,ROLLING TERRAIN,FOREST,HVY ROCK,COMBAT BN CONSTR	12	7	7,079	6,260		2,535	6,795
85130KN	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED HILLY TERRAIN,GRASS,NO ROCK,COMBAT BN CONSTR	17	11	8,970	1,318		463	1,781
85130KP	ROAD,ONE LANE,CLASS C,ONE MILE,GRADED AND DRAINED,HILLY TERRAIN,GRASS,MOD ROCK,COMBAT BN CONSTR	17	13	9,102	2,746		1,176	3,922

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL MEAS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	IN MAN-HOURS	
		TONS	TONS		HOR	VERT	GENL	TOT
85130KR	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	17	13	9,228	4,223		1,906	6,131
85130KT	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	17	11	8,970	1,603		615	2,218
85130KU	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	17	13	9,102	3,043		1,296	6,299
85130KV	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	17	15	9,228	4,510		1,985	6,495
85130KW	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	17	11	8,970	3,174		2,249	5,423
85130KY	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	17	13	9,102	4,559		2,992	7,551
85130LA	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	17	13	9,228	3,929		3,721	9,630
85130LB	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	22	14	12,309	2,780		1,083	3,863
85130LC	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, MOD ROCK, COMBAT BN CONSTR	22	13	12,442	3,366		2,170	7,736
85130LD	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, HVY ROCK, COMBAT BN CONSTR	22	17	12,568	8,397		3,264	11,661
85130LE	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	22	14	12,309	3,234		1,328	6,362
85130LF	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, MOD ROCK, COMBAT BN CONSTR	22	15	12,442	6,266		2,385	8,651
85130LG	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, HVY ROCK, COMBAT BN CONSTR	22	17	12,568	8,778		3,479	12,257

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
85130LH	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	22	14	12,309	6,233		4,651	10,884
85130LJ	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, MOD ROCK, COMBAT BN CONSTR	22	15	12,642	8,381		5,613	13,994
85130LK	ROAD, ONE LANE, CLASS C, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, FOREST, HVY ROCK, COMBAT BN CONSTR	22	17	12,568	10,707		6,707	17,474
85140AA	ROAD MAINTENANCE, SINGLE LANE, BITUMINOUS SURFACED, COLD PATCH, 30 DAYS, 100 MILES	44	57	17,196	6,518	799	6,153	11,470
85140AB	ROAD MAINTENANCE, SINGLE LANE, EARTH SURFACE, 30 DAYS, 100 MILES	5	2	2,707	4,140		5,520	9,660
85140AC	ROAD MAINTENANCE, DOUBLE LANE, 30 DAY, 100 MILE, BITUMINOUS SURFACE, COLD PATCH	85	113	32,747	4,888	1,576	6,854	13,318
85140AD	SNOW REMOVAL, 100 MILES OF DOUBLE LANE ROAD, INCLUDING FENCING, PLOWING, AND SAND SPREADING FOR ONE TEMPERATE CLIMATE WINTER SEASON	33	30	13,920	4,706	4,370	9,660	18,136
85140AE	ROAD MAINTENANCE, DOUBLE LANE, 30 DAYS, 100 MILES, EARTH SURFACE	5	1	2,772	4,140		5,520	9,660
85190AA	ROAD, BEACH, 2 LANE, PORTABLE MAT SURFACING, 1 MILE	493	299	124,783		1,035	2,197	3,232
85190AB	ROAD, TWO LANE, WITH FIBERGLASS REINFORCED PLASTIC MATTING, 1 MILE UNIT	108	54	580,824	81		357	438
85210AA	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, GRASS, NO ROCK, COMBAT BN CONSTR	3	1	2,104	164		79	243
85210AB	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, SWAMP OR DELTA TERRAIN, FILL-4 FT, HAUL DISTANCE-2 MI, WOODLAND, NO ROCK, COMBAT BN CONSTR	3	1	2,104	169		82	251

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HHR VERT	EFFORT GENL	IN MAN-HOURS TOT	
85210AC	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-4 FT,HAUL DISTANCE-2 MI,FOREST,NO ROCK,COMBAT BN CONSTR	3	1	2,104	292		148	640
85210AD	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,HAUL DISTANCE-5 MI,GRASS,NO ROCK,COMBAT BN CONSTR	6	1	3,531	495		64	559
85210AE	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,HAUL DISTANCE-5 MI,WOODLAND,NO ROCK,COMBAT BN CONSTR	6	1	3,531	501		69	570
85210AF	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,HAUL DISTANCE-5 MI,FOREST,NO ROCK,COMBAT BN CONSTR	6	1	3,531	668		161	829
85210AG	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,GRASS,NO ROCK,COMBAT BN CONSTR	3	1	1,666	72		23	95
85210AH	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,GRASS,MODERATE ROCK,COMBAT BN CONSTR	3	1	1,684	198		68	266
85210AJ	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,GRASS,HEAVY ROCK,COMBAT BN CONSTR	3	2	1,702	323		113	636
85210AK	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,WOODLAND,NO ROCK,COMBAT BN CONSTR	3	1	1,666	83		30	113
85210AL	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,WOODLAND,MODERATE ROCK,COMBAT BN CONSTR	3	1	1,684	209		75	284
85210AM	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,WOODLAND,HEAVY ROCK,COMBAT BN CONSTR	3	2	1,702	335		120	455
85210AN	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,FOREST,NO ROCK,COMBAT BN CONSTR	3	1	1,666	160		69	229

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	TONS	WT SHT	VOL MEAS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS TOT
85210AP	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,FOREST,MODERATE ROCK,COMBAT BN CONSTR	3		1	1,684	285		114 399
85210AR	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,FLAT PLAIN TERRAIN,FOREST,HEAVY ROCK,COMBAT BN CONSTR	3		2	1,702	411		159 570
85210AT	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,GRASS,NO ROCK,COMBAT BN CONSTR	7		3	6,383	82		30 112
85210AU	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,GRASS,MODERATE ROCK,COMBAT BN CONSTR	7		3	6,402	233		84 317
85210AV	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,GRASS,HEAVY ROCK,COMBAT BN CONSTR	7		4	6,420	382		138 520
85210AW	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,WOODLAND,NO ROCK,COMBAT BN CONSTR	7		3	6,383	90		32 122
85210AY	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,WOODLAND,MODERATE ROCK,COMBAT BN CONSTR	7		3	6,402	247		89 336
85210BA	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,WOODLAND,HEAVY ROCK,COMBAT BN CONSTR	7		4	6,420	396		163 539
85210BB	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,FOREST,NO ROCK,COMBAT BN CONSTR	7		3	6,383	173		74 267
85210BC	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,FOREST,MODERATE ROCK,COMBAT BN CONSTR	7		3	6,402	342		137 479
85210BD	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,ROLLING TERRAIN,FOREST,HEAVY ROCK,COMBAT BN CONSTR	7		4	6,420	490		191 681
85210BE	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,HILLY TERRAIN,GRASS,NO ROCK,COMBAT BN CONSTR	11		5	6,750	139		46 183
85210BF	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,HILLY TERRAIN,GRASS,MODERATE ROCK,COMBAT BN CONSTR	11		5	6,769	376		136 512

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	SHT TONS	MEAS TONS	WT VOL	COST \$	CONST HHR	EFFORT IN MAN-HOURS	PERL TOT
85210B6	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, HILLY TERRAIN, GRASS, HEAVY ROCK, COMBAT BN CONSTR	11	3	6,787	613	225	225	838
85210BH	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	11	3	6,790	158	58	58	216
85210BJ	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, MODERATE ROCK, COMBAT BN CONSTR	11	3	6,789	393	147	147	540
85210BK	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, HILLY TERRAIN, WOODLAND, HEAVY ROCK, COMBAT BN CONSTR	11	3	6,787	624	237	237	861
85210BL	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, HILLY TERRAIN, FOREST, NO ROCK, COMBAT BN CONSTR	11	3	6,790	253	106	106	359
85210BM	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, HILLY TERRAIN, FOREST, MODERATE ROCK, COMBAT BN CONSTR	11	3	6,769	477	196	196	673
85210BN	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, HILLY TERRAIN, FOREST, HEAVY ROCK, COMBAT BN CONSTR	11	3	6,787	704	285	285	989
85210BP	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, NO ROCK, COMBAT BN CONSTR	19	6	11,353	300	99	99	399
85210BR	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, MODERATE ROCK, COMBAT BN CONSTR	19	6	11,372	683	212	212	895
85210BT	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, GRASS, HEAVY ROCK, COMBAT BN CONSTR	19	6	11,390	1,066	322	322	1,388
85210BU	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, NO ROCK, COMBAT BN CONSTR	19	6	11,353	362	129	129	673
85210BV	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, MODERATE ROCK, COMBAT BN CONSTR	19	6	11,372	729	242	242	971
85210BW	HARDSTAND, 1000 SQ YDS, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, WOODLAND, HEAVY ROCK, COMBAT BN CONSTR	19	6	11,390	1,110	392	392	1,482

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT HOR VERT	IN MAN-HOURS	GENL	TOT
85210BY	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,MOUNTAINOUS TERRAIN,FOREST,NO ROCK,COMBAT BN CONSTR	19	6	11,353	491		212	703
85210CA	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,MOUNTAINOUS TERRAIN,FOREST,MODERATE ROCK,COMBAT BN CONSTR	19	6	11,372	846		327	1,173
85210CB	HARDSTAND,1000 SQ YDS,GRADED AND DRAINED,MOUNTAINOUS TERRAIN,FOREST,HEAVY ROCK,COMBAT BN CONSTR	19	6	11,390	1,199		437	1,636
85290AA	CONCRETE HEADWALLS FOR CULVERTS,TWO LANE AND ONE LANE ROADS,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-4 FT,2 MILE HAUL DISTANCE,ALL TYPE VEGETATION AND ROCK CONDITIONS	12	11	1,097	99	176	49	324
85290AB	TIMBER HEADWALLS FOR CULVERTS,TWO LANE AND ONE LANE ROADS,ONE MILE,GRADED AND DRAINED, SWAMP OR DELTA TERRAIN,FILL-4 FT,2 MILE HAUL DISTANCE,ALL TYPE VEGETATION AND ROCK CONDITIONS	7	6	331	21	71	9	107
85290AC	SOIL-CEMENT FILLED SANDBAG HEADWALLS FOR CULVERTS,TWO LANE AND ONE LANE ROADS,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-4 FT,2 MILE HAUL DISTANCE,ALL TYPE VEGETATION AND ROCK CONDITIONS	6	4	433	14		62	76
85290AD	CONCRETE HEADWALLS FOR CULVERTS,TWO LANE AND ONE LANE ROADS,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,5 MILE HAUL DISTANCE,ALL TYPE VEGETATION AND ROCK CONDITIONS	13	12	1,298	95	169	68	312
85290AE	TIMBER HEADWALLS FOR CULVERTS,TWO LANE AND ONE LANE ROADS,ONE MILE,GRADED AND DRAINED, SWAMP OR DELTA TERRAIN,FILL-8 FT,5 MILE HAUL DISTANCE,ALL TYPE VEGETATION AND ROCK CONDITIONS	1	2	288	20	69	9	98
85290AF	SOIL CEMENT FILLED SANDBAG HEADWALLS FOR CULVERTS,TWO LANE AND ONE LANE ROADS,ONE MILE,GRADED AND DRAINED,SWAMP OR DELTA TERRAIN,FILL-8 FT,5 MILE HAUL DISTANCE,ALL TYPE VEGETATION AND ROCK CONDITIONS	6	5	438	14		62	76

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL								
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	VERT	SENL	TOT
85290AG	CONCRETE HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	13	12		1,268	105	190	53	348	
85290AH	TIMBER HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	2	2		313	21	74	9	104	
85290AJ	SOIL-CEMENT FILLED SANDBAG HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, FLAT PLAIN TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	7	5		478	16	72	88		
85290AK	CONCRETE HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	25	21		2,107	191	338	100	629	
85290AL	TIMBER HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	3	5		676	64	163	9	216	
85290AM	SOIL-CEMENT FILLED SANDBAG HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, ROLLING TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	16	11		1,108	37	166		203	
85290AN	CONCRETE HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	39	34		3,481	294	538	170	1,002	
85290AP	TIMBER HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	5	7		1,003	64	239	18	321	
85290AR	SOIL-CEMENT FILLED SANDBAG HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, HILLY TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	23	16		1,363	57	228		279	
85290AT	CONCRETE HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	51	45		6,340	390	707	221	1,318	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		HOR	VERT	GENL	TOT			
85290AU	TIMBER HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	7	10	1,356	86	322	23	431
85290AV	SOIL-CEMENT FILLED SANDBAG HEADWALLS FOR CULVERTS, TWO LANE AND ONE LANE ROADS, ONE MILE, GRADED AND DRAINED, MOUNTAINOUS TERRAIN, ALL TYPE VEGETATION AND ROCK CONDITIONS	31	23	2,166	69		311	380
85291AA	BAILEY BRIDGE 2X2 110 LF. THIS FACILITY SATISFIES A REQUIREMENT OF MILITARY PLANNERS AND THERE ARE NO DRAWINGS IN TM5-302. DATA SUPPLIED BY DAEN-SG IN DEC 1977.	1	72	42,533	23	39	439	501
85291AB	BRIDGE ERECTION SET, FIXED BAILEY BRIDGE		4	27,021				
86010AA	RAILROAD MATERIAL FOR ONE MILE OF SINGLE TRACK USING 90 LB. RAIL.	473	600	137,470	2,091		5,465	7,556
86010AB	RAILROAD TRACK TURNOUT NUMBER 8, 56-1/2 INCH GAGE 90 LB 90 LB RAIL WITH TIES AND FITTINGS	13	13	6,018	2	115	5	122
86030AA	RAILROAD BRIDGE SUPERSTRUCTURE TIMBER STRINGER 16 FT SPAN, SINGLE TRACK, E45 LOADING SQUARE ENDS	3	5	731	2	66	66	94
86030AB	RAILROAD BRIDGE SUPERSTRUCTURE TIMBER STRINGER 16 FT SPAN, SINGLE TRACK, E45 LOADING 30 DEG SKEW ENDS	3	5	747	2	51	51	104
86030AC	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 20 FT SPAN SINGLE TRACK E45 LOADING SQUARE ENDS	5	6	3,322	12	39	37	88
86030AD	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 20 FT SPAN SINGLE TRACK E45 LOADING 30 DEG SKEW ENDS	6	6	3,412	12	39	37	88
86030AE	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 30 FT SPAN SINGLE TRACK E45 LOADING SQUARE ENDS	8	9	5,167	75	51	66	112

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
86030AF	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 30 FT SPAN SINGLE TRACK E45 LOADING 30 DEG SKEW ENDS
86030AG	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 40 FT SPAN SINGLE TRACK E45 LOADING SQUARE ENDS
86030AH	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 40 FT SPAN SINGLE TRACK E45 LOADING 30 DEG SKEW ENDS
86030AJ	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 20 FT SPAN, SINGLE TRACK E80 LOADING SQUARE ENDS
86030AK	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 20 FT SPAN SINGLE TRACK E80 LOADING 30 DEG SKEW ENDS
86030AL	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 30 FT SPAN SINGLE TRACK E80 LOADING SQUARE ENDS
86030AM	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 30 FT SPAN SINGLE TRACK E80 LOADING 30 DEG SKEW ENDS
86030AN	RAILROAD BRIDGE SUPERSTRUCTURE STEEL STRINGER 40 FT SPAN SINGLE TRACK E80 LOADING SQUARE ENDS
86030AP	RAILROAD BRIDGE SUPERSTRUCTURE TIMBER STRINGER 40 FT SPAN SINGLE TRACK E80 LOADING 30 DEG SKEW ENDS
86030AR	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E45 16 FT TIMBER SPAN, WITH WALKWAY SQUARE ENDS
86030AT	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E45, 16 FT TIMBER SPAN, WITH WALKWAY, 30 DEG SKEW ENDS
86030AU	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E45 20 FT STEEL SPAN SQUARE ENDS

CONSTRUCTION MATERIAL							
WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	VERT	GENL	TOT
12	15	6,287	23	76	55	152	
15	15	10,214	18	64	55	137	
16	15	9,846	18	64	55	137	
7	6	4,481	12	39	37	88	
7	7	4,516	12	39	37	88	
12	11	8,879	16	53	46	115	
8	8	5,117	16	53	46	115	
24	23	16,783	23	74	55	152	
21	18	14,336	23	74	55	152	
5	5	720	33	51	83	167	
6	6	805	33	55	83	171	
7	7	1,051	38	90	97	225	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					HOR	VERT	GENL	TOT
86030AV	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E45 20 FT STEEL SPAN 30 DEG SKEW ENDS	7	8	1,140	38	99	97	234
86030AW	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E45 30 FT STEEL SPAN SQUARE ENDS	8	9	1,245	43	106	110	259
86030AY	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E45 30 FT STEEL SPAN 30 DEG SKEW ENDS	9	10	1,332	43	110	110	263
86030BA	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E45 40 FT AND E80, 20 FT STEEL SPAN SQUARE ENDS	9	10	1,778	47	113	124	284
86030BB	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E45 40 FT AND E80 20 FT STEEL SPAN 30 DEG SKEW ENDS	10	11	1,869	47	117	124	288
86030BC	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E80 30 FT STEEL SPAN SQUARE ENDS	12	13	2,139	56	128	131	315
86030BD	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E80, 30 FT STEEL SPAN 30 DEG SKEW ENDS	13	13	2,337	56	137	131	324
86030BE	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E80, 40 FT STEEL SPAN SQUARE ENDS	14	15	1,996	63	150	152	365
86030BF	RAILROAD BRIDGE SUBSTRUCTURE TIMBER ABUTMENT ON TIMBER PILES, SINGLE TRACK E80 40 FT STEEL SPAN 30 DEG SKEW ENDS	15	17	2,269	63	159	152	374
86030BG	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E45, 16 FT TIMBER SPAN SQUARE ENDS	6	6	4,334	37	48	69	154

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
86030BH	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E45, 16 FT TIMBER SPAN 30 DEG SKEW ENDS
86030BJ	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E45, 20 FT STEEL SPAN SQUARE ENDS
86030BK	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E45, 20 FT STEEL SPAN 30 DEG SKEW ENDS
86030BL	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E45, 30 FT STEEL SPAN SQUARE ENDS
86030BM	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E45, 30 FT STEEL SPAN 30 DEG SKEW ENDS
86030BN	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E45, 40 FT STEEL SPAN OR E80, 20 FT STEEL SPAN SQUARE ENDS
86030BP	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E45, 40 FT STEEL SPAN OR E80, 20 FT STEEL SPAN 30 DEG SKEW ENDS
86030BR	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E80, 30 FT STEEL SPAN SQUARE ENDS
86030BT	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E80, 30 FT STEEL SPAN 30 DEG SKEW ENDS
86030BU	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E80, 40 FT STEEL SPAN SQUARE ENDS
86030BV	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE ABUTMENT SINGLE TRACK, E80, 40 FT STEEL SPAN 30 DEG SKEW ENDS
86030BW	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 10 FT HIGH FOR E45, 32 FT TIMBER OR 40 FT STEEL MAXIMUM COMBINED SPANS

CONSTRUCTION MATERIAL

SHT TONS	VOL TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL	MAN-HOURS TOT
7	7	6,303	37	51	69	157
9	9	6,211	41	60	97	198
9	9	6,360	41	62	97	200
9	9	6,233	41	60	97	198
9	9	6,343	41	62	97	200
9	9	6,743	41	67	97	205
10	10	6,792	41	69	97	207
9	9	6,723	41	69	97	207
10	10	7,080	41	71	97	209
11	11	7,419	46	78	110	234
12	12	7,709	46	83	110	239
8	9	2,240	31	104	92	227

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL MEAS	COST TONS	CONST HOR	EFFORT IN MAN-HOURS		
		TONS	TONS	\$	HOR	VERT	GENL	TOT
86030BY	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 20 FT HIGH FOR E45, 32 FT TIMBER OR 40 FT STEEL MAXIMUM COMBINED SPANS	11	12	2,785	31	121	121	273
86030CA	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 30 FT HIGH FOR E45, 32 FT TIMBER OR 40 FT STEEL MAXIMUM COMBINED SPANS	14	14	3,042	31	150	150	331
86030CB	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK, 10 FT HIGH FOR E45, 60 FT STEEL MAXIMUM COMBINED SPANS	11	12	3,585	40	138	113	293
86030CC	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 20 FT HIGH FOR E45, 60 FT STEEL MAXIMUM COMBINED SPANS	16	16	4,151	40	155	132	327
86030CD	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 30 FT HIGH FOR E45, 60 FT STEEL MAXIMUM COMBINED SPANS	18	18	6,794	40	173	150	363
86030CE	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 10 FT HIGH FOR E45, 80 FT OR E80, 40 FT STEEL MAXIMUM COMBINED SPANS	18	20	4,591	47	178	132	357
86030CF	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 20 FT HIGH FOR E45, 80 FT OR E80, 40 FT STEEL MAXIMUM COMBINED SPANS	23	26	5,669	47	190	144	381
86030CG	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 30 FT HIGH FOR E45, 80 FT OR E80, 40 FT MAXIMUM COMBINED SPANS	28	30	9,515	47	207	161	415
86030CH	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 10 FT HIGH FOR E80, 60 FT STEEL MAXIMUM COMBINED SPANS	21	24	5,605	56	189	138	381
86030CJ	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 20 FT HIGH FOR E80, 60 FT STEEL MAXIMUM COMBINED SPANS	28	30	7,247	56	213	155	424

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HRS	EFFORT IN MAN-HOURS	GENL	TOT
86030CK	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 30 FT HIGH FOR E80, 60 FT STEEL MAXIMUM COMBINED SPANS	33	35	12,398	34	242	173	489
86030CL	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 10 FT HIGH FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	32	35	8,036	79	328	190	597
86030CM	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 20 FT HIGH FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	42	46	10,346	79	385	190	654
86030CN	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER PILE PIER SINGLE TRACK 30 FT HIGH FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	49	51	17,000	79	663	213	735
86030CP	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE PIER 10 FT HIGH SINGLE TRACK FOR E45, 32 FT TIMBER E45, 80 FT STEEL OR E80, 60 FT STEEL MAXIMUM COMBINED SPANS	10	9	7,151	30	71	46	167
86030CR	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE PIER 20 FT HIGH SINGLE TRACK FOR E45, 32 FT TIMBER E45, 80 FT STEEL OR E80, 60 FT STEEL MAXIMUM COMBINED SPANS	12	11	9,199	35	91	52	178
86030CT	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE PIER 30 FT HIGH SINGLE TRACK FOR E45, 32 FT TIMBER E45, 80 FT STEEL OR E80, 60 FT STEEL MAXIMUM COMBINED SPANS	15	14	11,295	40	115	58	215
86030CU	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE PIER 10 FT HIGH SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	12	11	8,963	38	85	58	181
86030CV	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE PIER 20 FT HIGH SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	15	14	11,357	41	100	63	204

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT	
					HOR	VERT	TOT	
86030CW	RAILROAD BRIDGE SUBSTRUCTURE STEEL PILE PIER 30 FT HIGH, SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	18	16	13,986	51	138	69	258
86030CY	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 10 FT HIGH, SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	8	10	2,211	14	184	138	336
86030DA	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 20 FT HIGH, SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	14	19	3,820	23	299	207	529
86030DB	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 30 FT HIGH, SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	22	30	5,739	37	384	317	738
86030DC	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 40 FT HIGH, SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	29	40	7,517	46	467	428	941
86030DD	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 50 FT HIGH, SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	36	50	9,452	58	585	531	1,174
86030DE	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 60 FT HIGH, SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	40	55	10,434	64	649	580	1,293
86030DF	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 10 FT HIGH, SINGLE TRACK FOR E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	15	20	4,376	23	321	214	558
86030DG	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 20 FT HIGH, SINGLE TRACK FOR E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	22	30	6,131	35	658	317	810
86030DH	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 30 FT HIGH, SINGLE TRACK FOR E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	30	41	8,643	48	624	433	1,107

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION	CONSTRUCTION MATERIAL						
		WT SHT TONS	VOL MEAS TONS	COST \$/ S	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
86030DJ	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 60 FT HIGH, SINGLE TRACK FOR E45, 80 FT OR E80, 40 FT STEEL MAXIMUM COMBINED SPANS	40	54	11,138	64	777	580	1,421
86030DK	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 50 FT HIGH, SINGLE TRACK FOR E45, 80 FT OR E80, 40 FT STEEL MAXIMUM COMBINED SPANS	48	65	13,282	74	886	828	1,788
86030DL	RAILROAD BRIDGE SUBSTRUCTURE, TIMBER TOWER 60 FT HIGH, SINGLE TRACK FOR E45, 80 FT OR E80, 40 FT STEEL MAXIMUM COMBINED SPANS	59	81	16,297	83	1,028	1,012	2,023
86030DM	RAILROAD BRIDGE SUBSTRUCTURE TIMBER TOWER 10 FT HIGH, SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	17	23	4,964	28	373	248	649
86030DN	RAILROAD BRIDGE SUBSTRUCTURE TIMBER TOWER 20 FT HIGH, SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	26	35	7,343	41	504	373	918
86030DP	RAILROAD BRIDGE SUBSTRUCTURE TIMBER TOWER 30 FT HIGH, SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	35	47	9,765	35	638	504	1,215
86030DR	RAILROAD BRIDGE SUBSTRUCTURE TIMBER TOWER 40 FT HIGH, SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	44	60	12,522	71	796	635	1,502
86030DT	RAILROAD BRIDGE SUBSTRUCTURE TIMBER TOWER 50 FT HIGH, SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	56	77	13,648	81	993	966	2,062
86030DU	RAILROAD BRIDGE SUBSTRUCTURE TIMBER TOWER 60 FT HIGH, SINGLE TRACK FOR E80, 80 FT STEEL MAXIMUM COMBINED SPANS	65	89	18,245	92	1,076	1,104	2,272
86030DV	RAILROAD BRIDGE SUBSTRUCTURE 15 CONCRETE FOOTINGS 10FT6IN X 2FT6IN 2500 PSF FOUNDATION SOIL CAPACITY FOR TIMBER TOWERS SINGLE TRACK E45 32 FT TIMBER MAXIMUM COMBINED SPANS	25	17	1,967	58	137	186	381

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT	VERT TOT
86030DW	RAILROAD BRIDGE SUBSTRUCTURE 15 CONCRETE FOOTINGS 4FT6IN X 2FT6IN 5000 PSF FOUNDATION SOIL CAPACITY FOR TIMBER TOWERS SINGLE TRACK E45 32 FT TIMBER MAXIMUM COMBINED SPANS	27	19	1,179	39	98	69	206
86030DY	RAILROAD BRIDGE SUBSTRUCTURE 10 CONCRETE FOOTINGS 14FT X 3FT6IN 2500 PSF FOUNDATION SOIL CAP FOR TIMBER TOWERS SINGLE TRACK E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	75	51	2,478	53	140	196	389
86030EA	RAILROAD BRIDGE SUBSTRUCTURE 10 CONCRETE FOOTINGS 6FT X 3FT PSF FOUNDATION SOIL CAPACITY FOR TIMBER TOWERS SINGLE TRACK E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	33	22	1,297	38	77	86	201
86030EB	RAILROAD BRIDGE SUBSTRUCTURE 15 CONCRETE FOOTINGS 5FT X 2FT6IN ON TIMBER PILES FOR TIMBER TOWERS SINGLE TRACK E45 32 FT TIMBER MAXIMUM COMBINED SPANS	31	25	2,712	55	116	258	429
86030EC	RAILROAD BRIDGE SUBSTRUCTURE 15 CONCRETE FOOTINGS 2FT6IN X 2FT6IN ON STEEL PILE FOR TIMBER TOWERS SINGLE TRACK E45 32 FT TIMBER MAXIMUM COMBINED SPANS	18	14	6,785	44	71	104	219
86030ED	RAILROAD BRIDGE SUBSTRUCTURE CONCRETE SPREAD FOOTINGS 2500 PSF FOUNDATION SOIL CAPACITY FOR TIMBER TOWERS SINGLE TRACK E80 80 FT STEEL MAXIMUM COMBINED SPANS	45	30	1,747	37	69	86	192
86030EE	RAILROAD BRIDGE SUBSTRUCTURE T2 CONCRETE FOOTINGS 11FT9IN X 4FT6IN 2500 PSF FOUNDATION SOIL CAPACITY FOR TIMBER TOWERS SINGLE TRACK E80 80 FT STEEL MAXIMUM COMBINED SPANS	96	65	3,063	78	171	304	553
86030EF	RAILROAD BRIDGE SUBSTRUCTURE 12 CONCRETE FOOTINGS 8FT9IN X 2FT6IN 5000 PSF FOUNDATION SOIL CAPACITY FOR TIMBER TOWERS SINGLE TRACK E80 80 FT STEEL MAXIMUM COMBINED SPANS	54	37	1,908	52	116	166	334

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL	HAN-HOURS TOT
86030EG	RAILROAD BRIDGE SUBSTRUCTURE 10 CONCRETE FOOTINGS 7FT6IN X 2FT6IN ON TIMBER PILES FOR TIMBER TOWERS SINGLE TRACK E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	31	24	2,626	69	89	166	304
86030EH	RAILROAD BRIDGE SUBSTRUCTURE 12 CONCRETE FOOTINGS 7FT6IN X 2FT6IN ON TIMBER PILES FOR TIMBER TOWERS SINGLE TRACK E80 80 FT STEEL MAXIMUM COMBINED SPANS	37	29	3,181	56	105	193	354
86030EJ	RAILROAD BRIDGE SUBSTRUCTURE 10 CONCRETE FOOTINGS 6FT6IN X 2FT6IN ON STEEL PILES FOR TIMBER TOWERS SINGLE TRACK E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	26	21	9,142	53	84	132	269
86030EK	RAILROAD BRIDGE SUBSTRUCTURE 12 CONCRETE FOOTINGS 6FT6IN X 2FT6IN ON STEEL PILES FOR TIMBER TOWERS SINGLE TRACK E80 80 FT STEEL MAXIMUM COMBINED SPANS	32	25	10,975	60	98	155	313
86030EL	RAILROAD BRIDGE SUBSTRUCTURE 15 TIMBER FOOTINGS 2FT4IN X 8FT 2500 PSF FOUNDATION SOIL CAP FOR TIMBER TOWERS SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	6	9	1,122	17	69	69	135
86030EM	RAILROAD BRIDGE SUBSTRUCTURE 15 TIMBER FOOTINGS 2FT4IN X 4FT 5000 PSF FOUNDATION SOIL CAP FOR TIMBER TOWERS SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	3	5	625	17	63	63	143
86030EN	RAILROAD BRIDGE SUBSTRUCTURE 10 TIMBER FOOTINGS 3FT X 12FT 2500 PSF FOUNDATION SOIL CAP FOR TIMBER TOWERS SINGLE TRACK FOR E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	8	11	1,400	20	84	75	179
86030EP	RAILROAD BRIDGE SUBSTRUCTURE 10 TIMBER FOOTINGS 3FT X 6FT 5000 PSF FOUNDATION SOIL CAP FOR TIMBER TOWERS SINGLE TRACK FOR E45 80 FT OR E80 40 FT STEEL MAXIMUM COMBINED SPANS	5	7	847	20	75	75	170

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			
					<u>HOR</u>	<u>VERT</u>	<u>GENL</u>	<u>TOT</u>
86030ER	RAILROAD BRIDGE SUBSTRUCTURE TIMBER GRILLAGE FOOTINGS 2500 PSF FOUNDATION SOIL CAPACITY FOR TIMBER TOWERS SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	14	21	2,587	31	121	121	273
86030ET	RAILROAD BRIDGE SUBSTRUCTURE 12 TIMBER FOOTINGS 3FT6IN X 11FT 2500 PSF FOUNDATION SOIL CAP FOR TIMBER TOWERS SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	11	16	1,956	21	109	109	239
86030EU	RAILROAD BRIDGE SUBSTRUCTURE 12 TIMBER FOOTINGS 2FT4IN X 8FT6IN 5000 PSF FOUNDATION SOIL CAP FOR TIMBER TOWERS SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	6	8	1,033	21	86	86	193
86030EV	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 10 FT HIGH SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	11	15	15,609	30	90	64	184
86030EW	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 20 FT HIGH SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	1	1	8,356	64	144	78	266
86030EY	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 30 FT HIGH SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	18	19	28,590	53	173	101	327
86030FA	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 40 FT HIGH SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	1	3	17,052	68	229	124	421
86030FB	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 50 FT HIGH SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	1	4	25,146	79	259	152	490
86030FC	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 60 FT HIGH SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	2	5	25,845	95	320	175	590

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	IN HRS	VERT GENL	TOT
86030FD	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 70 FT HIGH SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	2	6	34,025	106	368	198	652
86030FE	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 80 FT HIGH SINGLE TRACK FOR E45 32 FT TIMBER MAXIMUM COMBINED SPANS	2	7	34,794	122	409	221	752
86030FF	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 10 FT HIGH SINGLE TRACK FOR E45 80 FT OR E80 60 FT STEEL MAXIMUM COMBINED SPANS	1	2	7,857	33	95	69	197
86030FG	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 20 FT HIGH SINGLE TRACK FOR E45 80 FT OR E80 60 FT STEEL MAXIMUM COMBINED SPANS	16	16	19,601	67	150	83	280
86030FH	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 30 FT HIGH SINGLE TRACK FOR E45 80 FT OR E80 60 FT STEEL MAXIMUM COMBINED SPANS	20	20	29,987	56	178	106	340
86030FJ	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 40 FT HIGH SINGLE TRACK FOR E45 80 FT OR E80 60 FT STEEL MAXIMUM COMBINED SPANS	22	20	32,261	71	235	129	435
86030FK	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 50 FT HIGH SINGLE TRACK FOR E45 80 FT OR E80 60 FT STEEL MAXIMUM COMBINED SPANS	28	28	44,296	83	265	156	504
86030FL	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 60 FT HIGH SINGLE TRACK FOR E45 80 FT OR E80 60 FT STEEL MAXIMUM COMBINED SPANS	29	28	46,200	99	325	179	603
86030FM	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 70 FT HIGH SINGLE TRACK FOR E45 80 FT OR E80 60 FT STEEL MAXIMUM COMBINED SPANS	37	35	58,763	109	354	202	665
86030FN	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 80 FT HIGH SINGLE TRACK FOR E45 80 FT OR E80 60 FT STEEL MAXIMUM COMBINED SPANS	42	39	63,942	125	415	225	765

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	SHT TONS	WT VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS VERT	GENL	TOT
86030FP	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 10 FT HIGH SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	13	16	16,953	32	95	69	196
86030FR	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 20 FT HIGH SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	16	16	19,642	46	150	83	279
86030FT	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 30 FT HIGH SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	21	20	30,224	55	178	106	339
86030FU	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 40 FT HIGH SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	24	23	33,732	70	235	129	436
86030FV	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 50 FT HIGH SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	29	27	44,618	82	265	156	503
86030FW	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 60 FT HIGH SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	34	32	49,064	98	323	179	602
86030FY	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 70 FT HIGH SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	36	35	58,817	108	356	202	664
86030GA	RAILROAD BRIDGE SUBSTRUCTURE STEEL TOWER 80 FT HIGH SINGLE TRACK FOR E80 80 FT STEEL MAXIMUM COMBINED SPANS	43	39	64,183	124	415	223	766
86030GB	RAILROAD BRIDGE SUBSTRUCTURE 2 CONCRETE FOOTINGS 11:-0:: X 28:-0:: 2500 PSF FOUNDATION SOIL CAPACITY FOR STEEL TOWERS SINGLE TRACK E45 32 FT TIMBER, E45 80 FT STEEL OR E80 80 FT STEEL MAXIMUM COMBINED SPANS	57	37	2,487	51	90	150	291

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
			HOR	VERT	GENL

66	64	2,300	38	108	173	339
----	----	-------	----	-----	-----	-----

860306C RAILROAD BRIDGE SUBSTRUCTURE 6 CONCRETE FOOTINGS
11:-0:: X 11:-0:: 2500 PSF FOUNDATION SOIL CAPACITY
FOR STEEL TOWERS SINGLE TRACK E45 32 FT TIMBER
E45 80 FT STEEL OR E80 80 FT STEEL MAXIMUM COMBINED SPANS

860306D RAILROAD BRIDGE SUBSTRUCTURE 6 CONCRETE FOOTINGS
7:-0:: X 7:-0:: 5000 PSF FOUNDATION SOIL CAPACITY FOR STEEL
TOWERS, SINGLE TRACK E45 32 FT TIMBER E45 80 FT STEEL
OR E80 80 FT STEEL MAXIMUM COMBINED SPANS

860306E RAILROAD BRIDGE SUBSTRUCTURE 6 CONCRETE FOOTINGS
5:-0:: X 5:-0:: ON STEEL PILES FOR STEEL TOWERS SINGLE TRACK
E45 32 FT TIMBER, E45 80 FT STEEL OR E80 80 FT STEEL
MAXIMUM COMBINED SPANS

860306F RAILROAD BRIDGE SUBSTRUCTURE TIMBER GRILLAGE FOOTINGS
2500 PSF FOUNDATION SOIL CAPACITY FOR STEEL TOWERS
SINGLE TRACK FOR E45 32 FT TIMBER, E45 80 FT STEEL
OR E80 80 FT STEEL MAXIMUM COMBINED SPANS

860306G RAILROAD BRIDGE SUBSTRUCTURE 6 TIMBER FOOTINGS
10:-0:: X 10:-0:: 2500 PSF FOUNDATION SOIL CAPACITY FOR STEEL
TOWERS SINGLE TRACK FOR E45 32 FT TIMBER, E45 80 FT
STEEL OR E80 80 FT STEEL MAXIMUM COMBINED SPANS

860306H RAILROAD BRIDGE SUBSTRUCTURE 6 TIMBER FOOTINGS
7:-0:: X 7:-0:: 5000 PSF FOUNDATION SOIL CAPACITY FOR STEEL
TOWERS SINGLE TRACK FOR E45 32 FT TIMBER E45 80 FT
STEEL OR E80 80 FT STEEL MAXIMUM COMBINED SPANS

860306J RAILROAD BRIDGE SUPERSTRUCTURE WALKWAY
16 FT TIMBER STRINGER SPAN, SQUARE ENDS

860306K RAILROAD BRIDGE SUPERSTRUCTURE WALKWAY
16 FT TIMBER STRINGER SPAN 30 DEG SKEW ENDS

860306L RAILROAD BRIDGE SUPERSTRUCTURE WALKWAY
20 FT STEEL STRINGER SPAN SQUARE ENDS

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		HOR	VERT	GENL	TOT			
86030GM	RAILROAD BRIDGE SUPERSTRUCTURE WALKWAY 20 FT STEEL STRINGER SPAN 30 DEG SKEW ENDS	2	3	1,533	5	30	18	53
86030GN	RAILROAD BRIDGE SUPERSTRUCTURE WALKWAY 30 FT STEEL STRINGER SPAN SQUARE ENDS	4	4	2,218	5	36	23	64
86030GP	RAILROAD BRIDGE SUPERSTRUCTURE WALKWAY 30 FT STEEL STRINGER SPAN 30 DEG SKEW ENDS	4	4	2,227	5	36	23	64
86030GR	RAILROAD BRIDGE SUPERSTRUCTURE WALKWAY 40 FT STEEL STRINGER SPAN SQUARE ENDS	5	5	2,993	6	44	28	78
86030GT	RAILROAD BRIDGE SUPERSTRUCTURE WALKWAY 40 FT STEEL STRINGER SPAN 30 DEG SKEW ENDS	5	5	2,989	6	44	28	78
86030GU	RAILROAD BRIDGE SUBSTRUCTURE TIMBER PLATFORMS FOR TIMBER PILE PIER FACILITIES 86030BM THRU BR AND FOR TIMBER TOWER FACILITIES 86030CN THRU CY	1	1	138		39	9	48
86030GV	RAILROAD BRIDGE SUBSTRUCTURE TIMBER PLATFORMS FOR TIMBER PILE PIER FACILITIES 86030BS THRU CA	1	1	155		44	9	53
86030GW	RAILROAD BRIDGE SUBSTRUCTURE TIMBER PLATFORMS FOR STEEL PILE PIER FACILITIES 86030CB THRU CG	1	1	172		44	9	53
86030GY	RAILROAD BRIDGE SUBSTRUCTURE TIMBER PLATFORMS FOR TIMBER TOWER FACILITIES 86030CH THRU CM	1	2	269		79	17	96
86030HA	RAILROAD BRIDGE SUBSTRUCTURE TIMBER PLATFORMS FOR STEEL TOWER FACILITIES 86030DT THRU EA	1	2	279		79	17	96
86030HB	RAILROAD BRIDGE SUBSTRUCTURE TIMBER PLATFORMS FOR STEEL TOWER FACILITIES 86030EB THRU EQ	1	2	725		61	9	50
86030TP	BOMB DAMAGE REPAIR TO A RAILROAD BRIDGE ONE 40 FT, FOUR-BEAM SPAN AND ONE 30 FT PIER	32	29	14,503	150	676	497	1,323

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					WOR	VERT	GENL	TOT
86040AA	RAILROAD COAL LOADING PLATFORM W/TIMBER FOOTINGS, SUBSTRUCTURE & DECK, 12 X 84	22	32	5,496	219	435	155	829
86091AA	RAILHEAD, BREAKBULK W/HARDSTAND 110FT X 110FT AND RAILROAD UNLOADING PLATFORM W/RAMPS. REQUIRES 32.3 CY LOCAL AGGREGATE AND 445.0 CY EARTH FILL.	108	78	4,328	316	106	267	689
86091AB	RAILHEAD, CONTAINER W/HARDSTAND 110FT X 110FT. REQUIRES 30.6 LOCAL AGGREGATE.	134	111	3,158	342		146	488
87190AB	CLEARING & GRUBBING, ONE ACRE				39		41	80
87190AC	GRADING & DRAINAGE, 1000 CU YD				368		437	805
87190AD	CLEARING & GRUBBING, ONE LINEAR MILE X 50 FT WIDE				23		23	46
87190AE	SITE PREPARATION FOR COMBAT SUPPORT HOSPITAL, MUST, STANDARD.	173	160	534,349	1,757		639	2,396
87190AG	SITE PREPARATION FOR EVACUATION HOSPITAL, STANDARD.	189	205	428,601	1,757		639	2,396
87210AA	CHAINLINK FENCE WITH TWO OUTRIGGERS, 1000 LINEAL FEET TYPE A 10 FEET HIGH	17	31	12,074	144		460	604
87210AB	BARBED WIRE FENCE WITH TWO OUTRIGGERS, 1000 LINEAL FEET, TYPE B, 10 FEET HIGH	6	8	1,673	403	690	690	1,783
87210AD	TRIPLE CONCERTINA BARBED TAPE OBSTACLE 1000 LINEAL FEET, TYPE D	117	70	1,962	32		129	161
87210AE	CHAINLINK FENCE WITH 18 INCH COIL BARBED TAPE AT TOP 1000 LINEAL FEET TYPE E 10 FEET HIGH	15	60	7,488	144		460	604
87210AF	PERSONNEL GATE CHAINLINK FENCE-10 FEET HIGH X 3 FEET WIDE SINGLE LEAF-TWO PANEL W/GATE	1	2	279	7		14	21
87210AG	VEHICLE GATE CHAINLINK FENCE-10 FEET HIGH BY 12 FOOT OPNG DOUBLE LEAF-TWO PANEL W/GATE	1	2	401	8		17	25

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	IN MAN-HOURS	
					HOR	VERT	GENL	TOT
87210AH	PERSONNEL GATE-BARBED WIRE FENCE-SINGLE LEAF-3 FT X 7 FT OPENING IN	1	1	358	8	12	5	25
87210AJ	CORNER POST ASSEMBLY CHAINLINK FENCE 2 PANEL W/CORNER POST 10 FEET HIGH			109	12		9	21
87210AK	CORNER POST ASSEMBLY, BARBED WIRE FENCE 2 PANEL W/CORNER POST 10 FEET HIGH	1	1	127	10	16	16	42
87210AL	VEHICLE GATE CHAINLINK FENCE-10 FEET HIGH BY 32 FOOT OPNG DOUBLE LEAF-TWO PANEL W/GATE	1	2	401	8		17	25
87210AM	VEHICLE GATE, BARBED WIRE FENCE-10 FT HIGH BY 12 FOOT OPENING-SINGLE LEAF	2	2	1,023	8	12	16	36
87210AN	SECURITY FENCE, TYPE W, WARNING FENCE W/LIGHTING, 1000 FT UNIT	9	10	3,141	53	543	294	890
87210AP	SECURITY FENCE, TYPE X, PROTECTIVE FENCE W/O LIGHTING, 1000 FT UNIT	8	9	1,656	53	292	294	639
87210AR	SECURITY FENCE, TYPE Y, INTERIOR FENCE W/O LIGHTING, 1000 FT UNIT	7	8	1,404	55	255	258	568
87210AT	VEHICLE & MAN GATE FOR SECURITY FENCE	2	2	332	9	138	55	202
87210AU	SECURITY FENCE, TYPE X CONVERTED TO TYPE W, 1000 FT UNIT	1	1	1,498		248		248
87210AV	DOUBLE APRON FENCE, 4&2 PACE,U-TYPE POSTS,100 YARDS,91.44 METERS,REFER TO FM 5-15	20	12	206	1	25	26	
87210AW	FOUR-STRAND PROTECTIVE FENCE,U-TYPE POSTS,100 YARDS,91.44 METERS,REFER TO FM 5-15	1		81	1	9	10	
87210AY	TRIPLE STANDARD CONCERTINA FENCE,U-TYPE POSTS,100 YARDS, 91.44 METERS,REFER TO FM 5-15	1	3	3,842	122	610	732	

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
87220AA	GUARD TOWER, 11 X 11 PLATFORM SHELTERED, 14 FT HIGH
87220AC	GUARD TOWER, 16 X 24 PLÄTFORM W/B X 8 SHELTER, 15 FT HIGH
87230AA	SENTRY BOX 4X4
89045BG	MECHANICAL EQUIPMENT - 106 TONS/1940 KBH
89045BJ	MECH.EQMT.-150 TONS/3000 KBH
89045BK	MECHANICAL EQUIPMENT - 205 TONS/1940 KBH
89050AA	ICE PLANT, 1 TON PER DAY, WOOD FRAME, 20 X 24, GROSS STORAGE 1260 CU FT, NET STORAGE 450 CU FT OR 5.4 TONS, W/SKID MOUNTED GASOLINE UNIT
89050AB	ICE PLANT, 3.6 TONS PER DAY, WOOD FRAME, 20 X 31, GROSS STORAGE 1260 CU FT NET STORAGE 490 CU FT OR 5 TONS, W/ELECTRIC DRIVEN UNIT
89050AC	ICE PLANT, 15 TONS PER DAY, WOOD FRAME BLDG W/METAL ROOF & CLADDING, 40 X 60, GROSS STORAGE 9200 CU FT, NET STORAGE 4130 CU FT OR 100 TON MAX
93101AA	TYPE IV,40 FT WIDE 80 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT,.6 IN CONC FLR.4 2-3FTX4FT FIXED WINDOWS.4 2-3FTX7FT PERS DOORS.1 12FTXT2FT SINGLE SLIDE DOOR.2FT-6INX3IN LOUVER CONT RIDGE ROOF VENT,ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.
93101AB	TYPE IV,40 FT WIDE 60 FT LONG,12 FT CLDG HEIGHT,14 FT EAVE HEIGHT,.6IN CONC FLR.3 3FTX4FT FIXED WINDOWS.PRE-ENGINEERED METAL BLDG.
93101AC	TYPE IV,40 FT WIDE 60 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT,.6IN CONC FLR.2 3FTX4FT AND 1 2-3FTX4FT FIXED WINDOWS 3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT,ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL						
WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	IN MAN-HOURS	
			HOR	VERT	GENL	TOT
3	4	7,053	8	83	51	142
6	10	1,607	31	94	69	176
		122	109	460	230	799
9	17	31,000	155	2,297	991	3,443
13	4	83,000	138	2,209	974	3,321
10	18	33,000	200	2,431	1,135	3,766
21	43	10,200		817	184	1,001
61	294	57,164	71	1,067	299	1,437
137	368	73,436		2,685	702	3,387
9	161	39,918	207	2,070	1,035	3,312
6	75	21,601	115	1,150	575	1,860
7	113	28,293	150	1,695	748	2,393

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			
					<u>HOR</u>	<u>VERT</u>	<u>GENL</u>	<u>TOT</u>
93101AD	TYPE IV,40 FT WIDE 80 FT LONG,12 FT CLDG HEIGHT,14 FT EAVE HEIGHT,.6IN CONC FLR.1 6FTX4FT SLIDING WINDOW.1 2-3FTX7FT AND 2 3FTX7FT PERS DOORS.4 PAIRS AND 6 SINGLES 2FT-6INX3FT LOUVERS W/FILTER.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6. PRE-ENGINEERED METAL BLDG.	8	.161	32,431	161	1,610	805	2,576
93101AE	TYPE IV,40 FT WIDE 140 FT LONG,12 FT CLDG HEIGHT,14 FT EAVE HEIGHT,.6IN CONC FLR.3 6FTX4FT SLIDING WINDOWS.2 3FTX7FT AND 2 2-3FTX7FT PERS DOORS.10 PAIR AND 1 SINGLE 2FT-6INX3FT LOUVERS W/FILTER.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6. PRE-ENGINEERED METAL BLDG.	14	.263	55,428	322	3,220	1,610	5,152
93101AF	TYPE II,40 FT WIDE 180 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT,.6IN CONC FLR.14 2-3FTX5FT COM PROJ WINDOWS.4 2-3FTX 7FT PERS DOORS.9 ROUND CONT RIDGE ROOF VENTS.PRE-ENGINEERED METAL BLDG.	16	.355	63,663	368	3,680	1,840	5,888
93101AG	TYPE V,20 FT WIDE 180 FT LONG,15 FT CLDG HEIGHT,18 FT EAVE HEIGHT.2 12FTX14FT SINGLE SLIDE DOORS.CONT RIDGE ROOF VENT. PRE-ENGINEERED METAL BLDG.	9	.170	36,213	262	2,415	1,208	3,865
93101AH	TYPE II,40 FT WIDE 100 FT LONG,15 FT CLDG HEIGHT,18 FT EAVE HEIGHT,.6IN CONC FLOOR.6 2-3FTX5FT COM PROJ WINDOWS. 1 3FTX7FT AND 5 2-3FTX7FT PERS DOORS.2 2-6FTX12FT DBL SLIDE DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	9	.180	36,670	299	2,990	1,610	4,899
93101AJ	TYPE II,40 FT WIDE 40 FT LONG,12 FT CLDG HEIGHT,16 FT EAVE HEIGHT,.6IN CONC FLR.6 2-3FTX5FT COM PROJ WINDOWS.2 2-5FTX10 FT DBL SLIDE DOORS CONT RIDGE ROOF VENT PRE-ENGINEERED METAL BLDG.	4	.75	15,783	127	1,265	635	2,025
93101AK	TYPE II,40 FT WIDE 60 FT LONG,12 FT CLDG HEIGHT,16 FT EAVE HEIGHT,.6IN CONC FLR.6 2-3FTX5FT COM PROJ WINDOWS.2 2-5FTX10 FT DBL SLIDE DOORS.CONT RIDGE ROOF VENT.BATT R-6.PRE- ENGINEERED METAL BLDG.	6	.113	22,228	138	1,380	690	2,208
93101AL	TYPE II,80 FT WIDE 240 FT LONG,12 FT CLDG HEIGHT,16 FT EAVE HEIGHT,.6IN CONC FLR.23 2-3FTX5FT COM PROJ WINDOWS. 2 10FTX12FT SINGLE SLIDE AND 5 2-5FTX12FT DBL SLIDE DOORS. CONT RIDGE ROOF VENT.BATT R-6.PRE-ENGINEERED METAL BLDG.	41	.875	164,728	1,231	12,305	5,980	19,516

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST HHR	EFFORT IN MAN-HOURS	VERT	GENL	TOT
93101AH	TYPE III,80 FT WIDE 240 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT,6IN CONC FLR.18 2-3FTX5FT COM PROJ WINDOWS.6 2-3FTX7FT PERS DOORS.6 2-3FTX16FT DBL SLIDE AND 4 12FTX16FT SINGLE SLIDE DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	42	875	166,120	1,231	12,305	3,980	19,510	
93101AN	TYPE II,40 FT WIDE 180 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT.EARTH FLR.16 2-3FTX5FT COM PROJ WINDOWS.8 2-3FTX7FT PERS DOORS.2 14FTX16FT SINGLE SLIDE DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	18	355	74,033	460	4,600	2,300	7,360	
93101AP	TYPE III,80 FT WIDE 160 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT.EARTH FLR.14 2-3FTX5FT COM PROJ WINDOWS.7 2-3FT X7FT PERS DOORS.4 14FTX16FT SINGLE SLIDE DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	31	625	125,205	828	8,280	4,140	13,248	
93101AR	TYPE VI,20 FT WIDE 160 FT LONG,15 FT CLDG HEIGHT,18 FT EAVE HEIGHT.4IN CONC FLR.2 2-7FTX14FT DBL SLIDE DOORS.16-ROUND ROOF VENT.PRE-ENGINEERED METAL BLDG.	13	160	52,805	207	2,070	1,035	3,312	
93101AT	TYPE III,80 FT WIDE 240 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT.EARTH FLR.22 2-3FTX5FT COM PROJ WINDOWS.12 2-3FTX7FT PERS DOORS.4 14FTX16FT SINGLE SLIDE DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	43	875	171,740	1,231	12,305	3,980	19,510	
93101AU	TYPE VI,20 FT WIDE 240 FT LONG,15 FT CLDG HEIGHT,18 FT EAVE HEIGHT.CONC FLR.1 14FTX12FT SINGLE SLIDE DOOR.24-ROUND ROOF VENT.PRE-ENGINEERED METAL BLDG.	17	212	63,140	345	3,450	1,725	5,520	
93101AV	TYPE II,80 FT WIDE 200 FT LONG,12 FT CLDG HEIGHT,16 FT EAVE HEIGHT.4IN CONC FLOOR.16 3FTX5FT COM PROJ WINDOWS.4 12FTX 10FT SINGLE SLIDE DOORS.2 24INX24IN AUTOMATIC AND 1 24INX 24IN LIGHT PROOF LOUVERS.CONTINIOUS RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	37	775	147,153	690	6,900	3,450	11,040	
93101AW	TYPE IV,80 FT WIDE 100 FT LONG,12 FT CLDG HEIGHT,16 FT EAVE HEIGHT.4IN CONC FLR.16 3FTX5FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOOR.1 2-7FTX10FT DBL SLIDE AND 2-5FTX10FT DBL SLIDE DOORS.1-20INX20IN AUTOMATIC LOUVER.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	19	375	75,478	368	3,680	1,840	5,888	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL TOT
93101AY	TYPE IV,40 FT WIDE 100 FT LONG,12 FT CLDG HEIGHT,16 FT EAVE HEIGHT,4IN CONC FLOOR,16 3FTX5FT COM PROJ WINDOWS,2 3FTX7FT PERS DOORS,1 2-5FTX10FT DBL SLIDE DOOR,1-20INX20 IN AUTOMATIC LOUVER,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6 PRE-ENGINEERED METAL BLDG.	11	194	42,354	184	1,840	920 2,944
93101BA	TYPE II,40FT WIDE 300 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT,EARTH FLOOR,30 2-3FTX5FT COM PROJ WINDOWS,8 2-3FTX7FT PERS DOORS,2 2-6FTX16FT SWING TYPE DOORS,CONT RIDGE ROOF VENT,PRE-ENGINEERED METAL BLDG.	29	535	115,711	552	5,520	2,760 8,832
93101BB	TYPE V,20 FT WIDE 300 FT LONG,15 FT CLDG HEIGHT,18 FT EAVE HEIGHT,15-ROUND ROOF VENT, PRE-ENGINEERED METAL BLDG.	17	278	69,961	276	2,760	1,380 4,616
93101BC	TYPE V,20 FT WIDE 140 FT LONG,15 FT CLDG HEIGHT,18 FT EAVE HEIGHT,22-ROUND ROOF VENT,PRE-ENGINEERED METAL BLDG.	12	138	47,945	161	1,610	805 2,576
93101BD	TYPE II,40 FT WIDE 80 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT,EARTH FLOOR,8 2-3FTX5FT COM PROJ WINDOWS,2 2-3FTX7FT PERS DOORS,4 2-6FTX16FT SWING TYPE DOORS,CONT RIDGE ROOF VENT,PRE-ENGINEERED METAL BLDG.	9	158	37,445	161	1,610	805 2,576
93101BE	TYPE V,20 FT WIDE 80 FT LONG,15 FT CLDG HEIGHT,18 FT EAVE HEIGHT,4-ROUND ROOF VENT,PRE-ENGINEERED METAL BLDG.	6	80	25,245	127	1,265	633 2,025
93101BF	TYPE II,40 FT WIDE 220 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT,EARTH FLOOR,22 2-3FTX5FT COM PROJ WINDOWS,4 2-3FTX7FT PERS DOORS,4 2-6FTX16FT SWING TYPE DOORS,CONT RIDGE ROOF VENT,PRE-ENGINEERED METAL BLDG.	22	415	87,419	518	5,175	2,645 8,338
93101BG	TYPE V,20 FT WIDE 100 FT LONG,15 FT CLDG HEIGHT,18 FT EAVE HEIGHT,4IN CONC FLOOR,5-ROUND ROOF VENT,PRE-ENGINEERED METAL BLDG.	9	95	36,169	127	1,265	633 2,025
93101BH	TYPE II,40 FT WIDE 120 FT LONG,20 FT CLDG HEIGHT,24 FT EAVE HEIGHT,4IN CONC FLOOR,15 2-3FTX5FT COM PROJ WINDOWS,2 3FTX7FT PERS DOORS,4 2-7FTX16FT SWING TYPE DOORS,CONT RIDGE ROOF VENT,PRE-ENGINEERED METAL BLDG.	14	212	54,146	345	3,450	1,725 5,520

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION	CONSTRUCTION MATERIAL					
		WT SHT TONS	VOL MEAS TONS	COST 3	CONST EFFORT IN MAN-HOURS		
					HOR	VERT	GENL
93101BJ	TYPE IV,40 FT WIDE 100 FT LONG,14 FT CLDG HEIGHT,16 FT EAVE HEIGHT,4IN CONC FLOOR.24 3FTX4FT SINGLE WINDOWS.4 2-3FTX7FT DOORS.11-24INX24IN AUTOMATIC LOUVERS.CONT RIDGE ROOF VENT. ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	16	194	66,894	253	2,530	1,265 4,048
93101BK	TYPE I,20 FT WIDE 50 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR.12 3FTX4FT SINGLE HG W/GDS WINDOWS. 2 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	3	50	10,546	69	690	343 1,104
93101BL	TYPE I,20 FT WIDE 100 FT LONG,8 FT CLDG HEIGHTS,10 FT EAVE HEIGHT,4IN CONC FLOOR.18 3FTX4FT SINGLE HG W/GDS WINDOWS. 2 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	5	95	19,318	127	1,265	633 2,025
93101BM	TYPE I,40 FT WIDE 100 FT LONG,12 FT CLDG HEIGHT,16 FT EAVE HEIGHT,6IN CONC FLOOR.6 3FTX4FT SINGLE HG W/GDS WINDOWS. 4 6FTX10FT SINGLE SLIDE DOORS.CONT RIDGE ROOF VENT.PRE- ENGINEERED METAL BLDG.	9	194	36,428	253	2,530	1,265 4,048
93101BN	TYPE II,80 FT WIDE 220 FT LONG,12 FT CLDG HEIGHT,16 FT EAVE HEIGHT,6IN CONC FLOOR.22 3FTX4FT SINGLE HG W/GDS WINDOWS. 6 6FTX10FT SINGLE SLIDE DOORS.CONT RIDGE ROOF VENT.PRE- ENGINEERED METAL BLDG.	35	198	138,983	115	1,150	575 1,840
93101BP	TYPE I,20 FT WIDE 20 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR.2 3FTX4FT SINGLE HG W/GDS WINDOWS. 1 2-3FTX7FT DOOR.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	1	5	4,215	23	230	113 368
93101BR	TYPE I,20 FT WIDE 30 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR.2 3FTX4FT SINGLE HG W/GDS WINDOWS. 1 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.	1	7	5,816	35	343	173 993
93101BT	TYPE I,30 FT WIDE 70 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR.10 3FTX4FT SINGLE HG W/GDS WINDOWS. 6 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	6	26	23,456	138	1,380	690 2,208

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
93101BU	TYPE I,30 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,17 3FTX4FT SINGLE HG W/GDS WINDOWS. 4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
93101BV	TYPE I,30 FT WIDE 100 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,18 3FTX4FT SINGLE HG W/GDS WINDOWS. 4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
93101BW	TYPE I,30 FT WIDE 110 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,22 3FTX4FT SINGLE HG W/GDS WINDOWS. 4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
93101BY	TYPE I,30 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,15 3FTX4FT SINGLE HG W/GDS WINDOWS. 4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
93101CA	TYPE I,30 FT WIDE 110FTLONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,19 3-3FTX4FT SINGLE HG W/GDS WINDOWS. 4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
93101CB	TYPE I,30 FT WIDE 40 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,7 3FTX4FT SINGLE HG W/GDS WINDOWS. 3 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
93101CC	TYPE I,30 FT WIDE 50 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,9 3FTX4FT SINGLE HG W/GDS WINDOWS. 3 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
93101CD	TYPE IV,40 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,8 3FTX4FT SINGLE HG AND 9 3FTX4FT SINGLE HG W/GDS WINDOWS,4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL						
WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	IN MAN-HOURS	GENL	TOT
HOR	VERT					
7	30	28,596	173	1,725	863	2,761
8	34	31,353	184	1,840	920	2,944
8	37	34,491	207	2,070	1,035	3,312
7	30	28,341	173	1,725	863	2,761
10	37	38,954	207	2,070	1,035	3,312
3	14	13,673	81	805	403	1,289
6	17	16,556	92	920	660	1,672
8	41	35,304	230	2,300	1,150	3,680

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

93101CE TYPE IV,40 FT WIDE 110 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,10 3FTX4FT SINGLE HG AND 12 3FTX4FT SINGLE HG W/GDS WINDOWS,4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CF TYPE IV,40 FT WIDE 120 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,10 3FTX4FT SINGLE HG AND 13 3FTX4FT SINGLE HG W/GDS WINDOWS,4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CG TYPE IV,30 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,7 3FTX4FT SINGLE HG AND 9 3FTX4FT SINGLE HG W/GDS WINDOWS,4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CH TYPE IV,30 FT WIDE 100 FT LONG,8FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,21 3FTX4FT SINGLE HG WINDOWS,3 2-3FT X7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CJ TYPE IV,40 FT WIDE 260 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,33 3FTX4FT SINGLE HG AND 13 3FTX4FT SINGLE HG W/GDS WINDOWS,7 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CK TYPE IV,30 FT WIDE 70 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,8 3FTX4FT SINGLE HG AND 2 3FTX4FT SINGLE HG W/GDS WINDOWS,3 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CL TYPE IV,30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,6 3FTX4FT SINGLE HG AND 3 3FTX4FT SINGLE HG W/GDS WINDOWS,3 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CM TYPE IV,40 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,20 3FTX4FT SINGLE HG WINDOWS,3 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
			HOR	VERT	GENL	TOT
11	50	42,634	276	2,760	1,380	4,416
11	54	46,108	311	3,105	1,553	4,969
7	30	28,475	173	1,725	863	2,761
8	34	31,230	184	1,840	920	2,964
20	117	93,923	667	6,670	3,335	10,672
6	24	21,941	138	1,380	690	2,208
5	20	19,185	115	1,150	575	1,860
9	41	35,181	230	2,300	1,150	3,680

DHDXER1

RUN DATE 860128

DESERT CLIMATEFACILITY
NUMBERDESCRIPTION

93101CN TYPE IV,30 FT WIDE 80 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,17 3FTX4FT SINGLE HG WINDOWS,3 2-3FTX 7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6.
PRE-ENGINEERED METAL BLDG.

93101CP TYPE IV,40 FT WIDE 150 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,28 3FTX4FT SINGLE HG WINDOWS,2 2-3FTX 7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6.
PRE-ENGINEERED METAL BLDG.

93101CR TYPE IV,40 FT WIDE 110 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,21 3FTX4FT SINGLE HG WINDOWS,
2 2-3FTX7FT PERS DOORS,4-24INX24IN AUTOMATIC LOUVERS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CT TYPE IV,40 FT WIDE 100 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,18 3FTX4FT SINGLE HG WINDOWS,3 2-3FTX 7FT PERS DOORS,2-24INX24IN AUTOMATIC LOUVERS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CU TYPE IV,40 FT WIDE 120 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,19 3FTX4FT SINGLE HG WINDOWS,3 2-3FTX 7FT PERS DOORS,2-12INX12IN AUTOMATIC LOUVERS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CV TYPE IV,40 FT WIDE 100 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,17 3FTX4FT SINGLE HG WINDOWS,3 2-3FTX XFT PERS DOORS,2-T2INXT2IN AUTOMATIC LOUVERS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

93101CW TYPE IV,30 FT WIDE 100 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,19 3FTX4FT SINGLE HG WINDOWS,3 2-3FTX 7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6.
PRE-ENGINEERED METAL BLDG.

93101CY TYPE IV,30 FT WIDE 100 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,19 3FTX4FT SINGLE HG WINDOWS,3 2-3FTX 7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6.
PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
7	27	25,344	161	1,610	805	2,576
14	68	55,776	391	3,910	1,955	6,256
11	50	41,874	276	2,760	1,380	4,416
10	45	38,461	265	2,665	1,323	4,233
12	54	45,140	311	3,105	1,553	4,969
9	45	38,193	276	2,760	1,380	4,416
8	34	31,035	196	1,955	978	3,129
8	34	31,035	196	1,955	978	3,129

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	SHT TONS	MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
93101DA	TYPE IV,30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS. 4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	4	20	16,301	115	1,150	575	1,860
93101DB	TYPE IV,30 FT WIDE 50 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.7 3FTX4FT SINGLE HG WINDOWS. 3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	4	17	13,923	92	920	460	1,472
93101DC	TYPE IV,30 FT WIDE 40 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.5 3FTX4FT SINGLE HG WINDOWS.4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6. PRE-ENGINEERED METAL BLDG.	8	14	31,788	81	805	403	1,289
93101DD	TYPE IV,40 FT WIDE 80 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.16 3FTX4FT SINGLE HG AND 2 3FTX4FT FIXED WINDOWS. 3 2-3FTX7FT PERS DOORS.2-24INX24 LIGHTPRF LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	8	36	35,258	207	2,070	1,035	3,312
93101DE	TYPE IV,40 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.20 3FTX4FX SINGLE HG WINDOWS. 3 2-3FTX7FT PERS DOORS.2-24INX24IN LIGHTPRF LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	8	41	35,258	230	2,300	1,150	3,680
93101DF	TYPE IV,40 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.16 3FTX4FT SINGLE HG WINDOWS. 3 2-3FTX7FT PERS DOORS.1-24INX24IN LIGHTPRF LOUVER.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	8	41	34,704	230	2,300	1,150	3,680
93101DG	TYPE IV,40 FT WIDE 110 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.21 3FTX4FT SINGLE HG WINDOWS. 4 2-3FTX7FT PERS DOORS.2-24INX24IN LIGHTPRF LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	11	50	42,775	276	2,760	1,380	4,416

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
93101DH	TYPE IV.30 FT WIDE 130 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.26 3FTX4FT SINGLE HG WINDOWS. 4 2-3FTX7FT PERS DOORS.1-24INX24IN LIGHTPROOF LOUVER.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	11	44	40,304	253	2,530	1,265	4,048
93101DJ	TYPE IV.30 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.19 3FTX4FT SINGLE HG WINDOWS. 4 2-3FTX7FT PERS DOORS.1-24INX24IN LIGHTPRF LOUVER.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	8	30	28,896	173	1,725	863	2,761
93101DK	TYPE IV.30 FT WIDE 40 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.13 3FTX4FT SINGLE HG (OBSCURE GLASS IN TOILETS)WINDOWS.2 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	4	14	13,933	81	805	403	1,289
93101DL	TYPE IV.30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.11 3FTX6FT SINGLE HG WINDOWS. 4 2-3FTX7FT PERS DOORS.1-24INX24IN LIGHTPRF LOUVER.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	5	20	19,990	115	1,150	575	1,840
93101DM	TYPE IV.30 FT WIDE 80 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.13 3FTX4FT SINGLE HG WINDOWS. 6 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	7	27	26,600	161	1,610	805	2,576
93101DN	TYPE IV.30 FT WIDE 40 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.15 3FTX4FT SINGLE HG WINDOWS. 6 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	7	14	29,351	173	1,725	863	2,761
93101DP	TYPE IV.30 FT WIDE 70 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.11 3FTX4FT SINGLE HG WINDOWS. 5 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	6	24	23,079	138	1,380	690	2,208

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

93101DR TYPE VI,20 FT WIDE 60 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT,.4IN CONC FLOOR.12 3FTX4FT SINGLE HG AND 1 3FTX4FT SINGLE HG W/GDS WINDOWS.2 2-3FTX7FT PERS DOORS.1-24INX24IN LIGHTPRF LOUVER.3-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101DT TYPE VI,20 FT WIDE 60 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT,.4IN CONC FLOOR.15 3FTX4FT SINGLE HG AND 2 3FTX6FT SINGLE HG W/GDS WINDOWS.2 2-3FTX7FT PERS DOORS.3-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101DU TYPE VI,20 FT WIDE 70 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT,.4IN CONC FLOOR.15 3FTX4FT SINGLE HG AND 1 3FTX4FT SINGLE HG W/GDS WINDOWS.2 2-3FTX7FT PERS DOORS.3-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101DV TYPE VI,20 FT WIDE 100 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT,.4IN CONC FLOOR.19 3FTX6FT SINGLE HG AND 1 3FTX4FT SINGLE HG W/GDS WINDOWS.2 2-3FTX7FT PERS DOORS.1-24INX24IN LIGHTPRF LOUVER.5-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101DW TYPE IV,60 FT WIDE 110 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.2IN CONC FLOOR.21 3FTX4FT SINGLE HG W/GDS WINDOWS.3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101DY TYPE IV,30 FT WIDE 80 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.17 3FTX4FT SINGLE HG WINDOWS.4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101EA TYPE IV,30 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.19 3FTX4FT SINGLE HG WINDOWS.4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS				TOT
			HOR	VERT	GENL	TOT	
1	14	13,764	81	805	403	1,289	
5	18	18,108	104	1,035	518	1,657	
4	16	16,024	92	920	460	1,672	
6	23	21,577	127	1,265	633	2,025	
11	50	62,301	276	2,760	1,380	4,416	
7	27	27,344	161	1,610	805	2,576	
8	30	28,841	173	1,725	863	2,761	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
93101EB	TYPE IV,30 FT WIDE 110 FT WIDE,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,22 3FTX4FT SINGLE HG WINDOWS. 4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	8	37	34,491	207	2,070	1,035	3,312
93101EC	TYPE IV,30 FT WIDE 110 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,17 3FTX4FT SINGLE HG AND 5 3FTX4FT SINGLE HG W/GDS WINDOWS,3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	8	37	33,986	207	2,070	1,035	3,312
93101ED	TYPE VI,20 FT WIDE 30 FT LONG,8 FT (LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT,.4IN CONC FLOOR,.6 3FTX4FT SINGLE HG WINDOWS,2 2-3FTX7FT PERS DOORS,2-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	2	7	7,783	35	365	173	333
93101EE	TYPE VI,20 FT WIDE 50 FT LONG,8 FT (LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT,.4IN CONC FLOOR,10 3FTX4FT SINGLE HG WINDOWS,2 2-3FTX7FT PERS DOORS,2-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	3	11	11,663	69	690	345	1,104
93101EF	TYPE II,40 FT WIDE 100 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,24 3FTX4FT SINGLE HG WINDOWS. 4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	11	45	42,343	265	2,645	1,323	4,233
93101EG	TYPE VI,20 FT WIDE 40 FT LONG,8 FT (LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT,.4IN CONC FLOOR,.8 3FTX4FT SINGLE HG WINDOWS,2 2-3FTX7FT PERS DOORS,3-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	3	9	10,175	46	460	230	736
93101EH	TYPE VI,20 FT WIDE 100 FT LONG,8 FT (LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT,.4IN CONC FLOOR,19 3FTX4FT SINGLE HG WINDOWS,4 2-3FTX7FT PERS DOORS,5-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	6	23	24,035	127	1,265	633	2,025
93101EJ	TYPE IV,30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR,11 3FTX4FT SINGLE HG WINDOWS. 3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	5	20	19,440	115	1,150	575	1,840

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST \$	CONST EFFORT IN MAN-HOURS			
						HOR	VERT	SEAL	TOT
93101EK	TYPE IV,30 FT WIDE 100 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,19 3FTX4FT SINGLE HG WINDOWS. 3 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.	8	34		30,975	184	1,840	920	2,966
93101EL	TYPE III,80 FT WIDE 180 FT LONG,10FT CLDG HEIGHT,14 FT EAVE HEIGHT,4IN CONC FLOOR,35 3FFX5FT COM PROJ WINDOWS. 9 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.	31	162		124,039	920	9,200	4,600	14,720
93101EM	TYPE II,20 FT WIDE 40 FT LONG,10 FT CLDG HEIGHT,14 FT EAVE HEIGHT,4 3FTX4FT COM PROJ WINDOWS,PRE-ENGINEERED METAL BLDG	2	9		9,284	46	460	230	736
93101EN	TYPE III,120 FT WIDE 80 FT LONG,10 FT CLDG HEIGHT,14 FT EAVE HEIGHT,4IN CONC FLOOR,29 3FTX5FT COM PROJ WINDOWS. 7 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.	21	108		85,890	621	6,210	3,105	9,936
93101EP	TYPE II,20 FT WIDE 20 FT LONG,10 FT CLDG HEIGHT,14 FT EAVE HEIGHT,4 3FTX4FT COM PROJ WINDOWS,PRE-ENGINEERED METAL BLDG	1	5		5,099	23	230	115	368
93101ER	TYPE II,80 FT WIDE 100 FT LONG,10 FT CLDG HEIGHT,14 FT EAVE HEIGHT,4IN CONC FLOOR,26 3FTX5FT COM PROJ WINDOWS. 7 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.	18	90		70,132	529	5,290	2,645	8,464
93101ET	TYPE II,20 FT WIDE 20 FT LONG,10 FT CLDG HEIGHT,14 FT EAVE HEIGHT,2 3FTX4FT COM PROJ WINDOWS,PRE-ENGINEERED METAL BLDG	1	5		4,964	23	230	115	368
93101EU	TYPE II,40 FT WIDE 100 FT LONG,10 FT CLDG HEIGHT,14 FT EAVE HEIGHT,4IN CONC FLOOR,23 3FTX5FT COM PROJ WINDOWS. 4 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.	11	45		41,416	253	2,530	1,265	4,048
93101EV	TYPE II,42 FT WIDE 100 FT WIDE,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,4IN CONC FLOOR,15 2-3FTX4FT SINGLE HG AND 2 3FTX4FT SINGLE HG WINDOWS,4 2-3FTX7FT AND 2 3FTX7FT PERS DOORS. 34 3FTX3FT FIXED (UNDER EACH WINDOW) LOUVERS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-10,PRE-ENGINEERED METAL BLDG./TROPIC METAL BLDG 00004200SF	9	47		36,765	265	2,665	1,323	4,233

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

93101EW TYPE II,42 FT WIDE 100 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.15 2-3FTX4FT SINGLE HG AND 2 3FTX4FT SINGLE HG WINDOWS.4 2-3FTX7FT AND 2 3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101EY TYPE II,42 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.4 2-3FTX4FT SINGLE HG AND 2 3FTX4FT SINGLE HG WINDOWS.2 3FTX7FT AND 2 2-2FT6INX7FT PERS DOORS.10 3FTX3FT FIXED(UNDER EACH WINDOW)LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-10.TROPIC ZONE.PRE-ENGINEERED METAL BLDG.

93101FA TYPE II,42 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.4 2-3FTX4FT SINGLE HG AND 2 3FTX4FT SINGLE HG WINDOWS.2 3FTX7FT AND 2 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101FB TYPE II,42 FT WIDE 140 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.22 2-3FTX4FT SINGLE HG AND 1 3FTX4FT SINGLE HG WINDOWS.2 3FTX7FT AND 4 2-3FTX7FT PERS DOORS.45 3FTX3FT FIXED(UNDER EACH WINDOW)LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-10.TROPIC ZONE.PRE-ENGINEERED METAL BLDG.

93101FC TYPE II,42 FT WIDE 140 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.22 2-3FTX4FT SINGLE HG AND 1 3FTX4FT SINGLE HG WINDOWS.2 3FTX7FT AND 4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101FD TYPE II,42 FT WIDE 80 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.7 2-3FTX4FT SINGLE HG AND 1 3FTX4FT SINGLE HG WINDOWS.2 3FTX7FT AND 2 2-3FTX7FT PERS DOORS.15 3FTX3FT FIXED(UNDER EACH WINDOW)LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-10.TROPIC ZONE.PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS
11	47	42,533	265 2,645 1,323 4,233

HOR	VERT	GENL	TOT
7	28	27,029	161 1,610 805 2,576

161	1,610	805	2,576
-----	-------	-----	-------

16	66	62,175	368 3,680 1,840 5,888
----	----	--------	-----------------------

14	66	57,669	368 3,680 1,840 5,888
----	----	--------	-----------------------

8	38	33,898	207 2,070 1,035 3,312
---	----	--------	-----------------------

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

93101FE TYPE II,42 FT WIDE 80 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT.4IN CONC FLOOR.7 2-3FTX4FT SINGLE HG AND 1 3FTX4FT SINGL HG WINDOWS.2 3FTX7FT AND 2 3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLD.

93101FF TYPE VI,20 FT WIDE 20 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR. 4 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101FG TYPE VI,20 FT WIDE 10 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR. 4 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101FH TYPE VI,20 FT WIDE 10 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR. 4 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101FJ TYPE VI,20 FT WIDE 10 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR. 4 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101FK TYPE VI,10 FT WIDE 20 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.4 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101FL TYPE VI,10 FT WIDE 20 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.4 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101FM TYPE VI,20 FT WIDE 20 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.5 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
			HOR	VERY GENL	TOT	
8	38	31,890	207	2,070	1,035	3,312
1	5	5,088	23	230	115	368
1	2	3,409	12	115	58	185
1	2	3,409	12	115	58	185
1	2	3,409	12	115	58	185
1	2	3,409	12	115	58	185
1	2	3,409	12	115	58	185
1	5	5,215	23	230	115	368

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT	VOL	COST	CONST EFFORT IN MAN-HOURS			TOT
		SHT TONS	MEAS TONS		HOR	VERT	GENL	
93101FN	TYPE VI,20 FT WIDE 30 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.6 3FTX4FT COM PROJ WINDOWS.2 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	2	7	7,526	35	345	173	553
93101FP	TYPE VI,20 FT WIDE 30 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.10 3FTX4FT COM PROJ WINDOWS.2 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	1	11	5,215	69	690	345	1,104
93101FR	TYPE VI,20 FT WIDE 30 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.7 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	1	7	5,975	35	345	173	553
93101FU	TYPE VI,20 FT WIDE 30 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.10 3FTX4FT COM PROJ WINDOWS.2 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	3	11	9,873	69	690	345	1,104
93101FV	TYPE VI,20 FT WIDE 80 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.16 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	4	18	14,450	104	1,035	518	1,657
93101FY	TYPE VI,20FT WIDE 30 FT LONG,8FT(LOW PT)CLDG HEIGHT,10FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.5 3FTX4FT COM PROJ WINDOWS.1 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	2	7	6,894	35	345	173	553
93101GA	TYPE VI,20 FT WIDE 40 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.8 3FTX4FT COM PROJ WINDOWS.2 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	3	9	9,913	46	460	230	736
93101GB	TYPE VI,20 FT WIDE 60 FT LONG,8 FT(LOW PT)CLDG HEIGHT,10 FT (LOW SIDE)EAVE HEIGHT.2IN CONC FLOOR.10 3FTX4FT COM PROJ WINDOWS.2 2-3FTX7FT PERS DOORS.1 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	3	14	13,226	81	805	403	1,289

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

WT TONS	VOL TONS	COST \$	CONSTRUCTION MATERIAL			CONST EFFORT IN MAN-HOURS HOR	VERT GENL	TOT
			SHT	MEAS	CONST EFFORT IN MAN-HOURS TOT			
3	11	17,620			69	690	345	1,104
4	18	17,365			104	1,035	518	1,657
3	11	17,115			69	690	345	1,104
5	225	21,204			138	1,380	690	2,208
5	20	18,170			115	1,150	575	1,840
7	34	28,685			196	1,955	978	3,129
5	20	18,818			113	1,150	575	1,840
8	34	31,103			196	1,955	978	3,129

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
931016L	TYPE I,20 FT WIDE 40 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR,7 3FTX4FT COM PROJ WINDOWS. 1 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
931016M	TYPE I,20 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR,7 3FTX4FT SINGLE HG AND 4 3FTX4FT SNG HG W/GDS WINDOWS,2 2-3FTX7FT PERS DOORS,CONT RIDGE ROOF VEN PRE-ENGINEERED METAL BLDG.
931016N	TYPE IV,40 FT WIDE 80 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR,15 3FTX4FT COM PROJ WINDOWS. 1 2-3FTX7FT AND 3 3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT, ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
931016P	TYPE IV,30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR,8 3FTX4FT COM PROJ WINDOWS. 1 2-3FTX7FT AND 5 3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT, ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
931016R	TYPE I,20 FT WIDE 30 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR,6 3FTX4FT COM PROJ WINDOWS,1 2-3FT X 7FT AND 1 3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
931016T	TYPE I,20 FT WIDE 50 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR, 3FTX4FT COM PROJ WINDOWS,1 2-3FT X 7FT AND 1 3FTX7FT PERS DOORS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.
931016U	TYPE IV,40FT WIDE 100FT LONG,8 FT CLDG HEIGHT,12 FT EAVE HEIGHT,4IN CONC FLOOR,20 3FTX4FT COM PROJ WINDOWS 3 2-3FT X 7FT AND 1 3FTX7FT PERS DOORS,2 24INX24IN AUTOMATIC LOUVERS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED META BLDG.
931016V	TYPE II,80 FT WIDE 120 FT LONG,14 FT CLDG HEIGHT,18 FT EAVE HEIGHT,4IN CONC FLOOR,18 3FTX5FT COM PROJ WINDOWS,5 2-3FT X 7FT,AND 1 3FTX7FT PERS DOORS,2-24INX24IN AUTOMATIC AND 1-12INX12IN LIGHTPRF LOUVERS,CONT RIDGE ROOF VENT,ALL WALLS BATT R-6,PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL						
WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
3	9	9,543	46	460	230	736
4	14	14,033	69	690	345	1,104
8	36	30,945	207	2,070	1,035	3,312
5	20	19,310	115	1,150	575	1,860
2	7	7,756	35	363	173	553
3	11	12,089	58	575	288	921
10	45	39,636	253	2,530	1,265	4,048
20	116	90,490	621	6,210	3,105	9,936

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY

NUMBER

DESCRIPTION

93101GW TYPE I,20 FT WIDE 30 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR,6 3FTX4FT COM PROJ WINDOWS.
2 3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.

93101GY TYPE I,20 FT WIDE 50 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR,12 3FTX4FT COM PROJ WINDOWS.
4 3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.PRE-ENGINEERED METAL BLDG.

93101HA TYPE III,100 FT WIDE 200 FT LONG,14 FT CLDG HEIGHT,18 FT EAVE HEIGHT,4IN CONC FLOOR,21 3FTX5FT COM PROJ AND 1 2-3FT X5FT COM PROJ WINDOWS,4 2-3FTX7FT PERS DOORS,14-24INX24IN LIGHTPRF AND 3 30INX30IN AUTOMATIC LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101HB TYPE III,40 FT WIDE 100 FT LONG,14 FT CLDG HEIGHT,18 FT EAVE HEIGHT,4IN CONC FLOOR,14 3FTX5FT COM PROJ WINDOWS.
1 2-3FTX7FT PERS DOORS,12 24INX24IN LIGHTPRF AND 2 30INX30IN AUTOMATIC LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101HC TYPE II,60 FT WIDE 60 FT LONG,14 FT CLDG HEIGHT,18 FT EAVE HEIGHT,4IN CONC FLOOR,9 3FTX5FT COM PROJ WINDOWS.
2 3-7FT PERS DOORS,4 24INX24IN LIGHTPRF AND 1 30INX30IN AUTOMATIC LOUVERS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101HD TYPE I,40 FT WIDE 100FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,2IN CONC FLOOR,34 3FTX4FT COM PROJ WINDOWS.
2 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

93101HE TYPE III,80 FT WIDE 100FT LONG,18FT CLDG HEIGHT,18 FT EAVE HEIGHT,2IN CONC FLOOR,34 3FTX5FT COM PROJ WINDOWS.
2 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
			HOR	VERT	GENL	TOT
2	7	6,074	35	345	173	553
3	11	10,546	58	575	288	921
4	225	178,084	138	12,880	6,440	19,458
1	45	42,861	253	2,530	1,265	4,048
1	61	26,884	150	1,695	748	2,393
1	45	39,808	253	2,530	1,265	4,048
2	90	76,522	518	5,175	2,588	8,281

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					HOR	VERT	GENL	TOT
93101HF	TYPE VI,20 FT WIDE 60 FT LONG,8 FT (LOW PT) CLDG HEIGHT,10 FT (LOW SIDE) EAVE HEIGHT,2IN CONC FLOOR,.9 3FTX4FT SINGLE HG AND 2 3FTX4FT SINGLE HG W/GDS WINDOWS.1 2-3FTX7FT PERS DOOR 3-ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGD METAL BLDG.	3	16	12,864	35	345	173	553
93101HG	TYPE VI,20 FT WIDE 100FT LONG,8 FT (LOW PT) CLDG HEIGHT,10 FT (LOW SIDE) EAVE HEIGHT,2IN CONC FLOOR,.18 3FTX4FT SINGLE HG W/GDS WINDOWS,4 2-3FTX7FT PERS DOORS,4 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	6	23	21,458	127	1,265	633	2,025
93101HH	TYPE VI,20 FT WIDE 30 FT LONG,8 FT (LOW PT) CLDG HEIGHT,10 FT (LOW SIDE) EAVE HEIGHT,2IN CONC FLOOR,.6 3FTX4FT SINGLE HG W/GDS WINDOWS,2 2-3FTX7FT PERS DOORS,2 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	2	7	7,222	46	460	230	736
93101HJ	TYPE VI,20 FT WIDE 50 FT LONG,8 FT (LOW PT) CLDG HEIGHT,10 FT (LOW SIDE) EAVE HEIGHT,2IN CONC FLOOR,10 3FTX4FT SINGLE HG W/GDS WINDOWS,2 2-3FTX7FT PERS DOORS,2 ROUND ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG	3	11	11,108	69	690	345	1,104
93101HK	TYPE VI,20 FT WIDE 80 FT LONG,8 FT (LOW PT) CLDG HEIGHT,10 FT (LOW SIDE) EAVE HEIGHT,2 IN CONC FLOOR,15 3FTX4FT SGL HG W/GDS HG W/GD WINDOWS,3 2-3FTX7FT PERS DOORS,4 ROUND ROOF VENT. ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	4	9	17,028	104	1,035	518	1,657
93101HL	TYPE VI,40 FT WIDE 100FT LONG,8 FT CLDG HEIGHT,12 FT EAVE HEIGHT,2IN CONC FLOOR,12 3FTX4FT SGL HG W/GDS AND 7 3FTX4FT SINGLE HG WINDOWS, 3 2-3FTX7FT PERS DOORS,CON RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGD METAL BLDG.	10	45	38,356	253	2,530	1,265	4,048
93101HM	TYPE VI,40 FT WIDE 50 FT LONG,8 FT CLDG HEIGHT,12 FT EAVE HEIGHT,2IN CONC FLOOR(4IN IN VAULT),11 3FTX4FT COM PROJ WINDOWS,3 2-3FTX7FT PERS DOORS,CONT RIDGEROOF VENT.ALL WALL BATT R-6.PRE-ENGINEERED METAL BLDG.	5	101	20,275	127	1,265	633	2,025
93101HN	TYPE VI,40 FT WIDE 70 FT LONG,8 FT CLDG HEIGHT,12 FT EAVE HEIGHT,2IN CONC FLOOR(4IN IN VAULT),14 3FTX4FT COM PROJ WINDOWS,3 2-3FTX7FT PERS DOORS,CONTRIDGEROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	7	32	27,482	173	1,725	863	2,761

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

93101HP TYPE IV, 60 FT WIDE 90 FT LONG, 8 FT CLDG HEIGHT, 12 FT EAVE HEIGHT, .2IN CONC(.6IN IN VAULT), 18 3FTX4FT COM PROJ WINDOWS, 3 2-3FTX7FT PERS DOORS, CONT RIDGE ROOF VENT, ALL WALLS BATT R-6, PRE-ENGINEERED METAL BLDG.

93101HR TYPE IV, 80 FT WIDE 160 FT LONG, 14 FT CLDG HEIGHT, 18 FT EAVE HEIGHT, .6IN CONC FLOOR, 13 3FTX5FT COM PROJ WINDOWS, 1 2-3FT X 7FT PERS DOOR, 7 10FTX10FT SINGLE SIDE DOORS, CONT RIDGE ROOF VENT, PRE-ENGINEERED METAL BLDG.

93101HT TYPE IV, 80 FT WIDE 200 FT LONG, 14 FT CLDG HEIGHT, 18 FT EAVE HEIGHT, .6IN CONC FLOOR, 17 2-3FTX4FT COM PROJ WINDOWS, 1 2-3FT 7FT PERS DOORS, 9 10FTX10FT SINGLE SLIDE DOORS, CONT RIDGE ROOF VENT, PRE-ENGINEERED METAL BLDG.

93101HU TYPE IV, 80 FT WIDE 240 FT LONG, 14 FT CLDG HEIGHT, 18 FT EAVE HEIGHT, .6IN CONC FLOOR, 19 2-3FTX4FT COM PROJ WINDOWS, 1 2-3FT 7FT PERS DOOR, 11 10FTX10FT SINGLE SLIDE DOORS, CONT RIDGE ROOF VENT, PRE-ENGINEERED METAL BLDG.

93101HV TYPE IV, 60 FT WIDE 60 FT LONG, 8 FT CLDG HEIGHT, 10 FT EAVE HEIGHT, .6IN CONC FLOOR, 16 2-3FTX4FT SINGLE HG W/GDS WINDOWS, 4 2-3FTX7FT PERS DOORS, CONT RIDGE ROOF VENT, PRE-ENGINEERED METAL BLDG.

93101HW TYPE IV, 60 FT WIDE 100FT LONG, 8 FT CLDG HEIGHT, 10 FT EAVE HEIGHT, .6IN CONC FLOOR, 24 2-3FTX4FT SINGLE HG WINDOWS, 4 2-3FTX7FT PERS DOORS, CONT RIDGE ROOF VENT, PRE-ENGINEERED METAL BLDG.

93101HY TYPE IV, 60 FT WIDE 60 FT LONG, 8 FT CLDG HEIGHT, 10 FT EAVE HEIGHT, .6IN CONC FLOOR, 13 3FTX4FT COM PROJ WINDOWS, 2 2-3FTX7FT PERS DOORS, CONT RIDGE ROOF VENT, PRE-ENGINEERED METAL BLDG.

93101JA TYPE IV, 30 FT WIDE 60 FT LONG, 8 FT CLDG HEIGHT, 10 FT EAVE HEIGHT, .6IN CONC FLOOR, 10 3FTX4FT COM PROJ WINDOWS, 3 2-3FTX7FT PERS DOORS, CONT RIDGE ROOF VENT, PRE-ENGINEERED METAL BLDG.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST 3	CONST EFFORT IN MAN-HOURS			
			HON	VERY	GENL	TOT
9	41	34,816	230	2,300	1,150	3,680
24	126	94,687	713	7,130	3,565	11,408
34	180	133,945	1,024	10,235	5,118	16,377
40	216	160,705	1,231	12,305	5,796	19,332
5	27	20,908	130	1,495	748	2,393
8	45	33,833	253	2,530	1,265	4,048
5	27	20,020	130	1,495	748	2,393
4	20	15,765	115	1,150	575	1,840

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL					
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	
		SHT	HOR	VERT	GENL	TOT	
93101JB	TYPE IV,30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.10 3FTX4FT COM PROJ WINDOWS. 3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	4	20	17,683	115	1,150	575 1,840
93101JC	TYPE IV,30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.9 3FTX4FT COM PROJ WINDOWS. 3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	5	20	18,450	115	1,150	575 1,840
93101JF	TYPE IV,40 FT WIDE 70 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.12 3FTX4FT SINGLE HG AND 2 3FTX4FT SINGLE HG W/GDS WINDOWS.4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	5	32	18,578	175	1,723	863 2,761
93101JG	TYPE IV,40 FT WIDE 90 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.16 3FTX4FT SINGLE HG AND 2 3FTX4FT SINGLE HG W/GDS WINDOWS.4 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	9	41	36,460	230	2,300	1,150 3,680
93101JH	TYPE IV,30 FT WIDE 40 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.2IN CONC FLOOR.11 3FTX4FT COM PROJ WINDOWS. 2 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT. PRE-ENGINEERED METAL BLDG.	3	14	11,062	69	690	345 1,104
93101JJ	TYPE IV,30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.2IN CONC FLOOR.14 3FTX4FT COM PROJ WINDOWS. 2 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT. PRE-ENGINEERED METAL BLDG.	4	20	16,023	115	1,150	575 1,840
93101JK	TYPE IV,40 FT WIDE 70 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.14 2-3FTX4FT SINGLE HG AND 3 3FTX4FT SINGLE HG W/GDS WINDOWS 3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	7	32	27,380	175	1,723	863 2,761
93101JL	TYPE IV,30 FT WIDE 60 FT LONG,8 FT CLDG HEIGHT,10 FT EAVE HEIGHT,.4IN CONC FLOOR.11 2-3FTX4FT SINGLE HG WINDOWS. 3 2-3FTX7FT PERS DOORS.CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENGINEERED METAL BLDG.	5	20	18,705	115	1,150	575 1,840

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST \$	CONST EFFORT IN MAN-HOURS		
		SHT TONS	HOR VERT	GENL	TOT	NHR		
93101JH	TYPE IV/40 FT WIDE 60 FT LONG, 8 FT CLDG HEIGHT, 10 FT EAVE HEIGHT, 2IN CONC FLOOR, 12 3FTX4FT COM PROJ WINDOWS, 4 2-3FTX7FT PERS DOORS, COMT RIDGE ROOF VENT, ALL WALLS BATT R-6, PRE-ENGINEERED METAL BLDG.	6	27	23,645	750	1,495	768	2,393
93101JN	TYPE II/60 FT WIDE 200FT LONG, 8 FT CLDG HEIGHT, 10 FT EAVE HEIGHT, 2IN CONC FLOOR, 52 3FTX4FT COM PROJ WINDOWS, 9 2-3FTX7FT PERS DOORS, COMT RIDGE ROOF VENT, ALL WALLS BATT R-6, PRE-ENGINEERED METAL BLDG.	35	176	134,853	1,001	10,005	4,945	15,951
93101JP	TYPE VI/20 FT WIDE 40 FT LONG, 8 FT (LOW PT) CLDG HEIGHT, 10 FT (LOW SIDE) EAVE HEIGHT, 4IN CONC FLOOR, 3 3FTX4FT COM PROJ WINDOWS, 3 2-3FTX7FT PERS DOORS, 2 ROUND ROOF VENT, PRE-ENGINEERED METAL BLDG.	2	90	7,028	46	460	230	736
93101JR	TYPE VI/20 FT WIDE 70 FT LONG, 8 FT (LOW PT) CLDG HEIGHT, 10 FT (LOW SIDE) EAVE HEIGHT, 4IN CONC FLOOR, 9 3FTX4FT COM PROJ WINDOWS, 3 2-3FTX7FT AND 1 3FTX7FT PERS DOORS, 3 ROUND ROOF VENT, PRE-ENGINEERED METAL BLDG.	3	16	12,364	81	805	403	1,289
93101JT	TYPE VI/20 FT WIDE 30 FT LONG, 8 FT (LOW PT) CLDG HEIGHT, 10 FT (LOW SIDE) EAVE HEIGHT, 4IN CONC FLOOR, 6 3FTX4FT COM PROJ WINDOWS, 2 2-3FTX7FT PERS DOORS, 2 ROUND ROOF VENT, PRE-ENGINEERED METAL BLDG.	2	11	8,533	69	690	345	1,104
93101KA	TYPE IV/50 FT WIDE 80 FT LONG, 8 FT CLDG HEIGHT 10 FT EAVE HEIGHT 2IN, CONC FLOOR, 20 3FT.X4FT, SINGLE HG WINDOWS, 4 3X7 FT, PERS. DOORS, COMT RIDGE ROOF VENT ALL WALLS BATT R-6, PRE-ENGINEERED METAL BLDG.	7	34	32,000	184	1,639	892	2,715
93101KG	TYPE IV/60 FT WIDE 60 FT LONG, 8 FT CLDG HEIGHT TO FT, EAVE HEIGHT 2IN, CONC FLOOR, 20 3FT.X4FT, SINGLE HG WINDOWS, 4 3X7 FT, PERS. DOORS, COMT RIDGE ROOF VENT, ALL WALLS BATT R-6, PRE-ENGINEERED METAL BLDG.	8	37	34,000	198	1,668	920	2,786
93101KP	TYPE IV/30FT WIDE 60FT LONG; 8FT CLDG HEIGHT; 10FT EAVE HEIGHT; 2IN CONC FLOOR, 8 4FTX4FT COM PROJ WINDOWS, 2 3FTX7FT PERS. DOORS, 2 ROUND ROOF VENTS, 1 LOUVER, ALL WALLS BATT R, PRE-ENGINEERED METAL BLDG.	4	20	15,765	115	1,150	575	1,840

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
93101KT	TYPE IV;30FT WIDE 60FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT;.4IN CONC FLOOR.4 2-3FT X 7FT PERS DOORS. 2 3FTX7FT PERS DOORS. 1 ROUND ROOF VENT.12 3FTX2FT6IN LOUVERS. PRE-ENGINEERED METAL BUILDING.	4	20	15,765	115	1,150	575	1,840
93101KU	TYPE I;20FT WIDE 100FT LONG;8FT CLDG HEIGHT; 10FT EAVE HEIGHT;.4IN CONC FLOOR. 14 3FTX4FT SINGLE HG WINDOWS. 2 2-3FTX7FT PERS DOORS. ALL WALLS BATT R-6. PRE-ENGINEERED METAL BUILDING.	6	23	21,000	127	1,265	633	2,025
93101KV	TYPE I;20FT WIDE 100FT LONG;8FT CLDG HEIGHT; 10FT EAVE HEIGHT;.4IN CONC FLOOR.14 3FTX4FT SINGLE HG WINDOWS.	6	23	21,450	127	1,265	633	2,025
93101KW	TYPE I;20FT WIDE 100FT LONG;8FT CLDG HEIGHT; 10FT EAVE HEIGHT;.4IN CONC FLOOR.14 3FTX4FT SINGLE HG WINDOWS. 2 2-3FTX7FT PERS DOORS.14 3FTX2FT6IN LOUVERS. PRE-ENGINEERED METAL BLDG.	6	23	21,450	127	1,265	633	2,025
93101KY	TYPE I;20FT WIDE 100FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT;.4IN CONC FLOOR.14 3FTX4FT SINGLE HG WINDOWS. 2 2-3FTX7FT PERS DOORS. ALL WALLS BATT R-6. PRE-ENGINEERED METAL BLDG.	6	23	21,650	127	1,265	633	2,025
93101LA	TYPE I; 20FT WIDE 50FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT;.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS. 3 3FTX7FT PERS DOORS.ALL WALLS BATT R-6 PRE-ENGINEERED METAL BLDG.	3	11	12,100	69	690	345	1,104
93101LB	TYPE I;20FT WIDE 50FT LONG;8FT CLDG HEIGHT; 10FT EAVE HEIGHT;.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS. 3 3FTX7FT PERS DOORS.9 3FTX2FT6IN LOUVERS. PRE-ENGINEERED METAL BLDG.	3	11	12,100	69	690	345	1,104
93101LC	TYPE I; 20FT WIDE 50FT LONG;8FT CLDG HEIGHT; 10FT EAVE HEIGHT;.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS. 3 3FTX7FT PERS DOORS.9 3FTX2FT6IN LOUVERS PRE-ENGINEERED METAL BLDG.	3	11	12,100	69	690	345	1,104

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
93101LD	TYPE I;20FT WIDE 50FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS 3 3FTX7FT PERS DOORS.ALL WALLS BATT R-6 PRE-ENGINEERED METAL BLDG.	3	11	12,100	69	690	345	1,104
93101LE	TYPE I;60FT WIDE 70FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS. 3 3FTX7FT < 3 2-3FT X 7FT PERS DOORS.1 ROUND ROOF VENT ALL WALLS BATT R-6. PRE-ENGINEERED METAL BUILDING.	7	30	27,000	143	1,380	690	2,213
93101LF	TYPE I; 60FT WIDE 70FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS. 2 3FT X 7FT < 3 2-3FT X 7FT PERS DOORS.9 3FTX2FT6IN LOUVERS ROUND ROOF VENT; PRE-ENGINEERED METAL BUILDING.	7	30	27,000	143	1,380	690	2,213
93101LG	TYPE I;40FT WIDE 70FT LONG;8FT CLDG HEIGHT; 10FT EAVE HEIGHT.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS. 3 3FTX7FT < 3 2-3FT X 7FT PERS DOORS.9 3FTX2FT6IN LOUVERS ROUND ROOF VENT; PRE-ENGINEERED METAL BLDG.	7	30	27,000	143	1,380	690	2,213
93101LH	TYPE I;60FT WIDE 70FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.4IN CONC FLOOR.9 3FTX4FT SINGLE HG WINDOWS. 3 3FTX7FT < 3 2-3FT X 7FT PERS DOORS.1 ROUND ROOF VENT. ALL WALLS BATT R-6. PRE-ENGINEERED METAL BLDG.	7	30	27,000	143	1,380	690	2,213
93101MD	TYPE I;60FT WIDE 50FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.2IN CONC FLOOR.7 2-3FTX4FT SINGLE HG WINDOWS. 1 3FTX7FT PERS DOOR. 2 4FTX7FT DBL SLIDE DOORS. CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENG MET BLDG.	5	101	20,275	107	1,036	519	1,662
93101ME	TYPE I;60FT WIDE 100FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.2IN CONC FLOOR.10 2-3FTX4FT SINGLE HG WINDOWS. 3 3FTX7FT PERS DOORS.4 4FTX7FT DBL SLIDE DOORS. CONT RIDGE ROOF VENT,ALL WALLS BATT R-6.PRE-ENG METAL BLDG.	10	45	38,356	202	1,961	981	3,144
93101MF	TYPE I;20FT WIDE 30FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.2IN CONC FLOOR.4 2-3FTX4FT SINGLE HG WINDOWS. 2 3FTX7FT PERS DOORS.1 4FTX7FT DBL SLIDE DOOR. CONT.RIDGE ROOF VENT ALL WALLS BATT R-6. PRE-ENGINEERED METAL BUILDING. METAL BLDG 00000600SF	19	7	7,756	61	397	199	637

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL SHT MEAS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
93101NG	TYPE I 120FT WIDE SOFT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.2IN CONC FLOOR.4 2-3FTX4FT SINGLE HG WINDOWS. 3 3FTX7FT PERS DOORS.1 4FTX7FT DBLE SLIDE DOORS. CONT RIDGE ROOF VENT.ALL WALLS BATT R-6 PRE-ENGINEERED METAL BUILDING. METAL BLDG 00001000SF	3	11	12,089	69	690	345	1,104
93101NH	TYPE I 140FT WIDE SOFT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.2IN CONC FLOOR.3 2-3FTX4FT SINGLE HG WINDOWS. 5 3FTX7FT PERS DOORS.2 4FTX7FT DBLE SLIDE DOORS. CONT RIDGE ROOF VENT.ALL WALLS BATT R-6 PRE-ENGINEERED METAL BUILDING. METAL BLDG 00002000SF	5	101	20,275	107	1,036	519	1,662
93101HJ	TYPE I 140FT WIDE 100FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.2IN CONC FLOOR.8 20FTX4FT SINGLE HG WINDOWS. 6 3FTX7FT PERS DOORS.2 4FTX7FT DBLE SLIDE DOORS. CONT RIDGE ROOF VENT.ALL WALLS BATT R-6 PRE-ENGINEERED METAL BLDGS.	10	45	38,336	202	1,961	981	3,144
93101HK	TYPE I 30FT WIDE 40FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.2IN CONC FLOOR.2 2-3FTX4FT SINGLE HG WINDOWS. 1 3FTX7FT PERS DOOR. CONT RIDGE ROOF VENT.ALL WALLS BATT R-6 PRE-ENGINEERED METAL BLDGS.	3	14	13,673	72	699	350	1,121
93101HLL	TYPE I 140FT WIDE 60FT LONG;8FT CLDG HEIGHT;10FT EAVE HEIGHT.2IN CONC FLOOR.9 2-3FTX4FT SINGLE HG WINDOWS. 1 2-3FTX7FT PERS DOOR. CONT RIDGE ROOF VENT.ALL WALLS BATT R-6.PRE-ENG MET BLDG.	5	27	20,908	110	1,068	535	1,713
93101HM	TYPE I-40FT.WIDE BY 135FT LONG 14FT CLDG.HEIGHT 16FT EAVES 6EA.2-3X4FT SGL HUNG WINDOWS.1EA.3X7FT PERS.DOORS.7EA 12FT BY 13FT OVERHEAD DOORS.CONT.ROOF VENTS.ALL WALLS BATT R-6. PRE-ENGINEERED METAL BUILDING.	12	50	64,000	230	2,473	1,380	4,083
93101HN	TYPE I 40FT.WIDE BY 75FT LONG 14FT CLDG HEIGHT 16FT EAVES 6EA.2-3X4FT SGL HUNG WINDOWS.1EA.3X7FT PERS DOORS.3EA 12FT BY 13FT OVERHEAD DOORS/CONT.ROOF VENTS.ALL WALLS BATT R-6. PRE-ENGINEERED METAL BUILDING.	8	37	36,000	163	1,587	828	2,578

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
93101MP	TYPE II 60FT WIDE 100FT LONG; 8FT CLDG HEIGHT; 10FT EAVE HEIGHT; 2IN CONC FLOOR. PRE-ENGINEERED METAL BUILDING
93101MR	TYPE IV; 60FT WIDE 40FT LONG; 8FT CLDG HEIGHT; 10FT EAVE HEIGHT; 2IN CONC FLOOR. PRE-ENGINEERED METAL BLDG.
93101MT	TYPE IV; 40 FT. WIDE 70 FT. LONG, 8 FT CLDG HEIGHT 10 FT. EAVE HEIGHT 2IN. CONC FLOOR. 18 3FT. X 4FT. SINGLE HG WINDOWS. 4 3X7 FT. PERS. DOORS. CONT RIDGE ROOF VENT. ALL WALLS BATT R-6. PRE-ENGINEERED METAL BLDG.
93101MU	TYPE I; 40FT WIDE 130FT LONG; 8FT CLDG HEIGHT; 10FT EAVE HEIGHT; 2IN CONC FLOOR. PRE-ENGINEERED METAL BLDG.
93101NB	TYPE I 60 FT WIDE 120 FT LONG 12 FT CLDG HEIGHT 16 FT EAVE HEIGHT 4IN CONC FLR 25 3X4FT SLIDING WINDOWS 2 3X7FT AND 0 2-3X7FT PERSONNEL DOORS CONT ROOF VENT ALL WALLS BATT R-6 PRE-ENGINEERED METAL BUILDING
93102AA	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 8 FT HIGH
93102AB	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 8 FT HIGH BUILDING, 4 FT WIDE 1 DOOR SECTION
93102AC	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 8 FT HIGH BUILDING, 4 FT WIDE 2 WINDOW SECTION
93102AD	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 8 FT HIGH BUILDING, 4 FT WIDE SOLID SECTION
93102AE	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 8 FT HIGH BUILDING, 2 FT WIDE SOLID SECTION
93102AF	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 20 FT HIGH

CONSTRUCTION MATERIAL						
WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
			HOR	VERT	GENL	TOT
75	175	24,684	378	3,779	1,889	6,046
4	180	14,056	100	997	498	1,595
7	30	27,000	161	1,582	805	2,548
13	60	34,000	263	2,550	1,275	4,088
16	355	63,683	331	3,312	1,656	5,299
			1	748	3	2
			1	532	3	2
			1	579	3	2
				288	3	2
				258	2	1
			1	1,251	3	5

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL	TOT
93102A6	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 20 FT HIGH BUILDING, 4 FT WIDE, 1 DOOR SECTION	1		736	1	3	5	9
93102AH	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 20 FT HIGH BUILDING, 4 FT WIDE 2 WINDOW SECTION	1		994	1	3	5	9
93102AJ	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 20 FT HIGH BUILDING, 4 FT WIDE SOLID SECTION	1		608	1	3	5	9
93102AK	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 20 FT WIDE AND 20 FT HIGH BUILDING, 2 FT WIDE SOLID SECTION			406	1	2	2	5
93102AL	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 30 FT WIDE AND 8 FT HIGH WITH 1 WINDOW AND 1 DOOR	1		1,223		7	5	12
93102AM	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 30 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY WITH 2 DOORS AND 2 WINDOWS	2	16	4,294		17	15	32
93102AN	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 30 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY WITH 2 WINDOWS	2	16	4,153		17	15	32
93102AP	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 30 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY WITH 4 WINDOWS	2	16	3,153		17	15	32
93102AR	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 30 FT WIDE AND 8 FT HIGH BUILDING, 10 FT BAY WITH 2 WINDOWS	2	8	2,710		9	8	17
93102AT	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 30 FT WIDE AND 8 FT HIGH BUILDING, 40 FT SECTION WITH 8 WINDOWS	6	33	9,682		9	8	17
93102AU	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 30 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY WITH 4 WINDOWS	4	17	6,451		17	15	32
93102BG	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 12 FT HIGH, 40 FT BAY WITH 4 WINDOWS AND 4 DOORS	8	43	12,547	7	41	28	76

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		SHT TONS	MEAS TONS		HOR	VERT	GENL	TOT
93102BH	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 8 FT HIGH WITH 1 WINDOW AND 1 DOOR	1	2	1,646	1	7	5	13
93102BJ	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY WITH 2 WINDOWS	3	20	4,867	3	20	13	36
93102BK	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY WITH 4 WINDOWS	3	20	4,965	3	20	13	36
93102BL	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY SOLID SECTION	3	20	4,729	3	20	13	36
93102BM	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 8 FT HIGH BUILDING, 10 FT BAY SOLID SECTION	2	11	3,035	2	10	7	19
93102BN	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY WITH 2 WINDOWS AND 2 DOORS	3	20	4,989	3	20	13	36
93102BP	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 8 FT HIGH BUILDING, 20 FT BAY WITH 1 WINDOW AND 1 DOOR	3	20	4,859	3	20	13	36
93102BR	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 8 FT HIGH BUILDING, 40 FT BAY WITH 12 WINDOWS	5	35	7,888	7	39	25	71
93102BT	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 12 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 2 DOORS	3	21	5,598	3	21	14	38
93102BU	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 12 FT HIGH, 20 FT BAY WITH 4 WINDOWS	3	21	5,970	3	21	14	38
93102BV	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 12 FT HIGH, 20 FT BAY WITH 2 8 BY 8 FT DOUBLE DOORS	3	23	5,775	3	21	14	38
93102BW	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 12 FT HIGH, 20 FT BAY SOLID SECTION	3	21	5,339	3	21	14	38

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT	IN MAN-HOURS	
					HOR	VERT	GENL	TOT
93102BY	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 12 FT HIGH, 40 FT BAY WITH 4 8 BY 8 FT DOUBLE DOORS	8	47	12,828	7	41	28	76
93102CA	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH SOLID SECTION	1	3	2,308	1	8	5	14
93102CB	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 2 DOORS	4	21	5,945	5	23	16	64
93102CC	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 2 WINDOWS	4	21	5,839	5	23	16	64
93102CD	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 4 WINDOWS	4	21	6,282	5	23	16	64
93102CE	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 6 WINDOWS	4	21	6,039	5	23	16	64
93102CF	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 1 8 BY 8 FT DOUBLE DOOR	3	21	5,110	5	23	16	64
93102CG	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 2 DOORS	3	19	4,116	5	17	10	32
93102CH	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 40 FT BAY WITH 8 WINDOWS	8	46	13,389	9	66	32	87
93102CJ	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 40 FT BAY WITH 12 WINDOWS	9	46	14,456	9	46	32	87
93102CK	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 40 FT BAY WITH 2 8 BY 8 FT DOUBLE DOORS	6	39	8,948	9	46	32	87
93102CL	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, 40 FT BAY WITH 4 WINDOWS AND 4 DOORS	6	39	9,320	9	35	21	65
93102CM	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 14 FT HIGH, WITH 1 WINDOW AND 1 DOOR	1	3	2,628	1	9	5	15

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY
NUMBER

DESCRIPTION

93102CN INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 16 FT HIGH, 20 FT BAY WITH 1 8 BY 8 FT DOUBLE DOOR

93102CP INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 16 FT HIGH, 20 FT BAY SOLID SECTION

93102CR EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 16 FT HIGH, 40 FT BAY WITH 18 WINDOWS

93102CT INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 2 DOORS

93102CU INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 1 WINDOW AND 1 DOOR

93102CV INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 2 WINDOWS

93102CW INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 1 12 BY 16 ROLL UP DOOR

93102CY EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 40 FT WIDE AND 20 FT HIGH, 40 FT BAY WITH 2 WINDOWS AND 2 DOORS

93102DA ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 8 FT HIGH, SOLID SECTION

93102DB INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 8 FT HIGH BUILDING 20 FT BAY WITH 2 DOORS AND 3 WINDOWS

93102DC INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 8 FT HIGH, 20 FT BAY SOLID SECTION

93102DD EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 8 FT HIGH BUILDING, 40 FT BAY WITH 4 DOORS AND 6 WINDOWS

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS				TOT
			HOR	VERT	GENL		
4	22	6,078	5	26	17	48	
3	19	4,751	5	26	17	48	
9	46	13,050	5	26	17	48	
4	22	6,960	5	26	25	56	
4	22	6,862	5	26	25	56	
4	22	6,850	5	26	25	56	
4	22	7,787	5	29	28	62	
10	46	15,831	5	26	25	56	
1	2	2,059	1	7	6	14	
4	24	6,158	5	20	20	45	
4	24	5,840	5	20	20	45	
7	45	10,425	9	39	39	87	

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			<u>TOT</u>
					<u>HOR</u>	<u>VERT</u>	<u>GENL</u>	
93102DE	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 12 FT HIGH SOLID SECTION	1	3	2,760	2	7	7	16
93102DF	INTERIOR BAY;LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 12 FT HIGH, 20 FT BAY WITH 2 DOORS AND 1 WINDOW	4	25	6,624	6	21	21	48
93102DG	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 12 FT HIGH, 20 FT BAY WITH 2 WINDOWS	4	25	6,515	6	21	21	48
93102DH	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 12 FT HIGH, 20 FT BAY WITH 1 16 BY 12 FT ROLL UP DOOR	4	25	6,220	6	30	30	66
93102DJ	EXTERIOR BAY;LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 12 FT HIGH, 40 FT BAY WITH 4 DOORS AND 2 WINDOWS	9	52	14,783	12	41	41	94
93102DK	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 14 FT HIGH SOLID SECTION	2	4	3,045	2	8	7	17
93102DL	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 1 DOOR AND 2 WINDOWS	4	26	6,932	6	22	21	69
93102DM	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 14 FT HIGH, 10 FT BAY SOLID SECTION	3	13	4,256	3	12	10	25
93102DN	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 50 FT WIDE AND 14 FT HIGH, 40 FT BAY WITH 2 DOORS AND 4 WINDOWS	10	53	15,955	12	44	41	97
93102EA	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 12 FT HIGH, SOLID SECTION	1	3	3,119	2	8	7	17
93102EB	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 12 FT HIGH, 20 FT BAY WITH 2 DOORS	5	29	7,236	6	23	23	52
93102EC	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 12 FT HIGH, 40 FT BAY WITH 4 WINDOWS	10	59	14,475	12	46	46	104
93102ED	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 14 FT HIGH, SOLID SECTION	2	4	3,467	2	9	8	19

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		HOR	VERT	GENL	TOT			
93102EE	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 6 WINDOWS	5	29	7,504	6	26	26	58
93102EF	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 14 FT HIGH, 20 FT BAY, SOLID SECTION	5	30	7,546	6	26	26	58
93102EG	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 2 DOORS AND 3 WINDOWS	5	30	7,865	6	26	26	58
93102EH	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 14 FT HIGH, 20 FT BAY WITH 7 WINDOWS	5	30	7,959	6	26	26	58
93102EJ	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 14 FT HIGH, 40 FT BAY WITH 4 DOORS AND 6 WINDOWS	11	61	17,040	12	53	53	118
93102EK	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, WITH 1 DOOR AND 1 WINDOW	2	5	4,289	2	10	10	22
93102EL	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 1 12 BY 16 ROLL UP DOOR	5	31	10,940	7	38	37	82
93102EM	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 1 8 BY 8 DOUBLE DOOR	5	31	8,487	7	33	32	72
93102EN	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE	5	30	8,594	7	33	32	72
93102EP	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 1 12 BY 16 ROLL UP DOOR	5	31	9,661	7	33	32	72
93102ER	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, 20 FT BAY WITH 1 DOOR AND 13 WINDOWS	5	30	8,995	7	33	32	72
93102ET	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, 20 FT BAY WITH 12 WINDOWS	5	30	8,866	7	38	37	82

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		HOR	VERT	GENL	TOT			
93102EU	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, 20 FT BAY, SOLID SECTION	3	24	4,149	7	33	32	72
93102EV	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, 20 FT BAY WITH 2 12 BY 16 ROLL UP DOORS	5	31	10,853	7	33	32	72
93102EW	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 18 FT HIGH, 40 FT BAY WITH 4 WINDOWS AND 2 12 BY 16 ROLL UP DOORS	11	61	17,192	16	71	69	154
93102FA	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE 20 FT HIGH	2	6	6,337	2	12	12	26
93102FB	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 4 WINDOWS AND 2 12 BY 16 ROLLUP DOORS	3	32	11,665	7	40	39	86
93102FC	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 4 WINDOWS	6	11	8,574	7	36	35	78
93102FD	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 20 FT BAY, SOLID SECTION	6	31	8,708	7	36	35	78
93102FE	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 1 12 BY 16 ROLL UP DOOR	5	31	10,027	7	39	37	83
93102FF	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 4 DOORS	5	31	8,967	7	36	35	78
93102FG	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 2 12 BY 16 ROLL UP DOORS	5	32	11,372	7	40	39	86
93102FH	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 1 16 BY 18 ROLL UP DOOR	5	32	10,843	7	38	37	82
93102FJ	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 40 FT BAY WITH 8 WINDOWS AND 4 12 BY 16 ROLL UP DOORS	13	66	25,561	14	71	69	154

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
93102FK	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 40 FT BAY WITH 3 WINDOWS
93102FL	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 60 FT WIDE AND 20 FT HIGH, 40 FT BAY WITH 4 12 BY 16 ROLL UP DOOR
93102FM	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING 60 FT WIDE AND 12 FT HIGH, 20 FT BAY WITH 2 WINDOWS AND 2 8 BY 8 DOORS
93102GA	INSULATION PACKAGE FOR LIGHTWEIGHT STEEL PANEL BUILDINGS, R-6, 1000 SF, DESERT/TROPIC CLIM
93102GD	STRIP FOOTINGS WITH REINFORCING STEEL PACKAGE, 100 LF
93102GE	ISOLATED FOOTING WITH REINFORCING STEEL PACKAGE, 30/40 FT WIDE BUILDING, 12 FT HIGH AND LESS
93102GF	ISOLATED FOOTING WITH REINFORCING STEEL PACKAGE, 30/40 FT WIDE BUILDING, TALLER THAN 12 FT HIGH
93102GG	ISOLATED FOOTING WITH REINFORCING STEEL PACKAGE, 50/60 FT WIDE BUILDING, 12 FT HIGH AND LESS
93102GH	ISOLATED FOOTING WITH REINFORCING STEEL PACKAGE, 50/60 FT WIDE BUILDING TALL THAN 12 FT HIGH
93102GL	ISOLATED FOOTING WITH REINFORCING STEEL PACKAGE, 90 FT TENSION FABRIC MEMBRANE BUILDING
93102GN	ISOLATED FOOTING WITH REINFORCING STEEL PACKAGE, 124 FT TENSION FABRIC MEMBRANE BUILDING
93102HA	BASIC BUILDING, LIGHTWEIGHT TENSION FABRIC MEMBRANE BUILDING, 90 BY 140 BY 12/34
93102HB	INTERIOR BAY, LIGHTWEIGHT TENSION FABRIC MEMBRANE BUILDING, 90 BY 50 BY 34

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS				TOT
			MHR	VERT	GENL	TOT	
13	64	20,237	14	71	69	154	
12	66	25,212	14	81	78	173	
3	27	4,737	6	23	23	52	
	2	350		18		18	
2	1	84	3		18	23	
		24	2	7	7	16	
1		32	2	8	8	18	
1	1	40	2	8	8	18	
1	1	55	2	9	9	20	
1	1	86	2	8	8	18	
1	1	90	2	9	9	20	
12	10	39,928	35	206	206	467	
11	11	70,972	52	235	235	522	

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT</u>	<u>VOL MEAS</u>	<u>COST TONS</u>	<u>CONST EFFORT IN MAN-HOURS</u>			
		TONS	TONS	\$	HOR	VERT	GENL	TOT
93102HC	BASIC BUILDING, LIGHTWEIGHT TENSION FABRIC MEMBRANE BUILDING, 124 BY 184 BY 14/42	19	11	71,559	14	30	30	74
93102HD	INTERIOR BAY, LIGHTWEIGHT TENSION FABRIC MEMBRANE BUILDING, 124 BY 60 BY 42	10	9	62,732	21	32	32	85
93102JA	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING, 20 FT WIDE AND 16 FT HIGH, SOLID SECTION	1	2	1,421		3	3	6
93102JB	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 20 FT WIDE AND 16 FT HIGH, 4 FT BAY, SOLID SECTION	1		565		3	3	6
93102JC	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 20 FT WIDE AND 16 FT HIGH, 4 FT BAY, WITH 1 WINDOW AND 1 DOOR	1		744		3	3	6
93102JD	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 40 FT WIDE AND 8 FT HIGH, 20 FT BAY, WITH 2 8 BY 8 FT DOORS	2	17	2,834	3	20	13	36
93102JE	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING, 20 FT WIDE AND 8 FT HIGH, WITH 1 8 BY 8 FT DOOR	2		942		3	2	5
93102JF	ENDWALL UNIT LIGHTWEIGHT STEEL PANEL BUILDING 40FT WIDE AND 8 FT HIGH, WITH 1 4 BY 7 FT DOOR AND 1 8 BY 8 FT DOOR	1		1,456	1	7	5	13
93102JG	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING, 30 FT WIDE AND 20 FT HIGH, WITH 2 16 BY 18 FT ROLL UP DOORS	3	5	4,202	2	12	12	26
93102JH	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 40 FT WIDE AND 8 FT HIGH, 40 FT BAY, WITH 4 WINDOWS AND 3 DOORS	6	10	7,141	7	39	25	71
93102JJ	INTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 30 FT WIDE AND 14 FT HIGH, 20 FT BAY, WITH 2 16 BY 12 FT ROLL UP DOORS	5	24	5,709	12	48	46	106
93102JK	ENDWALL UNIT, LIGHTWEIGHT STEEL PANEL BUILDING, 30 FT WIDE AND 14 FT HIGH, WITH 1 WINDOW AND 1 DOOR	1	2	1,690	1	7	6	14
93102JL	EXTERIOR BAY, LIGHTWEIGHT STEEL PANEL BUILDING, 30 FT WIDE AND 14 FT HIGH, 40 FT BAY, WITH 2 DOORS	6	34	11,155	5	35	39	79

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER

DESCRIPTION

CONSTRUCTION MATERIAL

WT SNT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS				TOT
			HOR	VERT	GENL		
3	17	3,339	2	17	20	39	
1	2	2,052	1	7	5	13	
2	4	2,920	1	9	8	18	
5	33	9,269		35	30	65	
7	41	11,058	7	39	25	71	
7	43	12,237	7	41	28	76	
7	43	11,775	7	41	28	76	
8	34	13,676	9	53	35	97	
10	46	16,056	9	53	51	113	
9	45	18,489	9	62	55	126	
12	62	18,363	14	67	64	145	
4	16	5,872	3	17	16	36	

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			
		HOR	VERT	GENL	TOT			
93102LA	BARRACKS TYPE, BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 20 BY 20, 8 FT MIN CLEARANCE, TEMP CLIM	4	11	5,200				
93102LB	WAREHOUSE TYPE, BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 30 BY 30 FOR PERSONNEL USE, 8 FOOT MINIMUM CLEARANCE, TEMP CLIM	5	13	6,800				
93102LC	BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 40 BY 40, WITH CONCRETE FOUNDATION, 20 FOOT MINIMUM CLEARANCE, TEMP CLIM	6	16	8,200				
93102LD	SHOP TYPE BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 60 BY 60, 20 FT MINIMUM CLEARANCE, TEMP CLIM	7	22	10,400				
93102LE	SHOP TYPE BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 60 BY 80, 20 FT MINIMUM CLEARANCE, TEMP CLIM	9	26	13,600				
93102LG	BARRACKS TYPE, BASIC BUILDING LIGHTWEIGHT STEEL PANEL BUILDING, 20 BY 20, 8 FT MIN CLEARANCE, DESERT/TROPIC CLIM	7	22	10,400				
93102LH	WAREHOUSE TYPE, BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 30 BY 30 FOR PERSONNEL USE, 8 FOOT MINIMUM CLEARANCE, DESERT/TROPIC CLIM	8	23	12,800				
93102LJ	BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 40 BY 40, WITH CONCRETE FOUNDATION, 20 FOOT MINIMUM CLEARANCE, DESERT/TROPIC CLIM	11	28	14,500				
93102LK	SHOP TYPE BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 60 BY 60, 20 FT MINIMUM CLEARANCE, DESERT/TROPIC CLIM	14	37	19,200				
93102LL	SHOP TYPE BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 60 BY 80, 20 FT MINIMUM CLEARANCE, DESERT/TROPIC CLIM							
93102LM	BARRACKS TYPE, BASIC BUILDING LIGHTWEIGHT STEEL PANEL BUILDING, 20 BY 20, 8 FT MIN CLEARANCE, FRIGID CLIM	16	45	26,000				

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	SHT TONS	WT TONS	VOL MEAS	COST \$	CONST HRS	EFFORT IN MAN-HOURS	GENL TOT
93102LN	WAREHOUSE TYPE, BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 30 BY 30 FOR PERSONNEL USE, 8 FOOT MINIMUM CLEARANCE, FRIGID CLIM	12	32		16,400			
93102LP	BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 40 BY 40, WITH CONCRETE FOUNDATION, 20 FOOT MINIMUM CLEARANCE, FRIGID CLIM	14	37		19,200			
93102LR	SHOP TYPE BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 60 BY 80, 20 FT MINIMUM CLEARANCE, FRIGID CLIM	24	63		32,600			
93102LT	SHOP TYPE BASIC BUILDING, LIGHTWEIGHT STEEL PANEL BUILDING, 60 BY 60, 20 FT MINIMUM CLEARANCE, FRIGID CLIM	28	73		38,000			
93102MR	BUILDING, LIGHTWEIGHT STEEL PANEL 20X30X8, WINDOWS 1 PERSONNEL DOOR					16	10	26
93102MB	BLDG, LTWT STL PNL 20X50X8 1 PERSONNEL DOOR					16	10	26
93102MC	BLDG, LTWT STL PNL 20X24X8 1 PERSONNEL DOOR					14	9	23
93102MD	BUILDING, LIGHTWEIGHT STEEL PANEL 20X20X8FT, 2 WINDOWS AND 1 PERSONNEL DOOR					14	9	23
93102ME	BUILDING, LIGHTWEIGHT STEEL PANEL 20X100X8FT, 2 WINDOWS AND 1 PERSONNEL DOOR					14	9	23
93102MG	BUILDING, LIGHTWEIGHT STEEL PANEL 20X40X8FT, 2 WINDOWS AND 1 PERSONNEL DOOR					16	10	26
93102MH	BUILDING, LIGHTWEIGHT STEEL PANEL 20X10X8FT, 2 WINDOWS AND 1 PERSONNEL DOOR					13	8	21
93102MJ	BUILDING, LIGHTWEIGHT STEEL PANEL 20X60X8FT, 2 WINDOWS AND 1 PERSONNEL DOOR					14	9	23

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL								
FACILITY NUMBER	DESCRIPTION	WT	VOL	SHT	MEAS	COST	CONST EFFORT IN MAN-HOURS			
		TONS	TONS				HOR	VERT	GENL	TOT
93102MK	BUILDING, LIGHTWEIGHT STEEL PANEL 20X80X8FT, 2 WINDOWS AND 1 PERSONNEL DOOR						14	9		23
93102MM	BUILDING, LIGHTWEIGHT STEEL PANEL 20X50X8FT, 2 WINDOWS AND 1 PERSONNEL DOOR						16	10		26
93102NA	BLDG, LTWT STL PNL 30X70X8 1 PERSONNEL DOOR						43	36		79
93102NB	3 PERSONNEL DOORS						60	51		111
93102NC	BUILDING, LIGHTWEIGHT STEEL PANEL 30X100X8FT, 17 WINDOWS 3 PERSONNEL DOORS						68	58		126
93102ND	BUILDING, LIGHTWEIGHT STEEL PANEL 30X110X8FT, 17 WINDOWS 3 PERSONNEL DOORS						60	51		111
93102NE	BUILDING, LIGHTWEIGHT STEEL PANEL 30X40X8FT, 7 WINDOWS AND 3 PERSONNEL DOORS						51	43		94
93102NF	BUILDING, LIGHTWEIGHT STEEL PANEL 30X50X8FT, 9 WINDOWS AND 3 PERSONNEL DOORS						51	43		94
93102NG	BUILDING, LIGHTWEIGHT STEEL PANEL 30X80X8FT, 15 WINDOWS AND 3 PERSONNEL DOORS						51	43		96
93102NH	BUILDING, LIGHTWEIGHT STEEL PANEL 30X60X8FT, 11 WINDOWS AND 3 PERSONNEL DOORS						33	28		61
93102PA	BLDG, LTWT STL PNL 40X50X8 PERSONNEL DOOR AND 1 VEHICLE DOOR						10	96		103
93102PB	BLDG, LTWT STL PNL 40X100X8 2 PERSONNEL DOORS, AND 2 VEHICLE DOORS						15	85		155
93102PC	BLDG, LTWT STL PNL 40X100X12 2 PERSONNEL DOORS AND 2 VEHICLE DOORS						18	110		202

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
93102PD	BLDG, LTWT STL PNL 40X100X14 2 PERSONEL DOORS
93102PE	BLDG, LTWT STL PNL 40X120X14 6 PERSONEL DOORS
93102PF	BUILDING, LIGHTWEIGHT STEEL PANEL 40X90X8FT, 17 WINDOWS AND 3 PERSONEL DOORS
93102PG	BUILDING, LIGHTWEIGHT STEEL PANEL 40X110X8FT, 21 WINDOWS 3 PERSONEL DOORS
93102PH	BUILDING, LIGHT WEIGHT STEEL PANEL 40X120X8FT, 21 WINDOWS 3 PERSONEL DOORS
93102PJ	BUILDING, LIGHTWEIGHT STEEL PANEL 40X80X8FT, 16 WINDOWS AND 3 PERSONEL DOORS
93102PK	BUILDING, LIGHTWEIGHT STEEL PANEL 40X60X8FT, 9 WINDOWS AND 1 PERSONEL DOOR
93102PL	BUILDING, LIGHTWEIGHT STEEL PANEL 40X70X8FT, 10 WINDOWS AND 2 PERSONEL DOORS
93102RA	BLDG, LTWT STL PNL 90X140X14 AND 1 VEHICLE DOOR
93102RB	BLDG, LTWT STL PNL 90X240X14 AND 2 VEHICLE DOORS
93102TA	BUILDING, LIGHTWEIGHT STEEL PANEL 30X150FT, 6 WINDOWS AND 3 PERSONEL DOORS
93102TB	BUILDING, LIGHTWEIGHT STEEL PANEL 50X130X14FT, 4 WINDOWS, 2 PERSONEL DOORS AND 2 VEHICLE DOORS
93111AA	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,LINED FOR TEMPERATE CLIMAT,BASIC BUILDING, ONE STORY,20FT W X 20FT L,CONCRETE FLOOR,CONCRETE FOOTINGS, 8FT MIN CLEARANCE

		CONSTRUCTION MATERIAL				CONST EFFORT IN MAN-HOURS			
WT SHT TONS	VOL MEAS TONS	COST \$	HRS	VERT	GENL	TOT			
			14	52	31	97			
			14	52	31	97			
			21	108	70	199			
			21	108	70	199			
			18	105	68	191			
			15	85	55	155			
			12	66	43	121			
			14	76	61	151			
			35	208	206	647			
			86	440	440	966			
			23	85	79	187			
			29	112	105	246			
		1,683	23	136	37	196			

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
93111AB	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,LINED FOR TEMPERATE CLIMATE,ADDITIONAL BAY, ONE STORY,20FT W X 10FT L,CONCRETE FLOOR,CONCRETE FOOTINGS, 8FT MIN CLEARANCE	4	5	728	2	38	14	54
93111AC	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE,BASIC BUILDING,ONE STORY,20FT W X 20FT L,CONCRETE FLOOR,CONCRETE FOOTINGS,8FT MIN CLEARANCE	12	14	2,401	23	131	37	191
93111AD	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE, ADDITIONAL BAY,ONE STORY,20FT X 10FT L,CONCRETE FLOOR, CONCRETE FOOTINGS,8FT MIN CLEARANCE	5	6	1,095	2	41	14	57
93111AE	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION BARRACKS TYPE,BASIC BUILDING, 30FT WX 40FT L,WOOD & ASPH ROOFING, CONCRETE FOUNDATION,8FT MIN CLEARANCE	27	29	3,934	32	322	62	416
93111AF	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION BARRACKS TYPE,ADDITIONAL 10FT BAY FOR 30FT WIDE BLDG,WOOD & FELT ROOFING,CONCRETE FOUNDATION,8FT MIN CLEARANCE	6	7	924	2	75	14	91
93111AG	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION BARRACKS TYPE,BASIC BUILDING, 30FT WX 40FT L,CORRUGATED STEEL ROOF, CONCRETE FOUNDATION,8FT MIN CLEARANCE	9	13	2,083	32	357	62	451
93111AH	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION BARRACKS TYPE,ADDITIONAL 10FT BAY FOR 30FT WIDE BLDG,CORRUGATED STEEL ROOF,CONCRETE FOUNDATION,8FT MIN CLEAR	4	6	915	2	67	14	83
93111AJ	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,LINED FOR TEMPERATE CLIMATE,BASIC BUILDING, ONE STORY,40FT W X 50FT L,CONCRETE FLOOR,CONCRETE FOOTINGS,8FT MIN CLEARANCE	42	44	5,872	37	501	110	648
93111AL	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE,BASIC BUILDING,ONE STORY,20FT W X 20FT L,WOOD FLOOR,CONCRETE FOOTINGS,8FT MIN CLEARANCE	10	15	2,739	37	304	110	631

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
93111AM	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE, ADDITIONAL BAY,ONE STORY,20FT W X 10FT L,WOOD FLOOR,CONC FOOTINGS,8FT MIN CLEARANCE
93111AN	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,LINED FOR TEMPERATE CLIMATE,BASIC BUILDING, ONE STORY,20FT W X 20FT L, WOOD FLOOR, WOOD FOOTINGS,8FT MIN CLEARANCE
93111AW	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE,BASIC BUILDING,ONE STORY,30FT W X 40FT L,WOOD FLOOR,CONCRETE FOOTINGS,8FT MIN CLEARANCE
93111AY	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE, ADDITIONAL BAY,ONE STORY,30FT W X 10FT L,WOOD FLOOR,CONC FOOTINGS,8FT MIN CLEARANCE
93111BA	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,LINED FOR TEMPERATE CLIMATE,BASIC BUILDING, ONE STORY,30FT W X 40FT L, WOOD FLOOR, WOOD FOOTINGS,8FT MIN CLEARANCE
93111BB	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,LINED FOR TEMPERATE CLIMATE,ADDITIONAL BAY, ONE STORY,30FT W X 10FT L, WOOD FLOOR, WOOD FOOTINGS,8FT MIN CLEARANCE
93111BC	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE,BASIC BUILDING,ONE STORY,30FT W X 40FT L,WOOD FLOOR,WOOD FOOTINGS,8FT MIN CLEARANCE
93111BD	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE, ADDITIONAL BAY,ONE STORY,30FT W X 10FT L,WOOD FLOOR,WOOD FOOTINGS,8FT MIN CLEARANCE

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	HOR	VERT	GENL	TOT
4	7	1,279	2	107	18	127	
7	12	2,029	2	106	5	113	
23	35	6,199	3	97	16	116	
5	8	1,546	5	140	18	163	
17	27	4,748	5	189	18	212	
4	6	1,122	3	104	16	123	
20	32	6,157	5	190	18	175	
5	8	1,546	5	196	18	219	

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>								
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>TONS</u>	<u>WT SHT</u>	<u>VOL MEAS</u>	<u>TONS</u>	<u>COST \$</u>	<u>CONST HOR</u>	<u>EFFORT VERT</u>	<u>IN MAN-HOURS GENL</u>	<u>TOT</u>
93111BE	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE,BASIC BUILDING,ONE STORY,30FT W X 40FT L,CONC FLOOR,CONCRETE FOOTINGS,8FT MIN CLEARANCE	29		33		5,327	5	131	18	154
93111BF	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE,ADDITIONAL BAY,ONE STORY,30FT W X 40FT L,CONC FLOOR,CONCRETE FOOTINGS,8FT MIN CLEARANCE	7		8		1,365	2	64	5	71
93111BG	BARRACKS TYPE,WOOD FRAME W/WOOD ROOF,ASPHALT ROOFING AND PLYWOOD SIDING,INSULATED CEILING FOR TROPIC CLIMATE,BASIC BUILDING,ONE STORY,40FT W X 50FT L,CONCRETE FLOOR,CONCRETE FOOTINGS,8FT MIN CLEARANCE	45		49		7,913	2	46	5	53
93111DA	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 32FT W X 32FT L,WOOD ROOF & ASPH ROOFING CONCRETE FOOTINGS,TEMPERATE CLIMATE,13FT 9IN MIN CLEARANCE	28		29		3,330	23	258	46	327
93111DB	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 32FT W X 32FT L,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	30		32		4,280	23	242	46	311
93111DC	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 32FT WIDE BLDG,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TEMPERATE CLIMATE,13FT 9IN MIN CLEARANCE	14		15		1,788	7	138	32	177
93111DD	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 32FT WIDE BLDG,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	15		16		2,254	7	133	32	172
93111DE	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 48FT W X 32FT L,WOOD ROOF & ASPH ROOFING CONCRETE FOOTINGS,TEMPERATE CLIMATE,13FT 9IN MIN CLEARANCE	40		41		4,487	23	389	55	467

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST \$	CONST EFFORT IN MAN-HOURS	GENL	TOT
93111DF	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 48FT W X 32FT L,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	43	46		6,096	23	382	55 460
93111DG	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 48FT WIDE BLDG,WOOD ROOF & ASPH ROOFING,CONCRETE FOOTINGS,13FT 9IN MIN CLEARANCE TEMPERATE CLIMATE	19	19		2,143	7	197	51 255
93111DH	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 48FT WIDE BLDG,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	20	21		2,769	7	173	51 231
93111DJ	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 64FT W X 32FT L,WOOD ROOF & ASPH ROOFING CONCRETE FOOTINGS,TEMPERATE CLIMATE,13FT 9IN MIN CLEARANCE	54	54		6,114	28	690	69 587
93111DK	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 64FT W X 32FT L,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	57	60		7,860	28	478	69 575
93111DL	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 64FT WIDE BLDG,WOOD ROOF & ASPH ROOFING,CONCRETE FOOTINGS,13FT 9IN MIN CLEARANCE TEMPERATE CLIMATE	24	23		2,493	7	260	69 336
93111DM	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 64FT WIDE BLDG,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	25	26		3,232	7	246	69 322
93111DN	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 80FT W X 32FT L,WOOD ROOF & ASPH ROOFING CONCRETE FOOTINGS,TEMPERATE CLIMATE,13FT 9IN MIN CLEARANCE	65	65		7,079	28	589	83 700

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST S	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
93111DP	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 80FT W X 32FT L,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	69	73	9,438	28	380	83	691
93111DR	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 80FT WIDE BLDG,WOOD ROOF & ASPH ROOFING,CONCRETE FOOTINGS,13FT 9IN MIN CLEARANCE TEMPERATE CLIMATE	29	28	2,851	9	314	81	404
93111DT	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 80FT WIDE BLDG,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	31	31	3,746	9	301	81	391
93111DU	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 96FT W X 32FT L,WOOD ROOF & ASPH ROOFING CONCRETE FOOTINGS,TEMPERATE CLIMATE,13FT 9IN MIN CLEARANCE	78	78	8,380	28	702	97	827
93111DV	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,BASIC BUILDING 96FT W X 32FT L,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	82	86	10,987	28	681	97	806
93111DW	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 96FT WIDE BLDG,WOOD ROOF & ASPH ROOFING,CONCRETE FOOTINGS,13FT 9IN MIN CLEARANCE TEMPERATE CLIMATE	34	32	3,222	9	389	101	479
93111DY	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION WAREHOUSE TYPE,ADDITIONAL 16FT BAY FOR 96FT WIDE BLDG,WOOD ROOF AND ASPHALT ROOFING,CONCRETE FOOTINGS,TROPICAL CLIMATE,13FT 9IN MIN CLEARANCE	35	35	4,229	9	361	101	471
93111LW	SLIDING DOOR;FOR OPENING 10FT WIDE X12FT HIGH;DOOR-IN-PAIR W/DOUBLE TRACK;WOOD FRAME WAREHOUSE TYPE BLDGS.	1	1	205	18	9	27	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
93111LY	SLIDING DOOR;FOR OPENING TO OR 12FT WIDE X12FT HIGH;ONE PANEL W/SINGLE TRACK;WOOD FRAME WAREHOUSE TYPE BLDGS.	1	1	122	16	7	24	
93111MN	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE BASIC BUILDING 100FT WS 100FT WOOD ROOF & ASPH ROOFING; CONCRETE FOUNDATION; 20FT MIN CLEARANCE; TEMPERATE	111	142	32,250				
93111HP	FRAME ROOF + FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE BASIC BUILDING 100FT W X 100FT L,CORRUGATED STEEL ROOF, CONCRETE FOUNDATION 20FT MIN CLEARANCE,TROPICAL	97	111	29,034				
93111MR	FRAME ROOF & FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE ADDITIONAL 20FT BAY FOR 100FT WIDE BLDG;WOOD ROOF & ASPH ROOFING; CONCRETE FOUNDATION 20FT MIN CLEARANCE; TEMPERATE.	19	24	5,507				
93111MT	FRAME ROOF < FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE ADDITIONAL 20FT BAY FOR 100FT WIDE BLDG CORRUGATED STEEL ROOF; CONCRETE FOUNDATION; 20FT MIN CLEARANCE; TROPICAL	17	21	5,452				
93111MU	FRAME ROOF < FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE BASIC BUILDING 140FT W X 140FT L; WOOD ROOF < ASPH ROOFING; CONCRETE FOUNDATION; 20FT MIN CLEARANCE; TEMPERATE	212	264	58,755				
93111MV	FRAME ROOF < FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE BASIC BUILDING 140FT W X 140FT L; CORRUGATED STEEL ROOF; CONCRETE FOUNDATION; 20FT MIN CLEARANCE; TROPICAL	159	190	49,230				
93111MN	FRAME ROOF < FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE ADDITIONAL 20FT BAY FOR 140FT WIDE BLDG; WOOD ROOF < ASPH ROOFING; CONCRETE FOUNDATION 20FT MIN CLEARANCE; TEMPERATE.	26	33	7,450				
93111HY	FRAME ROOF < FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE ADDITIONAL 20FT BAY FOR 140 FT WIDE BLDG;CORRUGATED STEEL ROOF; CONCRETE FOUNDATIONS; 20FT MIN CLEARANCE; TROPICAL	19	26	6,926				
93111NA	FRAME ROOF AND FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE BASIC LEAN-TO 20 FT W X 20 FT L; WOOD ROOF AND ASPHALT ROOFING; CONCRETE FOUNDATION; 14FT 6IN MIN CLEARANCE; TEMP	30	26	34,127				

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN GENL MAN-HOURS	TOT
93111ND	FRAME ROOF AND FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE ADDITIONAL 20FT BAY FOR 20 FT W LEAN-TO; WOOD ROOF AND ASPH ROOFING; CONCRETE FOUNDATION; 14FT 6IN MIN CLEARANCE;TEMP	15	13	17,043				
93111NE	FRAME ROOF AND FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE BASIC LEAN-TO 40 FT W X 20 FT L; WOOD ROOF AND ASPHALT ROOFING; CONCRETE FOUNDATION; 14FT 6IN MIN CLEARANCE;TEMP	58	50	67,126				
93111NF	FRAME ROOF AND FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE BASIC LEAN-TO 40 FT W X 20 FT L; WOOD ROOF AND ASPHALT ROOFING; CONCRETE FOUNDATION; 14FT 6IN MIN CLEARANCE;TEMP	59	50	67,206				
93111NG	FRAME ROOF AND FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE ADDITIONAL 20FT BAY FOR 40FT W LEAN-TO; WOOD ROOF AND ASPH ROOFING; CONCRETE FOUNDATION; 14FT 6IN MIN CLEARANCE;TEMP	26	21	32,695				
93111NH	FRAME ROOF AND FOUNDATION WOOD FRAME CONSTRUCTION SHOP TYPE ADDITIONAL 20FT BAY FOR 40FT W LEAN-TO; WOOD ROOF AND ASPH ROOFING; CONCRETE FOUNDATION; 14FT 6IN MIN CLEARANCE;TEMP	26	22	32,468				
93111NJ	SMOKE JACK FOR RAILROAD STEAM ENGINE HOUSE							
93111NK	TEN TON CRANE SUPPORT							
93111PA	FLOOR CONCRETE W/O REINFORCING 2 IN THICK 1000 SF ALL TYPE BUILDINGS	4	2	84	2	16	28	66
93111PB	FLOOR CONCRETE W/O REINFORCING 4 IN THICK 1000 SF ALL TYPE BUILDINGS	7	5	160	2	29	51	82
93111PC	FLOOR CONCRETE W/6X6 MESH REINFORCING 6 INCH THICK 1000 SF ALL TYPE BUILDING	11	8	373	3	37	87	107
93111PD	CLADDING CORRUGATED STEE W/DOORS & WINDOWS 100 FT PERIMETER OF BLDG,8FT HIGH, BARRACKS TYPE BLDG, WOOD FRAME CONST	1	1	503	2	87	5	94

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			
					<u>HOR</u>	<u>VERT</u>	<u>GENL</u>	<u>TOT</u>
93111PE	CLADDING CORRUGATED STEEL W/DOORS SCREENED OPENINGS & VENTS, 100 FT PERIMETER OF BLDG, 8FT HIGH, BARRACKS TYPE BLDG, WOOD FRAME CONST	2	2	686	2	127	3	134
93111PF	CLADDING CORRUGATED STEEL W/DOORS & WINDOWS 100 FT PERIMETER OF BLDG, 13FT-9IN HIGH, WAREHOUSE TYPE BLDG, WOOD FRAME CONST.	3	5	835	5	113	28	146
93111PG	CLADDING CORRUGATED STEEL W/DOORS SCREENED OPENINGS & VENTS, 100 FT PERIMETER OF BLDG, 13FT-9IN HIGH, WAREHOUSE TYPE BLDG, WOOD FRAME CONST	3	5	803	5	140	28	173
93111PH	LINER REFLECTIVE TYPE INSULATION FOR CEILING 1000 SF AREA COVERED, WOOD FRAME WAREHOUSE TYPE BLDGS.	1	1	484	2	37	5	44
93111RA	WOOD COLUMN FOR CORE MODULE WITH CONCRETE FOUNDATION ALL CLIMATES	9	7	1,240	2	26	2	30
93111RB	WOOD COLUMN FOR VEHICLE BAY MODULE WITH CONCRETE FOUNDATION ALL CLIMATES	10	7	1,288	2	26	5	35
93111RC	20 FOOT LONG WOOD WALL FOR CORE MODULE WITH CONCRETE FOUNDATION, WINDOWS, DOORS, CLADDING, INSULATION DESERT/TROPIC CLIMATES	24	21	1,819	20	334	66	420
93111RD	60 FOOT LONG WOOD WALL FOR VEHICLE BAY MODULE WITH CONCRETE FOUNDATION, WINDOWS, DOORS, CLADDING, INSULATION DESERT/TROPIC CLIMATES	71	76	4,914	83	946	240	1,269
93111RE	60 FOOT LONG WOOD WALL FOR CORE MODULE WITH CONCRETE FOUNDATION, WINDOWS, DOORS, CLADDING, INSULATION DESERT/TROPIC CLIMATES	73	70	8,451	69	863	197	1,129
93111RF	20 FOOT LONG WOOD WALL FOR VEHICLE BAY MODULE WITH CONCRETE FOUNDATION, WINDOWS, DOORS, CLADDING, INSULATION DESERT/TROPIC CLIMATES	36	32	4,142	28	315	81	424

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	IN GENL	TOT
93111RG	WOOD ROOF FRAMING FOR 1200S.F. INTERIOR BAY OR CORE MODULE WITH DECKING, ROOFING, INSULATION DESERT/TROPIC CLIMATES	8	27	3,359	24	393	76	493
93111RH	COMPLETER SET FOR WOOD ROOF FRAMING FOR END BAY MODULE WITH DECKING, ROOFING, INSULATION (USED WITH 93111RG FOR END SUBFACILITIES ONLY) DESERT/TROPIC CLIMATES	3	2	3,049	6	13	13	32
93111RJ	6 INCH CONCRETE FLOOR SLAB FOR VEHICLE BAY MODULE, 1200S.F. AREA ALL CLIMATES	199	135	1,360	14	3	6	23
93111RK	4 INCH CONCRETE FLOOR SLAB FOR CORE MODULE, 1200S.F., AREA ALL CLIMATES	133	90	942	14	3	6	23
93111RL	VEHICLE BAY END MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN ONE SIDE, ONE COLUMN TEMPERATE/FRIGID CLIMATES	366	328	26,506	132	1,305	353	1,790
93111RM	VEHICLE BAY END MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN ONE SIDE, TWO COLUMNS TEMPERATE/FRIGID CLIMATES	374	335	27,794	138	1,332	348	1,818
93111RN	VEHICLE BAY END MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, CLOSED ALL SIDES, TWO COLUMNS TEMPERATE/FRIGID CLIMATES	445	411	32,708	217	2,277	589	3,083
93111RP	1200 SQUARE FOOT CORE END MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN ONE SIDE, ONE COLUMN TEMPERATE/FRIGID CLIMATES	275	248	23,070	135	1,632	368	2,135
93111RR	1200 SQUARE FOOT CORE INTERIOR MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN TWO SIDES, ONE COLUMN TEMPERATE/FRIGID CLIMATES	199	176	11,570	60	757	159	976

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					HOR	VERT	GENL	TOT
93111RT	1200 SQUARE FOOT CORE END MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND WOOD ROOF DECKING, OPEN ONE SIDE, TWO COLUMNS TEMPERATE/FRIGID CLIMATES	357	325	32,761	206	1,026	567	1,799
93111RU	VEHICLE BAY INTERIOR MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECKING, OPEN TWO SIDES, ONE COLUMN TEMPERATE/FRIGID CLIMATES	290	246	16,983	68	715	176	939
93111RV	VEHICLE BAY END MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN ONE SIDE, ONE COLUMN DESERT/TROPIC CLIMATES	363	311	22,254	132	1,304	344	1,780
93111RW	VEHICLE BAY END MODULE-WOOD FRAME CONSTRUCTION, FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN ONE SIDE ONLY, TWO COLUMNS DESERT/TROPIC CLIMATE	373	318	23,542	135	1,331	348	1,814
93111RY	VEHICLE BAY END MODULE-WOOD FRAME CONSTRUCTION, FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN ONE SIDE, TWO COLUMNS DESERT/TROPIC CLIMATES	444	394	28,456	217	2,277	589	3,085
93111TA	1200 SQUARE FOOT CORE END MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN ONE SIDE, ONE COLUMN DESERT/TROPIC CLIMATES	274	238	20,679	135	1,632	359	2,126
93111TB	1200 SQUARE FOOT CORE INTERIOR MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECK, OPEN TWO SIDES, ONE COLUMN DESERT/TROPIC CLIMATES	198	166	9,179	60	757	150	967
93111TC	1200 SQUARE FOOT CORE END MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND WOOD ROOF DECKING, OPEN ONE SIDE, TWO COLUMNS DESERT/TROPIC CLIMATES	356	315	30,370	206	1,026	558	1,790

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	VERT	GENL	TC
93111TD	VEHICLE BAY INTERIOR MODULE-WOOD FRAME CONSTRUCTION, CONCRETE FLOOR AND FOUNDATIONS, WOOD CLADDING AND ROOF DECKING, OPEN TWO SIDES, ONE COLUMN DESERT/TROPIC CLIMATES	289	233	14,291	68	715	167	93	
93111TE	CORE-1200S.F.-ADDITIONAL WALL INSULATION FOR MAX."U"=0.1 TEMPERATE/FRIGID CLIMATES	1	10	2,391		1	9	1	
93111TF	CORE-2400S.F.-ADDITIONAL WALL INSULATION FOR MAX."U"=0.1 TEMPERATE/FRIGID CLIMATES	1	14	3,338		1	9	1	
93111TG	REPAIR BAY-ADDITIONAL SIDE WALL INSULATION FOR MAX."U"=0.1 TEMPERATE/FRIGID CLIMATES	1	11	2,692		1	9	1	
93111TH	REPAIR BAY-ADDITIONAL END WALL INSULATION FOR MAX."U"=0.1 TEMPERATE/FRIGID CLIMATES		6	1,360		1	9	1	
93112AA	PANELIZED WOOD BLDGS 12 FT WIDE DESERT/TROPICAL, COMPLETE CONCRETE FLOOR BLDG, X 24 FT LONG.	11	6	1,661	16	200	118	33	
93112AC	PANELIZED WOOD BLDGS 12 FT WIDE DESERT/TROPICAL, COMPLETE CONCRETE STEMWALL FTG, X 24 FT LONG.	12	13	3,179	18	213	124	39	
93112AE	PANELIZED WOOD BLDGS 12 FT WIDE DESERT/TROPICAL, COMPLETE WOOD FLOOR BLDG, X 24 FT LONG.	10	9	6,247	17	266	116	39	
93112AH	BUILDING SUPERSTRUCTURE FOR 12X24 FOOT PANELIZED WOOD BUILDING	3	7	1,603	5	100	44	14	
93112BA	PANELIZED WOOD BLDGS 24 FT WIDE DESERT/TROPICAL, COMPLETE CONCRETE FLOOR BLDG, X 24 FT LONG.	25	27	5,342	22	381	213	61	
93112BB	PANELIZED WOOD BLDGS 24 FT WIDE DESERT/TROPICAL, COMPLETE CONCRETE FLOOR BLDG, X 36 FT LONG.	36	37	6,638	29	526	238	71	
93112BC	PANELIZED WOOD BLDGS 24 FT WIDE DESERT/TROPICAL, COMPLETE CONCRETE FLOOR BLDG, X 48 FT LONG.	46	46	7,935	40	590	346	91	

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
93112BD	PANELIZED WOOD BLDGS 24 FT WIDE DESERT/TROPICAL, COMPLETE CONCRETE FLOOR BLDG, X 60 FT LONG.
93112BL	24 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY END BAY, PANELIZED WOOD BUILDING.
93112BM	24 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY INTERIOR BAY, PANELIZED WOOD BUILDING.
93112BN	24 FT WIDE WALL ASSEMBLY END BAY, PANELIZED WOOD BUILDING.
93112BP	24 FT WIDE WALL ASSEMBLY INTERIOR BAY, PANELIZED WOOD BUILDING.
93112CA	PANELIZED WOOD BLDGS 24 FT WIDE DESERT/TROPICAL, COMPLETE WOOD FLOOR BLDG, X 24 FT LONG.
93112CB	PANELIZED WOOD BLDGS 24 FT WIDE DESERT/TROPICAL, COMPLETE WOOD FLOOR BLDG, X 36 FT LONG.
93112CC	PANELIZED WOOD BLDGS 24 FT WIDE DESERT/TROPICAL, COMPLETE WOOD FLOOR BLDG, X 48 FT LONG.
93112CD	PANELIZED WOOD BLDGS 24 FT WIDE DESERT/TROPICAL, COMPLETE WOOD FLOOR BLDG, X 60 FT LONG.
93112DA	PANELIZED WOOD BLDGS 36 FT WIDE X 40 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.
93112DB	PANELIZED WOOD BLDGS 36 FT WIDE X 60 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.
93112DC	PANELIZED WOOD BLDGS 36 FT WIDE X 80 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.
93112DD	PANELIZED WOOD BLDGS 36 FT WIDE X 100 FT LONG X 8 FT HIGH, DESERT/TROPICAL, COMPLETE CONCRETE FLOOR BLDG.

SHT TONS	MEAS TONS	WT VOL	COST \$	CONSTRUCTION MATERIAL			
				HOR	VERT	GENL	TOT
56	55	9,231	48	695	413	1,156	
2	5	987	1	68	31	100	
1	4	326	1	54	28	83	
1	4	936	2	81	35	118	
1	1	572	1	28	13	42	
20	22	13,698	28	599	273	900	
25	27	16,328	36	784	360	1,180	
30	32	19,966	46	986	458	1,690	
34	35	22,280	54	1,179	552	1,785	
136	638	49,927	47	616	429	892	
203	961	75,176	67	590	546	1,203	
270	1,284	100,425	87	765	665	1,917	
337	1,607	125,674	106	937	783	1,826	

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			
					<u>HOR</u>	<u>VERT</u>	<u>GENL</u>	<u>TOT</u>
93112DE	PANELIZED WOOD BLDGS 36 FT WIDE X 120 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	404	1,930	150,923	128	1,111	900	2,139
93112DF	PANELIZED WOOD BLDGS 36 FT WIDE X 60 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	136	646	50,887	67	637	388	1,072
93112DG	PANELIZED WOOD BLDGS 36 FT WIDE X 60 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	204	973	76,729	68	844	531	1,661
93112DH	PANELIZED WOOD BLDGS 36 FT WIDE X 80 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	272	1,300	102,571	87	1,055	673	1,815
93112DJ	PANELIZED WOOD BLDGS 36 FT WIDE X 100 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	340	1,627	128,413	99	1,262	815	2,176
93112DK	PANELIZED WOOD BLDGS 36 FT WIDE X 120 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	408	1,954	154,255	128	1,470	959	2,557
93112DW	36 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY END BAY, PANELIZED WOOD BUILDING	43	303	21,930	2	102	38	162
93112DY	36 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY INTERIOR BAY,PANELIZED WOOD BUILDING.	46	312	23,915	2	84	40	126
93112EA	PANELIZED WOOD BLDGS 36 FT WIDE X 60 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	110	620	60,042	31	719	477	1,227
93112EB	PANELIZED WOOD BLDGS 36 FT WIDE X 60 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	162	935	90,127	40	1,052	622	1,714
93112EC	PANELIZED WOOD BLDGS 36 FT WIDE X 80 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	214	1,250	120,212	49	1,381	777	2,201
93112ED	PANELIZED WOOD BLDGS 36 FT WIDE X 100 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	266	1,565	150,298	59	1,724	907	2,690
93112EE	PANELIZED WOOD BLDGS 36 FT WIDE X 120 FT LONG X 8 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	318	1,880	180,383	67	2,045	1,065	3,177

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
93112EF	PANELIZED WOOD BLDGS 36 FT WIDE X 40 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG
93112EG	PANELIZED WOOD BLDGS 36 FT WIDE X 60 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG
93112EH	PANELIZED WOOD BLDGS 36 FT WIDE X 80 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG
93112EJ	PANELIZED WOOD BLDGS 36 FT WIDE X 100 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG
93112EK	PANELIZED WOOD BLDGS 36 FT WIDE X 120 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG
93112FA	36 FT WIDE 8 FT HIGH WALL ASSEMBLY END BAY/PANELIZED WOOD BUILDING.
93112FB	36 FT WIDE 8 FT HIGH WALL ASSEMBLY INTERIOR BAY,PANELIZED WOOD BUILDING.
93112FC	36 FT WIDE 12 FT HIGH WALL ASSEMBLY END BAY,PANELIZED WOOD BUILDING.
93112FD	36 FT WIDE 12 FT HIGH WALL ASSEMBLY INTERIOR BAY,PANELIZED WOOD BUILDING.
93112GA	PANELIZED WOOD BLDGS 48 FT WIDE X 60 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG
93112GB	PANELIZED WOOD BLDGS 48 FT WIDE X 80 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG
93112GC	PANELIZED WOOD BLDGS 48 FT WIDE X 100 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG
93112GD	PANELIZED WOOD BLDGS 48 FT WIDE X 120 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG

CONSTRUCTION MATERIAL

WT TONS	VOL TONS	COST \$	CONST HRS	EFFORT IN MAN-HOURS	IN MAN-HOURS	GENL	TOT
SHT TONS	MEAS TONS	COST \$	HRS	VERT	NOR	TOT	
110	622	60,738	31	917	400	1,368	
163	938	91,284	40	1,270	554	1,864	
216	1,254	121,702	49	1,625	708	2,382	
269	1,570	152,377	59	1,979	863	2,901	
322	1,886	182,923	67	2,333	1,017	3,617	
3	5	1,922	5	92	40	137	
1	1	690	2	48	21	71	
3	6	2,270	5	139	53	197	
2	2	1,131	2	71	29	102	
194	881	72,524	75	1,225	726	2,026	
207	896	76,450	91	1,518	886	2,495	
220	911	78,864	114	1,818	1,053	2,985	
233	926	82,034	130	2,129	1,227	3,486	

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>						
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>	<u>CONST EFFORT IN MAN-HOURS</u>			
					<u>HOR</u>	<u>VERT</u>	<u>GENL</u>	<u>TOT</u>
931126E	PANELIZED WOOD BLDGS 48 FT WIDE X 140 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	246	941	85,204	166	2,431	1,394	3,971
931126F	PANELIZED WOOD BLDGS 48 FT WIDE X 160 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	259	956	88,374	168	2,723	1,555	4,446
931126L	48 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY END BAY, PANELIZED WOOD BUILDING.	58	407	30,497	2	230	109	341
931126M	48 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY INTERIOR BAY, PANELIZED WOOD BUILDING.	6	9	1,539	2	193	95	290
931126N	48 FT WIDE WALL ASSEMBLY END BAY, PANELIZED WOOD BUILDING.	4	8	2,665	3	133	51	187
931126P	48 FT WIDE WALL ASSEMBLY INTERIOR BAY, PANELIZED WOOD BUIL- DING.	1	1	1,023	2	71	29	102
931126R	48 FT WIDE WOOD FLOOR FRAMING END BAY, PANELIZED WOOD BUIL- DING.	20	19	6,911	10	267	117	374
931126A	PANELIZED WOOD BLDGS 48 FT WIDE X 60 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG.	173	884	90,437	75	1,807	811	2,693
931126B	PANELIZED WOOD BLDGS 48 FT WIDE X 80 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG.	186	898	99,391	93	2,307	1,037	3,437
931126C	PANELIZED WOOD BLDGS 48 FT WIDE X 100 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG.	197	912	108,345	114	2,803	1,263	4,180
931126D	PANELIZED WOOD BLDGS 48 FT WIDE X 120 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG.	208	926	117,299	135	3,314	1,493	4,942
931126E	PANELIZED WOOD BLDGS 48 FT WIDE X 140 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG.	219	940	126,253	156	3,793	1,711	5,660

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
					HOR	VERT	GENL	TOT
93112HF	PANELIZED WOOD BLDGS 48 FT WIDE X 160 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG.	230	954	135,207	176	4,290	1,938	6,404
93112HG	PANELIZED WOOD BLDGS 48 FT WIDE X 60 FT LONG X 12 FT HIGH, TEMPERATE/FRIGID. COMPLETE WOOD FLOOR BLDG.	175	884	90,437	75	1,807	811	2,693
93112JA	PANELIZED WOOD BLDGS 60 FT WIDE X 60 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	243	1,087	86,714	102	1,273	797	2,172
93112JB	PANELIZED WOOD BLDGS 60 FT WIDE X 80 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	284	1,127	92,610	137	1,588	1,012	2,737
93112JC	PANELIZED WOOD BLDGS 60 FT WIDE X 100 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	325	1,167	98,450	167	1,887	1,219	3,273
93112JD	PANELIZED WOOD BLDGS 60 FT WIDE X 120 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	366	1,207	104,318	200	2,216	1,440	3,856
93112JE	PANELIZED WOOD BLDGS 60 FT WIDE X 140 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	407	1,247	110,186	232	2,530	1,654	4,416
93112JF	PANELIZED WOOD BLDGS 60 FT WIDE X 160 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	448	1,287	116,054	263	2,845	1,869	4,977
93112JG	PANELIZED WOOD BLDGS 60 FT WIDE X 180 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG.	489	1,327	121,922	294	3,159	2,083	5,536
93112JL	60 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY END BAY PANELIZED WOOD BUILDING.	62	493	35,513	3	201	84	288
93112JM	60 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY INTERIOR BAY,PANELIZED WOOD BUILDING.	7	17	3,689	3	168	74	243
93112JN	60 FT WIDE WALL ASSEMBLY END BAY,PANELIZED WOOD BUILDING.	4	8	3,189	5	166	63	234
93112JP	60 FT WIDE WALL ASSEMBLY INTERIOR BAY,PANELIZED WOOD BUIL- DING.	2	2	1,139	2	71	29	102

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT	IN MAN-HOURS	
					HOR	VERT	GENL	TOT
93112JR	60 FT WIDE WOOD FLOOR FRAMING END BAY, PANELIZED WOOD BUILDING.	25	22	8,529	14	324	155	493
93112KA	PANELIZED WOOD BLDGS 60 FT WIDE X 60 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	151	1,033	92,299	91	2,045	890	3,026
93112KB	PANELIZED WOOD BLDGS 60 FT WIDE X 80 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	216	1,102	122,766	118	2,574	1,119	3,811
93112KC	PANELIZED WOOD BLDGS 60 FT WIDE X 100 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	231	1,126	134,871	140	3,098	1,348	4,586
93112KD	PANELIZED WOOD BLDGS 60 FT WIDE X 120 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	246	1,152	147,724	164	3,629	1,574	5,367
93112KE	PANELIZED WOOD BLDGS 60 FT WIDE X 140 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	261	1,177	160,513	190	4,158	1,802	6,150
93112KF	PANELIZED WOOD BLDGS 60 FT WIDE X 160 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	276	1,202	173,302	210	4,686	2,030	6,926
93112KG	PANELIZED WOOD BLDGS 60 FT WIDE X 180 FT LONG X 12 FT HIGH, DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	287	1,228	185,455	236	5,198	2,241	7,675
93112LA	PANELIZED WOOD BLDGS 144 FT WIDE X 140 FT LONG X 12 FT HIGH DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG	739	2,828	256,776	436	6,972	3,856	11,264
93112LB	PANELIZED WOOD BLDGS 144 FT WIDE X 160 FT LONG X 12 FT HIGH DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG	788	2,883	267,059	491	7,792	4,308	12,591
93112LC	PANELIZED WOOD BLDGS 144 FT WIDE X 180 FT LONG X 12 FT HIGH DESERT/TROPICAL. COMPLETE CONCRETE FLOOR BLDG	837	2,938	277,342	545	8,612	4,761	13,918
93112LG	PANELIZED WOOD BLDGS 144 FT WIDE X 140 FT LONG X 12 FT HIGH DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	515	2,726	364,667	369	10,455	4,506	15,330
93112LH	PANELIZED WOOD BLDGS 144 FT WIDE X 160 FT LONG X 12 FT HIGH DESERT/TROPICAL. COMPLETE WOOD FLOOR BLDG	542	2,772	389,738	417	11,786	5,089	17,292

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS HOR VERT GENL TOT			
93112LJ	PANELIZED WOOD BLDGS 144 FT WIDE X 180 FT LONG X 12 FT HIGH DESERT/TROPICAL, COMPLETE WOOD FLOOR BLDG	569	2,818	474,809	465 13,127 3,671 19,263			
93112LL	144 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY END BAY PANELIZED WOOD BUILDING	155	1,203	90,862	7 779 307 1,093			
93112LM	144 FT WIDE DESERT/TROPICAL COMPLETE ROOF ASSEMBLY END BAY INTERIOR BAY, PANELIZED WOOD BUILDING.	15	31	7,868	7 658 290 955			
93112LP	144 FT WIDE WALL ASSEMBLY INTERIOR BAY, PANELIZED WOOD BUILDING.	2	3	1,183	2 75 30 107			
93112NA	FOOTING STEM WALL 40 LF 2 FT DEEP, PANELIZED WOOD BUILDING.	1	1	290	2 29 21 52			
93112NK	FOOTING STEM WALL 40 LF 5.5 FT DEEP, PANELIZED WOOD BUILDING	3	2	443	3 71 69 143			
93112NL	FOOTING STEM WALL 5.5 FT DEEP EXTERNAL COLUMN PAD, PANELIZED WOOD BUILDING.			49	3 3 2 10			
93112NM	FOOTING STEM WALL 5.5 FT DEEP EXTERNAL COLUMN PAD, PANELIZED WOOD BUILDING.			59	5 3 6 16			
93112NN	FOOTING THICK SLAB 40 LF, PANELIZED WOOD BUILDING.	2	1	326	2 21 17 40			
93112NP	FOOTING THICK SLAB INT. COLUMN PAD, PANELIZED WOOD BUILDING.			38	5 2 1 8			
93112NR	FOOTING THICK SLAB INT. COLUMN PAD, PANELIZED WOOD BUILDING.			48	5 3 3 11			
93112NT	CONCRETE SLAB 12 FT X 20 FT AREA 4 INCH THICK, PANELIZED WOOD BUILDING.	6	3	64	3 6 12 21			
93112NU	CONCRETE SLAB 12 FT X 20 FT AREA 6 INCH THICK, PANELIZED WOOD BUILDING.	6	4	108	3 9 17 29			
93112NW	ANCHOR BOLTY COL. AND TIE DOWN CONNECTOR, PANELIZED WOOD BUILDING.			7	1 1 1 2			

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	TONS	WT SHT	VOL HEAS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT
93112NY	CONCRETE 2500 POUNDS SQUARE INCH ONE CUBIC YARD, PANELIZED WOOD BUILDING.				12		2	3 5
93112PA	WOOD FLOOR INTERIOR EMBED POST FOR 10 FT GIRDERS, PANELIZED WOOD BUILDING.				151	9	5	3 17
93112PB	WOOD FLOOR EMBED POST AT O.S. PERIMETER AND 12 FT GIRDERS, PANELIZED WOOD BUILDING.	1			175	1	5	5 11
93112PC	WOOD FLOOR GIRDER INTERIOR BAY X 12 FT, PANELIZED WOOD BUILDING.				62	9	5	2 16
93112PD	WOOD FLOOR GIRDER END BAY X 12 FT, PANELIZED WOOD BUILDING.				39	9	2	1 12
93112PE	WOOD FLOOR GIRDER INTERIOR BAY X 10 FT, PANELIZED WOOD BUILDING.				16	9	3	2 14
93112PF	WOOD FLOOR GIRDER END BAY X 10 FT, PANELIZED WOOD BUILDING.				54	9	5	2 16
93112PG	WOOD FLOOR GIRDER END BAY AT COLUMNS 60 FT BUILDING, PANELIZED WOOD BUILDING				62	28	5	2 35
93112PH	WOOD FLOOR GIRDER INTERIOR BAY AT COL. 60 FT BUILDING, PANELIZED WOOD BUILDING	1			120	9	3	2 14
93112PL	WOOD FLOOR EXTERIOR COLUMN TO GIRDER CONNECTOR, PANELIZED WOOD BUILDING.	1			107		3	2 5
93112PM	WOOD FLOOR INTERIOR COLUMN TO GIRDER CONNECTOR, PANELIZED WOOD BUILDING.	1			64		3	2 5
93112PN	WOOD FLOOR SUPPORT FOR COLUMNS IN PANELIZED WOOD BUILDINGS	1		1	156	1	6	3 10
93112PP	WOOD FLOOR SUPPORT FOR INTERIOR COLUMNS 60 FT BUILDING, PANELIZED WOOD BUILDING.	1		2	282	1	10	5 16
93112PR	WOOD FLOOR PANEL 4 FT X 12 FT, PANELIZED WOOD BUILDING.				163	9	5	2 16

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS TONS	COST \$	CONST HOR	EFFORT	IN MAN-HOURS	
						HOR	VERT	GENL	TOT
93112PT	WOOD FLOOR POST FOR 10 FT GIRDERS, PANELIZED WOOD BUILDING.				145	9	3	1	13
93112PU	WOOD FLOOR POST FOR 12 FT GIRDERS, PANELIZED WOOD BUILDING.				167	9	3	2	16
93112PY	STAIRS AND PORCH, PANELIZED WOOD BUILDING.	1	2	1,071			18	5	23
93112RG	PANELIZED WOOD BUILDING, CORNER TIE DOWN CONNECTING GIRDER				87		1	1	2
93112TL	GABLE FOR 24 FT TRUSS 48 FT & 144 FT BUILDING, LEFT, PANELIZED WOOD BUILDING				58		8	5	13
93112TM	GABLE FOR 24 FT TRUSS 48 FT & 144 FT BUILDING, RIGHT, PANELIZED WOOD BUILDING				58		8	5	13
93112TN	GABLE FOR 24 FT TRUSS 144 FT BUILDING, RIDGE LEFT, PANELIZED WOOD BUILDING				58		8	5	13
93112TP	GABLE FOR 24 FT TRUSS 144 FT BUILDING, RIDGE RIGHT, PANELIZED WOOD BUILDING		1	138			8	5	13
93112TR	GABLE FOR 30 FT TRUSS 60 FT BUILDING, LEFT, PANELIZED WOOD BUILDING	1	1	277	124	10	6	140	
93112TW	ROOF PANEL FOR 12FOOT X 24FOOT BUILDING. DESERT/TROPIC CLIMATE ZONES				101	1	7	3	11
93112TY	ROOF PANEL FOR 12FOOT X 24FOOT BUILDING. TEMPERATE/FRIGID CLIMATE ZONE.				114	1	7	3	11
93112VC	INSULATION FIBERGLASS TYPE FLOOR 240 SQUARE FT, PANELIZED WOOD BUILDING.				21	2	2	1	5
93112VH	FILL NON-FROST SUSCEPTABLE 240 CUBIC FT, PANELIZED WOOD BUILDING.	13	6	66	5		2	7	
93112VK	WOOD FLOOR SKIRTING - 40 LF OF SIDEWALL, PANELIZED WOOD BUILDING.				18	5	2	1	8

DHDXER1

RUN DATE 860128

<u>DESERT CLIMATE</u>		<u>CONSTRUCTION MATERIAL</u>				<u>CONST EFFORT IN MAN-HOURS</u>			
<u>FACILITY NUMBER</u>	<u>DESCRIPTION</u>	<u>WT SHT TONS</u>	<u>VOL MEAS TONS</u>	<u>COST \$</u>		<u>HOR VERT</u>	<u>GENL</u>	<u>TOT</u>	
93112WD	WALL PANEL 8 FT HIGH,RIGH CORNER,PANELIZED WOOD BUILDING.			47		1	5	2	8
93112WW	WINDOW,DESERT/TROPICAL SINGLE GLAZING,PANELIZED WOOD BLDGS. BUILDING.			63		2	1	1	3
93115BA	BARRACKS, ARCH, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, TEMP CLIM	5	3	294					
93115BB	BARRACKS, ARCH, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, DESERT/TROPIC CLIM	5	3	294					
93115BC	BARRACKS, ARCH, LIGHTWEIGHT STEEL PANEL BUILDING WITH INTERIOR, 20 BY 50 BY 8, FRIGID CLIM	5	3	294					
99980AA	STANDARD DETAIL 1-A,INTERIOR PARTITION,10FT MAX HEIGHT, W/HARDPRESSED FIREBOARD TO 8FT HIGH ON ONE SIDE 100 LINEAL FEET UNIT.	3	4	740		69	9	9	78
99980AB	STANDARD DETAIL 1-B,INTERIOR PARTITION,10FT MAX HEIGHT, W/HARDPRESSED WALLBOARD TO 8FT HIGH ON ONE SIDE 100 LINEAL FEET UNIT.	4	5	1,746		69	9	9	78
99980AC	STANDARD DETAIL 1-C,INTERIOR PARTITION,10FT MAX HEIGHT, W/HARDPRESSED WALLBOARD TO 8FT HIGH ON ONE SIDE 100 LINEAL FEET UNIT.	3	4	802		92	14	14	106
99980AD	STANDARD DETAIL 1-D,INTERIOR PARTITION,10FT MAX HEIGHT, W/HARDPRESSED FIREBOARD TO 8FT HIGH ON ONE SIDE 100 LINEAL FEET UNIT.	2	2	723		92	14	14	106
99980AE	STANDARD DETAIL 1-E,INTERIOR PARTITION,10FT MAX HEIGHT, W/HARDPRESSED WALLBOARD TO 8FT HIGH ON ONE SIDE 100 LINEAL FEET UNIT.	4	5	1,090		127	18	18	145
99980AF	STANDARD DETAIL 1-F,INTERIOR PARTITION,10FT MAX HEIGHT, W/HARDPRESSED FIREBOARD TO 8FT HIGH ON ONE SIDE 100 LINEAL FEET UNIT.	2	2	817		127	18	18	145

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
99980A6	STANDARD DETAIL T-G, INTERIOR PARTITION, 10FT MAX HEIGHT, W/HARDPRESSED WALLBOARD TO 10ft HIGH ON BOTH SIDE 100 LINEAL FEET UNIT.	3	4		693	147	37	184	
99980AH	STANDARD DETAIL T-H, INTERIOR PARTITION, 10FT MAX HEIGHT, W/HARDPRESSED FIREBOARD TO 10ft HIGH ON BOTH SIDE 100 LINEAL FEET UNIT.	2	2		1,101	147	37	184	
99980AJ	STANDARD DETAIL 1-J, INTERIOR PARTITION, 10FT MAX HEIGHT, W/HARDPRESSED FIREBOARD ONE SIDE AND COMPOSITION WALLBOARD.	3	4		739	127	18	165	
99980AK	STANDARD DETAIL 1-K, INTERIOR PARTITION, 10FT MAX HEIGHT, W/HARDPRESSED FIBERBOARD ONE SIDE AND COMPOSITION WALLBOARD OTHER SIDE TO A FT HIGH 100 LINEAL FEET UNIT.	3	4		1,446	147	37	184	
99980AL	STANDARD DETAIL T-X, INTERIOR PARTITION, 10FT MAX HEIGHT 100 LINEAL FEET UNIT.	4	3		1,014	55	28	83	
99980AN	STANDARD DETAIL 1-L SOUNDPROOF PARTITION, 10 FT HIGH 100 LINEAL FEET UNIT.	4	6		1,392	184	37	221	
99980AN	STANDARD DETAIL 6-C COUNTER 1 FT 6 IN WIDE, 3 FT HIGH UNIT OF 100 LINEAL FEET FREE STANDING	2	2		722	101	18	119	
99980AP	STANDARD DETAIL 1-N, INTERIOR PARTITION, COMPOSITION 100 LINEAL FEET UNIT.	3	4		650	101	18	119	
99980AR	STANDARD DETAIL 1-P, LEADED PARTITION, 10FT MAX HEIGHT W/1 IN WOOD SHEATHING AND LEAD SHEET ONE SIDE AND HARDPRESSED FIBERBOARD OTHER SIDE 100 LINEAL FEET UNIT.	8	5		6,316	253	55	308	
99980AT	STANDARD DETAIL 1-Q, INTERIOR PARTITION, 10FT MAX HEIGHT FOR PHYSICAL TRAINING EQUIPMENT, 100 LINEAL FEET UNIT	3	3		1,199	147	18	165	
99980AU	STANDARD DETAIL 1-S, RAILING, 3FT HIGH, W/COMPOSITION WALLBOARD BOTH SIDES, 100 LINEAL FT UNIT.	1	1		269	78	9	87	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS		
		SHT			HOR	VERT	GENL	TOT
99980AV	STANDARD DETAIL 1-V. RAILING, 3FT HIGH W/HARDPRESSED FIBERBOARD BOTH SIDES, 100 LINEAL FEET UNIT.	1	1	296		78	9	87
99980AW	STANDARD DETAIL 1-Z, RAILING 3FT 6IN HIGH, 100 LINEAL FEET UNIT.	3	3	819		18	9	27
99980AY	STANDARD DETAIL 1-Z, GATE, 2FT 6IN WIDE OPENING FOR USE WITH 1-Z RAILING, UNIT OF TEN GATES.	1	1	308		55	28	83
99980BA	STANDARD DETAIL 1-T, SUSPENDED PARTITION, 3FT DROP, 100 LINEAL FT UNIT	1	2	884		69	37	106
99980BB	STANDARD DETAIL 1-W, INTERIOR PARTITION, 10FT MAX HEIGHT W/1 IN WOOD SHEATHING TO 4 1/2 FT AND 2 X 2 WIRE MESH TO 10 FT ALL ON ONE SIDE 100 LINEAL FEET UNIT.	3	4	1,119		55	18	73
99980BC	STANDARD DETAIL 1-AA INTERIOR PARTITION, 14FT MAX HEIGHT W/HARDPRESSED FIBERBOARD TO 8FT ON ONE SIDE AND BARBED WIRE TO 14FT 100 LINEAL FT UNIT.	3	3	680		92	28	120
99980BD	STANDARD DETAIL 1-BB INTERIOR PARTITION, 14FT MAX HEIGHT W/HARDPRESSED FIBERBOARD TO 14FT ON ONE SIDE ONLY 100 LINEAL FEET UNIT.	3	4	1,296		101	14	115
99980BE	STANDARD DETAIL 1-CC INTERIOR PARTITION, 14FT MAX HEIGHT W/HARDPRESSED FIBERBOARD TO 14FT ON BOTH SIDES 100 LINEAL FEET UNIT.	4	5	1,874		166	37	203
99980BF	STANDARD DETAIL 2-A PANEL DOOR 40IN X 84IN SINGLE LEAF COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS.	2	3	676		28	9	37
99980BG	STANDARD DETAIL 2-B PANEL DOOR 36IN X 84IN SINGLE LEAF COMPLETE WITH DOOR HARDWARE UNIT OF TENS DOORS.	2	3	789		28	9	37
99980BH	STANDARD DETAIL 2-C PANEL DOOR 30IN X 84IN SINGLE LEAF COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS.	2	4	847		28	9	37

DHDXER1

RUN DATE 860128

DESERT CLIMATE

FACILITY NUMBER	DESCRIPTION
99980BJ	STANDARD DETAIL 2-D PANEL DOOR 24IN X 84IN SINGLE LEAF COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS.
99980BK	STANDARD DETAIL 2-E PANEL DOOR 30IN X 84IN PAIR COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS OPENINGS.
99980BL	STANDARD DETAIL 2-F PANEL DOOR 30IN X 84IN W/VISION PANL COMPLETE WITH DOOR HARDWARD UNIT OF TEN DOORS.
99980BM	STANDARD DETAIL 2-G PANEL DOOR 30IN X 84IN IN PAIR W/DOOR HARDWARE UNIT OF TEN DOOR OPENINGS.
99980BN	STANDARD DETAIL 2-H BOARD &BATTEN DOOR 36IN X 82 IN COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS.
99980BP	STANDARD DETAIL 2-J BOARD &BATTEN DOOR 30IN X 82IN COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS.
99980BR	STANDARD DETAIL 2-K BOARD & BATTEN DOOR 36IN X 82IN IN PR COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS OPENINGS.
99980BT	STANDARD DETAIL 2-L BOARD & BATTEN DOOR 30IN X 82 IN IN PR COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS OPENINGS.
99980BU	STANDARD DETAIL 2-X BOARD &BATTEN DOOR 24IN X 82IN COMPLETE WITH DOOR HARDWARE UNIT OF 10 DOORS.
99980BV	STANDARD DETAIL 2-M PANEL DOOR 40IN X 84 IN LEAD FACED COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS OPENINGS.
99980BW	STANDARD DETAIL 2-N PANEL DOOR 36IN X 84 IN LEAD FACED COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS.
99980BY	STANDARD DETAIL 2-P PANEL DOOR 36IN X 84 IN LEAD FACED COMPLETE WITH DOOR HARDWARE UNIT OF TEN DOORS.
99980CA	STANDARD DETAIL 2-Q GATE 2FT 6IN W X 3FT HIGH OPENING UNIT OF TEN GATES.

CONSTRUCTION MATERIAL

WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS			
			HOR	VERT	GENL	TOT
3	5	579	28	9	37	
2	3	668	55	18	73	
2	3	505	46	9	55	
2	4	793	92	18	110	
1	2	200	74	9	83	
2	2	243	74	9	83	
3	5	477	101	18	119	
2	2	478	101	18	119	
2	2	610	74	9	83	
2	1	1,156	74	28	102	
2	1	1,196	74	28	102	
1	1	871	74	28	102	
		42	46			46

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL	TOT
99980CB	STANDARD DETAIL 2-R SCREENED LOUVER DOORS 2FT HX VARIABLE WIDTH UNIT OF 10 LOUVERS.			168		69		69
99980CC	STANDARD DETAIL 2-S LIGHT-PROOF LOUVER FOR DOORS 2FT HX VARIABLE WIDTH UNIT OF 10 LOUVERS.			121		92		92
99980CD	STANDARD DETAIL 2-U METAL COVERED DOOR 36IN X 82IN COMPLETE WITH DOOR HARDWARE AND BUCK UNIT OF 10 DOORS	1	2	1,774		115	18	133
99980CE	STANDARD DETAIL 2-W DUTCH DOOR 36IN X 82IN COMPLETE WITH DOOR HARDWARE UNIT OF 10 DOORS.	1	1	161		115	18	133
99980CF	STANDARD DETAIL 2-Y SLIDING DOOR FOR 24IN X 82IN OPENING COMPLETE WITH TRACK UNIT OF 10 DOORS.	1	1	310		46	9	55
99980CG	STANDARD DETAIL 3-A INTERIOR WINDOW 2FT X 3FT FIXED UNIT OF 10 WINDOWS.			106		37		37
99980CH	STANDARD DETAIL 3-B WICKERT 2FT W X 3FT H OPENING UNIT OF 10 WICKETS			172		37	9	46
99980CJ	STANDARD DETAIL 3-D REMOVABLE PANEL WITH LIGHT PROOF LOUVER 3FT X .7FT UNIT OF 10 PANELS.	1	1	199		104	14	118
99980CK	STANDARD DETAIL 3-F WICKET 2FT X 3 FT OPENING UNIT OF 10 WICKETS.	1	1	209		37	9	46
99980CL	STANDARD DETAIL 3-G INTERIOR WINDOW MULTIPLE UNIT OF 17 WINDOWS			210		55	9	64
99980CM	STANDARD DETAIL 3-H BLACKBOARD 8 FT WIDE X 4 FT HIGH UNIT OF 10 BLACKBOARDS	1		205		68	9	57
99980CN	STANDARD DETAIL 3-J BULLETIN BOARD 4 FT X 4 FT UNIT OF 10 BOARDS			82		37	5	42
99980CP	STANDARD DETAIL 4-A SHELVES 7 FT HIGH 1 FT DEEP UNIT OF 100 LINEAL FEET	2	3	438		75	18	92

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT VERT	IN MAN-HOURS GENL	TOT
99980CR	STANDARD DETAIL 4-B SHELVES 7 FT HIGH 1 FT 6 IN DEEP UNIT OF 100 LINEAL FEET	3	6	1,061	110	28	138	
99980CT	STANDARD DETAIL 4-C SHELVES 7 FT HIGH 2 FT DEEP UNIT OF 100 LINEAL FEET	6	5	1,203	147	28	175	
99980CU	STANDARD DETAIL 4-D SHELVES W/DOORS 7 FT HIGH 1 FT 6 IN DEEP. UNIT OF 100 LINEAL FEET	4	6	1,405	221	37	258	
99980CV	STANDARD DETAIL 4-E SHELVES W/DOORS 7 FT HIGH 2 FT DEEP UNIT OF 100 LINEAL FEET	5	7	1,548	262	46	308	
99980CW	STANDARD DETAIL 4-F CLOTHING SHELVES 7 FT HIGH 1 FT 6IN DEEP. UNIT OF 100 LINEAL FEET	2	2	931	97	18	115	
99980CY	STANDARD DETAIL 4-G COMPARTMENT SHELVES 7 FT HIGH 1 FT DEEP. UNIT OF 100 LINEAL FEET	2	3	561	110	18	128	
99980DA	STANDARD DETAIL 4-H COUNTER AND SHELVES UNIT OF 100 LINEAL FEET	6	6	1,278	147	28	175	
99980DB	STANDARD DETAIL 4-J COUNTER AND SHELVES UNIT OF 100 LINEAL FEET	3	4	823	166	28	194	
99980DC	STANDARD DETAIL 4-K LUGGAGE RACK 7 FT 7 IN HIGH 2 FT 4 IN DEEP 4 FT LONG UNIT OF 10 RACKS	2	3	669	55	9	64	
99980DD	STANDARD DETAIL 4-L CLOTHES HANGING RACK 7 FT 8 IN HIGH 4 FT 7 IN DEEP 4 FT LONG UNIT OF 10 RACKS	2	3	661	46	9	55	
99980DE	STANDARD DETAIL 4-M LOCKER 1 FT WIDE 1 FT 8 IN DEEP 6 FT 8 IN HIGH UNIT OF 10 LOCKERS	1	1	223	69	9	78	
99980DF	STANDARD DETAIL 4-N MOVABLE CLOTHES RACK,6 FT HIGH 10 FT LONG/UNIT OF 10 RACKS	1	2	244	28	5	33	
99980DG	STANDARD DETAIL 4-P GAS CYLINDER STORAGE RACK,WALL MOUNTED UNIT OF 10 RACKS 4 FT LONG			328	23	5	28	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT	IN MAN-HOURS	
					HOR	VERT	GENL	TOT
99980DH	STANDARD DETAIL 4-Q MOP RACK, 3 FT LONG UNIT OF 10 RACKS			70		18	2	20
99980DJ	STANDARD DETAIL 4-R GAS CYLINDER STORAGE RACK, FREE STANDING UNIT OF 10 RACKS 4 FT LONG	1	1	243		23	5	28
99980DK	STANDARD DETAIL 4-S WALL MOUNTED MOP RACK, 4 FT LONG UNIT OF 10 RACKS			58		28	2	30
99980DL	STANDARD DETAIL 4-T SHELVES 6 FT 3 IN HIGH, 1 FT 6 IN DEEP UNIT OF 100 LINEAL FEET	2	3	562		74	18	92
99980DM	STANDARD DETAIL 4-U COUNTER AND SHELVES UNIT OF 100 LINEAL FEET	4	6	1,134		124	28	152
99980DN	STANDARD DETAIL 4-W COUNTER AND SHELVES UNIT OF 100 LINEAL FEET	2	3	448		110	28	138
99980DP	STANDARD DETAIL 4-V PLATFORM 3 FT 6 IN WIDE X 8 FT LONG X 6 IN HIGH.			54		5	1	6
99980DR	STANDARD DETAIL 4-X PORTABLE WORK BENCH, 3 FT WIDE 15 FT LONG, UNIT OF 10 BENCHES	6	6	1,201		92	28	120
99980DT	STANDARD DETAIL 4-Y, 4-Z OR 4-BB STORAGE BINS UNIT OF 100 LINEAL FEET	3	5	700		138	37	175
99980DU	STANDARD DETAIL 4-AA STORAGE BINS 7 FT 4 IN HIGH, 4 FT DEEP UNIT OF 100 LINEAL FEET	5	7	1,793		124	37	161
99980DV	STANDARD DETAIL 4-CC SHELVES 6 FT 3 IN HIGH, 2 FT 6 IN DEEP UNIT OF 100 LINEAL FEET	4	6	535		74	28	102
99980DW	STANDARD DETAIL 4-DD WORK BENCH, 2 FT 9 INCH WIDE UNIT OF 10 0 LINEAL FEET	3	4	759		78	18	96
99980DY	STANDARD DETAIL 4-EE STORAGE BINS, 8 FT 2 INCH HIGH 1 FT 6 IN DEEP UNIT OF 100 LINEAL FEET	2	2	850		92	18	110

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT
99980EA	STANDARD DETAIL 4-FF STORAGE BINS, 8 FT 2 INCH HIGH 2 FT DEEP UNIT OF 100 LINEAL FEET	3	4	1,382		138	28	166
99980EB	STANDARD DETAIL 4-GG WORK TABLE, 4 FT WIDE X 3 FT HIGH UNIT OF 100 LINEAL FEET	2	3	683		92	18	110
99980EC	STANDARD DETAIL 4-LL AND 4-MM WORK BENCH, 3 FT 8 INCHES WIDE 3 FT HIGH 8 FT LONG UNIT OF 10 BENCHES	3	4	1,290		127	18	145
99980ED	STANDARD DETAIL 4-MM WORK BENCH, 3 FT 8 INCH WIDE, 3 FT HIGH 5 FT LONG UNIT OF 10 BENCHES	3	3	1,225		117	18	135
99980EE	STANDARD DETAIL 4-PP WORK BENCH, 3 FT WIDE, 3 FT HIGH UNIT OF 100 LINEAL FEET	3	4	948		147	28	175
99980EF	STANDARD DETAIL 4-RR BATTERY RACK, UNIT OF 100 LINEAL FEET	3	3	780		69	18	87
99980EG	STANDARD DETAIL 4-SS STORAGE BINS, 8 FT 2 IN HI/4 FT DEEP UNIT OF 100 LINEAL FEET	3	5	1,762		138	37	175
99980EH	STANDARD DETAIL 5-A WALL SHELVES, 4 FT HIGH, 1 FT DEEP UNIT OF 100 LINEAL FEET	1	2	524		35	18	73
99980EJ	STANDARD DETAIL 5-B WALL SHELVES 3 FT 2 IN HIGH, 8 IN DEEP UNIT OF 100 LINEAL FEET	1	1	420		46	9	55
99980EK	STANDARD DETAIL 5-C WALL SHELVES WITH DOORS, 4 FT HIGH 1 FT DEEP UNIT OF 100 LINEAL FEET	2	3	729		138	18	156
99980EL	STANDARD DETAIL 5-D SHELF AND HOOK STRIP UNIT OF 100 LINEAL FEET			106		18	5	23
99980EM	STANDARD DETAIL 5-E CLOSET SHELF AND POLE UNIT OF LINEAL FEET			119		28	5	33
99980EN	STANDARD DETAIL 5-F SCRUB-UP SHELF, UNIT OF 100 LINEAL FT			45		18		18

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS	HOR	VERT	GENL	TOT
99980EP	STANDARD DETAIL 6-A COUNTER W/O SINK, 1 FT 6 IN WIDE, 3 FT HI UNIT OF 100 LINEAL FEET WALL MOUNTED	1	2	297		69	18	87	
99980ER	STANDARD DETAIL 6-A COUNTER W/24 X 16 X 12 IN SINK, 1 FT 6 IN WIDE 3 FT HIGH 4 FT LONG UNIT OF 10 COUNTERS	1	2	724		110	18	128	
99980ET	STANDARD DETAIL 6-B COUNTER W/O SINK, 2 FT WIDE, 3 FT HIGH UNIT OF 100 LINEAL FEET WALL MOUNTED	1	2	347		69	18	87	
99980EU	STANDARD DETAIL 6-B COUNTER W/24 X 16 X 12 IN SINK, 2 FT WD 3 FT HIGH 4 FT LONG UNIT OF 10 COUNTERS	1	2	737		110	18	128	
99980EV	STANDARD DETAIL 6-C COUNTER 1 FT 6 IN WIDE, 3 FT HIGH UNIT OF 100 LINEAL FEET FREE STANDING	1	2	375		55	18	75	
99980EW	STANDARD DETAIL 6-D COUNTER FREE STANDING, 2 FT WIDE 3 FT H IGH UNIT OF 100 LINEAL FEET	2	2	747		55	14	69	
99980EY	STANDARD DETAIL 6-E COUNTER TOP HINGED, 2 FT WIDE, 3 FT 7 IN LONG UNIT OF 10 TOPS			728		46	9	55	
99980FA	STANDARD DETAIL 6-F COUNTER W/DOORS, 3 FT HIGH, 2 FT WIDE UNIT OF 100 LINEAL FEET	2	3	651		138	37	175	
99980FB	STANDARD DETAIL 6-G COUNTER KITCHENETTE, 1 FT 6 INCH WIDE 2 FT 5 IN HIGH 5 FT 6 IN LONG UNIT OF 10 COUNTERS	1	1	141		46	9	55	
99980FC	STANDARD DETAIL 6-H COUNTER FOR DISPOSAL CAN, 3 FT HIGH 2 F T WIDE 4 FT LONG UNIT OF 10 COUNTERS	1	1	200		46	9	55	
99980FD	STANDARD DETAIL 6-J COUNTER 3 FT WIDE, 3 FT HIGH, WITH LEAD -LINED TROUGH UNIT OF 100 LINEAL FEET	3	4	1,039		161	37	198	
99980FE	STANDARD DETAIL 6-K COUNTER DENTAL, 2 FT WIDE, 3 FT HIGH 4 F T LONG UNIT OF 10 COUNTERS	1	1	445		156	28	184	
99980FF	STANDARD DETAIL 6-L COUNTER W/24 X 16 X 12 IN SINK, 2 FT 2 IN WIDE 3 FT HIGH 4 FT LONG UNIT OF 10 COUNTERS	1	2	760		124	18	162	

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	MEAS	COST	CONST	EFFORT IN MAN-HOURS		
					\$	HOR	VERT	GENL	TOT
99980FE	STANDARD DETAIL 6-M COUNTER SERVING, 3 FT 10 IN WIDE, 3 FT H 1 UNIT OF 100 LINEAL FEET	2	2		559		92	18	110
99980FH	STANDARD DETAIL 6-N COUNTER PREPARATION, 2 FT 3 INCH WIDE 3 FT HIGH UNIT OF 100 LINEAL FEET	1	2		301		83	18	101
99980FJ	STANDARD DETAIL 6-P COUNTER DISHWASHING WITH 6 SINKS 24 X 16 X 12 IN PER 100 LINEAL FOOT UNIT	1	2		738		138	18	156
99980FK	STANDARD DETAIL 6-Q COUNTER POT WASHING WITH 6 SINKS 30 X 24 X 12 IN PER 100 LINEAL FOOT UNIT	2	3		1,071		156	18	176
99980FL	STANDARD DETAIL 6-R COUNTER AND FUME HOOD, 7 FT 9 INCH HIGH 2 FT DEEP 4 FT LONG UNIT OF 10 COUNTERS	1	1		218		184	37	221
99980FM	STANDARD DETAIL 6-T COUNTER POT SCRAPING, 2 FT 6 INCH WIDE 4 FT 6 IN LONG UNIT OF 10 COUNTERS	1	1		473		202	18	220
99980FN	STANDARD DETAIL 6-U COUNTER, 2 FT WIDE, 5 FT LONG UNIT OF 10 COUNTERS	1	2		285		92	9	101
99980FP	STANDARD DETAIL 6-W COUNTER, 2 FT WIDE, 14 FT LONG UNIT OF 10 COUNTERS	3	4		583		138	18	156
99980FR	STANDARD DETAIL 6-X COUNTER, 2 FT WIDE, 2 FT LONG UNIT OF 10 COUNTERS	1	1		209		46	9	55
99980FT	STANDARD DETAIL 6-Z COUNTER 2 FT WIDE 5 FT LONG UNIT OF 10 COUNTERS	2	2		349		58	9	67
99980FU	STANDARD DETAIL 6-AA COUNTER 2 FT WIDE 6 FT LONG UNIT OF 10 COUNTERS	2	3		381		58	9	67
99980FV	STANDARD DETAIL 6-BB COUNTER 2 FT WIDE 8 FT LONG UNIT OF 10 COUNTERS	2	3		416		58	9	67
99980FW	STANDARD DETAIL 6-CC COUNTER 2 FT WIDE 14 FT LONG UNIT OF 10 COUNTERS	3	4		485		92	18	110

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL							
FACILITY NUMBER	DESCRIPTION	WT SHT	VOL MEAS	COST	CONST HOR	EFFORT IN MAN-HOURS	IN	GENL	TOT
		TONS	TONS	\$	HOR	VERT			
99980FY	STANDARD DETAIL 6-DD COUNTER 1 FT 6 IN WIDE 3 FT HI 20FT LG WITH 3 FT WIDE GATE UNIT OF 10 COUNTERS	4	6	757	110	18			128
99980GA	STANDARD DETAIL 6-EE COUNTER 2 FT WIDE TOP,3 FT HIGH WITH DOORS UNIT OF 100 LINEAL FEET	2	3	618	133	37			170
99980GB	STANDARD DETAIL 7-A DESK AND DRAWERS UNIT OF 10 DESKS	2	3	899	276	37			313
99980GE	STANDARD DETAIL 19-C AND 19-D.VESTIBULE FOR SINGLE DOOR ENTRANCE								
99980GF	STANDARD DETAIL 7-E 3 FT W; 6 FT L; 3 FT H WORK TABLE UNIT OF 10 TABLES	1	2	319	12	3			15
99980GG	STANDARD DETAIL 11-A.SINK IN COUNTER								
99980GH	STANDARD DETAIL 11-B; SINK ON STAND UNIT OF 10 SINKS	1	1	89	13	2			15
99980GJ	STANDARD DETAIL,7-H LIBRARY TABLE 30X60INCH.UNIT OF 10 TABLES IN THIS FACILITY.	1	2	331	18	6			24
99980GK	STANDARD DETAIL 7-J; WORK TABLE 2 FT 5IN HIGH; 6 FT; 8-1/4 IN LONG; 2 FT DEEP UNIT OF 10 TABLES	3	5	722	2	1			3
99980GL	STANDARD DETAIL 11-K; WATER SERVICE BOX								
99980GM	STANDARD DETAIL 11-W.GREASE INTERCEPTOR/OIL SEPARATOR-CONC								
99980GN	STANDARD DETAIL 11-Q; VENT STACK FLASHING AND ROUGH-IN; UNIT OF 10 VENTS								
99980GP	STANDARD DETAIL 11-T; FLOOR DRAIN FOR 2 IN OR 4 IN PIPE; UNIT OF 10 DRAINS								
99980GR	STANDARD DETAIL 9-A.SPACE HEATER								
99980GT	STANDARD DETAIL 10-F.EXTERIOR LIGHTPROOF LOUVERS W/FAN								

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT TONS	VOL TONS	COST \$	CONST EFFORT IN MAN-HOURS			
		SHT	MEAS	HOR	VERT	GENL	TOT	
99980GU	STANDARD DETAIL 7-3; COOKS TABLE W/SINK; UNIT OF 10 TABLES	2	3	471		13	2	15
99980GV	STANDARD DETAIL 8-N; MONITOR WITH EXHAUST FAN							
99980GW	STANDARD DETAIL 11-M; OIL FIRED WATER HEATER AND STORAGE TANK					9	9	18
99980GY	STANDARD DETAIL 8-L; WEATHERPROOF ENCL	1	1	202		2	1	3
99980HA	STANDARD DETAIL 9-D; RADIATION CONNECTION					18	18	36
99980HB	STANDARD DETAIL 11-E; SHOWER PLUMBING					5	5	10
99980HC	STANDARD DETAIL, 8-C BENCH UNIT 1FOOT-3INCH WIDE,1FOOT-4INC H HIGH UNIT OF 100 LF OF BENCH IN THIS FACILITY.	1	1	158		5	1	6
99980HD	STANDARD DETAIL 11-X; TYPICAL HOSE BIBBS; UNIT OF 10 BIBBS			32		51	25	76
99980HE	STANDARD DETAIL 14-A; AIR CONDITIONING UNIT INSTALLATION FOR AIR COOLED OR WATER COOLED UNITS			36		46	46	92
99980HF	STANDARD DETAIL 15-G; UNIT HEATER CONNECTION					9	9	18
9999AA	CONTAINERIZED (TRICON) ROAD REPAIR AND FIELD FORTIFICATIONS KIT W/48 INCH CORRUGATED METAL PIPE AND SANDBAGS.	5	13	4,546				
9999AB	CONTAINERIZED (TRICON) ROAD REPAIR KIT W/36 INCH CORRUGATED METAL PIPE AND SANDBAGS.	5	12	4,391				
9999AC	CONTAINERIZED (TRICON) ROAD REPAIR KIT W/24 INCH CORRUGATED METAL PIPE AND SANDBAGS.	4	14	3,663				
9999AD	CONTAINERIZED (TRICON) ROAD REPAIR KIT W/18 INCH CORRUGATED METAL PIPE AND SANDBAGS.	4	16	3,175				

DHDXER1

RUN DATE 860128

DESERT CLIMATE		CONSTRUCTION MATERIAL						
FACILITY NUMBER	DESCRIPTION	WT SHT TONS	VOL MEAS TONS	COST \$	CONST HOR	EFFORT IN MAN-HOURS	GENL TOT	
99999AE	CONTAINERIZED (TRICON) SANDBAGS FOR EXPEDIENT CONSTRUCTION/ REPAIR OF ROADS AND FIELD FORTIFICATIONS.	5	18	5,963				
99999AF	CONTAINERIZED (TRICON) FIELD FORTIFICATIONS KIT W/BARBED TAPE CONCERTINA WIRE AND BARBED TAPE GLOVES.	2	16	12,390				
99999AG	CONTAINERIZED (TRICON) FIELD FORTIFICATIONS KIT W/BARBED WIRE, STEEL U-SHAPED PICKETS, ENGINEER TAPE AND STEEL I-SECTIONS.	8	15	5,266				
99999AH	CONTAINERIZED (MILVAN) FIELD FORTIFICATIONS AND GENERAL CONSTRUCTION KIT - 2 IN X 12 IN TREATED LUMBER.	16	49	6,324				
99999AJ	CONTAINERIZED (MILVAN) FIELD FORTIFICATIONS AND GENERAL CONSTRUCTION KIT - 8 IN X 12 IN TREATED STRUCTURAL TIMBER.	16	49	7,824				
99999AK	CONTAINERIZED (MILVAN) GENERAL CONSTRUCTION KIT - PLYWOOD, CORRUGATED SHEET METAL, 1X6 AND 2X4 TREATED LUMBER.	21	59	12,639				
99999AL	CONTAINERIZED (MILVAN) GENERAL CONSTRUCTION KIT - ASSORTED SIZES OF TREATED LUMBER (1X6 2X4 2X6 2X8 & 2X10)	16	49	5,349				
99999AM	CONTAINERIZED (TRICON) GENERAL CONSTRUCTION KIT OF CONSUMABLE SUPPLIES.	11	20	12,613				
99999AN	CONTAINERIZED (TRICON) GENERAL CONSTRUCTION KIT OF ELECTRICAL SUPPLIES.	9	38	52,212				
99999AP	CONTAINERIZED (TRICON) GENERAL CONSTRUCTION KIT OF PLUMBING SUPPLIES.	2	12	3,755				
99999AR	CONTAINERIZED (TRICON) RIGGING KIT W/ASSORTED SIZES OF FIBER ROPE - WIRE ROPE - CHAIN AND RELATED ACCESSORIES.	7	14	13,090				
99999AT	CONTAINERIZED (TRICON) MARKING & CAMOUFLAGE KIT W/MARKING & CAMOUFLAGE PAINT AND CAMOUFLAGE NET SETS (WOODLAND).	5	19	21,139				

DHDXER1

RUN DATE 860128

DESERT CLIMATE	FACILITY NUMBER	DESCRIPTION	CONSTRUCTION MATERIAL					
			WT SHT TONS	VOL MEAS TONS	COST \$	CONST EFFORT IN MAN-HOURS		
						HOR	VERT	GENL
								TOT
		99999AU CONTAINERIZED (TRICON) HAND TOOL KIT FOR USE BY INDIGENOUS LABOR.			373			
		99999AV CONTAINERIZED (TRICON) MARKING & CAMOUFLAGE KIT W/MARKING & CAMOUFLAGE PAINT AND CAMOUFLAGE NET SETS (DESERT).	4	15	8,160			

END REPORT DHDXER1

By Order of the Secretary of the Army:

JOHN A. WICKHAM, JR.
General, United States Army
Chief of Staff

Official:

R. L. DILWORTH
Brigadier General, United States Army
The Adjutant General

U.S. GOVERNMENT PRINTING OFFICE: 1995 - 406-421/40200

RECOMMENDED CHANGES TO EQUIPMENT TECHNICAL PUBLICATIONS

SOMETHING WRONG WITH THIS PUBLICATION?

THEN... JOT DOWN THE
DOPE ABOUT IT ON THIS
FORM, CAREFULLY TEAR IT
OUT, FOLD IT AND DROP IT
IN THE MAIL!

FROM: (PRINT YOUR UNIT'S COMPLETE ADDRESS)

DATE SENT

PUBLICATION NUMBER

PUBLICATION DATE

PUBLICATION TITLE

BE EXACT... PIN-POINT WHERE IT IS

PAGE NO. PARA. NO. FIGURE NO. TABLE NO.

IN THIS SPACE TELL WHAT IS WRONG
AND WHAT SHOULD BE DONE ABOUT IT:

TEAR ALONG PERFORATED LINE

PRINTED NAME, GRADE OR TITLE, AND TELEPHONE NUMBER

SIGN HERE:

DA FORM 1 JUL 78 2028-2

PREVIOUS EDITIONS
ARE OBSOLETE.P.S.—IF YOUR OUTFIT WANTS TO KNOW ABOUT YOUR
RECOMMENDATION MAKE A CARBON COPY OF THIS
AND GIVE IT TO YOUR HEADQUARTERS.

PIN: 024231-000